

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on June 24)

Place of sampling	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi
Time and Date of Sample Collection	2011/6/13 12:23	2011/6/13 11:44
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)	
I-131 (about 8 days)	9.2E-01	ND
Cs-134 (about 2 years)	1.0E+01	ND
Cs-137 (about 30 years)	1.2E+01	ND
H-3 (about 12 years)	3.7E+00	ND

. E - means . x10.

Data for I-131, Cs-134 and Cs-137 were published on June 14th.

(Comment)

H-3 was detected. This is considered result of the accident.