

Reference
-----------

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <1/3>  
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 26)

Place of Collection	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Unit 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/25 7:00 AM		2011/6/25 7:25 AM		2011/6/25 7:29 AM		2011/6/25 7:29 AM		2011/6/25 7:38 AM		
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	11	0.28	91	2.3	91	2.3	82	2.1	84	2.1	40
Cs-134 (about 2 years)	160	2.7	1,600	27	380	6.3	450	7.5	340	5.7	60
Cs-137 (about 30 years)	160	1.8	1,700	19	400	4.4	490	5.4	380	4.2	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference
-----------

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <2/3>  
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June

Place of Collection	Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	
I-131 (about 8 days)	1,300	33	74	1.9	65	1.6	75	1.9	70	1.8	40
Cs-134 (about 2 years)	810	14	330	5.5	790	13	580	9.7	490	8.2	60
Cs-137 (about 30 years)	880	9.8	350	3.9	870	9.7	620	6.9	510	5.7	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <3/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June

Place of Collection	Inside the south of 1F's Unit 1-4 Water Intake Canal										Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/25 7:57 AM										
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-	/	/	/	/	/	/	/	/	40
Cs-134 (about 2 years)	330	5.5	/	/	/	/	/	/	/	/	60
Cs-137 (about 30 years)	330	3.7	/	/	/	/	/	/	/	/	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/L" converted from the value originally in "Bq/cm<sup>3</sup>".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

"ND" is stated in the case that density is below detectable threshold.

Detectable thresholds of the main 3 nuclides are as follows: I-131: approx. 14Bq/L.