

## Results of Nuclide Analyses of Sub-drains

Reference
-----------

( Data summarized on June 30 )

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	June 29, 2011 12:27	June 29, 2011 12:17	June 29, 2011 12:13	June 29, 2011 11:55	June 29, 2011 12:02	June 29, 2011 11:58	June 29, 2011 9:50
Detected Nuclides (Half-life)	Radioactivity Density of Sample ( Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	ND	3.0E-01	1.3E-01	ND	ND	ND	ND
Cs-134 (about 2 years)	3.1E+00	9.1E+00	3.1E-01	1.4E-02	ND	9.7E-03	ND
Cs-137 (about 30 years)	3.8E+00	1.1E+01	4.0E-01	2.4E-02	ND	1.1E-02	ND

. E - means . ×10.

Data of other nuclides are under evaluation.

ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 3E-2Bq/cm<sup>3</sup>, Cs-134: approx. 6E-3Bq/cm<sup>3</sup>, Cs-137: approx. 7E-3Bq/cm<sup>3</sup>). However, nuclides below limits might be detected since detection limits depend on detector and condition of sample.