

( Attachment )

Fukushima Daiichi Nuclear Power Station

Result of Pu Analysis in Sub Drain

1. Sample Point: Fukushima Daiichi Nuclear Power Station      Unit 3 Sub Drain
2. Analysis Organization : Japan Chemical Analysis Center
3. Result:

(Unit:mBq/L)

Sample	Sampled Date	Pu-238	Pu-239,Pu-240
Unit3 Sub Drain	7/18	N.D. [ $<5.2 \times 10^{-1}$ ]	N.D. [ $<4.7 \times 10^{-1}$ ]

Numbers in [ ] show detecting limit

4. Evaluation

Pu-238, Pu-239, Pu-240 were not detected from samples measured this time.

END