Nuclide Analysis Results of Seawater <Coast>

Reference

(Data summarized on October 26)

Place of Sampling	North of Discha of 5-6u (approx. 30m n discharge o	of 1F orth of 5-6u	Around South Channel (appox. 330m Discharge (of 1F south of 1-4u	Around North Channel (Around 3,4u Chanr (approx. 10 ki	of 2F I Discharge nel)	Around Iwasawa (appox. 7 km s Discharge ((appox. 16 kr	south of 1,2u Channel)	Density limit by the announcement of Reactor Regulation (Bq/L)	
Time of Sampling	Oct 25, 1 08:4		Oct 25, 08:1		Oct 25, 08:2		Oct 25, 08:0		(the density limit in the water outside of	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	surrounding monitored areas in the section 6 of the appendix 2)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40	
Cs-134 (about 2 years)	3.0	0.05	2.0	0.03	ND	-	ND	-	60	
Cs-137 (about 30 years)	4.0	0.04	2.7	0.03	1.5	0.02	ND	-	90	

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 0.71Bq/L, Cs-134: approx. 0.90Bq/L, Cs-137: approx. 1.1Bq/L Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Results of Nuclide Analysis of Seawater <Offshore 1/2>

Reference

(Data summarized on October 26)

Place of Sampling	15 km offsh Minami-So CityUpper	i-Souma Minami-Souma		15 km offst Ukedo-gawa U		15 km offsh Ukedo-gawa Lo		15 km offshore of Fukushima Daiichi Upper layer		15 km offshore of Fukushima Daiichi Lower layer		Density limit by the announcement of Reactor Regulation	
Time of Sampling	N/A	N/A		Oct 24, 2011 (Not sampled)		Oct 24, 2011 (Not sampled)		Oct 24, 2011 (Not sampled)		Oct 24, 2011 (Not sampled)		(Bq/L) (the density limit in the	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90

Place of Sampling	15 km offsh Fukushima Da layer	ini Upper	15 km offshore of Fukushima Daini Lower layer		15 km offshore of Iwasawa Shore Upper layer		15 km offshore of Iwasawa Shore Lower layer		15 km offshore of Hirono-town Upper layer		15 km offshore of Hirono-town Lower layer		Density limit by the announcement of Reactor Regulation
Time of Sampling	Oct 24, 2 (Not samp		Oct 24, 2 (Not samp	-	N/A		N/A		N/A		N/A		(Bq/L) (the density limit in the
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

Results of Nuclide Analysis of Seawater <Offshore 2/2>

Reference

(Data summarized on October 26)

Place of Sampling	3 km offshore o Iwaki Uppe		of 3 km offshore of North of Iwaki Lower layer		3 km offshore of Natsui river Upper layer		3 km offshore of Natsui river Lower layer		3 km offshore of Onahama port Upper layer		3 km offshore of Onahama port Lower layer		Density limit by the announcement of Reactor Regulation
Time of Sampling	Oct 24,2 05:11		Oct 24, 2011 05:11		Oct 24, 2011 06:40		Oct 24, 2011 06:40		Oct 24, 2011 06:15		Oct 24, 2011 06:15		(Bq/L) (the density limit in the
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	1.3	0.02	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	2.3	0.03	ND	-	ND	-	ND	-	90

Place of Sampling	3 km offshore Upper la		3 km offshore of Ena Lower layer		3 km offsh Numanouchi U		3 km offshore of Numanouchi Lower layer		-		a 3 km offshore of Toyoma Lower layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the
Time of Sampling	Oct 24,2 06:45		,	Oct 24, 2011 06:45		Oct 24, 2011 06:00		Oct 24, 2011 06:00		Oct 24, 2011 06:23		011	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)
l-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 0.83Bq/L, Cs-134: approx. 0.94Bq/L, Cs-137: approx. 1.1Bq/L Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.