Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference

(Data summarized on October 27)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain			Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	26-Oct-11 9:59	26-Oct-11 10:03	26-Oct-11 10:10	26-Oct-11 10:03	26-Oct-11 9:50	26-Oct-11 9:43	26-Oct-11 9:25
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	7.5E-01	7.3E-01	3.0E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	9.7E-01	9.4E-01	ND	ND	ND	ND	ND

^{*} O.OE-O means O.O x 10-O

^{*} Data of other nuclides are under evaluation.

^{* &}quot;ND" means the sampled data is below measurable limit. I-131: approx. 2E-2Bq/cm3, Cs-134: approx. 3E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3) Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.