Nuclide Analysis Results of Seawater <Coast>

Reference

(Data summarized on November 8)

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)		Around South Discharge Channel of 1F (appox. 330m south of 1-4u Discharge Channel)		Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (appox. 7 km south of 1,2u Discharge Channel) (appox. 16 km from 1F)		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Nov. 07, 2011 8:55 AM		Nov. 07, 2011 8:35 AM		Nov. 07, 2011 8:25 AM		Nov. 07, 2011 8:00 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	2.8	0.05	1.7	0.03	ND	-	ND	-	60
Cs-137 (about 30 years)	3.2	0.04	2.0	0.02	ND	-	1.9	0.02	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 0.70Bq/L, Cs-134: approx. 0.98Bq/L, Cs-137: approx. 1.0Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Nuclide Analysis Results of Seawater <Offshore>

Reference

(Data summarized on November 8)

Place of Sampling	3 km offshore of Haramachi Ward Upper layer		3 km offshore of Haramachi Ward Lower layer		3 km offshore of Odaka Ward Upper layer		3 km offshore of Odaka Ward Lower layer		3 km offshore of Iwasawa shore Upper layer		3 km offshore of Iwasawa shore Lower layer		② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Nov.06, 2011 8:50 AM		Nov.06, 2011 8:50 AM		Nov.06, 2011 8:35 AM		Nov.06, 2011 8:35 AM		Nov.06, 2011 7:10 AM		Nov.06, 2011 7:10 AM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	8 km offshore of Odaka Ward Upper layer		8 km offshore of Odaka Ward Lower layer		8 km offshore of Iwasawa shore Upper layer		8 km offshore of Iwasawa shore Lower layer						② Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time of Sampling	Nov.06, 2011 8:15 AM		Nov.06, 2011 8:15 AM		Nov.06, 2011 7:25 AM		Nov.06, 2011 7:25 AM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-					40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-					60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-					90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 0.76Bq/L, Cs-134: approx. 0.94Bq/L, Cs-137: approx. 1.1Bq/L
Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.