

福島第一原子力発電所 モニタリングポスト空間線量率(μ Sv/h)

日時	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/6/17 0:00	5	24	15	15	18	39	121	102
2011/6/17 0:10	5	24	15	15	18	39	121	102
2011/6/17 0:20	5	24	15	15	18	39	121	102
2011/6/17 0:30	5	24	15	15	18	39	121	102
2011/6/17 0:40	5	24	15	15	18	39	121	102
2011/6/17 0:50	5	24	15	15	18	39	121	102
2011/6/17 1:00	5	24	15	15	18	39	121	101
2011/6/17 1:10	5	24	15	15	18	39	121	101
2011/6/17 1:20	5	24	15	15	18	39	121	101
2011/6/17 1:30	5	24	15	15	18	39	121	101
2011/6/17 1:40	5	24	15	15	18	39	121	101
2011/6/17 1:50	5	24	15	15	18	39	121	101
2011/6/17 2:00	5	24	15	15	18	39	121	101
2011/6/17 2:10	5	24	15	15	18	39	121	101
2011/6/17 2:20	5	24	15	15	18	39	121	101
2011/6/17 2:30	5	24	15	15	18	39	121	101
2011/6/17 2:40	5	24	15	15	18	39	121	101
2011/6/17 2:50	5	24	15	15	18	39	120	101
2011/6/17 3:00	5	24	15	15	18	39	120	101
2011/6/17 3:10	5	24	15	15	18	39	120	101
2011/6/17 3:20	5	24	15	15	18	39	120	101
2011/6/17 3:30	5	24	15	15	18	39	120	101
2011/6/17 3:40	5	24	15	15	18	39	120	101
2011/6/17 3:50	5	24	15	15	18	39	120	101
2011/6/17 4:00	5	24	15	15	18	39	120	101
2011/6/17 4:10	5	24	15	15	18	39	120	101
2011/6/17 4:20	5	24	15	15	18	39	120	101
2011/6/17 4:30	5	24	15	15	18	39	120	101
2011/6/17 4:40	5	24	15	15	18	39	120	101
2011/6/17 4:50	5	24	15	15	18	39	120	101
2011/6/17 5:00	5	24	15	15	18	39	120	101
2011/6/17 5:10	5	24	15	15	18	39	120	101
2011/6/17 5:20	5	24	15	15	18	39	120	101
2011/6/17 5:30	5	24	15	15	18	39	120	101
2011/6/17 5:40	5	24	15	15	18	39	120	101
2011/6/17 5:50	5	24	15	15	18	39	120	101
2011/6/17 6:00	5	24	15	15	18	39	120	101

福島第一原子力発電所 モニタリングポスト空間線量率($\mu\text{Sv/h}$)

日時	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/6/17 6:10	5	24	15	15	18	39	120	101
2011/6/17 6:20	5	24	15	15	18	39	120	101
2011/6/17 6:30	5	24	15	15	18	39	120	101
2011/6/17 6:40	5	24	15	15	18	39	120	101
2011/6/17 6:50	5	24	15	15	18	39	120	101
2011/6/17 7:00	5	24	15	15	18	39	120	101
2011/6/17 7:10	5	24	15	15	18	39	120	101
2011/6/17 7:20	5	24	15	15	18	39	120	101
2011/6/17 7:30	5	24	15	15	18	39	120	101
2011/6/17 7:40	5	24	15	15	18	39	120	101
2011/6/17 7:50	5	24	15	15	18	39	120	101
2011/6/17 8:00	5	24	15	15	18	39	120	101
2011/6/17 8:10	5	24	15	15	18	39	120	101
2011/6/17 8:20	5	24	15	15	18	39	120	101
2011/6/17 8:30	5	24	15	15	18	39	120	101
2011/6/17 8:40	5	24	15	15	18	39	120	101
2011/6/17 8:50	5	24	15	15	18	39	120	101
2011/6/17 9:00	5	24	15	15	18	39	120	101
2011/6/17 9:10	5	24	15	15	18	39	120	101
2011/6/17 9:20	5	24	15	15	18	39	120	101
2011/6/17 9:30	5	24	15	15	18	39	120	101
2011/6/17 9:40	5	24	15	15	18	39	120	101
2011/6/17 9:50	5	24	15	15	18	39	120	101
2011/6/17 10:00	5	24	15	15	18	39	120	101
2011/6/17 10:10	5	24	15	15	18	39	120	101
2011/6/17 10:20	5	24	15	15	18	39	120	101
2011/6/17 10:30	5	24	15	15	18	39	120	101
2011/6/17 10:40	5	24	15	15	18	39	120	101
2011/6/17 10:50	5	24	15	15	18	39	120	102
2011/6/17 11:00	5	24	15	15	18	39	120	102
2011/6/17 11:10	5	24	15	15	18	39	120	102
2011/6/17 11:20	5	24	15	15	18	39	120	102
2011/6/17 11:30	5	24	15	15	18	39	121	102
2011/6/17 11:40	5	24	15	15	18	39	121	102
2011/6/17 11:50	5	24	15	15	18	39	121	102
2011/6/17 12:00	5	24	15	15	18	39	121	102
2011/6/17 12:10	5	24	15	15	18	39	121	102

福島第一原子力発電所 モニタリングポスト空間線量率($\mu\text{Sv/h}$)

日時	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/6/17 12:20	5	24	15	15	18	39	121	102
2011/6/17 12:30	5	24	15	15	18	39	121	102
2011/6/17 12:40	5	24	15	15	18	39	121	102
2011/6/17 12:50	5	24	15	15	18	39	121	102
2011/6/17 13:00	5	24	15	15	18	39	121	102
2011/6/17 13:10	5	24	15	15	18	39	121	102
2011/6/17 13:20	5	24	15	15	18	39	121	102
2011/6/17 13:30	5	24	15	15	18	39	121	102
2011/6/17 13:40	5	24	15	15	18	39	121	102
2011/6/17 13:50	5	24	15	15	18	39	121	102
2011/6/17 14:00	5	24	15	15	18	39	121	102
2011/6/17 14:10	5	24	15	15	18	39	121	102
2011/6/17 14:20	5	24	15	15	18	39	121	102
2011/6/17 14:30	5	24	15	15	18	39	121	102
2011/6/17 14:40	5	24	15	15	18	39	121	102
2011/6/17 14:50	5	24	15	15	18	39	121	102
2011/6/17 15:00	5	24	15	15	18	39	121	102
2011/6/17 15:10	5	24	15	15	18	39	121	102
2011/6/17 15:20	5	24	15	15	18	39	121	102
2011/6/17 15:30	5	24	15	15	18	39	121	102
2011/6/17 15:40	5	24	15	15	18	39	121	102
2011/6/17 15:50	5	24	15	15	18	39	121	102
2011/6/17 16:00	5	24	15	15	18	39	121	102
2011/6/17 16:10	5	24	15	15	18	39	121	102
2011/6/17 16:20	5	24	15	15	18	39	121	102
2011/6/17 16:30	5	24	15	15	18	39	121	102
2011/6/17 16:40	5	24	15	15	18	39	121	102
2011/6/17 16:50	5	24	15	15	18	39	121	102
2011/6/17 17:00	5	24	15	15	18	39	121	102
2011/6/17 17:10	5	24	15	15	18	39	121	102
2011/6/17 17:20	5	24	15	15	18	39	121	102
2011/6/17 17:30	5	24	15	15	18	39	121	102
2011/6/17 17:40	5	24	15	15	18	39	121	102
2011/6/17 17:50	5	24	15	15	18	39	121	102
2011/6/17 18:00	5	24	15	15	18	39	121	102
2011/6/17 18:10	5	24	15	15	18	39	121	102
2011/6/17 18:20	5	24	15	15	18	39	121	102

福島第一原子力発電所 モニタリングポスト空間線量率(μ Sv/h)

日時	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/6/17 18:30	5	24	15	15	18	39	121	102
2011/6/17 18:40	5	24	15	15	18	39	121	102
2011/6/17 18:50	5	24	15	15	18	39	121	102
2011/6/17 19:00	5	24	15	15	18	39	121	102
2011/6/17 19:10	5	24	15	15	18	39	121	102
2011/6/17 19:20	5	24	15	15	18	39	121	102
2011/6/17 19:30	5	24	15	15	18	39	121	102
2011/6/17 19:40	5	24	15	15	18	39	121	102
2011/6/17 19:50	5	24	15	15	18	39	121	102
2011/6/17 20:00	5	24	15	15	18	39	121	102
2011/6/17 20:10	5	24	15	15	18	39	121	102
2011/6/17 20:20	5	24	15	15	18	39	121	102
2011/6/17 20:30	5	24	15	15	18	39	121	102
2011/6/17 20:40	5	24	15	15	18	39	121	102
2011/6/17 20:50	5	24	15	15	18	39	121	102
2011/6/17 21:00	5	24	15	15	18	39	121	102
2011/6/17 21:10	5	24	15	15	18	39	121	102
2011/6/17 21:20	5	24	15	15	18	39	121	102
2011/6/17 21:30	5	24	15	15	18	39	121	102
2011/6/17 21:40	5	24	15	15	18	39	121	102
2011/6/17 21:50	5	24	15	15	18	39	121	102
2011/6/17 22:00	5	24	15	15	18	39	121	102
2011/6/17 22:10	5	24	15	15	18	39	121	102
2011/6/17 22:20	5	24	15	15	18	39	121	102
2011/6/17 22:30	5	24	15	15	18	39	121	102
2011/6/17 22:40	5	24	15	15	18	39	120	102
2011/6/17 22:50	5	24	15	15	18	39	120	102
2011/6/17 23:00	5	24	15	15	18	39	121	102
2011/6/17 23:10	5	24	15	15	18	39	121	102
2011/6/17 23:20	5	24	15	15	18	39	120	102
2011/6/17 23:30	5	24	15	15	18	39	120	102
2011/6/17 23:40	5	24	15	15	18	39	120	102
2011/6/17 23:50	5	24	15	15	18	39	120	102

福島第一原子力発電所 モニタリング結果(可搬型MP)

日時	事務本館南側 線量率 ($\mu\text{Sv/h}$)	正門 線量率 ($\mu\text{Sv/h}$)	西門 線量率 ($\mu\text{Sv/h}$)
2011/6/17 0:00	361	5/21 11:00~ 装置故障により欠測 6/2 12:10より、モニタリ ングカーを西門→正門 に移動し測定	14
2011/6/17 0:30	361		14
2011/6/17 1:00	359		14
2011/6/17 1:30	361		14
2011/6/17 2:00	359		14
2011/6/17 2:30	356		14
2011/6/17 3:00	356		14
2011/6/17 3:30	355		14
2011/6/17 4:00	356		14
2011/6/17 4:30	355		14
2011/6/17 5:00	356		14
2011/6/17 5:30	358		14
2011/6/17 6:00	355		14
2011/6/17 6:30	356		14
2011/6/17 7:00	358		14
2011/6/17 7:30	358		14
2011/6/17 8:00	358		14
2011/6/17 8:30	356		14
2011/6/17 9:00	358		14
2011/6/17 9:30	358		14
2011/6/17 10:00	357		14
2011/6/17 10:30	356		14
2011/6/17 11:00	356		13
2011/6/17 11:30	355		14
2011/6/17 12:00	356		14
2011/6/17 12:30	355		14
2011/6/17 13:00	355		14
2011/6/17 13:30	354		14
2011/6/17 14:00	354		14
2011/6/17 14:30	353		14
2011/6/17 15:00	354		14
2011/6/17 15:30	352		14
2011/6/17 16:00	354		14
2011/6/17 16:30	353		14
2011/6/17 17:00	352		14
2011/6/17 17:30	352		14
2011/6/17 18:00	353		14
2011/6/17 18:30	353		14
2011/6/17 19:00	353		14
2011/6/17 19:30	353		14
2011/6/17 20:00	354		14
2011/6/17 20:30	357		14
2011/6/17 21:00	356	14	
2011/6/17 21:30	358	14	
2011/6/17 22:00	358	14	
2011/6/17 22:30	358	14	
2011/6/17 23:00	357	14	
2011/6/17 23:30	360	14	

福島第一原子力発電所 モニタリング結果(モニタリングカー)

※モニタリングカーでの測定は場所を移動する可能性があり、データが欠ける場合もある。

場所	日時	線量率 (μ Sv/h)	中性子線量率 (μ Sv/h)	天候	風向	風速 (m/s)
正門	2011/6/17 0:00	30.3	<0.01	曇り	SSE	1.6
正門	2011/6/17 0:10	30.3	<0.01	曇り	SSE	1.5
正門	2011/6/17 0:20	30.3	<0.01	曇り	SE	1.3
正門	2011/6/17 0:30	30.3	<0.01	曇り	SE	0.8
正門	2011/6/17 0:40	30.3	<0.01	曇り	S	1.1
正門	2011/6/17 0:50	30.3	<0.01	曇り	SSW	1.3
正門	2011/6/17 1:00	30.2	<0.01	曇り	SE	1.7
正門	2011/6/17 1:10	30.2	<0.01	曇り	SSE	1.4
正門	2011/6/17 1:20	30.2	<0.01	曇り	SE	1.5
正門	2011/6/17 1:30	30.1	<0.01	曇り	SE	1.6
正門	2011/6/17 1:40	30.2	<0.01	曇り	SSE	1.8
正門	2011/6/17 1:50	30.2	<0.01	曇り	SE	1.6
正門	2011/6/17 2:00	30.0	<0.01	曇り	SE	1.7
正門	2011/6/17 2:10	30.0	<0.01	雨	SSW	1.6
正門	2011/6/17 2:20	29.9	<0.01	雨	SE	1.2
正門	2011/6/17 2:30	29.9	<0.01	雨	SSE	1.9
正門	2011/6/17 2:40	29.9	<0.01	雨	SSE	1.9
正門	2011/6/17 2:50	29.9	<0.01	雨	S	2.1
正門	2011/6/17 3:00	29.9	<0.01	雨	N	2.3
正門	2011/6/17 3:10	29.8	<0.01	雨	NNE	2.9
正門	2011/6/17 3:20	29.9	<0.01	雨	ESE	1.1
正門	2011/6/17 3:30	29.9	<0.01	雨	S	1.3
正門	2011/6/17 3:40	29.9	<0.01	雨	SSE	1.4
正門	2011/6/17 3:50	29.8	<0.01	雨	SSE	1.6
正門	2011/6/17 4:00	29.8	<0.01	雨	SSE	1.6
正門	2011/6/17 4:10	29.8	<0.01	雨	SSE	1.5
正門	2011/6/17 4:20	29.9	<0.01	雨	SSE	1.5
正門	2011/6/17 4:30	29.9	<0.01	雨	SSE	1.3
正門	2011/6/17 4:40	29.9	<0.01	雨	SSE	1.4
正門	2011/6/17 4:50	29.9	<0.01	雨	S	1.5
正門	2011/6/17 5:00	29.8	<0.01	雨	SSE	1.8
正門	2011/6/17 5:10	29.8	<0.01	雨	E	1.9
正門	2011/6/17 5:20	29.9	<0.01	雨	SSE	1.9
正門	2011/6/17 5:30	29.9	<0.01	雨	SSE	1.2
正門	2011/6/17 5:40	29.9	<0.01	雨	S	1.9
正門	2011/6/17 5:50	29.7	<0.01	雨	S	1.8
正門	2011/6/17 6:00	30.0	<0.01	曇り	S	1.7
正門	2011/6/17 6:10	29.8	<0.01	曇り	SSE	1.4
正門	2011/6/17 6:20	29.9	<0.01	曇り	SE	1.5
正門	2011/6/17 6:30	30.0	<0.01	曇り	S	1.6
正門	2011/6/17 6:40	30.0	<0.01	曇り	S	1.6
正門	2011/6/17 6:50	29.9	<0.01	曇り	S	1.7
正門	2011/6/17 7:00	30.0	<0.01	曇り	SE	1.5
正門	2011/6/17 7:10	30.0	<0.01	曇り	S	1.3
正門	2011/6/17 7:20	30.0	<0.01	曇り	S	1.2
正門	2011/6/17 7:30	29.9	<0.01	曇り	SW	1.0
正門	2011/6/17 7:40	30.0	<0.01	曇り	SE	1.1

場所	日時	線量率 ($\mu\text{Sv/h}$)	中性子線量率 ($\mu\text{Sv/h}$)	天候	風向	風速 (m/s)
正門	2011/6/17 7:50	30.0	<0.01	曇り	SSE	1.0
正門	2011/6/17 8:00	29.8	<0.01	曇り	SE	1.2
正門	2011/6/17 8:10	29.8	<0.01	曇り	SSE	1.5
正門	2011/6/17 8:20	30.0	<0.01	曇り	S	1.4
正門	2011/6/17 8:30	29.9	<0.01	曇り	SSW	1.3
正門	2011/6/17 8:40	30.0	<0.01	曇り	E	1.6
正門	2011/6/17 8:50	29.7	<0.01	曇り	SSE	1.8
正門	2011/6/17 9:00	30.0	<0.01	曇り	S	1.9
正門	2011/6/17 9:10	29.8	<0.01	曇り	NE	2.0
正門	2011/6/17 9:20	29.8	<0.01	曇り	NE	3.1
正門	2011/6/17 9:30	29.8	<0.01	曇り	ENE	4.8
正門	2011/6/17 9:40	29.9	<0.01	曇り	S	3.2
正門	2011/6/17 9:50	29.8	<0.01	曇り	SSW	1.7
正門	2011/6/17 10:00	30.0	<0.01	曇り	SE	1.8
正門	2011/6/17 10:10	30.0	<0.01	曇り	SSE	1.8
正門	2011/6/17 10:20	29.8	<0.01	曇り	SSE	1.9
正門	2011/6/17 10:30	30.0	<0.01	曇り	SSE	2.3
正門	2011/6/17 10:40	30.2	<0.01	曇り	SE	2.0
正門	2011/6/17 10:50	29.8	<0.01	曇り	SSW	2.3
正門	2011/6/17 11:00	30.2	<0.01	曇り	S	2.4
正門	2011/6/17 11:10	29.8	<0.01	曇り	SSE	2.5
正門	2011/6/17 11:20	30.2	<0.01	曇り	S	2.4
西門	2011/6/17 11:30	13.9	<0.01	曇り	ENE	2.1
西門	2011/6/17 11:40	14.0	<0.01	曇り	E	1.4
西門	2011/6/17 11:50	14.0	<0.01	曇り	E	1.1
正門	2011/6/17 12:00	29.7	<0.01	曇り	S	2.7
正門	2011/6/17 12:10	30.0	<0.01	曇り	SSE	1.8
正門	2011/6/17 12:20	30.0	<0.01	曇り	SSE	2.1
正門	2011/6/17 12:30	29.9	<0.01	曇り	SSE	1.9
正門	2011/6/17 12:40	30.0	<0.01	曇り	S	2.0
正門	2011/6/17 12:50	30.1	<0.01	曇り	S	1.8
正門	2011/6/17 13:00	30.1	<0.01	曇り	SSE	1.4
正門	2011/6/17 13:10	30.0	<0.01	曇り	SE	1.7
正門	2011/6/17 13:20	30.2	<0.01	曇り	SSE	1.7
正門	2011/6/17 13:30	30.2	<0.01	曇り	SSE	1.4
正門	2011/6/17 13:40	30.2	<0.01	曇り	SE	1.5
正門	2011/6/17 13:50	30.0	<0.01	曇り	SE	1.7
正門	2011/6/17 14:00	30.0	<0.01	曇り	S	1.7
正門	2011/6/17 14:10	30.1	<0.01	曇り	SE	1.7
正門	2011/6/17 14:20	29.2	<0.01	曇り	SE	1.9
正門	2011/6/17 14:30	30.1	<0.01	曇り	SE	1.5
正門	2011/6/17 14:40	30.1	<0.01	曇り	SE	1.6
正門	2011/6/17 14:50	30.0	<0.01	曇り	SE	1.6
正門	2011/6/17 15:00	30.1	<0.01	曇り	ESE	1.7
正門	2011/6/17 15:10	29.7	<0.01	曇り	SE	1.5
正門	2011/6/17 15:20	30.3	<0.01	曇り	SE	1.6
正門	2011/6/17 15:30	30.0	<0.01	雨	SSE	1.3
正門	2011/6/17 15:40	30.1	<0.01	雨	SSE	1.3
正門	2011/6/17 15:50	30.1	<0.01	曇り	SSE	1.7
正門	2011/6/17 16:00	30.0	<0.01	曇り	SSE	1.5
正門	2011/6/17 16:10	30.1	<0.01	曇り	SSE	1.6
正門	2011/6/17 16:20	30.2	<0.01	曇り	SSE	1.4
正門	2011/6/17 16:30	30.2	<0.01	曇り	SSE	1.5
正門	2011/6/17 16:40	30.1	<0.01	曇り	S	1.6
正門	2011/6/17 16:50	30.2	<0.01	曇り	SSE	1.1

場所	日時	線量率 (μ Sv/h)	中性子線量率 (μ Sv/h)	天候	風向	風速 (m/s)
正門	2011/6/17 17:00	30.2	<0.01	曇り	SE	1.5
正門	2011/6/17 17:10	30.1	<0.01	曇り	SE	1.3
正門	2011/6/17 17:20	30.2	<0.01	曇り	SE	1.2
正門	2011/6/17 17:30	30.2	<0.01	曇り	SE	1.2
正門	2011/6/17 17:40	30.2	<0.01	曇り	SE	1.2
正門	2011/6/17 17:50	30.2	<0.01	曇り	SSE	1.1
正門	2011/6/17 18:00	30.2	<0.01	曇り	SSE	1.0
正門	2011/6/17 18:10	30.2	<0.01	曇り	SSE	0.9
正門	2011/6/17 18:20	30.2	<0.01	曇り	E	1.0
正門	2011/6/17 18:30	30.1	<0.01	曇り	SSE	1.0
正門	2011/6/17 18:40	30.2	<0.01	曇り	SSE	1.4
正門	2011/6/17 18:50	30.2	<0.01	曇り	SSE	0.9
正門	2011/6/17 19:00	30.3	<0.01	曇り	S	1.0
正門	2011/6/17 19:10	30.2	<0.01	曇り	S	0.9
正門	2011/6/17 19:20	30.3	<0.01	曇り	S	1.4
正門	2011/6/17 19:30	30.2	<0.01	曇り	E	1.4
正門	2011/6/17 19:40	30.3	<0.01	曇り	SE	0.8
正門	2011/6/17 19:50	30.2	<0.01	曇り	SE	0.7
正門	2011/6/17 20:00	30.3	<0.01	曇り	SE	0.9
正門	2011/6/17 20:10	30.2	<0.01	曇り	SSE	0.7
正門	2011/6/17 20:20	30.1	<0.01	曇り	S	0.8
正門	2011/6/17 20:30	30.2	<0.01	曇り	SW	0.9
正門	2011/6/17 20:40	30.2	<0.01	曇り	S	0.6
正門	2011/6/17 20:50	30.2	<0.01	曇り	W	0.4
正門	2011/6/17 21:00	30.2	<0.01	曇り	SW	0.6
正門	2011/6/17 21:10	30.2	<0.01	曇り	SW	0.7
正門	2011/6/17 21:20	30.3	<0.01	曇り	SW	0.6
正門	2011/6/17 21:30	30.2	<0.01	曇り	W	0.7
正門	2011/6/17 21:40	30.2	<0.01	曇り	SSW	1.1
正門	2011/6/17 21:50	30.2	<0.01	曇り	SW	1.1
正門	2011/6/17 22:00	30.2	<0.01	曇り	W	0.9
正門	2011/6/17 22:10	30.2	<0.01	曇り	S	0.9
正門	2011/6/17 22:20	30.2	<0.01	曇り	SW	1.1
正門	2011/6/17 22:30	30.3	<0.01	曇り	SW	0.8
正門	2011/6/17 22:40	30.2	<0.01	曇り	SSE	1.0
正門	2011/6/17 22:50	30.2	<0.01	曇り	SW	1.0
正門	2011/6/17 23:00	30.2	<0.01	曇り	S	0.8
正門	2011/6/17 23:10	30.2	<0.01	曇り	S	1.0
正門	2011/6/17 23:20	30.2	<0.01	曇り	S	1.1
正門	2011/6/17 23:30	30.2	<0.01	曇り	SE	1.2
正門	2011/6/17 23:40	30.1	<0.01	曇り	S	1.0
正門	2011/6/17 23:50	30.1	<0.01	曇り	SW	0.9

福島第一原子力発電所

2011/6/17
23:50現在

