

集中廃棄物処理施設周辺 サブドレン水核種分析結果

I-131(Bq/L)

測定場所	7/26	7/27	7/28	7/29	7/30	7/31	8/1	8/2	8/3	8/4	8/5	8/6	8/7	8/8	8/9	8/10	8/11				
	ND(6.0)	ND(5.4)	ND(7.5)	ND(6.5)	ND(7.5)	ND(6.4)	ND(6.1)	ND(7.2)	ND(7.1)	ND(5.7)	ND(6.4)	ND(6.4)	ND(10)	ND(6.0)	ND(6.1)	ND(5.6)	ND(5.6)				
	ND(6.2)	ND(4.8)	ND(7.0)	ND(6.0)	ND(6.6)	ND(6.8)	ND(6.8)	ND(6.2)	ND(6.2)	ND(6.8)	ND(7.0)	ND(7.2)	ND(5.7)	ND(6.0)	ND(7.1)	ND(6.2)	ND(5.8)				
	ND(6.8)	ND(5.9)	ND(7.0)	ND(6.4)	ND(6.6)	ND(7.5)	ND(7.3)	ND(7.2)	ND(7.5)	ND(6.4)	ND(5.7)	ND(6.4)	ND(6.5)	ND(6.7)	ND(6.4)	ND(6.0)	ND(6.3)				
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	ND(6.3)	ND(7.0)	ND(7.0)	ND(4.7)	ND(6.0)	ND(7.4)	ND(6.5)	ND(6.4)	ND(6.4)	ND(7.0)	ND(5.7)	ND(6.8)	ND(6.8)	ND(6.7)	ND(5.5)	ND(6.0)	ND(6.7)				
	-	ND(7.0)	-	-	-	-	-	-	ND(6.4)	-	-	-	-	-	-	ND(5.4)	-				
	ND(7.3)	ND(7.7)	ND(8.3)	ND(8.2)	ND(6.4)	ND(6.5)	ND(7.7)	ND(8.2)	ND(7.5)	ND(7.0)	ND(6.3)	ND(7.4)	ND(7.5)	ND(8.1)	ND(6.2)	ND(8.8)	ND(7.4)				
	ND(7.2)	ND(7.0)	ND(8.7)	ND(7.5)	ND(5.6)	ND(7.2)	ND(6.3)	ND(8.0)	ND(7.5)	ND(5.6)	ND(7.2)	ND(7.0)	ND(7.7)	ND(7.2)	ND(6.1)	ND(7.1)	ND(5.8)				
	ND(6.6)	ND(7.0)	ND(7.4)	ND(7.9)	ND(5.4)	ND(5.7)	ND(5.2)	ND(5.8)	ND(6.0)	ND(6.5)	ND(6.3)	ND(6.3)	ND(6.6)	ND(5.8)	ND(6.0)	ND(6.8)	ND(8.3)				

Cs-134(Bq/L)

測定場所	7/26	7/27	7/28	7/29	7/30	7/31	8/1	8/2	8/3	8/4	8/5	8/6	8/7	8/8	8/9	8/10	8/11				
	ND(11)	ND(11)	ND(11)	ND(10)	ND(8.8)	ND(10)	ND(10)	ND(10)	ND(11)	ND(10)	ND(10)	ND(9.7)	ND(11)	ND(10)	ND(11)	ND(10)	ND(11)				
	ND(11)	ND(11)	ND(10)	ND(10)	ND(11)	ND(10)	ND(10)	ND(12)	ND(11)	ND(10)	ND(12)	ND(10)	ND(9.7)	ND(10)	ND(9.8)	ND(11)	ND(11)				
	ND(11)	ND(11)	ND(11)	ND(9.8)	ND(11)	ND(10)	ND(9.8)	ND(11)	ND(11)	ND(11)	ND(9.4)	ND(11)	ND(11)	ND(11)	ND(10)	ND(9.4)	ND(10)				
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	ND(11)	ND(11)	ND(11)	ND(10)	ND(10)	ND(11)	ND(11)	ND(11)	ND(10)	ND(9.2)	ND(8.9)	ND(11)	ND(10)	ND(11)	ND(9.9)	ND(11)	ND(10)				
	-	ND(15)	-	-	-	-	-	-	ND(15)	-	-	-	-	-	-	ND(10)	-				
	13	18	ND(12)	12	ND(9.8)	ND(10)	13	18	12	ND(11)	ND(12)	ND(11)	13	14	11	12	13				
	ND(11)	11	12	9.7	ND(11)	ND(11)	ND(9.9)	ND(9.8)	ND(11)	ND(11)	11	ND(11)	ND(10)	ND(11)	ND(10)	ND(11)	ND(9.7)				
	ND(9.8)	ND(11)	ND(11)	ND(11)	ND(11)	ND(11)	ND(10)	ND(11)	ND(11)	ND(11)	ND(11)	ND(10)	ND(10)	ND(9.9)	ND(9.9)	ND(11)	ND(11)				

Cs-137(Bq/L)

測定場所	7/26	7/27	7/28	7/29	7/30	7/31	8/1	8/2	8/3	8/4	8/5	8/6	8/7	8/8	8/9	8/10	8/11				
	ND(18)	ND(17)	ND(18)	ND(18)	ND(17)	ND(17)	ND(16)	ND(17)	ND(17)	ND(16)	ND(16)	ND(17)	ND(18)	ND(18)	ND(18)	ND(16)	ND(16)				
	ND(17)	ND(18)	ND(17)	ND(17)	ND(17)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(16)	ND(16)	ND(16)	ND(18)	ND(18)				
	ND(18)	ND(19)	ND(18)	ND(17)	ND(18)	ND(17)	ND(17)	ND(18)	ND(18)	ND(16)	ND(17)	ND(16)	ND(18)	ND(18)	ND(18)	ND(16)	ND(18)				
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
	ND(19)	ND(17)	ND(18)	ND(17)	ND(19)	ND(18)	ND(18)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(18)	ND(18)	ND(18)	ND(18)	ND(16)				
	-	ND(17)	-	-	-	-	-	-	ND(16)	-	-	-	-	-	-	ND(16)	-				
	62	68	55	68	46	26	49	51	45	40	42	55	54	57	53	28	75				
	28	47	44	45	ND(18)	ND(18)	ND(18)	33	18	23	23	17	ND(16)	19	ND(18)	18	ND(17)				
	ND(17)	ND(18)	ND(18)	ND(18)	ND(17)	ND(17)	ND(17)	ND(18)	ND(18)	ND(19)	ND(18)	ND(18)	ND(16)	ND(16)	ND(16)	ND(18)	ND(18)				

「-」はサンプリング・測定を実施していないことを示す。  
 は採取不可となったため、地下水流の上流側として選定し、週1回程度の頻度で測定。(2011/4/29~)  
 は地下水流の下流側であることから、追加で測定。(2011/5/26~)  
 を追加で測定。(2011/5/30~)  
 を追加で測定。(2011/8/2~)  
 NDは検出限界値未満を表し、( )内に検出限界値を示す。

<測定箇所>  
 4号T/B建屋南東  
 プロセス主建屋北東  
 プロセス主建屋南東  
 プロセス主建屋南西  
 雑固体廃棄物減容処理建屋南  
 サイトバンカ建屋南西  
 焼却工作建屋 西側  
 雑固体廃棄物減容処理建屋北  
 サイトバンカ建屋南東