

### 福島第一原子力発電所、港湾口海水放射線モニタ指示値一覧 (1/1~1/4)

(単位: Bq/L)

日時	全β	Cs134	Cs137
2017/1/1 0:00	ND	0.06	0.84
2017/1/1 1:00	9.7	0.05	0.83
2017/1/1 2:00	ND	0.06	0.79
2017/1/1 3:00	ND	0.04	0.69
2017/1/1 4:00	10.0	0.08	0.49
2017/1/1 5:00	ND	0.06	0.59
2017/1/1 6:00	ND	0.05	0.55
2017/1/1 7:00	ND	0.06	0.51
2017/1/1 8:00	ND	ND	0.69
2017/1/1 9:00	ND	0.07	0.54
2017/1/1 10:00	ND	0.07	0.57
2017/1/1 11:00	ND	0.08	0.59
2017/1/1 12:00	ND	0.10	0.60
2017/1/1 13:00	ND	0.06	0.64
2017/1/1 14:00	ND	0.09	0.58
2017/1/1 15:00	ND	0.07	0.55
2017/1/1 16:00	ND	0.03	0.58
2017/1/1 17:00	ND	0.05	0.50
2017/1/1 18:00	ND	0.07	0.49
2017/1/1 19:00	ND	0.08	0.53
2017/1/1 20:00	9.0	0.08	0.62
2017/1/1 21:00	ND	0.10	0.64
2017/1/1 22:00	ND	0.07	0.70
2017/1/1 23:00	ND	0.09	0.71
平均値	9.6	0.07	0.62

NDは検出限界値未満を表す。

(単位: Bq/L)

日時	全β	Cs134	Cs137
2017/1/2 0:00	ND	0.07	0.79
2017/1/2 1:00	ND	0.08	0.65
2017/1/2 2:00	ND	0.09	0.56
2017/1/2 3:00	ND	0.08	0.51
2017/1/2 4:00	8.9	0.08	0.49
2017/1/2 5:00	ND	0.03	0.61
2017/1/2 6:00	ND	0.04	0.58
2017/1/2 7:00	ND	0.09	0.51
2017/1/2 8:00	ND	0.07	0.47
2017/1/2 9:00	ND	0.08	0.45
2017/1/2 10:00	ND	0.05	0.59
2017/1/2 11:00	ND	0.06	0.49
2017/1/2 12:00	ND	0.08	0.50
2017/1/2 13:00	8.8	0.05	0.58
2017/1/2 14:00	10.5	0.07	0.44
2017/1/2 15:00	10.4	0.06	0.46
2017/1/2 16:00	ND	0.04	0.59
2017/1/2 17:00	ND	0.07	0.42
2017/1/2 18:00	12.5	0.05	0.55
2017/1/2 19:00	ND	0.05	0.58
2017/1/2 20:00	ND	0.03	0.59
2017/1/2 21:00	ND	0.07	0.44
2017/1/2 22:00	ND	0.07	0.69
2017/1/2 23:00	ND	0.04	0.72
平均値	10.2	0.06	0.55

NDは検出限界値未満を表す。

(単位: Bq/L)

日時	全β	Cs134	Cs137
2017/1/3 0:00	ND	0.06	0.67
2017/1/3 1:00	ND	0.04	0.80
2017/1/3 2:00	ND	0.09	0.56
2017/1/3 3:00	11.1	0.07	0.55
2017/1/3 4:00	11.0	0.07	0.48
2017/1/3 5:00	9.5	0.04	0.57
2017/1/3 6:00	10.4	0.05	0.61
2017/1/3 7:00	ND	0.05	0.60
2017/1/3 8:00	ND	0.05	0.50
2017/1/3 9:00	ND	0.07	0.48
2017/1/3 10:00	9.7	0.09	0.53
2017/1/3 11:00	ND	0.07	0.56
2017/1/3 12:00	8.9	0.08	0.50
2017/1/3 13:00	10.7	0.06	0.52
2017/1/3 14:00	ND	0.04	0.61
2017/1/3 15:00	9.7	0.08	0.47
2017/1/3 16:00	9.9	0.08	0.43
2017/1/3 17:00	ND	0.07	0.46
2017/1/3 18:00	11.6	0.05	0.60
2017/1/3 19:00	13.8	0.03	0.60
2017/1/3 20:00	13.6	0.05	0.62
2017/1/3 21:00	ND	0.07	0.45
2017/1/3 22:00	11.0	0.07	0.49
2017/1/3 23:00	ND	0.06	0.49
平均値	10.8	0.06	0.55

NDは検出限界値未満を表す。

(単位: Bq/L)

日時	全β	Cs134	Cs137
2017/1/4 0:00	ND	0.05	0.58
2017/1/4 1:00	ND	ND	0.65
2017/1/4 2:00	ND	0.08	0.43
2017/1/4 3:00	ND	0.03	0.58
2017/1/4 4:00	ND	0.05	0.52
2017/1/4 5:00	ND	0.07	0.46
2017/1/4 6:00	11.0	0.04	0.60
2017/1/4 7:00	ND	0.08	0.46
2017/1/4 8:00	10.4	0.05	0.46
2017/1/4 9:00	ND	0.08	0.44
2017/1/4 10:00	11.6	0.05	0.60
2017/1/4 11:00	9.3	0.07	0.48
2017/1/4 12:00	ND	0.05	0.63
2017/1/4 13:00	13.7	0.05	0.64
2017/1/4 14:00	10.0	0.04	0.52
2017/1/4 15:00	ND	0.09	0.50
2017/1/4 16:00	ND	0.06	0.63
2017/1/4 17:00	9.0	0.04	0.62
2017/1/4 18:00	9.0	0.08	0.46
2017/1/4 19:00	9.7	0.06	0.49
2017/1/4 20:00	ND	0.05	0.54
2017/1/4 21:00	12.7	ND	0.67
2017/1/4 22:00	ND	0.09	0.45
2017/1/4 23:00	13.7	0.03	0.60
平均値	10.9	0.06	0.54

NDは検出限界値未満を表す。

(単位: Bq/L)

日時	全β	Cs134	Cs137
平均値			

NDは検出限界値未満を表す。

(単位: Bq/L)

日時	全β	Cs134	Cs137
平均値			

NDは検出限界値未満を表す。

(単位: Bq/L)

日時	全β	Cs134	Cs137
平均値			

NDは検出限界値未満を表す。

<p><b>&lt;備考&gt;</b>          (検出限界値 Bq/L)          ・セシウム(Cs)134 : 0.02          ・セシウム(Cs)137 : 0.05          ・全β : 8.7</p>	<p><b>(参考)</b>          東京電力株式会社福島第一原子力発電所原子炉施設の保安及び特定核燃料物質の防護に関する規則に定める告示濃度限度は以下の通り          ・セシウム(Cs)134:60 Bq/L          ・セシウム(Cs)137:90 Bq/L</p>
---	--







