

測定月報

測定日: 2016/10

(1/10)

日	モニタ									
	B001	B002	B003	B004	B005	B006	B007	B008	B009	B010
	入退域管理棟周辺	正門警備所周辺	環境管理棟周辺	車両スクリーニング場周辺	厚生棟休憩所周辺	登録センター休憩所周辺	5/6号サードビル棟屋体敷所周辺	シールド中央制御室周辺	免震重要棟周辺	5/6号防護本部周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	0.317	0.679	3.056	0.572	0.769	1.812	1.458	3.340	7.594	1.303
2	0.318	0.687	3.058	0.576	0.770	1.816	1.472	3.372	7.626	1.315
3	0.316	0.693	3.036	0.578	0.771	1.809	1.470	3.383	7.637	1.324
4	0.319	0.696	3.041	0.581	0.770	1.805	1.478	3.421	7.659	1.331
5	0.315	0.694	3.043	0.577	0.771	1.805	1.479	3.414	7.597	1.320
6	0.317	0.688	3.040	0.573	0.768	1.807	1.469	3.395	7.622	1.326
7	0.312	0.690	3.046	0.569	0.765	1.810	1.460	3.372	7.561	1.306
8	0.318	0.694	3.029	0.571	0.766	1.798	1.459	3.364	7.603	1.310
9	0.322	0.705	3.041	0.568	0.762	1.796	1.456	3.377	7.622	1.312
10	0.314	0.698	3.040	0.568	0.763	1.792	1.455	3.321	7.547	1.292
11	0.310	0.687	3.024	0.568	0.765	1.798	1.460	3.296	7.524	1.293
12	0.315	0.690	3.020	0.569	0.765	1.804	1.464	3.353	7.544	1.303
13	0.310	0.677	3.040	0.566	0.764	1.800	1.465	3.330	7.488	1.292
14	0.309	0.673	3.046	0.569	0.761	1.811	1.466	3.302	7.489	1.294
15	0.315	0.671	3.057	0.568	0.767	1.825	1.473	3.327	7.530	1.303
16	0.316	0.681	3.060	0.571	0.766	1.832	1.479	3.334	7.570	1.309
17	0.315	0.676	3.006	0.572	0.764	1.810	1.475	3.332	7.580	1.316
18	0.314	0.677	3.040	0.574	0.769	1.806	1.487	3.237	7.607	1.324
19	0.315	0.675	3.043	0.574	0.771	1.811	1.483	3.274	7.567	1.316
20	0.318	0.679	3.046	0.574	0.772	1.806	1.493	3.306	7.598	1.326
21	0.312	0.665	3.033	0.570	0.765	1.795	1.480	3.320	7.498	1.297
22	0.323	0.678	3.026	0.570	0.766	1.799	1.482	3.359	7.526	1.302
23	0.322	0.680	3.034	0.571	0.770	1.805	1.491	3.347	7.539	1.309
24	0.312	0.665	3.007	0.564	0.764	1.803	1.477	3.300	7.467	1.298
25	0.312	0.670	3.020	0.567	0.762	1.815	1.480	3.317	7.496	1.305
26	0.318	0.681	3.041	0.574	0.776	1.814	1.505	3.387	7.623	1.336
27	0.311	0.671	3.011	0.570	0.771	1.809	1.485	3.330	7.513	1.308
28	0.308	0.657	2.953	0.563	0.756	1.788	1.446	3.256	7.377	1.270
29	0.308	0.654	2.978	0.558	0.756	1.787	1.417	3.225	7.409	1.259
30	0.304	0.656	2.995	0.556	0.756	1.786	1.419	3.234	7.402	1.252
31	0.305	0.662	2.985	0.561	0.757	1.796	1.434	3.290	7.435	1.275
1ヶ月値	0.314	0.679	3.029	0.570	0.766	1.805	1.468	3.330	7.543	1.304
最大値	0.367	0.767	3.191	0.623	0.836	1.914	1.573	3.590	7.899	1.410
最大値日時	10/02 17:30	10/09 14:10	10/02 18:00	10/02 16:40	10/21 13:30	10/25 14:30	10/26 10:00	10/24 10:20	10/05 23:50	10/20 10:10
最小値	0.257	0.604	2.639	0.517	0.670	1.701	1.354	3.031	7.220	1.195
最小値日時	10/14 08:00	10/21 07:40	10/27 11:00	10/29 04:50	10/24 10:00	10/05 08:40	10/29 07:00	10/18 10:40	10/31 05:50	10/28 23:20

測定月報

測定日: 2016/10

(2/10)

日	モニタ									
	B011	B012	B013	B014	B015	B016	B017	B018	B019	B020
	1号北側法面上周辺 線量率 (μ Sv/h)	1/2号西側法面上周辺 線量率 (μ Sv/h)	3/4号西側法面上周辺 線量率 (μ Sv/h)	4号南側法面上周辺 線量率 (μ Sv/h)	一般焼却炉周辺 線量率 (μ Sv/h)	車両整備場周辺 線量率 (μ Sv/h)	多核種除去施設周辺 線量率 (μ Sv/h)	キャスク仮保管施設周辺 線量率 (μ Sv/h)	野島の森五差路周辺 線量率 (μ Sv/h)	5/6号機西側周辺 線量率 (μ Sv/h)
1	59.389	51.088	15.008	2.322	26.096	0.941	0.917	0.430	4.053	7.395
2	59.904	51.421	15.129	2.345	26.184	0.951	0.921	0.434	4.080	7.451
3	60.060	51.633	15.306	2.375	26.140	0.946	0.914	0.447	4.225	7.441
4	60.612	51.818	15.344	2.396	26.145	0.975	0.912	0.439	4.275	7.475
5	60.365	51.461	15.033	2.354	26.191	0.998	0.905	0.432	4.106	7.497
6	60.474	51.856	15.147	2.379	26.004	0.996	0.908	0.436	4.169	7.455
7	60.460	51.062	14.623	2.290	26.288	0.979	0.833	0.423	3.880	7.466
8	60.653	51.389	14.852	2.323	26.226	0.969	0.796	0.430	4.006	7.403
9	60.521	51.408	14.857	2.325	26.182	0.965	0.793	0.433	4.007	7.395
10	59.989	50.749	14.471	2.278	26.300	0.963	0.811	0.423	3.815	7.421
11	60.014	50.610	14.376	2.266	26.242	0.992	0.817	0.423	3.809	7.448
12	60.239	50.712	14.466	2.288	26.286	0.977	0.810	0.430	3.860	7.473
13	59.590	50.152	14.216	2.249	26.260	0.970	0.791	0.419	3.761	7.464
14	59.771	50.382	14.202	2.260	26.312	0.966	0.805	0.420	3.777	7.501
15	60.035	50.830	14.253	2.268	26.482	0.975	0.817	0.423	3.802	7.517
16	60.469	51.208	14.395	2.290	26.573	0.981	0.820	0.425	3.866	7.526
17	60.502	51.408	14.647	2.327	26.323	0.980	0.814	0.430	3.984	7.508
18	60.903	51.868	14.893	2.343	26.389	0.983	0.810	0.434	4.033	7.540
19	60.817	51.430	14.817	2.315	26.454	0.977	0.811	0.431	3.956	7.553
20	61.036	51.732	14.874	2.333	26.457	0.984	0.819	0.439	4.005	7.567
21	60.256	50.858	14.547	2.275	26.469	0.966	0.805	0.425	3.765	7.563
22	60.024	50.946	14.529	2.272	26.519	0.963	0.808	0.425	3.757	7.562
23	60.360	51.119	14.572	2.287	26.545	0.969	0.813	0.430	3.784	7.575
24	59.768	50.439	14.327	2.248	26.443	0.960	0.808	0.425	3.683	7.560
25	60.495	50.952	14.441	2.261	26.472	0.978	0.822	0.423	3.721	7.585
26	62.003	52.121	14.901	2.350	26.526	0.979	0.838	0.441	3.934	7.657
27	60.872	51.063	14.425	2.274	26.482	0.971	0.827	0.425	3.693	7.582
28	59.661	49.746	13.962	2.190	25.909	0.963	0.811	0.422	3.527	7.377
29	59.492	49.637	13.976	2.163	25.612	0.940	0.813	0.416	3.522	7.212
30	59.477	49.372	13.777	2.159	25.773	0.943	0.804	0.410	3.422	7.252
31	60.117	50.034	14.353	2.207	25.704	0.945	0.816	0.422	3.559	7.298
1ヶ月値	60.269	50.984	14.604	2.291	26.258	0.969	0.832	0.428	3.866	7.475
最大値	63.088	53.001	15.760	2.499	27.059	1.233	1.551	0.584	4.499	7.829
最大値日時	10/26 11:40	10/26 12:20	10/04 07:00	10/04 14:10	10/16 14:40	10/11 10:40	10/29 08:30	10/03 10:00	10/04 08:00	10/26 16:20
最小値	57.624	48.020	13.070	2.038	24.762	0.799	0.728	0.375	3.272	6.911
最小値日時	10/28 06:10	10/05 07:40	10/25 09:00	10/29 01:10	10/29 00:10	10/10 08:00	10/13 19:20	10/22 03:30	10/30 07:30	10/28 22:40

測定月報

測定日: 2016/10

(3/10)

日	モニタ									
	B021	B022	B023	B024	B025	B026	B027	B028	B029	B030
	研修棟周辺 線量率 (μ Sv/h)	企業棟休憩所A棟周辺 線量率 (μ Sv/h)	増設多核種除去設備西側周辺 線量率 (μ Sv/h)	Hタンクエリア周辺(連絡ダクトモニター点検時) 線量率 (μ Sv/h)	1・2号機海側(4m盤) 線量率 (μ Sv/h)	3・4号機海側(4m盤) 線量率 (μ Sv/h)	固体廃棄物貯蔵庫管理棟周辺 線量率 (μ Sv/h)	高性能多核種除去設備周辺 線量率 (μ Sv/h)	サブドレン浄化設備周辺 線量率 (μ Sv/h)	給油所周辺 線量率 (μ Sv/h)
1	1.978	0.828	0.430	7.764	17.496	29.462	15.093	2.338	0.347	0.608
2	1.984	0.845	0.433	7.783	17.684	29.727	15.369	2.351	0.375	0.613
3	1.980	0.835	0.432	7.786	18.004	30.000	15.262	2.351	0.654	0.612
4	2.005	0.839	0.428	7.801	19.374	30.310	15.274	2.358	0.855	0.617
5	2.014	0.834	0.417	7.834	19.850	30.011	15.219	2.346	0.933	0.614
6	2.004	0.832	0.422	7.828	20.042	30.126	14.959	2.346	0.701	0.614
7	1.998	0.833	0.405	7.812	19.417	29.492	14.666	2.327	0.407	0.609
8	1.988	0.835	0.416	7.770	19.719	29.627	14.025	2.331	0.367	0.610
9	1.981	0.836	0.420	7.739	19.695	29.558	11.969	2.325	0.342	0.608
10	1.983	0.834	0.404	7.746	19.228	29.155	12.153	2.420	0.357	0.603
11	1.979	0.834	0.400	7.757	19.115	29.091	12.038	2.571	0.369	0.605
12	1.993	0.835	0.406	7.786	19.191	29.289	12.175	2.595	0.352	0.607
13	1.991	0.830	0.397	7.773	18.910	28.943	12.020	2.590	0.381	0.603
14	1.991	0.833	0.395	7.788	19.036	28.977	11.853	2.604	0.396	0.604
15	1.997	0.839	0.400	7.802	19.149	29.083	12.409	2.612	0.339	0.609
16	2.004	0.841	0.404	7.829	19.290	29.293	12.437	2.621	0.362	0.609
17	2.002	0.834	0.413	7.805	19.467	29.455	12.211	2.613	0.335	0.614
18	2.014	0.840	0.416	7.825	19.651	29.708	11.531	2.623	0.348	0.617
19	2.016	0.839	0.414	7.828	19.460	29.496	10.553	2.617	0.325	0.615
20	2.011	0.839	0.417	7.831	19.655	29.558	10.330	2.629	0.334	0.618
21	2.014	0.834	0.399	7.817	19.114	28.965	10.086	2.599	0.397	0.613
22	2.020	0.840	0.401	7.813	19.183	28.989	10.077	2.595	0.338	0.610
23	2.022	0.841	0.404	7.829	19.298	29.147	9.773	2.602	0.340	0.611
24	2.023	0.832	0.397	7.825	18.932	28.701	9.328	2.576	0.331	0.611
25	2.023	0.832	0.398	7.833	19.102	28.895	9.407	2.590	0.329	0.612
26	2.030	0.842	0.416	7.891	19.784	29.731	9.794	2.616	0.335	0.622
27	2.005	0.838	0.399	7.847	19.138	29.029	9.548	2.600	0.341	0.613
28	1.973	0.818	0.392	7.719	18.471	28.013	9.305	2.532	0.371	0.605
29	1.940	0.821	0.391	7.637	18.477	27.896	9.638	2.513	0.337	0.593
30	1.946	0.824	0.384	7.652	18.255	27.750	9.650	2.528	0.336	0.595
31	1.950	0.817	*9 0.392	7.666	18.519	28.053	9.402	2.544	0.344	0.597
1ヶ月値	1.995	0.834	0.408	7.788	19.087	29.211	11.857	2.512	0.409	0.609
最大値	2.123	0.913	0.501	8.063	20.756	30.803	16.438	2.845	1.210	0.672
最大値日時	10/24 13:30	10/24 10:10	10/20 11:30	10/26 11:20	10/06 01:00	10/06 00:10	10/13 12:00	10/21 12:50	10/05 15:30	10/26 10:10
最小値	1.849	0.730	0.345	7.407	17.120	27.070	8.581	2.189	0.252	0.546
最小値日時	10/28 20:40	10/07 12:40	10/30 21:00	10/28 21:30	10/01 07:40	10/28 21:20	10/25 10:10	10/03 07:50	10/19 11:50	10/01 01:10

*9:その他 線量表示器の一時的な移動

測定月報

測定日: 2016/10

(4/10)

日	モニタ									
	B031	B032	B033	B034	B035	B036	B037	B038	B039	B040
	HIC保管エリア周辺	H8タンクエリア周辺	H4タンクエリア周辺	H5タンクエリア周辺	J2タンクエリア周辺	G6タンクエリア周辺	セシウム吸着塔中間貯蔵施設周辺	G4タンクエリア周辺	MP-8周辺	旧展望台周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	0.517	0.727	3.383	1.306	4.299	2.456	1.984	3.705	5.421	2.281
2	0.522	0.734	3.421	1.311	4.330	2.468	1.982	3.705	5.461	2.298
3	0.530	0.737	3.442	1.319	4.344	2.429	1.950	3.708	5.469	2.306
4	0.533	0.737	3.464	1.329	4.364	2.503	1.965	3.726	5.506	2.326
5	0.523	0.743	3.396	1.318	4.365	2.571	1.950	3.714	5.512	2.318
6	0.530	0.734	3.454	1.329	4.354	2.611	1.534	3.712	5.491	2.313
7	0.513	0.721	3.303	1.310	4.373	2.621	1.340	3.691	5.489	2.295
8	0.525	0.716	3.370	1.318	4.357	2.579	1.400	3.683	5.437	2.285
9	0.527	0.713	3.396	1.313	4.344	2.583	1.403	3.683	5.410	2.278
10	0.510	0.710	3.276	1.303	4.347	2.536	1.399	3.671	5.428	2.273
11	0.512	0.705	3.269	1.298	4.351	2.599	1.406	3.666	5.443	2.271
12	0.511	0.705	3.309	1.311	4.368	2.580	1.416	3.678	5.465	2.289
13	0.508	0.712	3.252	1.304	4.362	2.555	1.653	3.663	5.451	2.275
14	0.508	0.712	3.268	1.303	4.370	2.589	1.810	3.663	5.480	2.287
15	0.511	0.712	3.303	1.306	4.389	2.603	1.817	3.673	5.502	2.300
16	0.516	0.713	3.337	1.306	4.397	2.609	1.820	3.681	5.519	2.309
17	0.526	0.724	3.394	1.314	4.400	2.593	1.827	3.688	5.514	2.319
18	0.530	0.722	3.429	1.314	4.411	2.612	1.877	3.693	5.540	2.334
19	0.522	0.719	3.377	1.304	4.409	2.520	1.816	3.687	5.550	2.328
20	0.522	0.720	3.412	1.309	4.404	2.591	1.836	3.690	5.559	2.343
21	0.502	0.713	3.297	1.296	4.379	2.615	1.991	3.666	5.551	2.317
22	0.506	0.710	3.309	1.299	4.387	2.602	2.227	3.658	5.551	2.313
23	0.508	0.714	3.328	1.298	4.385	2.606	2.232	3.667	5.564	2.322
24	0.492	0.709	3.262	1.289	4.369	2.590	2.140	3.653	5.553	2.313
25	0.491	0.713	3.291	1.290	4.388	2.595	2.301	3.651	5.570	2.323
26	0.520	0.728	3.423	1.310	4.433	2.625	2.336	3.688	5.630	2.362
27	0.506	0.725	3.300	1.288	4.411	2.635	1.844	3.653	5.612	2.335
28	0.491	0.714	3.171	1.273	4.346	2.570	2.190	3.615	5.492	2.288
29	0.492	0.700	3.171	1.268	4.305	2.557	2.738	3.604	5.367	2.246
30	0.483	0.702	3.118	1.262	4.318	2.563	2.725	3.596	5.399	2.252
31	0.498	0.708	3.196	1.271	4.319	2.557	2.271	3.620	5.431	2.270
1ヶ月値	0.512	0.718	3.327	1.302	4.367	2.572	1.909	3.673	5.496	2.302
最大値	0.611	0.887	3.639	1.399	4.571	2.845	3.939	3.847	5.781	2.459
最大値日時	10/03 13:40	10/04 10:50	10/06 00:50	10/06 01:50	10/04 09:00	10/07 11:00	10/31 06:50	10/04 18:00	10/27 13:30	10/20 12:00
最小値	0.438	0.644	3.003	1.200	4.062	2.045	1.200	3.470	5.193	2.123
最小値日時	10/24 17:50	10/15 23:20	10/30 04:00	10/21 03:20	10/04 09:40	10/22 12:40	10/28 09:10	10/29 00:30	10/28 20:40	10/29 04:50

測定月報

測定日: 2016/10

(5/10)

日	モニタ									
	B041	B042	B043	B044	B045	B046	B047	B048	B049	B050
	集中RW西側法面上	大型メンテナンス建屋 東側	大熊通り中央付近	1～4号機PPゲート前	1 2uS/B周辺	3,4uS/B周辺	集中RW東側	集中RW南側	共用プール西側	4uR/B西側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	3.467	2.988	4.121	22.959	33.482	74.196	8.816	8.221	44.477	16.312
2	3.505	3.020	4.160	23.198	33.763	74.913	8.844	8.296	44.688	16.405
3	3.559	3.081	4.179	23.375	34.132	75.203	8.879	8.293	44.578	16.429
4	3.622	3.115	4.192	23.833	34.885	75.545	8.887	8.339	44.732	16.468
5	3.516	3.023	4.172	23.663	34.773	76.112	8.922	8.342	44.662	16.331
6	3.588	3.066	4.161	23.838	34.808	75.499	8.949	8.194	44.406	16.299
7	3.423	2.901	4.112	23.504	34.215	74.370	8.918	8.264	44.494	16.231
8	3.531	3.007	4.118	23.762	34.278	73.018	9.215	8.116	43.622	16.181
9	3.527	3.010	4.097	23.714	34.098	72.741	9.307	8.165	43.948	16.191
10	3.379	2.889	4.072	23.388	33.848	73.304	9.259	8.201	44.129	16.098
11	3.355	2.878	4.081	23.504	33.815	73.280	9.197	8.226	44.220	16.022
12	3.370	2.913	4.105	23.601	33.973	74.418	9.256	8.274	44.328	16.050
13	3.302	2.868	4.089	23.216	33.771	74.779	9.334	8.243	44.213	15.947
14	3.326	2.849	4.103	23.253	33.882	73.340	9.386	8.284	44.279	15.945
15	3.360	2.856	4.121	23.442	34.026	72.056	9.403	8.299	44.493	15.965
16	3.399	2.895	4.135	23.620	34.303	72.212	9.171	8.308	44.610	16.016
17	3.470	2.941	4.140	23.730	34.310	71.400	9.208	8.268	44.270	16.039
18	3.511	2.960	4.170	23.899	34.416	73.516	9.328	8.308	44.435	16.175
19	3.431	2.894	4.155	23.720	34.434	74.974	9.409	8.328	44.396	16.107
20	3.465	2.936	4.178	23.864	34.557	74.867	9.566	8.324	44.479	16.076
21	3.330	2.800	4.126	23.447	34.071	73.203	9.424	8.318	44.403	15.900
22	3.344	2.817	4.128	23.476	34.166	70.313	9.464	8.297	44.387	15.900
23	3.365	2.829	4.133	23.636	34.301	70.245	10.388	8.317	44.399	15.929
24	3.293	2.762	4.106	23.304	33.904	71.677	10.054	8.286	44.254	15.805
25	3.375	2.799	4.121	23.346	34.110	73.086	10.189	8.297	44.296	15.840
26	3.524	2.928	4.190	23.822	34.674	74.031	10.548	8.378	44.593	16.107
27	3.358	2.782	4.129	23.255	34.089	71.981	10.416	8.334	44.415	16.024
28	3.234	2.684	4.024	22.653	33.142	70.557	10.010	8.011	42.861	15.713
29	3.253	2.677	3.963	22.592	33.154	69.553	10.121	7.934	42.844	15.646
30	3.209	2.616	3.961	22.450	33.037	69.036	10.363	8.061	43.415	15.661
31	3.235	2.692	4.016	22.703	33.187	71.195	9.693	8.122	43.623	15.784
1ヶ月値	3.407	2.886	4.115	23.412	34.052	73.052	9.481	8.247	44.224	16.052
最大値	3.756	3.211	4.351	31.191	36.844	78.725	13.600	8.576	45.308	16.727
最大値日時	10/05 23:20	10/03 22:20	10/06 00:10	10/12 20:40	10/31 20:20	10/03 13:00	10/26 13:30	10/26 08:50	10/26 13:00	10/04 07:50
最小値	2.687	2.496	3.818	21.577	30.418	62.885	8.380	7.303	39.433	15.165
最小値日時	10/31 09:50	10/30 21:50	10/29 02:40	10/30 01:00	10/27 19:20	10/17 11:50	10/04 11:20	10/28 23:40	10/28 23:00	10/29 00:30

測定月報

測定日: 2016/10

(6/10)

日	モニタ									
	B051	B052	B053	B054	B055	B056	B057	B058	B059	B060
	3uR/B西側	2uR/B西側	1uR/B西側	1uR/B北側	物揚場周辺	固体庫1, 2棟周辺	旧事務本館北側	固体庫第9棟建設地周辺	危険物屋外貯蔵所周辺	6号機D/G建屋周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	160.330	122.595	95.967	65.932	10.542	6.927	14.551	0.587	1.517	2.357
2	160.834	123.119	96.158	66.509	10.619	6.992	14.634	0.571	1.533	2.386
3	160.823	123.336	95.915	66.652	10.648	7.002	14.681	0.576	1.534	2.385
4	161.279	123.682	95.193	66.994	10.764	7.032	14.787	0.562	1.547	2.405
5	160.481	122.853	96.161	66.885	10.670	6.931	14.663	0.589	1.548	2.415
6	159.963	123.140	97.392	66.504	10.680	6.887	14.735	0.582	1.533	2.341
7	158.906	122.107	96.473	66.403	10.537	6.798	14.605	0.574	1.536	2.387
8	157.795	122.365	98.067	66.279	10.621	6.786	14.733	0.538	1.530	2.337
9	157.310	122.063	97.954	66.033	10.623	6.754	14.757	0.532	1.526	2.357
10	156.321	121.236	96.433	65.847	10.479	6.659	14.565	0.528	1.525	2.372
11	155.357	120.721	94.825	66.029	10.475	6.625	14.512	0.534	1.530	2.395
12	155.703	120.920	84.872	66.348	10.557	6.821	14.563	0.560	1.541	2.410
13	154.221	120.320	84.662	65.919	10.477	6.915	14.431	0.573	1.538	2.403
14	153.563	119.817	95.227	66.523	10.460	6.870	14.459	0.608	1.543	2.422
15	153.173	119.863	84.336	67.256	10.530	6.837	14.529	0.581	1.550	2.425
16	153.752	120.561	75.369	67.744	10.621	6.878	14.631	0.575	1.562	2.433
17	154.118	120.564	74.125	67.662	10.650	6.883	14.670	0.581	1.557	2.423
18	154.767	120.867	84.571	67.961	10.737	6.889	14.767	0.569	1.566	2.408
19	155.542	120.381	86.312	67.931	10.578	6.939	14.593	0.598	1.566	2.422
20	156.112	120.963	77.870	68.297	10.609	6.928	14.752	0.565	1.576	2.434
21	155.295	119.137	73.882	67.537	10.467	6.869	14.534	0.531	1.563	2.440
22	154.565	117.701	70.005	67.583	10.506	6.896	14.562	0.534	1.560	2.432
23	154.852	117.803	70.893	67.865	10.600	6.931	14.596	0.538	1.567	2.443
24	154.654	116.470	74.576	67.381	10.473	6.856	14.426	0.571	1.556	2.438
25	155.208	116.203	77.946	67.717	10.464	6.879	14.347	0.598	1.562	2.449
26	155.449	117.442	78.512	68.858	10.653	7.047	14.583	0.638	1.589	2.468
27	152.886	115.929	78.822	67.889	10.493	6.985	14.426	0.581	1.572	2.462
28	148.310	113.648	80.862	66.474	10.267	6.789	14.177	0.554	1.532	2.353
29	149.418	113.219	81.333	65.491	10.287	6.709	14.160	0.590	1.482	2.282
30	150.723	113.069	82.342	65.698	10.260	6.731	14.103	0.594	1.499	2.331
31	154.039	114.003	80.823	66.363	10.404	6.823	14.278	0.596	1.511	2.360
1ヶ月値	155.669	119.552	85.738	66.921	10.540	6.867	14.542	0.571	1.544	2.399
最大値	164.310	124.712	101.815	69.911	11.043	7.253	15.289	0.681	1.672	2.568
最大値日時	10/04 06:20	10/04 08:20	10/05 13:40	10/26 12:20	10/05 23:40	10/26 11:00	10/26 14:50	10/26 13:10	10/26 15:40	10/26 15:40
最小値	141.408	109.651	62.290	64.149	9.814	6.084	13.232	0.450	1.403	2.108
最小値日時	10/03 13:20	10/01 08:10	10/22 08:20	10/28 22:30	10/28 19:30	10/18 10:30	10/19 10:50	10/06 09:10	10/29 00:00	10/28 23:40

測定月報

測定日: 2016/10

(7/10)

日	モニタ									
	B061	B062	B063	B064	B065	B066	B067	B068	B069	B070
	5・6号機放水口周辺	焼却設備建屋周辺	Fタンクエリア周辺	五洋ヤード P1東側周辺	焼却設備建屋前道路カーブミラー脇	鹿島建設資材置場	一時保管エリアC周辺	一時保管エリアI周辺	一時保管エリアH1周辺	土捨場資材置場
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.897	2.221	12.119	13.206	3.829	3.933	2.357	15.879	4.497	1.011
2	1.851	2.241	12.144	13.238	3.849	3.952	2.368	16.013	4.529	1.026
3	1.868	2.227	12.093	13.469	3.846	4.055	2.394	15.993	4.533	1.026
4	1.888	2.247	12.190	13.230	3.865	4.244	2.377	16.056	4.556	1.034
5	1.919	2.258	12.209	12.683	3.873	4.327	2.415	16.144	4.556	1.025
6	1.898	2.253	12.210	12.622	3.709	4.305	2.380	16.010	4.514	1.031
7	1.838	2.248	12.217	12.786	3.668	4.293	2.318	16.121	4.539	1.027
8	1.764	2.242	12.182	12.685	3.682	4.261	2.286	15.973	4.529	1.035
9	1.735	2.235	12.167	12.649	3.670	4.261	2.277	15.914	4.561	1.034
10	1.725	2.236	12.188	12.711	3.685	4.250	2.265	16.029	4.598	1.030
11	1.717	2.229	12.148	12.691	3.751	4.255	2.277	16.074	4.616	1.029
12	1.749	2.248	12.180	12.680	4.544	4.064	2.328	16.088	4.635	1.036
13	1.748	2.244	12.160	12.631	4.867	4.027	2.300	16.161	4.637	1.034
14	1.737	2.242	12.168	13.305	4.863	4.023	2.296	16.225	4.658	1.014
15	1.742	2.253	12.167	13.688	4.875	3.998	2.279	16.324	4.684	1.004
16	1.742	2.264	12.178	13.680	4.886	4.020	2.294	16.398	4.698	1.015
17	1.773	2.259	12.167	13.883	4.884	4.039	2.317	16.322	4.678	1.018
18	1.806	2.276	12.189	14.173	4.910	4.061	2.360	16.408	4.702	1.022
19	1.807	2.278	12.252	13.991	4.917	4.066	2.320	16.445	4.720	1.036
20	1.812	2.280	12.261	13.900	4.933	4.065	2.352	16.511	4.732	1.054
21	1.810	2.264	12.255	13.742	4.929	4.051	2.320	16.546	4.732	1.023
22	1.811	2.268	12.239	13.601	4.923	4.064	2.310	16.552	4.737	1.008
23	1.813	2.273	12.247	13.577	4.933	4.058	2.316	16.593	4.744	1.016
24	1.808	2.253	12.217	13.666	4.916	4.062	2.318	16.594	4.717	1.005
25	1.816	2.267	12.210	13.698	4.943	4.069	2.326	16.654	4.685	1.017
26	1.836	2.306	12.283	13.744	4.998	4.109	2.405	16.734	4.761	1.038
27	1.822	2.273	12.236	13.720	4.970	4.106	2.312	16.731	4.785	1.021
28	1.777	2.225	12.141	13.547	4.877	4.025	2.280	16.228	4.652	0.996
29	1.741	2.195	12.107	13.433	4.815	3.968	2.254	15.702	4.476	0.965
30	1.748	2.194	12.126	13.440	4.821	3.981	2.248	15.885	4.525	0.963
31	1.761	2.210	12.108	13.677	4.836	4.023	2.309	15.952	4.554	0.978
1ヶ月値	1.799	2.249	12.186	13.347	4.485	4.097	2.321	16.234	4.630	1.018
最大値	2.023	2.384	12.557	14.384	6.319	4.734	7.957	17.061	4.948	1.122
最大値日時	10/05 16:00	10/26 21:00	10/27 10:50	10/19 00:50	10/12 10:30	10/07 11:10	10/26 10:40	10/26 13:10	10/27 16:30	10/20 14:00
最小値	1.634	2.064	7.625	12.291	3.496	3.828	2.149	15.085	4.308	0.906
最小値日時	10/11 17:10	10/03 13:20	10/11 11:10	10/06 06:20	10/07 04:40	10/29 02:00	10/30 21:10	10/12 10:30	10/28 22:10	10/30 04:40

測定月報

測定日: 2016/10

(8/10)

日	モニタ									
	B071	B072	B073	B074	B075	B076	B077	B078	B079	B080
	土捨場東側資材置場	瓦礫保管Aテント周辺	覆土式瓦礫保管エリア北側	覆土式瓦礫保管エリア南側	一時保管エリアG2周辺	一時保管エリアG1周辺	5・6号機迂回道路付近	一時保管エリアM周辺	旧研修棟正面玄関前	3・4号機法面ダストモニタ周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	2.083	35.816	6.294	1.460	0.613	1.596	6.527	3.261	70.132	16.459
2	2.099	35.982	6.335	1.471	0.621	1.620	6.603	3.302	70.420	16.588
3	2.091	35.905	6.287	1.477	0.625	1.622	6.582	3.306	70.246	16.832
4	2.105	36.072	6.301	1.492	0.632	1.633	6.625	3.326	70.450	16.971
5	2.100	36.179	6.292	1.474	0.629	1.631	6.649	3.342	70.392	16.517
6	2.101	35.764	6.270	1.481	0.632	1.626	6.605	3.322	70.257	16.752
7	2.089	35.957	6.264	1.448	0.620	1.620	6.633	3.331	70.315	16.028
8	2.086	35.539	6.223	1.467	0.630	1.611	6.576	3.309	69.984	16.324
9	2.081	35.468	6.209	1.463	0.631	1.603	6.527	3.278	69.977	16.313
10	2.073	35.697	6.220	1.442	0.615	1.602	6.579	3.303	69.938	15.806
11	2.073	35.798	6.241	1.439	0.614	1.606	6.603	3.318	69.951	15.684
12	2.089	35.833	6.271	1.446	0.622	1.614	6.647	3.343	70.117	15.781
13	2.077	35.766	6.243	1.430	0.614	1.610	6.662	3.347	69.809	15.464
14	2.079	35.547	6.253	1.420	0.611	1.613	6.679	3.361	69.945	15.514
15	2.088	35.963	6.316	1.429	0.621	1.622	6.728	3.375	70.151	15.602
16	2.098	36.063	6.334	1.445	0.623	1.632	6.757	3.395	70.290	15.793
17	2.100	35.816	6.319	1.452	0.629	1.626	6.725	3.393	69.987	16.084
18	2.111	36.035	6.353	1.461	0.637	1.644	6.742	3.412	70.360	16.205
19	2.112	36.172	6.350	1.456	0.633	1.641	6.765	3.417	70.359	15.985
20	2.106	36.409	6.364	1.463	0.640	1.646	6.786	3.437	69.966	16.121
21	2.081	36.503	6.333	1.433	0.624	1.631	6.782	3.436	70.096	15.624
22	2.082	36.279	6.336	1.434	0.627	1.636	6.764	3.439	70.027	15.608
23	2.083	36.289	6.344	1.437	0.629	1.638	6.553	3.458	70.066	15.705
24	2.075	36.270	6.303	1.407	0.624	1.628	6.525	3.454	69.898	15.394
25	2.079	36.423	6.313	1.410	0.630	1.634	6.521	3.467	70.003	15.558
26	2.106	36.816	6.387	1.452	0.652	1.667	6.585	3.521	70.582	16.200
27	2.091	36.996	6.351	1.423	0.635	1.650	6.549	3.500	70.185	15.540
28	2.054	36.088	6.202	1.486	0.620	1.611	6.342	3.407	68.879	14.911
29	2.039	35.477	6.084	1.345	0.609	1.569	6.142	3.273	68.718	14.898
30	2.050	35.805	6.123	1.337	0.603	1.574	6.206	3.301	68.878	14.628
31	2.059	35.967	6.164	1.352	0.613	1.591	6.227	3.322	69.219	14.985
1ヶ月値	2.085	36.022	6.280	1.440	0.625	1.621	6.587	3.370	69.987	15.867
最大値	2.199	41.753	6.583	3.232	0.697	1.736	7.023	3.640	71.538	17.446
最大値日時	10/16 09:10	10/26 20:30	10/18 17:20	10/28 08:30	10/26 10:30	10/26 12:30	10/22 15:40	10/26 10:30	10/26 16:10	10/04 08:00
最小値	1.940	33.971	5.887	1.226	0.550	1.482	5.815	3.147	63.153	14.213
最小値日時	10/28 09:40	10/14 20:10	10/28 23:10	10/30 06:20	10/30 22:40	10/30 01:10	10/28 09:20	10/29 01:30	10/20 08:50	10/30 04:30

測定月報

測定日: 2016/10

(9/10)

日	モニタ									
	B081 Bタンクエリア周辺	B082 大型メンテナンス建屋周辺	B083 2, 3号機防道路西側(10m盤)	B084 2号機海側 (4m盤)	B085 中央交差点	B086 No.4倉庫周辺	B087 1, 2u排気筒西側	B088 線量表示器88	B089 線量表示器89	B090 線量表示器90
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.101	1.840	135.149	31.348	1.168	14.878	1623.643			
2	1.109	1.858	136.428	31.682	1.181	15.004	1625.038			
3	1.119	1.877	136.362	31.940	1.180	14.962	1624.945			
4	1.128	1.891	136.161	32.724	1.187	15.037	1629.373			
5	1.117	1.858	135.082	32.318	1.185	15.072	1627.118			
6	1.100	1.876	134.223	32.442	1.182	14.982	1627.460			
7	1.077	1.820	132.527	31.556	1.180	15.014	1623.636			
8	1.083	1.851	133.846	31.834	1.172	14.851	1621.357			
9	1.082	1.853	133.622	31.737	1.166	14.803	1619.751			
10	1.068	1.808	132.705	31.254	1.168	14.889	1617.504			
11	1.070	1.808	131.308	31.258	1.169	14.951	1615.845			
12	1.079	1.818	131.152	31.479	1.179	15.009	1615.957			
13	1.087	1.793	130.774	30.993	1.174	15.010	1611.811			
14	1.096	1.796	129.298	31.071	1.176	15.037	1614.063			
15	1.102	1.806	132.524	31.257	1.183	15.075	1615.494			
16	1.113	1.820	133.628	31.496	1.185	15.134	1616.553			
17	1.117	1.847	133.781	31.659	1.190	15.082	1618.563			
18	1.118	1.857	133.924	31.904	1.192	15.174	1620.031			
19	1.106	1.838	133.676	31.665	1.195	15.172	1617.813			
20	1.113	1.850	134.072	31.866	1.202	15.213	1619.209			
21	1.096	1.799	128.993	30.995	1.195	15.189	1613.621			
22	1.102	1.801	131.878	31.090	1.197	15.201	1611.489			
23	1.106	1.809	133.100	31.250	1.196	15.243	1611.454			
24	1.088	1.777	130.790	30.490	1.197	15.202	1607.346			
25	1.099	1.796	131.729	30.756	1.200	15.263	1608.229			
26	1.124	1.860	133.760	31.758	1.216	15.415	1617.512			
27	1.111	1.799	131.990	30.847	1.207	15.347	1611.277			
28	1.102	1.753	129.446	29.897	1.182	14.944	1598.681			
29	1.107	1.786	128.980	29.950	1.142	14.706	1595.131			
30	1.104	1.786	128.702	29.720	1.149	14.819	1593.728			
31	1.097	1.832	129.546	30.028	1.155	14.868	1598.052			
1ヶ月値	1.101	1.825	132.553	31.299	1.182	15.050	1615.216			
最大値	1.204	1.979	138.325	33.349	1.310	15.692	1637.609			
最大値日時	10/20 12:10	10/04 07:30	10/04 13:20	10/04 07:40	10/26 10:50	10/26 16:30	10/04 11:00			
最小値	0.991	1.674	67.803	26.679	1.085	14.165	1583.615			
最小値日時	10/31 07:20	10/29 00:10	10/14 10:10	10/21 14:40	10/29 06:20	10/28 23:50	10/11 14:10			