

水処理運転管理部 水処理運営G

承認	審査	作成
H30.3.5	H30.3.5	H30.3.5

各建屋滞留水移送ライン近傍線量率データ(月報)

2018年 2月分

各建屋滞留水移送ライン近傍線量率データ（2018年2月分）

月日	2号T／B出口 (mSv／h)	3号T／B入口 (mSv／h)	4号T／B出口 (mSv／h)	HTI建屋入口 (mSv／h)	プロセス主建屋入口 (mSv／h)	焼却工作建屋出口 (mSv／h)	備考
2/1	1.07E+02	2.17E+02	3.57E+01	7.64E+01	1.91E+01	3.38E+01	
2/2	1.03E+02	2.13E+02	3.45E+01	5.24E+01	1.76E+01	2.63E+01	
2/3	1.14E+02	3.16E+02	3.90E+01	6.25E+01	1.93E+01	3.10E+01	
2/4	1.15E+02	3.62E+02	4.30E+01	7.79E+01	2.21E+01	4.14E+01	
2/5	1.11E+02	2.60E+02	4.30E+01	1.13E+02	2.52E+01	5.33E+01	
2/6	1.16E+02	3.32E+02	1.79E+02	4.19E+02	9.06E+01	2.47E+02	
2/7	1.08E+02	2.23E+02	1.72E+02	4.22E+02	8.66E+01	2.49E+02	
2/8	1.35E+02	9.58E+02	2.46E+02	4.22E+02	1.35E+02	2.48E+02	
2/9	1.10E+02	3.14E+02	1.76E+02	4.22E+02	9.54E+01	2.48E+02	
2/10	1.11E+02	2.06E+02	2.81E+01	1.03E+02	1.78E+01	4.22E+01	
2/11	1.31E+02	7.72E+02	3.65E+01	9.91E+01	1.82E+01	4.67E+01	
2/12	1.30E+02	7.64E+02	2.84E+01	9.59E+01	1.54E+01	4.76E+01	
2/13	1.14E+02	4.86E+02	1.01E+02	9.60E+01	6.41E+01	4.67E+01	
2/14	1.06E+02	2.25E+02	3.55E+01	9.67E+01	1.84E+01	4.65E+01	
2/15	1.04E+02	1.95E+02	3.04E+01	9.64E+01	1.65E+01	4.71E+01	
2/16	1.11E+02	2.26E+02	3.45E+01	9.69E+01	1.89E+01	4.68E+01	
2/17	1.29E+02	7.26E+02	3.26E+01	9.71E+01	1.73E+01	4.67E+01	
2/18	1.28E+02	7.32E+02	9.20E+01	9.70E+01	5.60E+01	4.62E+01	
2/19	1.30E+02	7.48E+02	3.16E+01	9.86E+01	1.68E+01	4.59E+01	
2/20	1.22E+02	4.64E+02	3.16E+01	9.86E+01	1.81E+01	4.55E+01	
2/21	1.11E+02	2.12E+02	3.24E+01	9.84E+01	1.76E+01	4.57E+01	
2/22	1.13E+02	3.31E+02	7.42E+01	9.89E+01	5.14E+01	4.56E+01	
2/23	1.05E+02	2.27E+02	3.39E+01	9.97E+01	1.87E+01	4.58E+01	
2/24	1.11E+02	2.10E+02	3.20E+01	1.01E+02	1.71E+01	4.60E+01	
2/25	1.22E+02	4.82E+02	3.47E+01	1.01E+02	1.89E+01	4.58E+01	
2/26	1.11E+02	2.03E+02	3.20E+01	1.01E+02	1.63E+01	4.56E+01	
2/27	1.10E+02	2.08E+02	3.59E+01	1.01E+02	1.64E+01	4.59E+01	
2/28	1.10E+02	1.87E+02	3.12E+01	1.01E+02	1.67E+01	4.59E+01	