

測定月報

測定日: 2016/07

(1/5)

日	モニタ											
	A001 正門警備所 (DM74)			A002 正門警備所 (DM44)			A003 免震重要棟(DM-46)			A004 免震重要棟(DM-47)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.97E-06	1.0	100	5.57E-06	1.1	100	*1 6.75E-06	10.5	100	*1 6.48E-06	9.8	100
2	7.10E-06	1.1	100	5.64E-06	1.3	100	6.36E-06	10.6	100	6.00E-06	10.1	100
3	5.13E-06	1.1	100	4.12E-06	1.2	100	5.25E-06	10.6	100	5.26E-06	9.7	100
4	4.48E-06	1.1	100	*1 3.58E-06	1.2	100	3.95E-06	10.7	100	4.06E-06	9.5	100
5	1.22E-06	1.0	100	1.03E-06	1.1	100	1.13E-06	10.5	100	9.98E-07	9.7	100
6	2.48E-06	1.2	100	2.07E-06	1.2	100	2.35E-06	10.6	100	2.42E-06	9.6	100
7	2.79E-06	1.0	100	2.21E-06	1.2	100	2.67E-06	10.3	100	2.37E-06	9.7	100
8	2.82E-06	1.1	100	2.31E-06	1.2	100	2.09E-06	10.6	100	1.92E-06	9.9	100
9	5.35E-06	1.1	100	4.21E-06	1.3	100	4.96E-06	10.4	100	4.54E-06	9.7	100
10	6.99E-06	1.0	100	5.62E-06	1.3	100	6.41E-06	10.6	100	6.13E-06	9.6	100
11	*1 7.52E-06	1.1	100	6.22E-06	1.3	100	7.51E-06	10.4	100	6.91E-06	9.7	100
12	5.87E-06	1.1	100	5.04E-06	1.3	100	5.92E-06	10.6	100	5.94E-06	9.7	100
13	9.69E-06	1.2	100	7.90E-06	1.4	100	9.44E-06	10.8	100	9.22E-06	9.5	100
14	5.85E-06	1.1	100	4.74E-06	1.3	100	6.00E-06	10.3	100	5.62E-06	9.6	100
15	1.09E-06	1.2	100	9.86E-07	1.3	100	1.23E-06	10.5	100	1.18E-06	9.6	100
16	2.48E-06	1.1	100	2.05E-06	1.3	100	2.47E-06	10.4	100	2.41E-06	9.5	100
17	4.50E-06	1.0	100	3.80E-06	1.2	100	3.62E-06	10.4	100	3.60E-06	9.4	100
18	6.58E-06	1.1	100	5.38E-06	1.2	100	5.64E-06	10.5	100	5.36E-06	9.6	100
19	6.65E-06	1.1	100	5.27E-06	1.3	100	6.23E-06	10.7	100	6.18E-06	9.5	100
20	5.78E-06	1.2	100	4.71E-06	1.3	100	5.25E-06	10.8	100	4.92E-06	9.8	100
21	2.38E-06	1.0	100	1.88E-06	1.2	100	2.25E-06	10.6	100	2.20E-06	9.7	100
22	2.07E-06	1.1	100	1.56E-06	1.2	100	1.71E-06	10.6	100	1.53E-06	9.5	100
23	1.10E-06	1.0	100	8.51E-07	1.2	100	1.11E-06	10.4	100	9.87E-07	9.6	100
24	1.45E-06	1.0	100	1.05E-06	1.3	100	1.40E-06	10.6	100	1.37E-06	9.5	100
25	4.58E-06	1.1	100	3.83E-06	1.2	100	4.07E-06	10.9	100	4.05E-06	9.7	100
26	5.09E-06	1.1	100	4.22E-06	1.2	100	4.54E-06	10.5	100	4.05E-06	9.7	100
27	3.44E-06	1.1	100	2.91E-06	1.2	100	*1 2.32E-06	10.5	100	*1 2.18E-06	9.5	100
28	3.33E-06	1.1	100	2.77E-06	1.2	100	3.06E-06	10.6	100	3.09E-06	9.6	100
29	2.38E-06	1.1	100	*1 2.11E-06	1.2	100	2.45E-06	10.4	100	2.50E-06	9.4	100
30	5.62E-06	1.1	100	4.56E-06	1.2	100	5.41E-06	10.5	100	5.20E-06	9.5	100
31	5.32E-06	1.1	100	4.38E-06	1.2	100	5.24E-06	10.6	100	5.23E-06	9.5	100
1ヶ月値	4.45E-06	1.1	100	3.63E-06	1.2	100	4.15E-06	10.5	100	4.00E-06	9.6	100
最大値	2.66E-05	1.2	102	3.32E-05	1.4	101	3.33E-05	10.9	102	4.14E-05	10.1	102
最大値日時	07/13 04:06	07/06 00:12	07/01 00:56	07/13 04:16	07/13 03:57	07/01 00:09	07/11 00:28	07/25 00:27	07/09 18:07	07/13 04:22	07/02 04:12	07/02 04:15
最小値	0.00E+00	1.0	97	0.00E+00	1.1	98	0.00E+00	10.3	98	0.00E+00	9.4	98
最小値日時	07/06 00:12	07/01 00:12	07/07 08:56	07/06 03:58	07/01 03:57	07/13 19:40	07/01 00:27	07/07 00:27	07/01 21:42	07/01 04:12	07/17 04:12	07/01 03:16

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2016/07

(2/5)

日	モニタ											
	A005 5/6号警備所前(DM48)			A006 5/6号警備所前(DM49)			A007 1号北側法面上(旧厚生棟)(DM-50)			A008 1号北側法面上(旧厚生棟)(DM-51)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.25E-06	2.0	100	5.64E-06	1.5	100	6.19E-06	13.0	100	5.94E-06	10.0	100
2	5.49E-06	2.1	100	5.02E-06	1.6	100	5.48E-06	13.3	100	5.35E-06	10.1	100
3	5.62E-06	2.0	100	5.03E-06	1.6	100	5.23E-06	13.2	100	5.16E-06	10.0	100
4	*1 4.07E-06	2.0	100	*1 3.49E-06	1.6	100	3.99E-06	13.0	100	3.70E-06	10.0	100
5	9.35E-07	2.1	100	8.31E-07	1.6	100	1.03E-06	13.1	100	9.76E-07	10.0	100
6	2.26E-06	2.0	100	1.97E-06	1.5	100	2.53E-06	13.0	100	2.27E-06	10.1	100
7	2.51E-06	1.9	100	2.18E-06	1.5	100	2.36E-06	13.1	100	2.16E-06	10.1	100
8	1.94E-06	2.0	100	1.67E-06	1.6	100	1.91E-06	13.1	100	1.88E-06	9.9	100
9	4.34E-06	2.0	100	3.88E-06	1.5	100	4.48E-06	12.9	100	4.38E-06	9.8	100
10	6.28E-06	2.0	100	5.41E-06	1.5	100	5.64E-06	13.3	100	5.58E-06	9.9	100
11	7.33E-06	2.0	100	6.38E-06	1.5	100	6.54E-06	13.4	100	6.44E-06	10.0	100
12	5.86E-06	1.9	100	5.17E-06	1.7	100	5.86E-06	12.9	100	5.63E-06	10.0	100
13	8.63E-06	2.1	100	7.72E-06	1.6	100	9.29E-06	12.9	100	8.29E-06	9.9	100
14	5.42E-06	2.0	100	4.84E-06	1.5	100	5.71E-06	12.9	100	5.36E-06	9.9	100
15	1.10E-06	2.0	100	9.49E-07	1.6	100	1.04E-06	13.3	100	1.05E-06	10.1	100
16	2.20E-06	2.0	100	1.94E-06	1.6	100	2.21E-06	13.2	100	2.16E-06	10.1	100
17	3.38E-06	1.9	100	2.88E-06	1.5	100	2.98E-06	13.5	100	3.14E-06	10.1	100
18	4.86E-06	2.0	100	4.26E-06	1.6	100	4.90E-06	13.0	100	4.60E-06	10.2	100
19	6.04E-06	2.0	100	5.44E-06	1.5	100	5.94E-06	13.1	100	5.91E-06	10.0	100
20	5.38E-06	2.0	100	4.66E-06	1.6	100	5.25E-06	13.1	100	4.99E-06	10.0	100
21	2.08E-06	2.1	100	1.93E-06	1.5	100	1.96E-06	13.3	100	1.91E-06	10.2	100
22	1.42E-06	2.0	100	1.10E-06	1.6	100	1.37E-06	13.2	100	1.27E-06	10.0	100
23	8.16E-07	2.1	100	8.02E-07	1.5	100	1.12E-06	12.9	100	8.10E-07	10.2	100
24	1.33E-06	2.0	100	1.19E-06	1.5	100	1.27E-06	13.3	100	1.30E-06	10.1	100
25	3.95E-06	2.1	100	3.64E-06	1.5	100	*1 3.86E-06	13.1	100	*1 3.84E-06	10.0	100
26	4.61E-06	2.0	100	3.94E-06	1.6	100	4.19E-06	13.3	100	4.20E-06	9.9	100
27	1.86E-06	2.0	100	1.58E-06	1.6	100	1.87E-06	13.3	100	1.95E-06	10.0	100
28	3.26E-06	2.0	100	2.91E-06	1.5	100	3.00E-06	13.3	100	2.98E-06	10.2	100
29	*1 2.41E-06	2.0	100	*1 2.16E-06	1.6	100	2.51E-06	13.0	100	2.43E-06	10.0	100
30	5.93E-06	1.9	100	4.85E-06	1.6	100	5.46E-06	13.1	100	5.29E-06	10.0	100
31	5.84E-06	2.0	100	5.01E-06	1.6	100	5.28E-06	13.1	100	5.14E-06	10.1	100
1ヶ月値	3.98E-06	2.0	100	3.50E-06	1.6	100	3.88E-06	13.1	100	3.74E-06	10.0	100
最大値	2.66E-05	2.1	102	2.95E-05	1.7	103	3.37E-04	13.5	102	3.94E-05	10.3	102
最大値日時	07/13 04:25	07/02 00:42	07/01 06:20	07/13 04:41	07/12 04:27	07/01 07:39	07/13 16:51	07/17 00:57	07/01 06:33	07/13 04:42	07/23 04:42	07/01 05:02
最小値	0.00E+00	1.9	97	0.00E+00	1.5	97	0.00E+00	12.6	1	0.00E+00	9.8	98
最小値日時	07/01 00:42	07/04 13:55	07/29 02:32	07/04 14:12	07/01 00:01	07/02 09:16	07/02 00:57	07/13 16:51	07/11 13:41	07/02 04:42	07/09 04:42	07/01 02:06

*1: 3紙交換

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2016/07

(3/5)

日	モニタ											
	A009 1/2号西側法面上(DM75)			A010 1/2号西側法面上(DM65)			A011 3/4号西側法面上(DM45)			A012 3/4号西側法面上(DM54)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	7.23E-06	7.6	100	5.36E-06	9.6	100	5.00E-06	7.2	100	4.85E-06	8.0	100
2	6.64E-06	7.6	100	5.02E-06	9.5	100	4.80E-06	7.2	100	4.88E-06	7.9	100
3	6.02E-06	7.5	100	4.54E-06	9.7	100	4.29E-06	7.4	100	4.14E-06	8.5	100
4	4.62E-06	7.6	100	3.32E-06	9.5	100	*1 3.19E-06	7.2	100	3.07E-06	8.0	100
5	1.23E-06	7.7	100	8.12E-07	9.7	100	7.57E-07	7.1	100	8.19E-07	7.8	100
6	2.71E-06	7.8	100	1.96E-06	9.6	100	1.98E-06	7.0	100	1.93E-06	8.0	100
7	2.65E-06	7.8	100	1.99E-06	9.5	100	1.95E-06	7.2	100	1.85E-06	8.2	100
8	2.18E-06	7.8	100	1.86E-06	9.4	100	1.60E-06	7.2	100	1.87E-06	8.0	100
9	5.06E-06	7.8	100	3.81E-06	9.6	100	3.79E-06	7.0	100	3.58E-06	8.1	100
10	6.72E-06	7.7	100	4.98E-06	9.6	100	4.83E-06	7.3	100	4.79E-06	8.3	100
11	7.66E-06	8.0	100	5.68E-06	9.8	100	5.62E-06	7.1	100	5.59E-06	8.1	100
12	6.52E-06	7.6	100	4.94E-06	9.6	100	4.63E-06	7.0	100	4.66E-06	7.9	100
13	*1 1.02E-05	7.8	100	*1 7.60E-06	9.4	100	7.40E-06	7.1	100	*1 7.16E-06	8.0	100
14	6.41E-06	7.8	100	4.64E-06	9.4	100	4.42E-06	7.1	100	4.48E-06	8.0	100
15	1.26E-06	7.8	100	8.66E-07	9.6	100	7.31E-07	7.2	100	8.39E-07	7.9	100
16	2.69E-06	7.6	100	1.88E-06	9.4	100	1.83E-06	6.8	100	1.86E-06	7.7	100
17	3.79E-06	7.6	100	2.89E-06	9.2	100	2.71E-06	7.0	100	2.69E-06	7.9	100
18	5.94E-06	7.5	100	4.25E-06	9.3	100	4.25E-06	7.0	100	4.04E-06	7.9	100
19	7.14E-06	7.6	100	5.05E-06	9.4	100	4.89E-06	7.0	100	4.74E-06	7.8	100
20	6.03E-06	7.7	100	4.17E-06	9.3	100	4.38E-06	6.9	100	4.15E-06	7.8	100
21	2.32E-06	7.8	100	1.83E-06	9.1	100	1.68E-06	6.9	100	1.70E-06	7.6	100
22	1.56E-06	7.7	100	1.19E-06	9.3	100	1.04E-06	7.0	100	1.05E-06	7.8	100
23	1.02E-06	7.7	100	7.70E-07	9.4	100	6.43E-07	6.9	100	7.08E-07	7.7	100
24	1.47E-06	7.8	100	1.12E-06	9.2	100	1.02E-06	6.7	100	1.10E-06	7.4	100
25	4.35E-06	7.7	100	3.24E-06	9.3	100	3.26E-06	6.7	100	3.26E-06	7.5	100
26	5.03E-06	7.6	100	3.36E-06	9.4	100	3.57E-06	7.1	100	3.49E-06	7.9	100
27	2.40E-06	7.6	100	1.57E-06	9.5	100	1.72E-06	7.0	100	1.64E-06	7.9	100
28	3.64E-06	7.6	100	2.62E-06	9.3	100	2.35E-06	7.2	100	2.57E-06	7.8	100
29	2.80E-06	7.6	100	2.09E-06	9.2	100	*1 1.85E-06	7.1	100	1.83E-06	7.9	100
30	5.99E-06	8.0	100	4.86E-06	9.2	100	4.18E-06	7.2	100	4.39E-06	7.9	100
31	6.02E-06	7.8	100	4.48E-06	9.2	100	4.13E-06	7.0	100	4.15E-06	7.9	100
1ヶ月値	4.49E-06	7.7	100	3.31E-06	9.4	100	3.18E-06	7.1	100	3.16E-06	7.9	100
最大値	3.35E-05	8.0	103	2.87E-05	9.8	102	2.57E-05	7.4	102	2.87E-05	8.6	102
最大値日時	07/05 01:12	07/11 01:12	07/05 18:55	07/12 05:10	07/11 04:57	07/01 12:48	07/20 01:42	07/03 01:27	07/03 05:23	07/12 05:16	07/03 05:12	07/02 08:46
最小値	0.00E+00	7.5	97	0.00E+00	9.1	98	0.00E+00	6.7	98	0.00E+00	7.4	98
最小値日時	07/03 01:12	07/01 00:01	07/01 12:18	07/04 04:57	07/17 04:57	07/01 05:52	07/03 01:27	07/24 01:27	07/01 08:08	07/01 05:12	07/24 05:12	07/01 04:01

*1: ろ紙交換

*2: 最大・最小値に関しては、1日1回BQ測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2016/07

(4/5)

日	モニタ											
	A013 4号南側法面上[3号南側](DM58)			A014 4号南側法面上[3号南側](DM56)			A015 登録S休憩所 (DM52)			A016 登録S休憩所 (DM77)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	5.18E-06	1.6	100	4.82E-06	1.3	100	5.47E-06	2.5	100	7.01E-06	2.4	100
2	4.94E-06	1.5	100	4.76E-06	1.3	100	5.67E-06	2.6	100	7.32E-06	2.5	100
3	4.33E-06	1.8	100	4.22E-06	1.3	100	4.25E-06	2.5	100	5.35E-06	2.4	100
4	*1 3.25E-06	1.7	100	3.13E-06	1.2	100	3.65E-06	2.5	100	4.58E-06	2.5	100
5	9.06E-07	1.6	100	8.85E-07	1.2	100	9.61E-07	2.6	100	1.19E-06	2.5	100
6	1.95E-06	1.6	100	1.90E-06	1.3	100	2.03E-06	2.6	100	2.70E-06	2.3	100
7	2.37E-06	1.6	100	2.34E-06	1.3	100	2.10E-06	2.6	100	2.77E-06	2.4	100
8	1.79E-06	1.7	100	1.94E-06	1.2	100	2.13E-06	2.5	100	2.76E-06	2.4	100
9	3.87E-06	1.6	100	3.60E-06	1.3	100	4.10E-06	2.6	100	5.11E-06	2.6	100
10	5.44E-06	1.6	100	4.94E-06	1.4	100	5.04E-06	2.6	100	6.64E-06	2.4	100
11	5.74E-06	1.8	100	*1 5.74E-06	1.3	100	*1 5.72E-06	2.7	100	*1 7.84E-06	2.4	100
12	4.73E-06	1.7	100	4.63E-06	1.3	100	4.68E-06	2.5	100	5.98E-06	2.5	100
13	7.56E-06	1.7	100	7.28E-06	1.3	100	7.90E-06	2.6	100	9.82E-06	2.6	100
14	4.82E-06	1.7	100	4.89E-06	1.3	100	4.69E-06	2.7	100	6.06E-06	2.4	100
15	9.37E-07	1.7	100	9.65E-07	1.3	100	9.43E-07	2.6	100	1.28E-06	2.4	100
16	2.02E-06	1.4	100	1.80E-06	1.3	100	1.91E-06	2.5	100	2.41E-06	2.4	100
17	2.82E-06	1.7	100	2.65E-06	1.3	100	3.53E-06	2.7	100	4.66E-06	2.3	100
18	4.18E-06	1.7	100	4.16E-06	1.3	100	5.75E-06	2.5	100	7.56E-06	2.4	100
19	5.04E-06	1.7	100	5.02E-06	1.3	100	5.14E-06	2.6	100	6.59E-06	2.5	100
20	4.54E-06	1.7	100	4.35E-06	1.3	100	4.46E-06	2.5	100	5.67E-06	2.5	100
21	1.71E-06	1.7	100	1.65E-06	1.3	100	1.73E-06	2.7	100	2.32E-06	2.4	100
22	1.18E-06	1.6	100	1.23E-06	1.2	100	1.39E-06	2.7	100	2.11E-06	2.4	100
23	7.31E-07	1.7	100	7.63E-07	1.3	100	7.81E-07	2.6	100	1.10E-06	2.4	100
24	1.20E-06	1.4	100	1.02E-06	1.3	100	1.11E-06	2.5	100	1.39E-06	2.5	100
25	3.32E-06	1.7	100	3.19E-06	1.2	100	3.51E-06	2.6	100	4.62E-06	2.5	100
26	3.92E-06	1.7	100	3.88E-06	1.3	100	3.97E-06	2.6	100	5.14E-06	2.4	100
27	1.73E-06	1.7	100	1.67E-06	1.3	100	2.51E-06	2.7	100	3.53E-06	2.4	100
28	2.61E-06	1.6	100	2.58E-06	1.3	100	2.51E-06	2.7	100	3.55E-06	2.5	100
29	*1 1.97E-06	1.7	100	1.90E-06	1.4	100	1.77E-06	2.7	100	2.46E-06	2.5	100
30	4.74E-06	1.6	100	4.74E-06	1.4	100	4.43E-06	2.7	100	5.86E-06	2.4	100
31	4.33E-06	1.6	100	4.37E-06	1.2	100	4.16E-06	2.5	100	5.63E-06	2.5	100
1ヶ月値	3.35E-06	1.6	100	3.26E-06	1.3	100	3.48E-06	2.6	100	4.55E-06	2.4	100
最大値	2.61E-05	1.8	102	2.53E-05	1.4	102	2.32E-05	2.7	102	3.14E-05	2.6	101
最大値日時	07/20 01:53	07/03 01:42	07/01 11:26	07/12 05:39	07/10 05:27	07/03 17:30	07/13 02:56	07/11 01:57	07/06 03:33	07/12 05:58	07/09 05:42	07/01 00:02
最小値	0.00E+00	1.4	98	0.00E+00	1.2	98	0.00E+00	2.5	98	0.00E+00	2.3	98
最小値日時	07/03 01:42	07/16 01:42	07/01 07:10	07/06 05:27	07/04 05:27	07/01 01:21	07/02 01:57	07/01 01:57	07/01 06:56	07/02 05:42	07/06 05:42	07/01 08:01

*1: ろ紙交換

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2016/07

(5/5)

日	モニタ											
	A019 シールド中央制御室(DM-62)			A020 シールド中央制御室(DM-63)			A021 Hタンクエリア (DM76)			A022 Hタンクエリア (DM64)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	*1 6.51E-06	3.3	100	*1 6.22E-06	3.5	100	7.07E-06	3.4	100	5.39E-06	3.2	100
2	6.43E-06	3.3	100	5.96E-06	3.5	100	7.44E-06	3.4	100	5.32E-06	3.2	100
3	5.38E-06	3.3	100	4.95E-06	3.6	100	5.84E-06	3.4	100	4.32E-06	3.3	100
4	4.03E-06	3.3	100	3.86E-06	3.6	100	4.81E-06	3.2	100	3.47E-06	3.3	100
5	1.15E-06	3.2	100	1.03E-06	3.5	100	1.30E-06	3.4	100	9.31E-07	3.2	100
6	2.37E-06	3.4	100	2.30E-06	3.6	100	2.66E-06	3.5	100	2.11E-06	3.2	100
7	2.57E-06	3.3	100	2.32E-06	3.7	100	2.88E-06	3.4	100	2.14E-06	3.2	100
8	2.28E-06	3.4	100	2.09E-06	3.6	100	2.64E-06	3.5	100	1.95E-06	3.3	100
9	4.67E-06	3.3	100	4.40E-06	3.6	100	5.08E-06	3.5	100	3.99E-06	3.3	100
10	6.38E-06	3.3	100	5.94E-06	3.5	100	6.74E-06	3.6	100	5.16E-06	3.2	100
11	6.97E-06	3.5	100	6.73E-06	3.4	100	*1 8.08E-06	3.4	100	*1 6.12E-06	3.2	100
12	5.92E-06	3.3	100	5.22E-06	3.5	100	6.34E-06	3.3	100	4.56E-06	3.3	100
13	9.72E-06	3.3	100	8.80E-06	3.5	100	1.03E-05	3.4	100	7.58E-06	3.4	100
14	5.92E-06	3.2	100	5.69E-06	3.5	100	5.97E-06	3.7	100	4.57E-06	3.3	100
15	1.15E-06	3.4	100	1.18E-06	3.5	100	1.25E-06	3.4	100	9.05E-07	3.3	100
16	2.36E-06	3.4	100	2.19E-06	3.5	100	2.51E-06	3.5	100	1.83E-06	3.3	100
17	3.75E-06	3.4	100	3.31E-06	3.6	100	4.06E-06	3.5	100	3.06E-06	3.2	100
18	5.44E-06	3.3	100	5.26E-06	3.5	100	6.26E-06	3.5	100	4.86E-06	3.2	100
19	6.24E-06	3.1	100	5.70E-06	3.6	100	6.69E-06	3.4	100	5.03E-06	3.1	100
20	5.41E-06	3.5	100	5.10E-06	3.6	100	5.80E-06	3.5	100	4.42E-06	3.2	100
21	2.03E-06	3.4	100	1.96E-06	3.6	100	2.29E-06	3.5	100	1.79E-06	3.2	100
22	1.47E-06	3.4	100	1.47E-06	3.5	100	1.88E-06	3.4	100	1.37E-06	3.3	100
23	9.52E-07	3.3	100	9.21E-07	3.5	100	1.14E-06	3.4	100	7.56E-07	3.3	100
24	1.37E-06	3.2	100	1.31E-06	3.4	100	1.38E-06	3.5	100	1.06E-06	3.3	100
25	3.96E-06	3.5	100	3.84E-06	3.6	100	4.62E-06	3.4	100	3.31E-06	3.3	100
26	4.73E-06	3.4	100	4.50E-06	3.6	100	4.98E-06	3.7	100	3.82E-06	3.3	100
27	*1 2.44E-06	3.2	100	*1 2.25E-06	3.5	100	2.93E-06	3.5	100	2.22E-06	3.3	100
28	3.18E-06	3.2	100	2.93E-06	3.6	100	3.66E-06	3.3	100	2.70E-06	3.2	100
29	2.38E-06	3.3	100	2.11E-06	3.6	100	2.54E-06	3.5	100	1.95E-06	3.2	100
30	5.82E-06	3.3	100	5.31E-06	3.6	100	5.71E-06	3.5	100	4.38E-06	3.3	100
31	5.05E-06	3.5	100	4.85E-06	3.5	100	5.64E-06	3.4	100	4.29E-06	3.2	100
1ヶ月値	4.13E-06	3.3	100	3.86E-06	3.6	100	4.53E-06	3.5	100	3.40E-06	3.2	100
最大値	2.85E-05	3.5	102	5.41E-05	3.7	102	3.59E-05	3.7	102	2.29E-05	3.4	102
最大値日時	07/13 02:36	07/11 02:27	07/01 04:04	07/01 14:06	07/07 06:12	07/01 00:52	07/13 02:58	07/14 02:42	07/01 02:51	07/13 04:14	07/13 06:27	07/05 14:26
最小値	0.00E+00	3.1	97	0.00E+00	3.4	97	0.00E+00	3.2	98	0.00E+00	3.1	98
最小値日時	07/01 13:51	07/19 02:27	07/04 20:49	07/01 06:12	07/01 00:01	07/05 19:53	07/01 02:42	07/04 02:42	07/01 20:07	07/01 06:27	07/19 06:27	07/12 01:17

*1: ろ紙交換

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする