

構内連続ダストモニタ測定記録(2020 年 11 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

測定日：2020/11

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.86E-06	1.3	100	2.93E-06	1.5	100	2.56E-06	7.6	100	2.67E-06	7.8	100
2	3.38E-06	1.3	100	3.40E-06	1.5	100	2.83E-06	7.6	100	2.97E-06	7.8	100
3	4.35E-06	1.3	100	4.44E-06	1.5	100	4.11E-06	7.6	100	4.30E-06	7.8	100
4	3.32E-06	1.3	100	3.37E-06	1.5	100	3.29E-06	7.6	100	3.47E-06	7.8	100
5	2.83E-06	1.3	100	2.84E-06	1.5	100	2.71E-06	7.6	100	2.86E-06	7.8	100
6	*3 5.94E-06	1.0	100	5.77E-06	1.5	100	4.93E-06	7.6	100	5.14E-06	7.8	100
7	8.80E-06	0.8	100	8.30E-06	1.5	100	7.51E-06	7.6	100	7.72E-06	7.8	100
8	3.98E-06	0.8	100	3.66E-06	1.5	100	3.65E-06	7.6	100	3.77E-06	7.8	100
9	3.08E-06	0.8	100	*1 2.92E-06	1.4	100	2.82E-06	7.6	100	2.95E-06	7.8	100
10	3.33E-06	0.8	100	3.08E-06	1.4	100	2.85E-06	7.6	100	3.02E-06	7.8	100
11	3.50E-06	0.8	100	3.26E-06	1.4	100	2.77E-06	7.6	100	2.92E-06	7.8	100
12	3.83E-06	0.8	100	3.68E-06	1.4	100	3.08E-06	7.6	100	3.15E-06	7.8	100
13	6.86E-06	0.8	100	6.41E-06	1.4	100	5.60E-06	7.6	100	5.75E-06	7.8	100
14	4.50E-06	0.8	100	4.12E-06	1.4	100	3.97E-06	7.6	100	4.13E-06	7.8	100
15	4.99E-06	0.8	100	4.59E-06	1.4	100	4.30E-06	7.6	100	4.49E-06	7.8	100
16	4.02E-06	0.8	100	3.63E-06	1.4	100	3.44E-06	7.6	100	3.60E-06	7.8	100
17	5.51E-06	0.8	100	5.10E-06	1.4	100	4.73E-06	7.6	100	4.88E-06	7.8	100
18	5.92E-06	0.8	100	5.48E-06	1.4	100	4.87E-06	7.6	100	5.09E-06	7.8	100
19	4.24E-06	0.8	100	3.84E-06	1.4	100	3.74E-06	7.6	100	3.89E-06	7.8	100
20	2.86E-06	0.8	100	2.60E-06	1.4	100	2.59E-06	7.6	100	2.70E-06	7.8	100
21	2.55E-06	0.8	100	2.34E-06	1.4	100	2.23E-06	7.6	100	2.34E-06	7.8	100
22	3.36E-06	0.8	100	3.13E-06	1.4	100	2.83E-06	7.6	100	2.96E-06	7.8	100
23	3.09E-06	0.8	100	2.82E-06	1.4	100	2.73E-06	7.6	100	2.85E-06	7.8	100
24	3.51E-06	0.8	100	3.20E-06	1.4	100	2.93E-06	7.6	100	*1 2.96E-06	7.9	100
25	6.30E-06	0.8	100	5.85E-06	1.4	100	*1 5.30E-06	7.5	100	5.19E-06	8.0	100
26	5.46E-06	0.8	100	5.08E-06	1.4	100	4.45E-06	7.4	100	4.43E-06	8.0	100
27	6.17E-06	0.8	100	5.70E-06	1.4	100	5.13E-06	7.4	100	5.01E-06	8.0	100
28	5.00E-06	0.8	100	4.69E-06	1.4	100	4.30E-06	7.4	100	4.17E-06	8.0	100
29	3.82E-06	0.8	100	3.58E-06	1.4	100	3.59E-06	7.4	100	3.49E-06	8.0	100
30	5.57E-06	0.8	100	5.21E-06	1.4	100	4.75E-06	7.4	100	4.59E-06	8.0	100
31												
1ヶ月値	4.43E-06	0.9	100	4.17E-06	1.4	100	3.82E-06	7.6	100	3.91E-06	7.8	100
最大値	1.52E-05	1.3	102	1.44E-05	1.5	103	1.26E-05	7.6	102	1.24E-05	8.0	102
最大値日時	11/28 04:57	11/01 00:01	11/04 17:05	11/28 05:03	11/01 00:01	11/02 22:47	11/28 05:04	11/01 00:01	11/02 04:50	11/25 22:23	11/24 09:40	11/01 00:46
最小値	0.00E+00	0.8	98	5.89E-07	1.4	97	0.00E+00	7.4	98	0.00E+00	7.8	98
最小値日時	11/04 10:18	11/06 11:36	11/03 03:57	11/01 15:55	11/09 10:32	11/01 01:40	11/04 11:01	11/25 10:44	11/02 13:48	11/24 09:40	11/01 00:01	11/01 00:43

*3: 年次点検 *1: ろ紙交換

測定月報

測定日：2020/11

(2/8)

日	モニタ											
	A005 5/6号警備所前			A006 5/6号警備所前			A007 1号北側法面上(旧厚生棟)			A008 1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.66E-06	1.5	100	2.56E-06	1.7	100	2.75E-06	8.5	100	2.79E-06	5.8	100
2	3.14E-06	1.5	100	3.17E-06	1.7	100	3.06E-06	8.5	100	3.13E-06	5.8	100
3	4.38E-06	1.5	100	4.28E-06	1.7	100	4.34E-06	8.5	100	4.41E-06	5.8	100
4	3.62E-06	1.5	100	3.53E-06	1.7	100	3.50E-06	8.5	100	3.49E-06	5.8	100
5	2.90E-06	1.5	100	2.86E-06	1.7	100	2.79E-06	8.5	100	2.85E-06	5.8	100
6	5.11E-06	1.5	100	5.02E-06	1.7	100	5.10E-06	8.5	100	5.14E-06	5.8	100
7	7.87E-06	1.5	100	7.65E-06	1.7	100	7.68E-06	8.5	100	7.75E-06	5.8	100
8	3.96E-06	1.5	100	3.86E-06	1.7	100	3.77E-06	8.5	100	3.78E-06	5.8	100
9	3.04E-06	1.5	100	*1 2.97E-06	1.8	100	2.90E-06	8.5	100	2.95E-06	5.8	100
10	*1 3.05E-06	1.5	100	2.87E-06	1.8	100	2.96E-06	8.5	100	3.02E-06	5.8	100
11	2.97E-06	1.5	100	2.86E-06	1.8	100	2.90E-06	8.5	100	2.89E-06	5.8	100
12	3.34E-06	1.5	100	3.26E-06	1.8	100	3.22E-06	8.5	100	3.24E-06	5.8	100
13	5.89E-06	1.5	100	5.79E-06	1.8	100	5.62E-06	8.5	100	5.69E-06	5.8	100
14	4.17E-06	1.5	100	4.13E-06	1.8	100	4.10E-06	8.5	100	4.13E-06	5.8	100
15	4.53E-06	1.5	100	4.47E-06	1.8	100	4.68E-06	8.5	100	4.68E-06	5.8	100
16	3.75E-06	1.5	100	3.67E-06	1.8	100	3.58E-06	8.5	100	3.56E-06	5.8	100
17	4.97E-06	1.5	100	4.88E-06	1.8	100	*1 4.90E-06	8.4	100	4.78E-06	5.8	100
18	5.20E-06	1.5	100	5.08E-06	1.8	100	5.10E-06	8.4	100	5.16E-06	5.8	100
19	4.12E-06	1.5	100	3.98E-06	1.8	100	4.14E-06	8.4	100	4.11E-06	5.8	100
20	2.89E-06	1.5	100	2.80E-06	1.8	100	2.88E-06	8.4	100	2.86E-06	5.8	100
21	2.48E-06	1.5	100	2.36E-06	1.8	100	2.39E-06	8.4	100	2.38E-06	5.8	100
22	2.99E-06	1.5	100	2.93E-06	1.8	100	3.14E-06	8.4	100	3.09E-06	5.8	100
23	2.97E-06	1.5	100	2.86E-06	1.8	100	2.89E-06	8.4	100	2.90E-06	5.8	100
24	3.05E-06	1.5	100	2.97E-06	1.8	100	3.08E-06	8.4	100	*1 3.06E-06	5.8	100
25	5.70E-06	1.5	100	5.55E-06	1.8	100	5.42E-06	8.4	100	5.25E-06	5.8	100
26	4.71E-06	1.5	100	4.61E-06	1.8	100	4.77E-06	8.4	100	4.63E-06	5.8	100
27	5.19E-06	1.5	100	5.09E-06	1.8	100	5.14E-06	8.4	100	5.07E-06	5.8	100
28	4.50E-06	1.5	100	4.45E-06	1.8	100	4.45E-06	8.4	100	4.38E-06	5.8	100
29	3.80E-06	1.5	100	3.71E-06	1.8	100	3.73E-06	8.4	100	3.67E-06	5.8	100
30	4.95E-06	1.5	100	4.92E-06	1.8	100	4.88E-06	8.4	100	4.71E-06	5.8	100
31												
1ヶ月値	4.06E-06	1.5	100	3.99E-06	1.8	100	3.99E-06	8.5	100	3.98E-06	5.8	100
最大値	2.64E-05	1.5	102	1.31E-05	1.8	102	1.27E-05	8.5	102	4.43E-05	5.8	102
最大値日時	11/10 11:17	11/01 00:01	11/01 04:02	11/28 05:20	11/09 10:14	11/01 00:41	11/28 05:12	11/01 00:01	11/01 08:14	11/24 10:24	11/01 00:01	11/01 01:17
最小値	0.00E+00	1.5	98	0.00E+00	1.7	98	0.00E+00	8.4	98	4.78E-07	5.8	98
最小値日時	11/04 14:34	11/01 00:01	11/01 07:50	11/09 10:14	11/01 00:01	11/02 06:00	11/04 11:47	11/17 10:13	11/01 02:28	11/23 07:31	11/01 00:01	11/01 00:56

*1: ろ紙交換

測定月報

測定日：2020/11

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.55E-06	5.7	100	2.48E-06	6.0	100	2.67E-06	4.4	100	2.81E-06	4.0	100
2	2.90E-06	5.7	100	2.87E-06	6.0	100	3.00E-06	4.4	100	3.23E-06	4.0	100
3	4.15E-06	5.7	100	4.11E-06	6.0	100	4.33E-06	4.4	100	4.52E-06	4.0	100
4	3.34E-06	5.7	100	3.26E-06	6.0	100	3.39E-06	4.4	100	3.54E-06	4.0	100
5	2.66E-06	5.7	100	2.61E-06	6.0	100	2.74E-06	4.4	100	2.85E-06	4.0	100
6	4.66E-06	5.7	100	4.65E-06	6.0	100	5.08E-06	4.4	100	5.21E-06	4.0	100
7	7.25E-06	5.7	100	7.16E-06	6.0	100	7.81E-06	4.4	100	8.01E-06	4.0	100
8	3.60E-06	5.7	100	3.49E-06	6.0	100	3.71E-06	4.4	100	3.83E-06	4.0	100
9	2.86E-06	5.7	100	2.78E-06	6.0	100	2.93E-06	4.4	100	3.00E-06	4.0	100
10	2.89E-06	5.7	100	2.80E-06	6.0	100	2.85E-06	4.4	100	*1 3.12E-06	3.9	100
11	2.71E-06	5.7	100	2.61E-06	6.0	100	2.74E-06	4.4	100	2.99E-06	3.8	100
12	3.05E-06	5.7	100	2.98E-06	6.0	100	3.22E-06	4.4	100	3.41E-06	3.8	100
13	5.28E-06	5.7	100	5.21E-06	6.0	100	5.67E-06	4.4	100	6.02E-06	3.8	100
14	3.94E-06	5.7	100	3.88E-06	6.0	100	4.08E-06	4.4	100	4.37E-06	3.8	100
15	4.34E-06	5.7	100	4.30E-06	6.0	100	4.58E-06	4.4	100	4.86E-06	3.8	100
16	3.34E-06	5.7	100	3.30E-06	6.0	100	3.43E-06	4.4	100	3.75E-06	3.8	100
17	4.67E-06	5.7	100	4.62E-06	6.0	100	*1 4.87E-06	4.2	100	5.07E-06	3.8	100
18	4.69E-06	5.7	100	4.66E-06	6.0	100	5.11E-06	4.0	100	5.23E-06	3.8	100
19	3.67E-06	5.7	100	*1 3.65E-06	5.9	100	4.00E-06	4.0	100	4.10E-06	3.8	100
20	2.64E-06	5.7	100	2.54E-06	5.9	100	2.94E-06	4.0	100	2.95E-06	3.8	100
21	2.27E-06	5.7	100	2.20E-06	5.9	100	2.52E-06	4.0	100	2.52E-06	3.8	100
22	2.87E-06	5.7	100	2.79E-06	5.9	100	3.12E-06	4.0	100	3.14E-06	3.8	100
23	2.73E-06	5.7	100	2.69E-06	5.9	100	3.02E-06	4.0	100	3.01E-06	3.8	100
24	*1 2.89E-06	5.7	100	2.85E-06	5.9	100	3.21E-06	4.0	100	3.23E-06	3.8	100
25	4.91E-06	5.7	100	5.02E-06	5.9	100	5.59E-06	4.0	100	5.80E-06	3.8	100
26	4.29E-06	5.7	100	4.37E-06	5.9	100	5.00E-06	4.0	100	5.03E-06	3.8	100
27	4.81E-06	5.7	100	4.92E-06	5.9	100	5.40E-06	4.0	100	5.54E-06	3.8	100
28	4.07E-06	5.7	100	4.12E-06	5.9	100	4.54E-06	4.0	100	4.61E-06	3.8	100
29	3.47E-06	5.7	100	3.50E-06	5.9	100	3.75E-06	4.0	100	3.80E-06	3.8	100
30	4.51E-06	5.7	100	4.62E-06	5.9	100	5.07E-06	4.0	100	5.26E-06	3.8	100
31												
1ヶ月値	3.73E-06	5.7	100	3.70E-06	6.0	100	4.01E-06	4.2	100	4.16E-06	3.9	100
最大値	1.20E-05	5.7	102	1.23E-05	6.0	102	1.37E-05	4.4	102	3.34E-05	4.0	103
最大値日時	11/28 05:08	11/01 00:01	11/03 21:37	11/28 05:10	11/01 00:01	11/02 06:20	11/28 04:50	11/01 00:01	11/03 02:25	11/10 10:21	11/01 00:01	11/11 01:09
最小値	0.00E+00	5.7	98	3.38E-07	5.9	98	0.00E+00	4.0	98	0.00E+00	3.8	98
最小値日時	11/04 15:02	11/01 00:01	11/01 00:10	11/01 15:32	11/19 11:25	11/01 02:03	11/04 12:33	11/17 10:37	11/01 08:10	11/10 10:23	11/10 10:21	11/01 02:30

*1:ろ紙交換

測定月報

測定日：2020/11

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.92E-06	6.2	100	2.87E-06	0.6	100	2.99E-06	2.1	100	3.07E-06	1.9	100
2	3.18E-06	6.2	100	3.19E-06	0.6	100	3.38E-06	2.1	100	3.57E-06	1.9	100
3	4.57E-06	6.2	100	4.51E-06	0.6	100	4.43E-06	2.1	100	4.72E-06	1.9	100
4	3.54E-06	6.2	100	3.57E-06	0.6	100	3.44E-06	2.1	100	3.66E-06	1.9	100
5	2.95E-06	6.2	100	2.93E-06	0.6	100	2.87E-06	2.1	100	2.98E-06	1.9	100
6	5.10E-06	6.2	100	5.10E-06	0.6	100	*3 5.84E-06	2.4	100	6.26E-06	1.9	100
7	7.78E-06	6.2	100	7.80E-06	0.6	100	7.76E-06	2.7	100	8.77E-06	1.9	100
8	3.80E-06	6.2	100	3.78E-06	0.6	100	3.48E-06	2.7	100	3.97E-06	1.9	100
9	*1 2.95E-06	6.3	100	3.02E-06	0.6	100	2.65E-06	2.7	100	*1 2.89E-06	1.9	100
10	2.82E-06	6.4	100	3.00E-06	0.6	100	2.80E-06	2.7	100	2.94E-06	1.9	100
11	2.59E-06	6.4	100	2.81E-06	0.6	100	3.08E-06	2.7	100	3.24E-06	1.9	100
12	3.04E-06	6.4	100	3.32E-06	0.6	100	3.39E-06	2.7	100	3.54E-06	1.9	100
13	5.35E-06	6.4	100	5.76E-06	0.6	100	6.23E-06	2.7	100	6.51E-06	1.9	100
14	3.91E-06	6.4	100	4.15E-06	0.6	100	3.80E-06	2.7	100	4.08E-06	1.9	100
15	4.34E-06	6.4	100	4.62E-06	0.6	100	4.45E-06	2.7	100	4.77E-06	1.9	100
16	3.31E-06	6.4	100	3.58E-06	0.6	100	3.56E-06	2.7	100	3.82E-06	1.9	100
17	4.57E-06	6.4	100	4.92E-06	0.6	100	4.74E-06	2.7	100	5.06E-06	1.9	100
18	4.75E-06	6.4	100	5.04E-06	0.6	100	5.33E-06	2.7	100	5.56E-06	1.9	100
19	3.61E-06	6.4	100	3.85E-06	0.6	100	3.55E-06	2.7	100	3.77E-06	1.9	100
20	2.59E-06	6.4	100	2.80E-06	0.6	100	2.32E-06	2.7	100	2.51E-06	1.9	100
21	2.30E-06	6.4	100	2.48E-06	0.6	100	2.13E-06	2.7	100	2.31E-06	1.9	100
22	2.80E-06	6.4	100	3.00E-06	0.6	100	2.86E-06	2.7	100	3.08E-06	1.9	100
23	2.69E-06	6.4	100	2.94E-06	0.6	100	2.55E-06	2.7	100	2.73E-06	1.9	100
24	2.85E-06	6.4	100	3.08E-06	0.6	100	2.97E-06	2.7	100	3.20E-06	1.9	100
25	5.22E-06	6.4	100	*1 5.64E-06	0.6	100	5.30E-06	2.7	100	5.54E-06	1.9	100
26	4.55E-06	6.4	100	4.77E-06	0.6	100	4.74E-06	2.7	100	5.03E-06	1.9	100
27	5.06E-06	6.4	100	5.28E-06	0.6	100	5.22E-06	2.7	100	5.53E-06	1.9	100
28	4.16E-06	6.4	100	4.42E-06	0.6	100	4.31E-06	2.7	100	4.53E-06	1.9	100
29	3.28E-06	6.4	100	3.50E-06	0.6	100	3.38E-06	2.7	100	3.64E-06	1.9	100
30	4.50E-06	6.4	100	4.77E-06	0.6	100	4.66E-06	2.7	100	5.08E-06	1.9	100
31												
1ヶ月値	3.83E-06	6.3	100	4.01E-06	0.6	100	3.94E-06	2.6	100	4.21E-06	1.9	100
最大値	1.28E-05	6.4	103	3.02E-05	0.6	102	1.29E-05	2.7	102	1.46E-05	1.9	102
最大値日時	11/28 04:59	11/09 10:24	11/13 06:49	11/25 10:19	11/01 00:01	11/01 04:06	11/07 00:33	11/06 11:21	11/04 06:53	11/07 00:32	11/01 00:01	11/01 01:21
最小値	0.00E+00	6.2	97	7.48E-07	0.6	98	0.00E+00	2.1	98	0.00E+00	1.9	97
最小値日時	11/04 15:14	11/01 00:01	11/02 00:45	11/01 15:37	11/01 00:01	11/01 02:45	11/04 14:49	11/01 00:01	11/04 12:40	11/09 10:04	11/01 00:01	11/16 02:46

*3: 年次点検 *1: ろ紙交換

測定月報

測定日：2020/11

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シールド中央制御室			A020 シールド中央制御室		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	3.07E-06	5.1	100	2.94E-06	5.2	100	2.73E-06	2.5	100	2.68E-06	3.4	100
2	3.26E-06	5.1	100	3.14E-06	5.2	100	3.08E-06	2.5	100	3.02E-06	3.4	100
3	4.61E-06	5.1	100	4.38E-06	5.2	100	4.28E-06	2.5	100	4.22E-06	3.4	100
4	3.70E-06	5.1	100	3.63E-06	5.2	100	3.32E-06	2.5	100	3.24E-06	3.4	100
5	2.99E-06	5.1	100	2.93E-06	5.2	100	2.80E-06	2.5	100	2.71E-06	3.4	100
6	5.91E-06	5.1	100	5.66E-06	5.2	100	5.02E-06	2.5	100	5.00E-06	3.4	100
7	8.34E-06	5.1	100	8.09E-06	5.2	100	7.72E-06	2.5	100	7.69E-06	3.4	100
8	3.99E-06	5.1	100	3.84E-06	5.2	100	3.66E-06	2.5	100	3.59E-06	3.4	100
9	3.18E-06	5.1	100	3.06E-06	5.2	100	2.91E-06	2.5	100	2.80E-06	3.4	100
10	3.30E-06	5.1	100	3.14E-06	5.2	100	2.92E-06	2.5	100	2.85E-06	3.4	100
11	3.26E-06	5.1	100	3.14E-06	5.2	100	2.81E-06	2.5	100	2.74E-06	3.4	100
12	3.64E-06	5.1	100	3.49E-06	5.2	100	3.18E-06	2.5	100	3.11E-06	3.4	100
13	6.85E-06	5.1	100	6.46E-06	5.2	100	5.65E-06	2.5	100	5.61E-06	3.4	100
14	4.30E-06	5.1	100	4.14E-06	5.2	100	4.02E-06	2.5	100	3.94E-06	3.4	100
15	5.13E-06	5.1	100	4.95E-06	5.2	100	4.31E-06	2.5	100	4.27E-06	3.4	100
16	3.81E-06	5.1	100	*3 3.81E-06	5.1	100	3.43E-06	2.5	100	3.36E-06	3.4	100
17	5.14E-06	5.1	100	5.19E-06	5.1	100	4.70E-06	2.5	100	4.69E-06	3.4	100
18	5.76E-06	5.1	100	5.83E-06	5.1	100	4.91E-06	2.5	100	4.78E-06	3.4	100
19	4.26E-06	5.1	100	4.29E-06	5.1	100	3.64E-06	2.5	100	*1 3.76E-06	3.4	100
20	2.92E-06	5.1	100	3.00E-06	5.1	100	2.61E-06	2.5	100	2.71E-06	3.4	100
21	2.55E-06	5.1	100	2.64E-06	5.1	100	2.27E-06	2.5	100	2.36E-06	3.4	100
22	3.25E-06	5.1	100	3.41E-06	5.1	100	2.84E-06	2.5	100	3.05E-06	3.4	100
23	3.04E-06	5.1	100	3.07E-06	5.1	100	2.76E-06	2.5	100	2.87E-06	3.4	100
24	*1 3.39E-06	5.0	100	3.35E-06	5.1	100	*1 2.89E-06	2.6	100	3.13E-06	3.4	100
25	5.83E-06	4.9	100	5.88E-06	5.1	100	5.24E-06	2.7	100	5.87E-06	3.4	100
26	5.46E-06	4.9	100	5.51E-06	5.1	100	4.56E-06	2.7	100	5.12E-06	3.4	100
27	5.63E-06	4.9	100	5.51E-06	5.1	100	5.04E-06	2.7	100	5.67E-06	3.4	100
28	4.83E-06	4.9	100	4.76E-06	5.1	100	4.09E-06	2.7	100	4.51E-06	3.4	100
29	4.10E-06	4.9	100	4.07E-06	5.1	100	3.23E-06	2.7	100	3.59E-06	3.4	100
30	5.43E-06	4.9	100	5.48E-06	5.1	100	4.57E-06	2.7	100	5.03E-06	3.4	100
31												
1ヶ月値	4.36E-06	5.1	100	4.29E-06	5.2	100	3.84E-06	2.5	100	3.93E-06	3.4	100
最大値	1.35E-05	5.1	102	1.38E-05	5.2	102	1.27E-05	2.7	101	1.38E-05	3.4	102
最大値日時	11/28 05:20	11/01 00:01	11/11 14:12	11/26 02:41	11/01 00:01	11/23 23:50	11/28 05:08	11/24 10:54	11/01 00:09	11/28 04:54	11/01 00:01	11/01 06:38
最小値	0.00E+00	4.9	98	0.00E+00	5.1	98	0.00E+00	2.5	99	0.00E+00	3.4	98
最小値日時	11/04 13:57	11/24 10:47	11/01 06:49	11/16 10:28	11/16 10:28	11/11 23:21	11/04 15:24	11/01 00:01	11/01 00:06	11/19 11:34	11/01 00:01	11/01 09:28

*3:年次点検 *1:ろ紙交換

測定月報

測定日：2020/11

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.89E-06	2.2	100	2.71E-06	2.0	100	2.80E-06	17.1	100	2.59E-06	13.5	100
2	3.24E-06	2.2	100	3.02E-06	2.0	100	3.20E-06	17.1	100	2.98E-06	13.5	100
3	4.33E-06	2.2	100	4.13E-06	2.0	100	4.38E-06	17.1	100	4.06E-06	13.5	100
4	*1 3.37E-06	2.1	100	3.24E-06	2.0	100	3.56E-06	17.1	100	3.15E-06	13.5	100
5	2.74E-06	2.1	100	2.65E-06	2.0	100	3.06E-06	17.1	100	2.59E-06	13.5	100
6	5.17E-06	2.1	100	5.10E-06	2.0	100	*3 5.70E-06	15.8	100	4.76E-06	13.5	100
7	7.61E-06	2.1	100	7.57E-06	2.0	100	7.91E-06	14.7	100	7.36E-06	13.5	100
8	3.60E-06	2.1	100	3.55E-06	2.0	100	3.88E-06	14.7	100	3.54E-06	13.5	100
9	2.90E-06	2.1	100	2.84E-06	2.0	100	3.15E-06	14.7	100	2.84E-06	13.5	100
10	2.93E-06	2.1	100	2.90E-06	2.0	100	3.16E-06	14.7	100	2.75E-06	13.5	100
11	3.00E-06	2.1	100	2.90E-06	2.0	100	3.10E-06	14.7	100	2.66E-06	13.5	100
12	3.43E-06	2.1	100	3.36E-06	2.0	100	3.50E-06	14.7	100	3.05E-06	13.5	100
13	5.83E-06	2.1	100	5.64E-06	2.0	100	6.28E-06	14.7	100	5.68E-06	13.5	100
14	4.06E-06	2.1	100	3.95E-06	2.0	100	4.32E-06	14.7	100	3.91E-06	13.5	100
15	4.48E-06	2.1	100	4.35E-06	2.0	100	4.86E-06	14.7	100	4.39E-06	13.5	100
16	3.47E-06	2.1	100	3.39E-06	2.0	100	3.69E-06	14.7	100	3.35E-06	13.5	100
17	4.82E-06	2.1	100	4.68E-06	2.0	100	5.05E-06	14.7	100	*1 4.64E-06	13.6	100
18	5.06E-06	2.1	100	4.94E-06	2.0	100	5.37E-06	14.7	100	4.91E-06	13.6	100
19	3.76E-06	2.1	100	3.66E-06	2.0	100	4.18E-06	14.7	100	3.75E-06	13.6	100
20	2.65E-06	2.1	100	2.56E-06	2.0	100	3.03E-06	14.7	100	2.77E-06	13.6	100
21	2.36E-06	2.1	100	2.31E-06	2.0	100	2.49E-06	14.7	100	2.24E-06	13.6	100
22	3.03E-06	2.1	100	2.93E-06	2.0	100	3.13E-06	14.7	100	2.77E-06	13.6	100
23	2.79E-06	2.1	100	2.76E-06	2.0	100	2.99E-06	14.7	100	2.68E-06	13.6	100
24	3.16E-06	2.1	100	*1 3.07E-06	2.1	100	3.22E-06	14.7	100	2.85E-06	13.6	100
25	5.55E-06	2.1	100	5.45E-06	2.1	100	5.49E-06	14.7	100	4.95E-06	13.6	100
26	4.78E-06	2.1	100	4.64E-06	2.1	100	4.93E-06	14.7	100	4.50E-06	13.6	100
27	5.36E-06	2.1	100	5.19E-06	2.1	100	5.21E-06	14.7	100	4.75E-06	13.6	100
28	4.42E-06	2.1	100	4.26E-06	2.1	100	4.34E-06	14.7	100	3.94E-06	13.6	100
29	3.53E-06	2.1	100	3.42E-06	2.1	100	3.69E-06	14.7	100	3.30E-06	13.6	100
30	4.95E-06	2.1	100	4.83E-06	2.1	100	5.01E-06	14.7	100	4.51E-06	13.6	100
31												
1ヶ月値	3.97E-06	2.1	100	3.87E-06	2.0	100	4.16E-06	15.1	100	3.74E-06	13.5	100
最大値	1.35E-05	2.2	102	1.28E-05	2.1	102	3.37E-05	17.1	101	1.34E-05	13.6	102
最大値日時	11/28 05:13	11/01 00:01	11/01 04:29	11/28 05:05	11/24 10:46	11/01 09:34	11/06 10:48	11/01 00:01	11/01 00:20	11/17 10:46	11/17 10:44	11/01 01:56
最小値	0.00E+00	2.1	98	0.00E+00	2.0	98	0.00E+00	14.7	98	0.00E+00	13.5	97
最小値日時	11/04 10:36	11/04 10:36	11/01 01:09	11/24 10:46	11/01 00:01	11/06 21:03	11/01 15:00	11/06 10:46	11/15 03:36	11/17 10:44	11/01 00:01	11/01 13:27

*1:ろ紙交換 *3:年次点検

測定月報

測定日：2020/11

(7/8)

日	モニタ											
	A027 1号機海側2、5m盤			A028 1号機海側2、5m盤			A029 3号機海側2、5m盤			A030 3号機海側2、5m盤		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	3.06E-06	2.9	100	2.56E-06	3.8	100	2.69E-06	2.5	100	2.64E-06	1.9	100
2	3.50E-06	2.9	100	2.95E-06	3.8	100	3.10E-06	2.5	100	3.05E-06	1.9	100
3	4.84E-06	2.9	100	4.06E-06	3.8	100	4.23E-06	2.5	100	4.24E-06	1.9	100
4	3.92E-06	2.9	100	3.33E-06	3.8	100	3.51E-06	2.5	100	3.47E-06	1.9	100
5	3.23E-06	2.9	100	2.70E-06	3.8	100	2.87E-06	2.5	100	2.85E-06	1.9	100
6	5.48E-06	2.9	100	4.68E-06	3.8	100	4.92E-06	2.5	100	4.82E-06	1.9	100
7	8.25E-06	2.9	100	7.16E-06	3.8	100	7.41E-06	2.5	100	7.30E-06	1.9	100
8	4.25E-06	2.9	100	3.61E-06	3.8	100	3.81E-06	2.5	100	3.76E-06	1.9	100
9	3.29E-06	2.9	100	2.79E-06	3.8	100	2.97E-06	2.5	100	2.92E-06	1.9	100
10	3.38E-06	2.9	100	*1 2.91E-06	3.9	100	*1 2.95E-06	2.6	100	3.01E-06	1.9	100
11	3.23E-06	2.9	100	2.64E-06	3.9	100	2.68E-06	2.7	100	2.86E-06	1.9	100
12	3.55E-06	2.9	100	2.92E-06	3.9	100	2.95E-06	2.7	100	3.12E-06	1.9	100
13	6.05E-06	2.9	100	5.13E-06	3.9	100	5.00E-06	2.7	100	5.29E-06	1.9	100
14	4.53E-06	2.9	100	3.90E-06	3.9	100	3.93E-06	2.7	100	4.14E-06	1.9	100
15	5.02E-06	2.9	100	4.29E-06	3.9	100	4.37E-06	2.7	100	4.54E-06	1.9	100
16	4.03E-06	2.9	100	3.39E-06	3.9	100	3.40E-06	2.7	100	3.60E-06	1.9	100
17	5.17E-06	2.9	100	4.38E-06	3.9	100	4.48E-06	2.7	100	*1 4.68E-06	2.0	100
18	5.52E-06	2.9	100	4.72E-06	3.9	100	4.74E-06	2.7	100	4.94E-06	2.0	100
19	4.55E-06	2.9	100	3.81E-06	3.9	100	3.80E-06	2.7	100	3.97E-06	2.0	100
20	3.21E-06	2.9	100	2.66E-06	3.9	100	2.63E-06	2.7	100	2.80E-06	2.0	100
21	2.77E-06	2.9	100	2.28E-06	3.9	100	2.32E-06	2.7	100	2.49E-06	2.0	100
22	3.36E-06	2.9	100	2.75E-06	3.9	100	2.79E-06	2.7	100	2.96E-06	2.0	100
23	3.36E-06	2.9	100	2.77E-06	3.9	100	2.79E-06	2.7	100	2.97E-06	2.0	100
24	3.35E-06	2.9	100	2.81E-06	3.9	100	2.85E-06	2.7	100	2.98E-06	2.0	100
25	*1 5.64E-06	3.1	100	4.97E-06	3.9	100	4.99E-06	2.7	100	5.23E-06	2.0	100
26	4.70E-06	3.2	100	4.40E-06	3.9	100	4.50E-06	2.7	100	4.73E-06	2.0	100
27	4.94E-06	3.2	100	4.58E-06	3.9	100	4.63E-06	2.7	100	4.83E-06	2.0	100
28	4.38E-06	3.2	100	4.07E-06	3.9	100	4.13E-06	2.7	100	4.34E-06	2.0	100
29	3.75E-06	3.2	100	3.50E-06	3.9	100	3.56E-06	2.7	100	3.70E-06	2.0	100
30	4.94E-06	3.2	100	4.63E-06	3.9	100	4.67E-06	2.7	100	4.81E-06	2.0	100
31												
1ヶ月値	4.31E-06	3.0	100	3.71E-06	3.9	100	3.79E-06	2.6	100	3.90E-06	1.9	100
最大値	1.25E-05	3.2	101	2.22E-05	3.9	103	1.18E-05	2.7	102	1.20E-05	2.0	101
最大値日時	11/28 05:12	11/25 11:19	11/01 00:14	11/10 10:03	11/10 10:03	11/26 10:01	11/28 05:10	11/10 10:09	11/01 15:48	11/28 05:10	11/17 10:22	11/01 00:02
最小値	0.00E+00	2.9	99	0.00E+00	3.8	98	0.00E+00	2.5	98	0.00E+00	1.9	98
最小値日時	11/04 12:04	11/01 00:01	11/01 00:08	11/10 10:04	11/01 00:01	11/01 00:01	11/04 12:15	11/01 00:01	11/01 02:25	11/17 10:22	11/01 00:01	11/06 00:29

*1:ろ紙交換

測定月報

測定日：2020/11

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	3.01E-06	10.7	100	3.09E-06	6.8	100						
2	3.40E-06	10.7	100	3.44E-06	6.8	100						
3	4.69E-06	10.7	100	4.80E-06	6.8	100						
4	3.71E-06	10.7	100	3.75E-06	6.8	100						
5	3.09E-06	10.7	100	3.13E-06	6.8	100						
6	5.39E-06	10.7	100	5.55E-06	6.8	100						
7	8.43E-06	10.7	100	8.60E-06	6.8	100						
8	4.00E-06	10.7	100	4.12E-06	6.8	100						
9	3.22E-06	10.7	100	3.30E-06	6.8	100						
10	3.25E-06	10.7	100	3.30E-06	6.8	100						
11	3.04E-06	10.7	100	3.11E-06	6.8	100						
12	3.55E-06	10.7	100	3.63E-06	6.8	100						
13	6.30E-06	10.7	100	6.47E-06	6.8	100						
14	4.41E-06	10.7	100	4.53E-06	6.8	100						
15	4.91E-06	10.7	100	5.02E-06	6.8	100						
16	3.76E-06	10.7	100	3.87E-06	6.8	100						
17	5.21E-06	10.7	100	5.32E-06	6.8	100						
18	5.48E-06	10.7	100	5.50E-06	6.8	100						
19	4.25E-06	10.7	100	4.25E-06	6.8	100						
20	3.11E-06	10.7	100	3.05E-06	6.8	100						
21	2.64E-06	10.7	100	2.63E-06	6.8	100						
22	3.24E-06	10.7	100	3.23E-06	6.8	100						
23	3.10E-06	10.7	100	3.14E-06	6.8	100						
24	3.32E-06	10.7	100	*1 3.25E-06	6.8	100						
25	*1 5.53E-06	10.8	100	5.68E-06	6.8	100						
26	4.79E-06	10.9	100	5.11E-06	6.8	100						
27	5.31E-06	10.9	100	5.75E-06	6.8	100						
28	4.41E-06	10.9	100	4.68E-06	6.8	100						
29	3.64E-06	10.9	100	3.83E-06	6.8	100						
30	4.99E-06	10.9	100	5.28E-06	6.8	100						
31												
1ヶ月値	4.24E-06	10.7	100	4.35E-06	6.8	100						
最大値	4.13E-05	10.9	102	1.35E-05	6.8	102						
最大値日時	11/25 11:32	11/25 11:32	11/01 04:06	11/28 04:48	11/01 00:01	11/15 22:11						
最小値	0.00E+00	10.7	98	0.00E+00	6.8	98						
最小値日時	11/04 12:58	11/01 00:01	11/01 02:18	11/24 10:35	11/01 00:01	11/02 12:23						

*1: ろ紙交換