

# 構内連続ダストモニタ測定記録(2021 年 2 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

# 測定月報

測定日：2021/02

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	5.39E-06	0.9	100	4.93E-06	1.4	100	4.47E-06	7.4	100	4.97E-06	7.6	100
2	4.30E-06	0.9	100	*1 3.91E-06	1.5	100	3.72E-06	7.4	100	4.04E-06	7.6	100
3	4.80E-06	0.9	100	4.46E-06	1.5	100	4.27E-06	7.4	100	4.52E-06	7.6	100
4	3.71E-06	0.9	100	3.43E-06	1.5	100	3.30E-06	7.4	100	3.49E-06	7.6	100
5	2.91E-06	0.9	100	2.68E-06	1.5	100	2.54E-06	7.4	100	2.76E-06	7.6	100
6	4.19E-06	0.9	100	3.86E-06	1.5	100	3.62E-06	7.4	100	3.88E-06	7.6	100
7	4.31E-06	0.9	100	3.90E-06	1.5	100	3.80E-06	7.4	100	4.02E-06	7.6	100
8	5.60E-06	0.9	100	5.25E-06	1.5	100	*3 4.77E-06	6.6	100	4.93E-06	7.6	100
9	2.44E-06	0.9	100	2.25E-06	1.5	100	2.40E-06	6.0	100	2.40E-06	7.6	100
10	3.25E-06	0.9	100	2.99E-06	1.5	100	3.06E-06	6.0	100	3.04E-06	7.6	100
11	4.75E-06	0.9	100	4.36E-06	1.5	100	4.43E-06	6.0	100	4.40E-06	7.6	100
12	6.66E-06	0.9	100	6.07E-06	1.5	100	5.69E-06	6.0	100	5.75E-06	7.6	100
13	7.06E-06	0.9	100	6.59E-06	1.5	100	6.27E-06	6.0	100	6.32E-06	7.6	100
14	3.68E-06	0.9	100	3.27E-06	1.5	100	3.22E-06	6.0	100	3.26E-06	7.6	100
15	1.06E-06	0.9	100	9.16E-07	1.5	100	9.74E-07	6.0	100	*1 9.41E-07	7.7	100
16	2.90E-06	0.9	100	2.62E-06	1.5	100	2.72E-06	6.0	100	2.71E-06	7.7	100
17	3.04E-06	0.9	100	2.71E-06	1.5	100	2.81E-06	6.0	100	2.77E-06	7.7	100
18	2.72E-06	0.9	100	2.45E-06	1.5	100	2.78E-06	6.0	100	2.54E-06	7.7	100
19	2.54E-06	0.9	100	2.27E-06	1.5	100	2.51E-06	6.0	100	2.34E-06	7.7	100
20	4.06E-06	0.9	100	3.62E-06	1.5	100	4.04E-06	6.0	100	3.70E-06	7.7	100
21	6.41E-06	0.9	100	5.55E-06	1.5	100	5.82E-06	6.0	100	5.63E-06	7.7	100
22	*1 7.99E-06	0.9	100	7.01E-06	1.5	100	7.12E-06	6.0	100	7.06E-06	7.7	100
23	4.14E-06	0.9	100	3.62E-06	1.5	100	3.98E-06	6.0	100	3.77E-06	7.7	100
24	2.73E-06	0.9	100	2.39E-06	1.5	100	2.61E-06	6.0	100	2.48E-06	7.7	100
25	1.98E-06	0.9	100	1.76E-06	1.5	100	1.87E-06	6.0	100	1.77E-06	7.7	100
26	3.65E-06	0.9	100	3.19E-06	1.5	100	3.41E-06	6.0	100	3.32E-06	7.7	100
27	3.02E-06	0.9	100	2.66E-06	1.5	100	2.93E-06	6.0	100	2.75E-06	7.7	100
28	3.96E-06	0.9	100	3.49E-06	1.5	100	3.57E-06	6.0	100	3.54E-06	7.7	100
29												
30												
31												
1ヶ月値	4.04E-06	0.9	100	3.65E-06	1.5	100	3.67E-06	6.4	100	3.68E-06	7.6	100
最大値	1.33E-05	0.9	102	1.24E-05	1.5	103	1.20E-05	7.4	102	1.24E-05	7.7	102
最大値日時	02/22 04:54	02/01 00:01	02/04 01:30	02/22 05:12	02/02 11:33	02/01 01:12	02/13 08:33	02/01 00:01	02/03 04:00	02/01 07:42	02/15 08:14	02/01 07:36
最小値	1.17E-07	0.9	98	0.00E+00	1.4	97	0.00E+00	6.0	98	0.00E+00	7.6	98
最小値日時	02/15 16:46	02/01 00:01	02/01 00:12	02/02 11:33	02/01 00:01	02/04 02:29	02/08 10:28	02/08 10:28	02/01 04:27	02/15 08:14	02/01 00:01	02/01 04:32

\*1: ろ紙交換 \*3: 年次点検

# 測定月報

測定日：2021/02

(2/8)

日	モニタ											
	A005 5/6号警備所前			A006 5/6号警備所前			A007 1号北側法面上(旧厚生棟)			A008 1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.62E-06	1.6	100	4.67E-06	1.8	100	4.68E-06	8.4	100	4.75E-06	5.8	100
2	4.01E-06	1.6	100	*1 4.17E-06	1.7	100	3.82E-06	8.4	100	3.96E-06	5.8	100
3	*1 4.63E-06	1.5	100	4.68E-06	1.7	100	4.40E-06	8.4	100	4.51E-06	5.8	100
4	3.52E-06	1.4	100	3.51E-06	1.7	100	3.33E-06	8.4	100	3.39E-06	5.8	100
5	2.77E-06	1.4	100	2.72E-06	1.7	100	2.62E-06	8.4	100	2.67E-06	5.8	100
6	3.90E-06	1.4	100	3.94E-06	1.7	100	3.68E-06	8.4	100	3.70E-06	5.8	100
7	4.13E-06	1.4	100	4.19E-06	1.7	100	3.93E-06	8.4	100	3.96E-06	5.8	100
8	4.88E-06	1.4	100	4.93E-06	1.7	100	4.72E-06	8.4	100	4.74E-06	5.8	100
9	2.49E-06	1.4	100	2.50E-06	1.7	100	*1 2.40E-06	8.4	100	2.33E-06	5.8	100
10	3.01E-06	1.4	100	3.08E-06	1.7	100	3.00E-06	8.4	100	2.94E-06	5.8	100
11	4.48E-06	1.4	100	4.46E-06	1.7	100	4.39E-06	8.4	100	4.30E-06	5.8	100
12	5.74E-06	1.4	100	5.74E-06	1.7	100	5.76E-06	8.4	100	5.60E-06	5.8	100
13	6.90E-06	1.4	100	7.00E-06	1.7	100	6.63E-06	8.4	100	6.50E-06	5.8	100
14	3.99E-06	1.4	100	3.95E-06	1.7	100	3.41E-06	8.4	100	3.37E-06	5.8	100
15	1.03E-06	1.4	100	1.01E-06	1.7	100	9.56E-07	8.4	100	*1 1.03E-06	5.7	100
16	2.82E-06	1.4	100	2.81E-06	1.7	100	2.56E-06	8.4	100	2.70E-06	5.6	100
17	2.89E-06	1.4	100	2.89E-06	1.7	100	2.72E-06	8.4	100	2.88E-06	5.6	100
18	2.64E-06	1.4	100	2.64E-06	1.7	100	2.53E-06	8.4	100	2.58E-06	5.6	100
19	2.42E-06	1.4	100	2.42E-06	1.7	100	2.31E-06	8.4	100	2.39E-06	5.6	100
20	3.93E-06	1.4	100	3.91E-06	1.7	100	3.71E-06	8.4	100	3.91E-06	5.6	100
21	5.80E-06	1.4	100	5.80E-06	1.7	100	5.60E-06	8.4	100	5.89E-06	5.6	100
22	7.16E-06	1.4	100	7.23E-06	1.7	100	6.99E-06	8.4	100	7.24E-06	5.6	100
23	3.95E-06	1.4	100	3.92E-06	1.7	100	3.66E-06	8.4	100	3.85E-06	5.6	100
24	2.54E-06	1.4	100	2.52E-06	1.7	100	2.35E-06	8.4	100	2.43E-06	5.6	100
25	1.80E-06	1.4	100	1.75E-06	1.7	100	1.65E-06	8.4	100	1.76E-06	5.6	100
26	3.30E-06	1.4	100	3.28E-06	1.7	100	3.14E-06	8.4	100	3.36E-06	5.6	100
27	2.80E-06	1.4	100	2.78E-06	1.7	100	2.60E-06	8.4	100	2.79E-06	5.6	100
28	3.43E-06	1.4	100	3.47E-06	1.7	100	3.40E-06	8.4	100	3.52E-06	5.6	100
29												
30												
31												
1ヶ月値	3.77E-06	1.4	100	3.78E-06	1.7	100	3.61E-06	8.4	100	3.68E-06	5.7	100
最大値	6.05E-05	1.6	102	2.25E-05	1.8	102	1.23E-05	8.4	102	1.23E-05	5.8	102
最大値日時	02/03 10:58	02/01 00:01	02/01 04:14	02/02 11:24	02/01 00:01	02/01 01:30	02/13 08:49	02/01 00:01	02/06 23:31	02/13 08:51	02/01 00:01	02/01 00:22
最小値	0.00E+00	1.4	98	0.00E+00	1.7	98	0.00E+00	8.4	98	0.00E+00	5.6	98
最小値日時	02/15 16:14	02/03 10:58	02/01 06:51	02/02 11:25	02/02 11:24	02/01 06:52	02/09 09:57	02/01 00:01	02/01 03:28	02/15 09:56	02/15 09:56	02/01 00:49

\*1: ろ紙交換

# 測定月報

測定日：2021/02

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.65E-06	5.7	100	4.44E-06	5.8	100	4.77E-06	4.1	100	4.99E-06	3.5	100
2	3.93E-06	5.7	100	3.71E-06	5.8	100	3.93E-06	4.1	100	*1 4.13E-06	3.7	100
3	4.37E-06	5.7	100	4.24E-06	5.8	100	4.39E-06	4.1	100	4.47E-06	3.9	100
4	3.33E-06	5.7	100	3.21E-06	5.8	100	3.38E-06	4.1	100	3.38E-06	3.9	100
5	2.64E-06	5.7	100	2.53E-06	5.8	100	2.60E-06	4.1	100	2.59E-06	3.9	100
6	3.66E-06	5.7	100	3.55E-06	5.8	100	3.78E-06	4.1	100	3.75E-06	3.9	100
7	3.92E-06	5.7	100	3.77E-06	5.8	100	3.94E-06	4.1	100	4.00E-06	3.9	100
8	4.78E-06	5.7	100	4.56E-06	5.8	100	4.86E-06	4.1	100	*3 4.98E-06	3.5	100
9	2.32E-06	5.7	100	*1 2.33E-06	5.8	100	*1 2.44E-06	4.0	100	2.28E-06	3.2	100
10	2.91E-06	5.7	100	2.89E-06	5.8	100	3.24E-06	3.9	100	2.84E-06	3.2	100
11	4.28E-06	5.7	100	4.34E-06	5.8	100	4.74E-06	3.9	100	4.37E-06	3.2	100
12	5.61E-06	5.7	100	5.84E-06	5.8	100	6.27E-06	3.9	100	5.74E-06	3.2	100
13	6.24E-06	5.7	100	6.36E-06	5.8	100	6.94E-06	3.9	100	6.26E-06	3.2	100
14	2.93E-06	5.7	100	3.25E-06	5.8	100	3.53E-06	3.9	100	3.11E-06	3.2	100
15	8.03E-07	5.7	100	9.15E-07	5.8	100	1.22E-06	3.9	100	1.09E-06	3.2	100
16	*1 2.69E-06	5.8	100	2.60E-06	5.8	100	2.92E-06	3.9	100	2.68E-06	3.2	100
17	2.66E-06	5.8	100	2.73E-06	5.8	100	3.06E-06	3.9	100	2.77E-06	3.2	100
18	2.45E-06	5.8	100	2.42E-06	5.8	100	2.78E-06	3.9	100	2.52E-06	3.2	100
19	2.25E-06	5.8	100	2.27E-06	5.8	100	2.50E-06	3.9	100	2.30E-06	3.2	100
20	3.65E-06	5.8	100	3.64E-06	5.8	100	4.02E-06	3.9	100	3.68E-06	3.2	100
21	5.45E-06	5.8	100	5.55E-06	5.8	100	6.20E-06	3.9	100	5.75E-06	3.2	100
22	6.86E-06	5.8	100	6.71E-06	5.8	100	7.62E-06	3.9	100	6.91E-06	3.2	100
23	3.57E-06	5.8	100	3.68E-06	5.8	100	4.08E-06	3.9	100	3.73E-06	3.2	100
24	2.28E-06	5.8	100	2.39E-06	5.8	100	2.67E-06	3.9	100	2.42E-06	3.2	100
25	1.55E-06	5.8	100	1.59E-06	5.8	100	1.92E-06	3.9	100	1.73E-06	3.2	100
26	3.11E-06	5.8	100	3.12E-06	5.8	100	3.52E-06	3.9	100	3.25E-06	3.2	100
27	2.57E-06	5.8	100	2.61E-06	5.8	100	2.96E-06	3.9	100	2.62E-06	3.2	100
28	3.34E-06	5.8	100	3.33E-06	5.8	100	3.67E-06	3.9	100	3.36E-06	3.2	100
29												
30												
31												
1ヶ月値	3.53E-06	5.7	100	3.52E-06	5.8	100	3.86E-06	4.0	100	3.63E-06	3.4	100
最大値	2.29E-05	5.8	102	1.12E-05	5.8	102	1.34E-05	4.1	102	1.20E-05	3.9	102
最大値日時	02/16 09:48	02/16 09:48	02/01 05:58	02/13 08:35	02/01 00:01	02/01 03:21	02/22 04:24	02/01 00:01	02/24 20:54	02/13 08:35	02/02 10:20	02/02 15:29
最小値	0.00E+00	5.7	98	0.00E+00	5.8	98	0.00E+00	3.9	98	0.00E+00	3.2	97
最小値日時	02/15 14:45	02/01 00:01	02/01 00:30	02/09 11:30	02/01 00:01	02/01 00:24	02/09 10:25	02/09 10:25	02/01 01:57	02/02 10:20	02/08 11:10	02/09 07:13

\*1: ろ紙交換 \*3: 年次点検

# 測定月報

測定日：2021/02

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.30E-06	6.5	100	4.88E-06	0.7	100	4.55E-06	2.4	100	4.65E-06	1.8	100
2	*1 3.72E-06	6.5	100	4.07E-06	0.7	100	3.68E-06	2.4	100	*1 3.92E-06	1.8	100
3	4.29E-06	6.5	100	4.46E-06	0.7	100	4.34E-06	2.4	100	4.52E-06	1.8	100
4	3.21E-06	6.5	100	3.42E-06	0.7	100	3.27E-06	2.4	100	3.50E-06	1.8	100
5	2.50E-06	6.5	100	2.73E-06	0.7	100	2.53E-06	2.4	100	2.70E-06	1.8	100
6	3.51E-06	6.5	100	3.75E-06	0.7	100	3.73E-06	2.4	100	3.83E-06	1.8	100
7	3.79E-06	6.5	100	3.98E-06	0.7	100	3.72E-06	2.4	100	3.84E-06	1.8	100
8	4.62E-06	6.5	100	4.89E-06	0.7	100	5.17E-06	2.4	100	5.32E-06	1.8	100
9	2.12E-06	6.5	100	2.31E-06	0.7	100	2.19E-06	2.4	100	2.33E-06	1.8	100
10	2.69E-06	6.5	100	2.79E-06	0.7	100	2.95E-06	2.4	100	3.07E-06	1.8	100
11	4.20E-06	6.5	100	4.27E-06	0.7	100	4.19E-06	2.4	100	4.27E-06	1.8	100
12	5.43E-06	6.5	100	5.52E-06	0.7	100	5.86E-06	2.4	100	6.08E-06	1.8	100
13	6.25E-06	6.5	100	6.35E-06	0.7	100	6.71E-06	2.4	100	7.00E-06	1.8	100
14	2.93E-06	6.5	100	3.08E-06	0.7	100	3.16E-06	2.4	100	3.36E-06	1.8	100
15	7.76E-07	6.5	100	9.59E-07	0.7	100	9.11E-07	2.4	100	9.83E-07	1.8	100
16	2.51E-06	6.5	100	*1 2.79E-06	0.6	100	2.48E-06	2.4	100	2.62E-06	1.8	100
17	2.68E-06	6.5	100	2.91E-06	0.6	100	2.53E-06	2.4	100	2.71E-06	1.8	100
18	2.38E-06	6.5	100	2.54E-06	0.6	100	2.37E-06	2.4	100	2.49E-06	1.8	100
19	2.12E-06	6.5	100	2.33E-06	0.6	100	2.16E-06	2.4	100	2.28E-06	1.8	100
20	3.59E-06	6.5	100	3.72E-06	0.6	100	3.46E-06	2.4	100	3.68E-06	1.8	100
21	5.52E-06	6.5	100	5.58E-06	0.6	100	5.27E-06	2.4	100	5.59E-06	1.8	100
22	7.06E-06	6.5	100	7.20E-06	0.6	100	*1 6.84E-06	2.3	100	7.06E-06	1.8	100
23	3.54E-06	6.5	100	3.75E-06	0.6	100	3.50E-06	2.3	100	3.59E-06	1.8	100
24	2.23E-06	6.5	100	2.46E-06	0.6	100	2.37E-06	2.3	100	2.41E-06	1.8	100
25	1.53E-06	6.5	100	1.79E-06	0.6	100	1.86E-06	2.3	100	1.84E-06	1.8	100
26	3.04E-06	6.5	100	3.29E-06	0.6	100	3.19E-06	2.3	100	3.27E-06	1.8	100
27	2.42E-06	6.5	100	2.70E-06	0.6	100	2.58E-06	2.3	100	2.67E-06	1.8	100
28	3.01E-06	6.5	100	3.38E-06	0.6	100	3.59E-06	2.3	100	3.73E-06	1.8	100
29												
30												
31												
1ヶ月値	3.43E-06	6.5	100	3.64E-06	0.7	100	3.54E-06	2.4	100	3.69E-06	1.8	100
最大値	2.75E-05	6.5	102	1.24E-05	0.7	102	1.25E-05	2.4	101	1.34E-05	1.8	102
最大値日時	02/02 11:40	02/01 00:01	02/01 00:48	02/22 06:15	02/01 00:01	02/01 01:21	02/13 20:50	02/01 00:01	02/01 00:04	02/13 20:31	02/01 00:01	02/02 02:40
最小値	0.00E+00	6.5	97	1.15E-07	0.6	98	0.00E+00	2.3	99	0.00E+00	1.8	98
最小値日時	02/02 11:41	02/01 00:01	02/02 18:59	02/15 16:57	02/16 10:11	02/01 02:54	02/22 11:33	02/22 11:33	02/01 00:07	02/02 11:13	02/01 00:01	02/01 01:41

\*1:ろ紙交換

# 測定月報

測定日：2021/02

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シールド中央制御室			A020 シールド中央制御室		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	5.23E-06	5.1	100	4.85E-06	5.0	100	4.61E-06	2.8	100	4.53E-06	3.3	100
2	4.27E-06	5.1	100	4.02E-06	5.0	100	3.88E-06	2.8	100	3.77E-06	3.3	100
3	4.94E-06	5.1	100	4.64E-06	5.0	100	4.29E-06	2.8	100	4.21E-06	3.3	100
4	3.72E-06	5.1	100	3.58E-06	5.0	100	3.31E-06	2.8	100	3.20E-06	3.3	100
5	2.87E-06	5.1	100	2.70E-06	5.0	100	2.60E-06	2.8	100	2.47E-06	3.3	100
6	4.11E-06	5.1	100	3.85E-06	5.0	100	3.68E-06	2.8	100	3.55E-06	3.3	100
7	4.26E-06	5.1	100	4.01E-06	5.0	100	3.85E-06	2.8	100	3.80E-06	3.3	100
8	5.39E-06	5.1	100	5.02E-06	5.0	100	4.82E-06	2.8	100	4.76E-06	3.3	100
9	2.49E-06	5.1	100	*1 2.47E-06	5.1	100	2.14E-06	2.8	100	*1 2.12E-06	3.4	100
10	3.29E-06	5.1	100	3.16E-06	5.1	100	2.77E-06	2.8	100	2.62E-06	3.5	100
11	4.71E-06	5.1	100	4.62E-06	5.1	100	4.28E-06	2.8	100	4.26E-06	3.5	100
12	6.55E-06	5.1	100	6.38E-06	5.1	100	5.44E-06	2.8	100	5.47E-06	3.5	100
13	7.39E-06	5.1	100	7.21E-06	5.1	100	6.07E-06	2.8	100	6.11E-06	3.5	100
14	3.64E-06	5.1	100	3.45E-06	5.1	100	2.93E-06	2.8	100	3.03E-06	3.5	100
15	1.14E-06	5.1	100	1.02E-06	5.1	100	8.34E-07	2.8	100	8.41E-07	3.5	100
16	*1 2.93E-06	5.1	100	2.67E-06	5.1	100	*1 2.48E-06	2.7	100	2.45E-06	3.5	100
17	2.98E-06	5.1	100	2.79E-06	5.1	100	2.62E-06	2.6	100	2.51E-06	3.5	100
18	2.71E-06	5.1	100	2.57E-06	5.1	100	2.37E-06	2.6	100	2.27E-06	3.5	100
19	2.43E-06	5.1	100	2.32E-06	5.1	100	2.19E-06	2.6	100	2.14E-06	3.5	100
20	3.90E-06	5.1	100	3.78E-06	5.1	100	3.46E-06	2.6	100	3.48E-06	3.5	100
21	5.92E-06	5.1	100	5.70E-06	5.1	100	5.31E-06	2.6	100	5.39E-06	3.5	100
22	7.43E-06	5.1	100	7.20E-06	5.1	100	6.69E-06	2.6	100	6.75E-06	3.5	100
23	3.97E-06	5.1	100	3.85E-06	5.1	100	3.53E-06	2.6	100	3.51E-06	3.5	100
24	2.53E-06	5.1	100	2.40E-06	5.1	100	2.28E-06	2.6	100	2.24E-06	3.5	100
25	1.86E-06	5.1	100	1.76E-06	5.1	100	1.67E-06	2.6	100	1.60E-06	3.5	100
26	3.42E-06	5.1	100	3.37E-06	5.1	100	3.12E-06	2.6	100	3.05E-06	3.5	100
27	2.84E-06	5.1	100	2.77E-06	5.1	100	2.57E-06	2.6	100	2.48E-06	3.5	100
28	3.80E-06	5.1	100	3.68E-06	5.1	100	3.10E-06	2.6	100	3.06E-06	3.5	100
29												
30												
31												
1ヶ月値	3.96E-06	5.1	100	3.78E-06	5.1	100	3.46E-06	2.7	100	3.42E-06	3.4	100
最大値	1.36E-05	5.1	102	1.27E-05	5.1	102	1.21E-05	2.8	101	1.22E-05	3.5	103
最大値日時	02/01 07:39	02/01 00:01	02/03 22:23	02/01 07:18	02/09 10:33	02/06 08:16	02/13 08:50	02/01 00:01	02/01 00:18	02/22 05:31	02/09 11:40	02/24 21:46
最小値	0.00E+00	5.1	98	0.00E+00	5.0	98	0.00E+00	2.6	99	0.00E+00	3.3	97
最小値日時	02/15 16:43	02/01 00:01	02/01 21:07	02/09 10:33	02/01 00:01	02/03 19:15	02/15 16:04	02/16 10:04	02/01 00:13	02/09 11:40	02/01 00:01	02/10 02:30

\*1:ろ紙交換

# 測定月報

測定日：2021/02

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.70E-06	2.2	100	5.06E-06	3.0	100	5.02E-06	14.5	100	5.19E-06	16.0	100
2	3.81E-06	2.2	100	4.15E-06	3.0	100	4.26E-06	14.5	100	4.58E-06	16.0	100
3	4.34E-06	2.2	100	4.70E-06	3.0	100	4.65E-06	14.5	100	4.99E-06	16.0	100
4	3.36E-06	2.2	100	3.57E-06	3.0	100	3.62E-06	14.5	100	3.74E-06	16.0	100
5	2.59E-06	2.2	100	2.80E-06	3.0	100	2.89E-06	14.5	100	2.95E-06	16.0	100
6	3.74E-06	2.2	100	4.04E-06	3.0	100	4.01E-06	14.5	100	4.14E-06	16.0	100
7	3.89E-06	2.2	100	4.16E-06	3.0	100	4.24E-06	14.5	100	4.31E-06	16.0	100
8	5.14E-06	2.2	100	5.33E-06	3.0	100	5.06E-06	14.5	100	5.24E-06	16.0	100
9	2.28E-06	2.2	100	2.33E-06	3.0	100	2.45E-06	14.5	100	2.48E-06	16.0	100
10	2.97E-06	2.2	100	3.08E-06	3.0	100	3.09E-06	14.5	100	3.12E-06	16.0	100
11	4.45E-06	2.2	100	4.54E-06	3.0	100	4.54E-06	14.5	100	4.60E-06	16.0	100
12	6.14E-06	2.2	100	6.28E-06	3.0	100	6.07E-06	14.5	100	6.24E-06	16.0	100
13	6.71E-06	2.2	100	6.79E-06	3.0	100	6.76E-06	14.5	100	7.07E-06	16.0	100
14	3.17E-06	2.1	100	3.33E-06	3.0	100	3.43E-06	14.5	100	4.50E-06	16.0	100
15	9.47E-07	2.1	100	9.11E-07	3.0	100	7.70E-07	14.5	100	1.48E-06	16.0	100
16	2.66E-06	2.1	100	*1 2.88E-06	2.9	100	2.22E-06	14.5	100	*1 3.06E-06	16.4	100
17	2.76E-06	2.1	100	3.05E-06	2.8	100	2.20E-06	14.5	100	3.08E-06	16.7	100
18	2.52E-06	2.1	100	2.74E-06	2.8	100	1.93E-06	14.5	100	2.70E-06	16.7	100
19	2.27E-06	2.1	100	2.55E-06	2.8	100	1.74E-06	14.5	100	2.57E-06	16.7	100
20	3.60E-06	2.1	100	3.99E-06	2.8	100	3.26E-06	14.5	100	4.21E-06	16.7	100
21	5.58E-06	2.1	100	6.11E-06	2.8	100	5.16E-06	14.5	100	6.01E-06	16.7	100
22	*1 6.91E-06	2.1	100	7.79E-06	2.8	100	*1 7.00E-06	14.1	100	7.41E-06	16.7	100
23	3.62E-06	2.1	100	4.07E-06	2.8	100	3.74E-06	13.7	100	4.00E-06	16.7	100
24	2.38E-06	2.1	100	2.60E-06	2.8	100	2.37E-06	13.7	100	2.60E-06	16.7	100
25	1.73E-06	2.1	100	1.92E-06	2.8	100	1.71E-06	13.7	100	1.92E-06	16.7	100
26	3.18E-06	2.1	100	3.54E-06	2.8	100	3.23E-06	13.7	100	3.50E-06	16.7	100
27	2.61E-06	2.1	100	2.91E-06	2.8	100	2.66E-06	13.7	100	2.91E-06	16.7	100
28	3.42E-06	2.1	100	3.82E-06	2.8	100	3.43E-06	13.7	100	3.64E-06	16.7	100
29												
30												
31												
1ヶ月値	3.62E-06	2.1	100	3.90E-06	2.9	100	3.62E-06	14.3	100	4.01E-06	16.3	100
最大値	1.21E-05	2.2	102	1.31E-05	3.0	102	5.70E-05	14.5	101	1.48E-05	16.7	101
最大値日時	02/13 08:37	02/01 00:01	02/01 03:12	02/22 05:43	02/01 00:01	02/06 03:46	02/22 10:43	02/01 00:01	02/01 00:20	02/14 00:51	02/16 11:13	02/01 00:08
最小値	0.00E+00	2.1	98	0.00E+00	2.8	98	0.00E+00	13.7	99	0.00E+00	16.0	98
最小値日時	02/14 03:40	02/14 03:40	02/01 00:22	02/15 15:59	02/16 09:55	02/01 02:03	02/15 10:33	02/22 10:43	02/01 00:07	02/15 14:39	02/01 00:01	02/04 16:25

\*1:ろ紙交換

# 測定月報

測定日：2021/02

(7/8)

日	モニタ											
	A027 1号機海側2、5m盤			A028 1号機海側2、5m盤			A029 3号機海側2、5m盤			A030 3号機海側2、5m盤		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	4.63E-06	3.4	100	4.63E-06	4.2	100	4.39E-06	2.7	100	4.31E-06	2.2	100
2	4.04E-06	3.4	100	4.15E-06	4.2	100	*1 4.06E-06	2.8	100	3.77E-06	2.2	100
3	4.56E-06	3.4	100	4.55E-06	4.2	100	4.58E-06	2.8	100	4.18E-06	2.2	100
4	3.48E-06	3.4	100	3.43E-06	4.2	100	3.46E-06	2.8	100	3.14E-06	2.2	100
5	2.66E-06	3.4	100	2.68E-06	4.2	100	2.70E-06	2.8	100	2.46E-06	2.2	100
6	3.88E-06	3.4	100	3.82E-06	4.2	100	3.77E-06	2.8	100	3.50E-06	2.2	100
7	4.15E-06	3.4	100	4.08E-06	4.2	100	4.06E-06	2.8	100	3.78E-06	2.2	100
8	4.78E-06	3.4	100	4.74E-06	4.2	100	4.79E-06	2.8	100	4.43E-06	2.2	100
9	2.38E-06	3.4	100	*1 2.40E-06	4.3	100	2.32E-06	2.8	100	*1 2.34E-06	2.2	100
10	2.94E-06	3.4	100	2.86E-06	4.4	100	2.84E-06	2.8	100	2.95E-06	2.2	100
11	4.38E-06	3.4	100	4.33E-06	4.4	100	4.30E-06	2.8	100	4.36E-06	2.2	100
12	5.70E-06	3.4	100	5.59E-06	4.4	100	5.76E-06	2.8	100	5.71E-06	2.2	100
13	6.93E-06	3.4	100	6.56E-06	4.4	100	6.63E-06	2.8	100	6.65E-06	2.2	100
14	3.67E-06	3.4	100	3.70E-06	4.4	100	3.86E-06	2.8	100	3.80E-06	2.2	100
15	*1 1.04E-06	3.5	100	1.19E-06	4.4	100	1.00E-06	2.8	100	1.05E-06	2.2	100
16	2.71E-06	3.5	100	2.84E-06	4.4	100	2.75E-06	2.8	100	2.71E-06	2.2	100
17	2.80E-06	3.5	100	2.98E-06	4.4	100	2.89E-06	2.8	100	2.85E-06	2.2	100
18	2.58E-06	3.5	100	2.70E-06	4.4	100	2.58E-06	2.8	100	2.63E-06	2.2	100
19	2.28E-06	3.5	100	2.48E-06	4.4	100	2.34E-06	2.8	100	2.35E-06	2.2	100
20	3.88E-06	3.5	100	3.98E-06	4.4	100	3.71E-06	2.8	100	3.76E-06	2.2	100
21	5.81E-06	3.5	100	5.94E-06	4.4	100	5.58E-06	2.8	100	5.72E-06	2.2	100
22	7.27E-06	3.5	100	7.31E-06	4.4	100	6.71E-06	2.8	100	6.80E-06	2.2	100
23	3.89E-06	3.5	100	3.99E-06	4.4	100	3.75E-06	2.8	100	3.78E-06	2.2	100
24	2.40E-06	3.5	100	2.62E-06	4.4	100	2.39E-06	2.8	100	2.43E-06	2.2	100
25	1.64E-06	3.5	100	1.91E-06	4.4	100	1.67E-06	2.8	100	1.70E-06	2.2	100
26	3.23E-06	3.5	100	3.36E-06	4.4	100	3.23E-06	2.8	100	3.28E-06	2.2	100
27	2.65E-06	3.5	100	2.80E-06	4.4	100	2.62E-06	2.8	100	2.69E-06	2.2	100
28	3.42E-06	3.5	100	3.52E-06	4.4	100	3.32E-06	2.8	100	3.42E-06	2.2	100
29												
30												
31												
1ヶ月値	3.71E-06	3.4	100	3.76E-06	4.3	100	3.65E-06	2.8	100	3.59E-06	2.2	100
最大値	1.33E-05	3.5	101	1.38E-05	4.4	102	3.38E-05	2.8	102	1.57E-05	2.2	102
最大値日時	02/22 08:52	02/15 10:09	02/01 00:03	02/22 08:59	02/09 10:04	02/01 02:20	02/02 10:08	02/02 10:08	02/01 01:39	02/14 00:14	02/01 00:01	02/14 05:23
最小値	0.00E+00	3.4	99	0.00E+00	4.2	98	0.00E+00	2.7	98	5.58E-08	2.2	98
最小値日時	02/15 10:09	02/01 00:01	02/01 00:29	02/09 10:04	02/01 00:01	02/01 00:29	02/15 15:55	02/01 00:01	02/01 00:12	02/15 16:34	02/01 00:01	02/01 03:57

\*1:ろ紙交換



# 測定月報

測定日：2021/02

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	5.12E-06	10.6	100	5.15E-06	6.7	100						
2	4.38E-06	10.6	100	4.30E-06	6.7	100						
3	4.80E-06	10.6	100	4.86E-06	6.7	100						
4	3.69E-06	10.6	100	3.70E-06	6.7	100						
5	2.92E-06	10.6	100	2.97E-06	6.7	100						
6	4.23E-06	10.6	100	4.08E-06	6.7	100						
7	4.56E-06	10.6	100	4.44E-06	6.7	100						
8	5.36E-06	10.6	100	5.42E-06	6.7	100						
9	2.61E-06	10.6	100	*1 2.71E-06	6.8	100						
10	3.23E-06	10.6	100	3.39E-06	6.8	100						
11	4.67E-06	10.6	100	4.88E-06	6.8	100						
12	6.12E-06	10.6	100	6.43E-06	6.8	100						
13	6.83E-06	10.6	100	7.32E-06	6.8	100						
14	3.58E-06	10.6	100	3.75E-06	6.8	100						
15	1.15E-06	10.6	100	1.10E-06	6.8	100						
16	*1 2.88E-06	10.5	100	2.92E-06	6.8	100						
17	2.98E-06	10.5	100	3.07E-06	6.8	100						
18	2.76E-06	10.5	100	2.79E-06	6.8	100						
19	2.55E-06	10.5	100	2.52E-06	6.8	100						
20	4.00E-06	10.5	100	4.05E-06	6.8	100						
21	5.99E-06	10.5	100	6.25E-06	6.8	100						
22	7.63E-06	10.5	100	7.85E-06	6.8	100						
23	4.07E-06	10.5	100	4.06E-06	6.8	100						
24	2.68E-06	10.5	100	2.67E-06	6.8	100						
25	1.92E-06	10.5	100	1.83E-06	6.8	100						
26	3.41E-06	10.5	100	3.45E-06	6.8	100						
27	2.87E-06	10.5	100	2.88E-06	6.8	100						
28	3.56E-06	10.5	100	3.58E-06	6.8	100						
29												
30												
31												
1ヶ月値	3.95E-06	10.6	100	4.01E-06	6.8	100						
最大値	1.28E-05	10.6	102	1.34E-05	6.8	102						
最大値日時	02/22 06:13	02/01 00:01	02/01 07:39	02/13 08:56	02/09 10:17	02/04 04:02						
最小値	0.00E+00	10.5	98	0.00E+00	6.7	98						
最小値日時	02/15 13:07	02/16 11:01	02/01 02:16	02/09 10:17	02/01 00:01	02/01 00:50						

\*1: ろ紙交換