

# 構内連続ダストモニタ測定記録(2021 年 9 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

# 測定月報

測定日：2021/09

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.67E-06	0.8	100	7.17E-06	1.3	100	6.60E-06	5.7	100	6.40E-06	5.4	100
2	2.74E-06	0.8	100	2.98E-06	1.3	100	2.86E-06	5.7	100	2.71E-06	5.4	100
3	2.02E-06	0.8	100	2.22E-06	1.3	100	2.11E-06	5.7	100	1.97E-06	5.4	100
4	9.97E-07	0.8	100	1.17E-06	1.3	100	1.09E-06	5.7	100	9.43E-07	5.4	100
5	1.12E-06	0.8	100	1.31E-06	1.3	100	1.26E-06	5.7	100	1.14E-06	5.4	100
6	1.16E-06	0.8	100	1.33E-06	1.3	100	1.24E-06	5.7	100	1.11E-06	5.4	100
7	1.27E-06	0.8	100	1.43E-06	1.3	100	1.33E-06	5.7	100	1.20E-06	5.4	100
8	2.27E-06	0.8	100	2.52E-06	1.3	100	2.28E-06	5.7	100	*1 2.15E-06	5.3	100
9	4.16E-06	0.8	100	4.45E-06	1.3	100	4.00E-06	5.7	100	3.80E-06	5.3	100
10	6.18E-06	0.8	100	6.61E-06	1.3	100	6.19E-06	5.7	100	6.06E-06	5.3	100
11	6.75E-06	0.8	100	7.29E-06	1.3	100	6.65E-06	5.7	100	6.44E-06	5.3	100
12	8.16E-06	0.8	100	8.77E-06	1.3	100	8.22E-06	5.7	100	8.08E-06	5.3	100
13	4.11E-06	0.8	100	*3 4.39E-06	1.2	100	4.33E-06	5.7	100	4.19E-06	5.3	100
14	4.32E-06	0.8	100	4.65E-06	1.2	100	*1 4.18E-06	5.9	100	4.09E-06	5.3	100
15	3.92E-06	0.8	100	4.23E-06	1.2	100	3.75E-06	6.0	100	3.71E-06	5.3	100
16	8.50E-07	0.8	100	9.45E-07	1.2	100	6.64E-07	6.0	100	7.45E-07	5.3	100
17	2.07E-06	0.8	100	2.24E-06	1.2	100	1.97E-06	6.0	100	2.01E-06	5.3	100
18	9.14E-07	0.8	100	1.00E-06	1.2	100	7.87E-07	6.0	100	8.68E-07	5.3	100
19	2.38E-06	0.8	100	2.57E-06	1.2	100	2.35E-06	6.0	100	2.43E-06	5.3	100
20	4.12E-06	0.8	100	4.31E-06	1.2	100	3.93E-06	6.0	100	3.96E-06	5.3	100
21	4.35E-06	0.8	100	4.56E-06	1.2	100	4.05E-06	6.0	100	4.08E-06	5.3	100
22	*1 5.22E-06	0.7	100	5.52E-06	1.2	100	4.56E-06	6.0	100	4.56E-06	5.3	100
23	3.04E-06	0.7	100	3.10E-06	1.2	100	2.57E-06	6.0	100	2.65E-06	5.3	100
24	3.25E-06	0.7	100	3.34E-06	1.2	100	3.00E-06	6.0	100	3.04E-06	5.3	100
25	1.62E-06	0.7	100	1.70E-06	1.2	100	1.41E-06	6.0	100	1.50E-06	5.3	100
26	3.18E-06	0.7	100	3.30E-06	1.2	100	2.46E-06	6.0	100	2.47E-06	5.3	100
27	3.05E-06	0.7	100	3.22E-06	1.2	100	2.71E-06	6.0	100	2.74E-06	5.3	100
28	3.12E-06	0.7	100	3.21E-06	1.2	100	2.93E-06	6.0	100	2.94E-06	5.3	100
29	3.24E-06	0.7	100	3.34E-06	1.2	100	2.65E-06	6.0	100	2.68E-06	5.3	100
30	1.95E-06	0.7	100	2.00E-06	1.2	100	1.54E-06	6.0	100	1.61E-06	5.3	100
31												
1ヶ月値	3.34E-06	0.8	100	3.50E-06	1.2	100	3.12E-06	5.9	100	3.08E-06	5.3	100
最大値	1.67E-05	0.8	102	1.83E-05	1.3	102	1.57E-05	6.0	102	1.60E-05	5.4	102
最大値日時	09/12 00:50	09/01 00:01	09/01 04:45	09/12 00:18	09/01 00:01	09/01 00:13	09/12 00:44	09/14 07:53	09/03 22:06	09/12 01:12	09/01 00:01	09/04 07:09
最小値	0.00E+00	0.7	98	0.00E+00	1.2	97	0.00E+00	5.7	98	0.00E+00	5.3	98
最小値日時	09/04 12:52	09/22 09:37	09/01 08:12	09/13 10:41	09/13 10:41	09/08 21:15	09/14 07:53	09/01 00:01	09/01 21:12	09/07 15:12	09/08 09:47	09/01 10:28

\*1: ろ紙交換 \*3: 年次点検

# 測定月報

測定日：2021/09

(2/8)

日	モニタ											
	A005 5/6号警備所前			A006 5/6号警備所前			A007 1号北側法面上(旧厚生棟)			A008 1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.90E-06	1.4	100	6.69E-06	1.6	100	6.86E-06	7.9	100	6.86E-06	5.7	100
2	3.07E-06	1.4	100	2.97E-06	1.6	100	2.99E-06	7.9	100	2.83E-06	5.7	100
3	2.22E-06	1.4	100	2.11E-06	1.6	100	2.20E-06	7.9	100	2.02E-06	5.7	100
4	1.13E-06	1.4	100	1.10E-06	1.6	100	1.15E-06	7.9	100	9.94E-07	5.7	100
5	1.32E-06	1.4	100	1.27E-06	1.6	100	1.31E-06	7.9	100	1.14E-06	5.7	100
6	1.29E-06	1.4	100	1.24E-06	1.6	100	1.32E-06	7.9	100	1.14E-06	5.7	100
7	1.31E-06	1.4	100	1.29E-06	1.6	100	1.39E-06	7.9	100	1.19E-06	5.7	100
8	2.29E-06	1.4	100	2.27E-06	1.6	100	2.46E-06	7.9	100	2.29E-06	5.7	100
9	4.13E-06	1.4	100	4.03E-06	1.6	100	4.09E-06	7.9	100	3.94E-06	5.7	100
10	6.61E-06	1.4	100	6.36E-06	1.6	100	6.34E-06	7.9	100	6.30E-06	5.7	100
11	6.73E-06	1.4	100	6.56E-06	1.6	100	6.81E-06	7.9	100	6.73E-06	5.7	100
12	8.88E-06	1.4	100	8.66E-06	1.6	100	8.70E-06	7.9	100	8.78E-06	5.7	100
13	4.65E-06	1.4	100	*3 4.26E-06	1.7	100	4.61E-06	7.9	100	4.42E-06	5.7	100
14	*1 4.45E-06	1.4	100	3.92E-06	1.7	100	4.38E-06	7.9	100	4.19E-06	5.7	100
15	4.01E-06	1.4	100	3.53E-06	1.7	100	3.93E-06	7.9	100	3.77E-06	5.7	100
16	7.46E-07	1.4	100	6.23E-07	1.7	100	7.90E-07	7.9	100	6.37E-07	5.7	100
17	2.04E-06	1.4	100	1.79E-06	1.7	100	2.20E-06	7.9	100	2.10E-06	5.7	100
18	1.01E-06	1.4	100	8.63E-07	1.7	100	1.08E-06	7.9	100	9.08E-07	5.7	100
19	2.62E-06	1.4	100	2.28E-06	1.7	100	2.61E-06	7.9	100	2.48E-06	5.7	100
20	4.26E-06	1.4	100	3.73E-06	1.7	100	4.21E-06	7.9	100	4.12E-06	5.7	100
21	4.30E-06	1.4	100	3.83E-06	1.7	100	*3 4.39E-06	8.4	100	4.34E-06	5.7	100
22	4.35E-06	1.4	100	3.95E-06	1.7	100	4.54E-06	8.7	100	4.69E-06	5.7	100
23	2.85E-06	1.4	100	2.52E-06	1.7	100	2.76E-06	8.7	100	2.73E-06	5.7	100
24	3.31E-06	1.4	100	2.90E-06	1.7	100	3.09E-06	8.7	100	*1 3.29E-06	5.5	100
25	1.57E-06	1.4	100	1.36E-06	1.7	100	1.55E-06	8.7	100	1.65E-06	5.3	100
26	2.02E-06	1.4	100	1.79E-06	1.7	100	2.18E-06	8.7	100	2.39E-06	5.3	100
27	3.15E-06	1.4	100	2.71E-06	1.7	100	2.77E-06	8.7	100	2.98E-06	5.3	100
28	2.99E-06	1.4	100	2.67E-06	1.7	100	2.97E-06	8.7	100	3.23E-06	5.3	100
29	2.67E-06	1.4	100	2.40E-06	1.7	100	2.84E-06	8.7	100	3.03E-06	5.3	100
30	1.69E-06	1.4	100	1.47E-06	1.7	100	1.65E-06	8.7	100	1.79E-06	5.3	100
31												
1ヶ月値	3.29E-06	1.4	100	3.04E-06	1.7	100	3.27E-06	8.2	100	3.23E-06	5.6	100
最大値	1.69E-05	1.4	102	1.67E-05	1.7	102	1.78E-05	8.7	102	1.80E-05	5.7	102
最大値日時	09/12 00:18	09/01 00:01	09/29 06:41	09/11 23:56	09/13 10:24	09/03 00:28	09/12 01:06	09/21 10:08	09/05 14:05	09/11 23:56	09/01 00:01	09/01 01:06
最小値	2.33E-07	1.4	98	0.00E+00	1.6	98	0.00E+00	7.9	98	0.00E+00	5.3	97
最小値日時	09/18 11:15	09/01 00:01	09/06 21:07	09/13 10:24	09/01 00:01	09/08 10:35	09/05 20:33	09/01 00:01	09/01 22:15	09/07 14:59	09/24 10:30	09/19 23:29

\*3: 年次点検 \*1: ろ紙交換

# 測定月報

測定日：2021/09

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.63E-06	5.4	100	6.67E-06	7.5	100	6.71E-06	8.6	100	6.31E-06	3.6	100
2	2.78E-06	5.4	100	2.95E-06	7.5	100	2.69E-06	8.6	100	2.61E-06	3.6	100
3	2.09E-06	5.4	100	2.23E-06	7.5	100	1.98E-06	8.6	100	1.96E-06	3.6	100
4	1.04E-06	5.4	100	1.19E-06	7.5	100	9.84E-07	8.6	100	1.00E-06	3.6	100
5	1.25E-06	5.4	100	1.39E-06	7.5	100	1.16E-06	8.6	100	1.16E-06	3.6	100
6	1.25E-06	5.4	100	1.38E-06	7.5	100	1.11E-06	8.6	100	1.13E-06	3.6	100
7	1.32E-06	5.4	100	1.46E-06	7.5	100	1.24E-06	8.6	100	1.22E-06	3.6	100
8	2.27E-06	5.4	100	2.38E-06	7.5	100	2.18E-06	8.6	100	2.13E-06	3.6	100
9	3.84E-06	5.4	100	3.98E-06	7.5	100	3.78E-06	8.6	100	3.64E-06	3.6	100
10	6.07E-06	5.4	100	6.14E-06	7.5	100	6.04E-06	8.6	100	5.87E-06	3.6	100
11	6.54E-06	5.4	100	6.60E-06	7.5	100	6.63E-06	8.6	100	6.31E-06	3.6	100
12	8.34E-06	5.4	100	8.31E-06	7.5	100	8.30E-06	8.6	100	7.82E-06	3.6	100
13	4.39E-06	5.4	100	4.40E-06	7.5	100	4.33E-06	8.6	100	4.14E-06	3.6	100
14	4.25E-06	5.4	100	4.34E-06	7.5	100	4.29E-06	8.6	100	*1 4.09E-06	3.7	100
15	3.71E-06	5.4	100	3.85E-06	7.5	100	3.77E-06	8.6	100	3.57E-06	3.7	100
16	7.74E-07	5.4	100	9.73E-07	7.5	100	7.39E-07	8.6	100	6.57E-07	3.7	100
17	2.04E-06	5.4	100	2.22E-06	7.5	100	2.00E-06	8.6	100	1.88E-06	3.7	100
18	9.43E-07	5.4	100	1.14E-06	7.5	100	8.92E-07	8.6	100	8.34E-07	3.7	100
19	2.56E-06	5.4	100	2.73E-06	7.5	100	2.49E-06	8.6	100	2.33E-06	3.7	100
20	4.13E-06	5.4	100	4.26E-06	7.5	100	4.05E-06	8.6	100	3.84E-06	3.7	100
21	4.10E-06	5.4	100	4.32E-06	7.5	100	4.11E-06	8.6	100	3.85E-06	3.7	100
22	4.46E-06	5.4	100	4.67E-06	7.5	100	*1 4.63E-06	8.7	100	4.37E-06	3.7	100
23	2.74E-06	5.4	100	2.94E-06	7.5	100	2.75E-06	8.7	100	2.57E-06	3.7	100
24	*1 3.27E-06	5.4	100	*1 3.28E-06	7.8	100	3.11E-06	8.7	100	2.87E-06	3.7	100
25	1.60E-06	5.4	100	1.53E-06	8.0	100	1.44E-06	8.7	100	1.35E-06	3.7	100
26	2.55E-06	5.4	100	2.48E-06	8.0	100	2.58E-06	8.7	100	2.42E-06	3.7	100
27	2.85E-06	5.4	100	2.85E-06	8.0	100	2.71E-06	8.7	100	2.57E-06	3.7	100
28	*3 2.94E-06	6.0	100	2.88E-06	8.0	100	2.90E-06	8.7	100	2.77E-06	3.7	100
29	2.69E-06	6.4	100	2.57E-06	8.0	100	2.87E-06	8.7	100	2.71E-06	3.7	100
30	1.44E-06	6.4	100	1.30E-06	8.0	100	1.54E-06	8.7	100	1.47E-06	3.7	100
31												
1ヶ月値	3.16E-06	5.5	100	3.25E-06	7.6	100	3.13E-06	8.6	100	2.98E-06	3.7	100
最大値	1.72E-05	6.4	103	1.75E-05	8.0	102	1.77E-05	8.7	102	1.60E-05	3.7	115
最大値日時	09/12 00:00	09/28 10:13	09/02 08:05	09/12 00:04	09/24 10:08	09/01 08:43	09/12 00:26	09/22 09:50	09/01 22:37	09/11 23:58	09/14 10:29	09/14 10:29
最小値	0.00E+00	5.4	96	0.00E+00	7.5	98	0.00E+00	8.6	98	0.00E+00	3.6	98
最小値日時	09/18 11:56	09/01 00:01	09/04 05:46	09/07 16:01	09/01 00:01	09/01 02:20	09/05 16:18	09/01 00:01	09/01 06:41	09/14 10:30	09/01 00:01	09/01 10:39

\*1: ろ紙交換 \*3: 年次点検

# 測定月報

測定日：2021/09

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	7.17E-06	1.4	100	6.84E-06	3.2	100	6.38E-06	1.9	100	6.69E-06	2.4	100
2	3.02E-06	1.4	100	2.74E-06	3.2	100	2.58E-06	1.9	100	2.74E-06	2.4	100
3	2.20E-06	1.4	100	1.95E-06	3.2	100	1.91E-06	1.9	100	2.00E-06	2.4	100
4	1.15E-06	1.4	100	9.40E-07	3.2	100	9.39E-07	1.9	100	1.01E-06	2.4	100
5	1.33E-06	1.4	100	1.09E-06	3.2	100	1.08E-06	1.9	100	1.17E-06	2.4	100
6	1.29E-06	1.4	100	1.10E-06	3.2	100	1.10E-06	1.9	100	1.19E-06	2.4	100
7	1.34E-06	1.4	100	1.11E-06	3.2	100	1.21E-06	1.9	100	1.30E-06	2.4	100
8	*1 2.36E-06	1.3	100	2.05E-06	3.2	100	2.26E-06	1.9	100	2.35E-06	2.4	100
9	4.08E-06	1.3	100	3.79E-06	3.2	100	4.07E-06	1.9	100	4.24E-06	2.4	100
10	6.63E-06	1.3	100	6.30E-06	3.2	100	5.99E-06	1.9	100	6.26E-06	2.4	100
11	7.22E-06	1.3	100	7.02E-06	3.2	100	6.55E-06	1.9	100	6.94E-06	2.4	100
12	8.97E-06	1.3	100	8.55E-06	3.2	100	7.72E-06	1.9	100	8.16E-06	2.4	100
13	4.65E-06	1.3	100	4.38E-06	3.2	100	3.91E-06	1.9	100	4.14E-06	2.4	100
14	4.51E-06	1.3	100	*1 4.37E-06	2.9	100	*1 4.16E-06	1.8	100	*1 4.33E-06	2.3	100
15	4.07E-06	1.3	100	3.93E-06	2.7	100	3.80E-06	1.7	100	3.93E-06	2.2	100
16	8.03E-07	1.3	100	8.05E-07	2.7	100	9.55E-07	1.7	100	1.02E-06	2.2	100
17	2.17E-06	1.3	100	2.07E-06	2.7	100	2.17E-06	1.7	100	2.28E-06	2.2	100
18	1.03E-06	1.3	100	9.97E-07	2.7	100	9.34E-07	1.7	100	1.01E-06	2.2	100
19	2.66E-06	1.3	100	2.55E-06	2.7	100	2.41E-06	1.7	100	2.51E-06	2.2	100
20	4.38E-06	1.3	100	4.13E-06	2.7	100	3.93E-06	1.7	100	4.06E-06	2.2	100
21	4.51E-06	1.3	100	4.25E-06	2.7	100	4.20E-06	1.7	100	4.32E-06	2.2	100
22	5.13E-06	1.3	100	4.75E-06	2.7	100	5.16E-06	1.7	100	5.38E-06	2.2	100
23	3.16E-06	1.3	100	2.95E-06	2.7	100	2.86E-06	1.7	100	2.97E-06	2.2	100
24	3.41E-06	1.3	100	3.23E-06	2.7	100	3.08E-06	1.7	100	3.16E-06	2.2	100
25	1.68E-06	1.3	100	1.65E-06	2.7	100	1.59E-06	1.7	100	1.64E-06	2.2	100
26	2.60E-06	1.3	100	2.46E-06	2.7	100	3.17E-06	1.7	100	3.33E-06	2.2	100
27	3.03E-06	1.3	100	2.90E-06	2.7	100	2.74E-06	1.7	100	2.82E-06	2.2	100
28	3.11E-06	1.3	100	3.00E-06	2.7	100	2.91E-06	1.7	100	3.02E-06	2.2	100
29	3.01E-06	1.3	100	2.91E-06	2.7	100	2.92E-06	1.7	100	3.06E-06	2.2	100
30	1.73E-06	1.3	100	1.68E-06	2.7	100	1.75E-06	1.7	100	1.81E-06	2.2	100
31												
1ヶ月値	3.42E-06	1.3	100	3.22E-06	2.9	100	3.15E-06	1.8	100	3.29E-06	2.3	100
最大値	1.92E-05	1.4	102	1.84E-05	3.2	102	1.59E-05	1.9	102	1.65E-05	2.4	103
最大値日時	09/12 00:03	09/01 00:01	09/02 02:16	09/12 00:10	09/01 00:01	09/01 14:16	09/10 00:12	09/01 00:01	09/01 18:45	09/12 00:56	09/01 00:01	09/04 09:28
最小値	0.00E+00	1.3	98	0.00E+00	2.7	98	0.00E+00	1.7	97	1.06E-07	2.2	97
最小値日時	09/08 11:44	09/08 11:44	09/01 03:45	09/07 15:13	09/14 10:03	09/01 05:35	09/14 10:20	09/14 10:20	09/25 06:49	09/07 18:38	09/14 09:47	09/01 18:17

\*1:ろ紙交換

# 測定月報

測定日：2021/09

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シールド中央制御室			A020 シールド中央制御室		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	7.27E-06	5.3	100	7.03E-06	4.8	100	6.10E-06	2.0	100	7.26E-06	2.5	100
2	2.96E-06	5.3	100	2.97E-06	4.8	100	2.51E-06	2.0	100	3.05E-06	2.5	100
3	2.16E-06	5.3	100	2.21E-06	4.8	100	1.84E-06	2.0	100	2.25E-06	2.5	100
4	1.08E-06	5.3	100	1.19E-06	4.8	100	9.09E-07	2.0	100	1.18E-06	2.5	100
5	1.23E-06	5.3	100	1.33E-06	4.8	100	1.10E-06	2.0	100	1.40E-06	2.5	100
6	1.24E-06	5.3	100	1.35E-06	4.8	100	1.05E-06	2.0	100	1.36E-06	2.5	100
7	1.33E-06	5.3	100	1.44E-06	4.8	100	1.10E-06	2.0	100	1.38E-06	2.5	100
8	2.52E-06	5.3	100	2.56E-06	4.8	100	1.90E-06	2.0	100	*1 2.29E-06	2.6	100
9	4.13E-06	5.3	100	4.12E-06	4.8	100	3.52E-06	2.0	100	3.97E-06	2.7	100
10	6.50E-06	5.3	100	6.44E-06	4.8	100	5.57E-06	2.0	100	6.49E-06	2.7	100
11	7.09E-06	5.3	100	6.95E-06	4.8	100	6.18E-06	2.0	100	7.02E-06	2.7	100
12	9.02E-06	5.3	100	8.80E-06	4.8	100	7.62E-06	2.0	100	8.68E-06	2.7	100
13	4.61E-06	5.3	100	4.58E-06	4.8	100	3.84E-06	2.0	100	4.39E-06	2.7	100
14	4.48E-06	5.3	100	4.53E-06	4.8	100	3.83E-06	2.0	100	4.38E-06	2.7	100
15	3.97E-06	5.3	100	3.99E-06	4.8	100	3.49E-06	2.0	100	4.07E-06	2.7	100
16	7.55E-07	5.3	100	8.78E-07	4.8	100	6.35E-07	2.0	100	7.10E-07	2.7	100
17	2.27E-06	5.3	100	2.37E-06	4.8	100	1.76E-06	2.0	100	2.00E-06	2.7	100
18	9.74E-07	5.3	100	1.09E-06	4.8	100	7.75E-07	2.0	100	8.83E-07	2.7	100
19	2.60E-06	5.3	100	2.69E-06	4.8	100	2.20E-06	2.0	100	2.48E-06	2.7	100
20	4.39E-06	5.3	100	4.48E-06	4.8	100	3.67E-06	2.0	100	4.20E-06	2.7	100
21	4.62E-06	5.3	100	4.68E-06	4.8	100	3.80E-06	2.0	100	4.32E-06	2.7	100
22	5.11E-06	5.3	100	*1 5.17E-06	4.7	100	4.39E-06	2.0	100	5.04E-06	2.7	100
23	2.87E-06	5.3	100	3.01E-06	4.7	100	2.59E-06	2.0	100	2.96E-06	2.7	100
24	*1 3.38E-06	5.2	100	3.38E-06	4.7	100	*1 2.93E-06	1.9	100	3.24E-06	2.7	100
25	1.69E-06	5.2	100	1.77E-06	4.7	100	1.43E-06	1.9	100	1.55E-06	2.7	100
26	2.86E-06	5.2	100	2.87E-06	4.7	100	2.47E-06	1.9	100	2.73E-06	2.7	100
27	3.09E-06	5.2	100	3.05E-06	4.7	100	2.69E-06	1.9	100	2.96E-06	2.7	100
28	3.35E-06	5.2	100	3.33E-06	4.7	100	2.71E-06	1.9	100	3.06E-06	2.7	100
29	3.36E-06	5.2	100	3.36E-06	4.7	100	2.63E-06	1.9	100	2.91E-06	2.7	100
30	1.81E-06	5.2	100	1.86E-06	4.7	100	1.46E-06	1.9	100	1.61E-06	2.7	100
31												
1ヶ月値	3.42E-06	5.3	100	3.45E-06	4.8	100	2.89E-06	2.0	100	3.33E-06	2.7	100
最大値	1.83E-05	5.3	102	4.66E-05	4.8	105	1.61E-05	2.0	103	1.79E-05	2.7	107
最大値日時	09/11 23:50	09/01 00:01	09/01 00:56	09/22 10:13	09/01 00:01	09/22 10:13	09/12 00:13	09/01 00:01	09/04 13:29	09/12 00:17	09/08 11:34	09/08 11:34
最小値	0.00E+00	5.2	98	0.00E+00	4.7	98	0.00E+00	1.9	97	0.00E+00	2.5	98
最小値日時	09/07 16:38	09/24 10:51	09/07 11:34	09/22 10:16	09/22 10:13	09/16 23:03	09/24 10:00	09/24 10:00	09/01 17:49	09/08 11:34	09/01 00:01	09/27 05:47

\*1:ろ紙交換

# 測定月報

測定日：2021/09

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	7.19E-06	1.9	100	7.63E-06	2.6	100	6.90E-06	13.6	100	7.11E-06	15.4	100
2	2.92E-06	1.9	100	3.09E-06	2.6	100	2.97E-06	13.6	100	2.89E-06	15.4	100
3	2.16E-06	1.9	100	2.26E-06	2.6	100	2.22E-06	13.6	100	2.17E-06	15.4	100
4	1.08E-06	1.9	100	1.13E-06	2.6	100	1.13E-06	13.6	100	9.57E-07	15.4	100
5	1.29E-06	1.9	100	1.36E-06	2.6	100	1.34E-06	13.6	100	1.21E-06	15.4	100
6	1.26E-06	1.9	100	1.34E-06	2.6	100	1.31E-06	13.6	100	1.14E-06	15.4	100
7	1.38E-06	1.9	100	1.44E-06	2.6	100	1.46E-06	13.6	100	1.29E-06	15.4	100
8	*1 2.43E-06	2.0	100	2.58E-06	2.6	100	*1 2.46E-06	13.8	100	2.44E-06	15.4	100
9	3.97E-06	2.0	100	4.48E-06	2.6	100	3.92E-06	13.9	100	4.10E-06	15.4	100
10	6.25E-06	2.0	100	7.03E-06	2.6	100	6.21E-06	13.9	100	6.60E-06	15.4	100
11	6.92E-06	2.0	100	7.77E-06	2.6	100	6.74E-06	13.9	100	7.07E-06	15.4	100
12	8.37E-06	2.0	100	9.32E-06	2.6	100	8.69E-06	13.9	100	9.05E-06	15.4	100
13	4.30E-06	2.0	100	4.77E-06	2.6	100	4.51E-06	13.9	100	4.84E-06	15.4	100
14	4.35E-06	2.0	100	4.86E-06	2.6	100	4.42E-06	13.9	100	4.67E-06	15.4	100
15	3.92E-06	2.0	100	4.39E-06	2.6	100	3.85E-06	13.9	100	4.06E-06	15.4	100
16	8.24E-07	2.0	100	9.30E-07	2.6	100	7.43E-07	13.9	100	7.55E-07	15.4	100
17	2.13E-06	2.0	100	2.37E-06	2.6	100	2.12E-06	13.9	100	2.21E-06	15.4	100
18	9.00E-07	2.0	100	1.01E-06	2.6	100	9.93E-07	13.9	100	9.99E-07	15.4	100
19	2.46E-06	2.0	100	2.75E-06	2.6	100	2.55E-06	13.9	100	2.74E-06	15.4	100
20	4.09E-06	2.0	100	4.57E-06	2.6	100	4.30E-06	13.9	100	4.61E-06	15.4	100
21	4.28E-06	2.0	100	4.73E-06	2.6	100	4.33E-06	13.9	100	4.60E-06	15.4	100
22	4.92E-06	2.0	100	5.51E-06	2.6	100	4.67E-06	13.9	100	5.12E-06	15.4	100
23	2.85E-06	2.0	100	3.17E-06	2.6	100	2.76E-06	13.9	100	3.00E-06	15.4	100
24	3.17E-06	2.0	100	*1 3.64E-06	2.5	100	3.03E-06	13.9	100	*1 3.47E-06	15.4	100
25	1.54E-06	2.0	100	1.80E-06	2.5	100	1.28E-06	13.9	100	1.65E-06	15.4	100
26	3.03E-06	2.0	100	3.47E-06	2.5	100	2.51E-06	13.9	100	2.89E-06	15.4	100
27	2.90E-06	2.0	100	3.33E-06	2.5	100	2.64E-06	13.9	100	3.06E-06	15.4	100
28	*3 2.99E-06	2.1	100	3.48E-06	2.5	100	2.89E-06	13.9	100	3.37E-06	15.4	100
29	3.01E-06	2.1	100	3.54E-06	2.5	100	2.77E-06	13.9	100	3.30E-06	15.4	100
30	1.69E-06	2.1	100	2.02E-06	2.5	100	1.42E-06	13.9	100	1.81E-06	15.4	100
31												
1ヶ月値	3.29E-06	2.0	100	3.66E-06	2.6	100	3.24E-06	13.8	100	3.44E-06	15.4	100
最大値	1.66E-05	2.1	102	2.11E-05	2.6	102	1.86E-05	13.9	101	1.90E-05	15.4	101
最大値日時	09/12 00:55	09/28 10:33	09/02 04:20	09/24 09:53	09/01 00:01	09/04 23:30	09/08 10:24	09/08 10:24	09/01 00:06	09/12 01:03	09/01 00:01	09/01 00:02
最小値	0.00E+00	1.9	98	0.00E+00	2.5	98	0.00E+00	13.6	99	0.00E+00	15.4	98
最小値日時	09/08 11:26	09/01 00:01	09/01 19:41	09/24 09:54	09/24 09:53	09/02 07:34	09/05 21:35	09/01 00:01	09/01 00:22	09/03 22:44	09/01 00:01	09/24 05:05

\*1:ろ紙交換 \*3:年次点検

# 測定月報

測定日：2021/09

(7/8)

日	モニタ											
	A027 1号機海側2、5m盤			A028 1号機海側2、5m盤			A029 3号機海側2、5m盤			A030 3号機海側2、5m盤		
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	6.78E-06	3.9	100	6.65E-06	4.7	100	6.39E-06	2.6	100	6.50E-06	2.2	100
2	2.91E-06	3.9	100	2.80E-06	4.7	100	2.74E-06	2.6	100	2.78E-06	2.2	100
3	2.14E-06	3.9	100	2.06E-06	4.7	100	1.97E-06	2.6	100	2.03E-06	2.2	100
4	1.05E-06	3.9	100	9.98E-07	4.7	100	1.00E-06	2.6	100	1.05E-06	2.2	100
5	1.21E-06	3.9	100	1.15E-06	4.7	100	1.16E-06	2.6	100	1.20E-06	2.2	100
6	1.22E-06	3.9	100	1.16E-06	4.7	100	1.18E-06	2.6	100	1.23E-06	2.2	100
7	1.28E-06	3.9	100	1.24E-06	4.7	100	1.26E-06	2.6	100	*3 1.29E-06	2.8	100
8	*1 2.27E-06	4.0	100	2.22E-06	4.7	100	2.18E-06	2.6	100	2.22E-06	3.3	100
9	3.89E-06	4.0	100	3.81E-06	4.7	100	3.65E-06	2.6	100	3.59E-06	3.3	100
10	6.42E-06	4.0	100	6.14E-06	4.7	100	5.89E-06	2.6	100	5.78E-06	3.3	100
11	6.77E-06	4.0	100	6.51E-06	4.7	100	6.20E-06	2.6	100	6.10E-06	3.3	100
12	8.87E-06	4.0	100	8.59E-06	4.7	100	8.25E-06	2.6	100	8.16E-06	3.3	100
13	4.59E-06	4.0	100	4.50E-06	4.7	100	4.33E-06	2.6	100	4.29E-06	3.3	100
14	4.39E-06	4.0	100	4.23E-06	4.7	100	*1 4.09E-06	2.7	100	4.11E-06	3.3	100
15	3.82E-06	4.0	100	3.69E-06	4.7	100	3.46E-06	2.7	100	3.62E-06	3.3	100
16	6.29E-07	4.0	100	6.35E-07	4.7	100	5.61E-07	2.7	100	6.30E-07	3.3	100
17	2.02E-06	4.0	100	1.99E-06	4.7	100	1.81E-06	2.7	100	1.89E-06	3.3	100
18	8.92E-07	4.0	100	9.09E-07	4.7	100	7.85E-07	2.7	100	8.27E-07	3.3	100
19	2.60E-06	4.0	100	2.58E-06	4.7	100	2.40E-06	2.7	100	2.44E-06	3.3	100
20	4.25E-06	4.0	100	4.21E-06	4.7	100	3.93E-06	2.7	100	3.93E-06	3.3	100
21	4.25E-06	4.0	100	4.19E-06	4.7	100	3.95E-06	2.7	100	3.89E-06	3.3	100
22	4.32E-06	4.0	100	*1 4.53E-06	4.6	100	4.00E-06	2.7	100	4.01E-06	3.3	100
23	2.69E-06	4.0	100	2.96E-06	4.5	100	2.58E-06	2.7	100	2.57E-06	3.3	100
24	3.10E-06	4.0	100	3.37E-06	4.5	100	2.85E-06	2.7	100	2.95E-06	3.3	100
25	1.31E-06	4.0	100	1.57E-06	4.5	100	1.36E-06	2.7	100	1.40E-06	3.3	100
26	1.71E-06	4.0	100	1.98E-06	4.5	100	1.66E-06	2.7	100	1.70E-06	3.3	100
27	2.73E-06	4.0	100	2.94E-06	4.5	100	2.57E-06	2.7	100	2.62E-06	3.3	100
28	2.90E-06	4.0	100	3.19E-06	4.5	100	2.80E-06	2.7	100	2.84E-06	3.3	100
29	2.73E-06	4.0	100	3.03E-06	4.5	100	2.71E-06	2.7	100	2.73E-06	3.3	100
30	1.42E-06	4.0	100	1.69E-06	4.5	100	1.36E-06	2.7	100	1.40E-06	3.3	100
31												
1ヶ月値	3.17E-06	4.0	100	3.18E-06	4.6	100	2.97E-06	2.7	100	2.99E-06	3.1	100
最大値	1.90E-05	4.0	101	1.78E-05	4.7	102	1.64E-05	2.7	102	1.56E-05	3.3	101
最大値日時	09/12 00:18	09/08 10:13	09/01 00:02	09/12 00:40	09/01 00:01	09/05 05:14	09/12 01:06	09/14 10:16	09/02 14:02	09/12 00:16	09/07 11:08	09/01 00:18
最小値	0.00E+00	3.9	98	0.00E+00	4.5	98	0.00E+00	2.6	98	0.00E+00	2.2	98
最小値日時	09/07 15:09	09/01 00:01	09/09 07:23	09/07 15:17	09/22 10:19	09/01 11:19	09/14 10:16	09/01 00:01	09/01 06:00	09/05 15:46	09/01 00:01	09/13 01:58

\*3: 年次点検 \*1: ろ紙交換



# 測定月報

測定日：2021/09

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm <sup>3</sup> )	計数率 (cps)	流量 (L/min)
1	7.27E-06	10.0	100	7.18E-06	6.3	100						
2	3.00E-06	10.0	100	3.00E-06	6.3	100						
3	2.20E-06	10.0	100	2.27E-06	6.3	100						
4	1.03E-06	10.0	100	9.95E-07	6.3	100						
5	1.28E-06	10.0	100	1.29E-06	6.3	100						
6	1.17E-06	10.0	100	1.16E-06	6.3	100						
7	1.36E-06	10.0	100	1.39E-06	6.3	100						
8	2.31E-06	10.0	100	2.33E-06	6.3	100						
9	4.19E-06	10.0	100	4.18E-06	6.3	100						
10	6.93E-06	10.0	100	7.08E-06	6.3	100						
11	7.30E-06	10.0	100	7.42E-06	6.3	100						
12	9.27E-06	10.0	100	9.42E-06	6.3	100						
13	4.92E-06	10.0	100	4.97E-06	6.3	100						
14	4.81E-06	10.0	100	4.67E-06	6.3	100						
15	4.23E-06	10.0	100	4.18E-06	6.3	100						
16	8.12E-07	10.0	100	7.81E-07	6.3	100						
17	2.21E-06	10.0	100	2.16E-06	6.3	100						
18	9.35E-07	10.0	100	8.56E-07	6.3	100						
19	2.71E-06	10.0	100	2.73E-06	6.3	100						
20	4.55E-06	10.0	100	4.47E-06	6.3	100						
21	*3 4.42E-06	9.5	100	4.59E-06	6.3	100						
22	4.16E-06	9.2	100	*1 5.20E-06	6.2	100						
23	2.48E-06	9.2	100	3.32E-06	6.1	100						
24	2.80E-06	9.2	100	3.67E-06	6.1	100						
25	1.25E-06	9.2	100	1.74E-06	6.1	100						
26	2.17E-06	9.2	100	2.89E-06	6.1	100						
27	2.47E-06	9.2	100	3.24E-06	6.1	100						
28	2.60E-06	9.2	100	3.46E-06	6.1	100						
29	2.56E-06	9.2	100	3.31E-06	6.1	100						
30	1.36E-06	9.2	100	1.87E-06	6.1	100						
31												
1ヶ月値	3.29E-06	9.7	100	3.53E-06	6.2	100						
最大値	1.50E-04	10.0	103	2.07E-05	6.3	102						
最大値日時	09/21 10:22	09/01 00:01	09/25 08:17	09/12 00:38	09/01 00:01	09/02 08:41						
最小値	0.00E+00	9.2	97	0.00E+00	6.1	98						
最小値日時	09/05 13:14	09/21 10:22	09/23 04:25	09/07 18:17	09/22 09:58	09/02 13:37						

\*3: 年次点検 \*1: ろ紙交換