

構内連続ダストモニタ測定記録(2021 年 11 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

測定日：2021/11

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	7.02E-06	0.8	100	7.12E-06	1.3	100	6.89E-06	5.7	100	6.54E-06	5.4	100
2	6.11E-06	0.8	100	6.28E-06	1.3	100	6.14E-06	5.7	100	*1 5.77E-06	5.5	100
3	3.44E-06	0.8	100	3.53E-06	1.3	100	3.68E-06	5.7	100	3.43E-06	5.5	100
4	2.75E-06	0.8	100	2.85E-06	1.3	100	3.04E-06	5.7	100	2.84E-06	5.5	100
5	3.75E-06	0.8	100	3.83E-06	1.3	100	3.76E-06	5.7	100	3.45E-06	5.5	100
6	3.47E-06	0.8	100	3.58E-06	1.3	100	3.56E-06	5.7	100	3.27E-06	5.5	100
7	3.39E-06	0.8	100	3.48E-06	1.3	100	3.37E-06	5.7	100	3.14E-06	5.5	100
8	3.27E-06	0.8	100	3.33E-06	1.3	100	3.18E-06	5.7	100	2.95E-06	5.5	100
9	1.85E-06	0.8	100	1.90E-06	1.3	100	*1 1.72E-06	5.8	100	1.54E-06	5.5	100
10	2.32E-06	0.8	100	*1 2.41E-06	1.3	100	2.48E-06	5.9	100	2.36E-06	5.5	100
11	4.74E-06	0.8	100	4.85E-06	1.3	100	4.98E-06	5.9	100	4.67E-06	5.5	100
12	2.43E-06	0.8	100	2.49E-06	1.3	100	2.58E-06	5.9	100	2.45E-06	5.5	100
13	2.38E-06	0.8	100	2.46E-06	1.3	100	2.51E-06	5.9	100	2.36E-06	5.5	100
14	4.52E-06	0.8	100	4.71E-06	1.3	100	4.71E-06	5.9	100	4.46E-06	5.5	100
15	2.76E-06	0.8	100	2.82E-06	1.3	100	2.90E-06	5.9	100	2.73E-06	5.5	100
16	4.75E-06	0.8	100	4.91E-06	1.3	100	5.18E-06	5.9	100	4.81E-06	5.5	100
17	*1 4.76E-06	0.8	100	4.97E-06	1.3	100	5.06E-06	5.9	100	4.79E-06	5.5	100
18	5.26E-06	0.8	100	5.43E-06	1.3	100	5.38E-06	5.9	100	5.09E-06	5.5	100
19	6.01E-06	0.8	100	6.24E-06	1.3	100	6.12E-06	5.9	100	5.78E-06	5.5	100
20	5.95E-06	0.8	100	6.20E-06	1.3	100	6.30E-06	5.9	100	5.92E-06	5.5	100
21	7.52E-06	0.8	100	7.79E-06	1.3	100	7.77E-06	5.9	100	7.30E-06	5.5	100
22	6.49E-06	0.8	100	6.77E-06	1.3	100	6.66E-06	5.9	100	6.31E-06	5.5	100
23	2.95E-06	0.8	100	3.05E-06	1.3	100	3.20E-06	5.9	100	3.07E-06	5.5	100
24	1.45E-06	0.8	100	1.45E-06	1.3	100	1.53E-06	5.9	100	1.46E-06	5.5	100
25	3.13E-06	0.8	100	3.22E-06	1.3	100	3.22E-06	5.9	100	3.06E-06	5.5	100
26	2.20E-06	0.8	100	2.25E-06	1.3	100	2.39E-06	5.9	100	2.25E-06	5.5	100
27	1.82E-06	0.8	100	1.89E-06	1.3	100	2.12E-06	5.9	100	1.99E-06	5.5	100
28	1.66E-06	0.8	100	1.73E-06	1.3	100	1.82E-06	5.9	100	1.77E-06	5.5	100
29	3.67E-06	0.8	100	3.88E-06	1.3	100	3.69E-06	5.9	100	*1 3.63E-06	5.4	100
30	3.62E-06	0.8	100	3.70E-06	1.3	100	4.01E-06	5.9	100	3.77E-06	5.3	100
31												
1ヶ月値	3.86E-06	0.8	100	3.97E-06	1.3	100	4.00E-06	5.8	100	3.77E-06	5.5	100
最大値	1.60E-05	0.8	102	4.77E-05	1.3	102	1.68E-05	5.9	102	1.60E-05	5.5	102
最大値日時	11/22 05:57	11/01 00:01	11/02 16:32	11/10 10:43	11/01 00:01	11/01 02:37	11/22 04:53	11/09 07:56	11/04 01:44	11/02 09:39	11/02 09:39	11/01 06:18
最小値	0.00E+00	0.8	98	1.12E-07	1.3	97	0.00E+00	5.7	98	0.00E+00	5.3	98
最小値日時	11/29 02:49	11/01 00:01	11/01 03:27	11/09 15:58	11/01 00:01	11/22 16:07	11/09 07:57	11/01 00:01	11/02 04:40	11/02 09:40	11/29 08:17	11/01 03:29

*1:ろ紙交換

測定月報

測定日：2021/11

(2/8)

日	モニタ											
	A005 5/6号警備所前			A006 5/6号警備所前			A007 1号北側法面上(旧厚生棟)			A008 1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.05E-06	1.4	100	6.70E-06	1.5	100	6.55E-06	8.9	100	6.06E-06	6.6	100
2	5.46E-06	1.4	100	6.13E-06	1.5	100	5.84E-06	8.9	100	5.44E-06	6.6	100
3	3.33E-06	1.4	100	3.72E-06	1.5	100	3.46E-06	8.9	100	3.28E-06	6.6	100
4	2.61E-06	1.4	100	2.89E-06	1.5	100	2.77E-06	8.9	100	2.63E-06	6.6	100
5	3.26E-06	1.4	100	3.63E-06	1.5	100	3.44E-06	8.9	100	3.17E-06	6.6	100
6	3.00E-06	1.4	100	3.35E-06	1.5	100	3.26E-06	8.9	100	3.06E-06	6.6	100
7	2.65E-06	1.4	100	2.94E-06	1.5	100	3.03E-06	8.9	100	2.86E-06	6.6	100
8	2.65E-06	1.4	100	2.98E-06	1.5	100	2.86E-06	8.9	100	2.76E-06	6.6	100
9	1.45E-06	1.4	100	*1 1.64E-06	1.6	100	1.66E-06	8.9	100	1.59E-06	6.6	100
10	*1 2.11E-06	1.5	100	2.34E-06	1.6	100	2.40E-06	8.9	100	2.28E-06	6.6	100
11	4.00E-06	1.6	100	4.41E-06	1.6	100	4.71E-06	8.9	100	4.36E-06	6.6	100
12	2.16E-06	1.6	100	2.42E-06	1.6	100	2.51E-06	8.9	100	2.39E-06	6.6	100
13	2.04E-06	1.6	100	2.29E-06	1.6	100	2.42E-06	8.9	100	2.28E-06	6.6	100
14	3.80E-06	1.6	100	4.28E-06	1.6	100	4.60E-06	8.9	100	4.25E-06	6.6	100
15	2.35E-06	1.6	100	2.73E-06	1.6	100	2.69E-06	8.9	100	2.62E-06	6.6	100
16	4.24E-06	1.6	100	4.75E-06	1.6	100	*1 4.79E-06	9.0	100	4.41E-06	6.6	100
17	4.13E-06	1.6	100	4.67E-06	1.6	100	4.89E-06	9.1	100	*1 4.50E-06	6.7	100
18	4.33E-06	1.6	100	4.81E-06	1.6	100	5.17E-06	9.1	100	4.61E-06	6.8	100
19	5.02E-06	1.6	100	5.56E-06	1.6	100	5.84E-06	9.1	100	5.20E-06	6.8	100
20	5.01E-06	1.6	100	5.53E-06	1.6	100	5.80E-06	9.1	100	5.24E-06	6.8	100
21	6.32E-06	1.6	100	6.97E-06	1.6	100	7.35E-06	9.1	100	6.51E-06	6.8	100
22	5.59E-06	1.6	100	6.09E-06	1.6	100	6.06E-06	9.1	100	5.61E-06	6.8	100
23	2.75E-06	1.6	100	3.14E-06	1.6	100	3.00E-06	9.1	100	2.75E-06	6.8	100
24	1.21E-06	1.6	100	1.42E-06	1.6	100	1.43E-06	9.1	100	1.35E-06	6.8	100
25	2.50E-06	1.6	100	2.82E-06	1.6	100	2.99E-06	9.1	100	2.78E-06	6.8	100
26	1.94E-06	1.6	100	2.24E-06	1.6	100	2.17E-06	9.1	100	1.99E-06	6.8	100
27	1.73E-06	1.6	100	1.99E-06	1.6	100	1.96E-06	9.1	100	1.83E-06	6.8	100
28	1.43E-06	1.6	100	1.67E-06	1.6	100	1.69E-06	9.1	100	1.59E-06	6.8	100
29	2.77E-06	1.6	100	3.09E-06	1.6	100	3.49E-06	9.1	100	3.24E-06	6.8	100
30	3.14E-06	1.6	100	3.55E-06	1.6	100	3.80E-06	9.1	100	3.39E-06	6.8	100
31												
1ヶ月値	3.30E-06	1.5	100	3.69E-06	1.6	100	3.75E-06	9.0	100	3.47E-06	6.7	100
最大値	1.36E-05	1.6	102	1.44E-05	1.6	102	1.94E-05	9.1	101	1.40E-05	6.8	102
最大値日時	11/22 04:45	11/10 10:19	11/01 03:46	11/09 11:00	11/09 11:00	11/07 03:49	11/16 10:43	11/16 10:43	11/01 00:23	11/22 04:58	11/17 10:09	11/01 09:45
最小値	0.00E+00	1.4	98	0.00E+00	1.5	98	0.00E+00	8.9	98	0.00E+00	6.6	97
最小値日時	11/10 10:19	11/01 00:01	11/01 04:58	11/09 11:05	11/01 00:01	11/08 04:28	11/09 09:59	11/01 00:01	11/13 09:02	11/09 14:22	11/01 00:01	11/15 17:54

*1:ろ紙交換

測定月報

測定日：2021/11

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.71E-06	6.2	100	7.13E-06	7.4	100	6.73E-06	8.6	100	6.79E-06	3.5	100
2	6.00E-06	6.2	100	6.33E-06	7.4	100	6.10E-06	8.6	100	5.90E-06	3.5	100
3	3.54E-06	6.2	100	3.75E-06	7.4	100	3.51E-06	8.6	100	3.50E-06	3.5	100
4	2.94E-06	6.2	100	3.08E-06	7.4	100	2.83E-06	8.6	100	2.80E-06	3.5	100
5	3.60E-06	6.2	100	3.73E-06	7.4	100	3.58E-06	8.6	100	3.62E-06	3.5	100
6	3.42E-06	6.2	100	3.61E-06	7.4	100	3.36E-06	8.6	100	3.38E-06	3.5	100
7	3.36E-06	6.2	100	3.47E-06	7.4	100	3.27E-06	8.6	100	3.32E-06	3.5	100
8	3.05E-06	6.2	100	3.20E-06	7.4	100	2.99E-06	8.6	100	3.04E-06	3.5	100
9	1.68E-06	6.2	100	1.76E-06	7.4	100	1.64E-06	8.6	100	*1 1.67E-06	3.5	100
10	2.51E-06	6.2	100	2.65E-06	7.4	100	2.34E-06	8.6	100	2.34E-06	3.5	100
11	4.83E-06	6.2	100	5.03E-06	7.4	100	4.72E-06	8.6	100	4.72E-06	3.5	100
12	2.62E-06	6.2	100	2.69E-06	7.4	100	2.43E-06	8.6	100	2.41E-06	3.5	100
13	2.51E-06	6.2	100	2.61E-06	7.4	100	2.34E-06	8.6	100	2.35E-06	3.5	100
14	4.66E-06	6.2	100	4.87E-06	7.4	100	4.57E-06	8.6	100	4.50E-06	3.5	100
15	2.84E-06	6.2	100	2.96E-06	7.4	100	2.67E-06	8.6	100	2.68E-06	3.5	100
16	4.95E-06	6.2	100	5.18E-06	7.4	100	*1 4.90E-06	8.5	100	4.81E-06	3.5	100
17	4.97E-06	6.2	100	*1 5.11E-06	7.6	100	4.86E-06	8.4	100	4.69E-06	3.5	100
18	5.09E-06	6.2	100	5.03E-06	7.7	100	5.19E-06	8.4	100	5.05E-06	3.5	100
19	5.84E-06	6.2	100	5.89E-06	7.7	100	5.97E-06	8.4	100	5.83E-06	3.5	100
20	6.04E-06	6.2	100	6.10E-06	7.7	100	6.19E-06	8.4	100	5.78E-06	3.5	100
21	7.32E-06	6.2	100	7.48E-06	7.7	100	7.44E-06	8.4	100	7.06E-06	3.5	100
22	6.13E-06	6.2	100	6.31E-06	7.7	100	6.26E-06	8.4	100	5.80E-06	3.5	100
23	3.21E-06	6.2	100	3.18E-06	7.7	100	3.14E-06	8.4	100	2.73E-06	3.5	100
24	*1 1.56E-06	6.4	100	1.49E-06	7.7	100	1.53E-06	8.4	100	1.13E-06	3.5	100
25	3.03E-06	6.5	100	3.07E-06	7.7	100	3.14E-06	8.4	100	2.73E-06	3.5	100
26	2.22E-06	6.5	100	2.28E-06	7.7	100	2.31E-06	8.4	100	1.90E-06	3.5	100
27	1.99E-06	6.5	100	2.03E-06	7.7	100	2.00E-06	8.4	100	1.57E-06	3.5	100
28	1.73E-06	6.5	100	1.79E-06	7.7	100	1.76E-06	8.4	100	1.38E-06	3.5	100
29	3.45E-06	6.5	100	3.48E-06	7.7	100	3.55E-06	8.4	100	3.15E-06	3.5	100
30	3.70E-06	6.5	100	3.70E-06	7.7	100	3.69E-06	8.4	100	3.22E-06	3.5	100
31												
1ヶ月値	3.85E-06	6.3	100	3.97E-06	7.5	100	3.83E-06	8.5	100	3.66E-06	3.5	100
最大値	1.46E-05	6.5	103	4.10E-05	7.7	102	6.73E-05	8.6	102	1.55E-05	3.5	102
最大値日時	11/22 05:39	11/24 09:56	11/09 17:28	11/17 11:00	11/17 11:00	11/09 17:21	11/16 11:03	11/01 00:01	11/02 02:13	11/22 05:45	11/01 00:01	11/01 13:21
最小値	0.00E+00	6.2	98	0.00E+00	7.4	98	0.00E+00	8.4	97	0.00E+00	3.5	97
最小値日時	11/09 12:03	11/01 00:01	11/02 08:06	11/09 11:29	11/01 00:01	11/01 11:05	11/08 22:40	11/16 11:03	11/06 06:31	11/09 10:13	11/01 00:01	11/13 04:01

*1:ろ紙交換

測定月報

測定日：2021/11

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.22E-06	1.3	100	7.05E-06	2.8	100	6.67E-06	1.9	100	6.81E-06	2.3	100
2	5.51E-06	1.3	100	6.27E-06	2.8	100	5.87E-06	1.9	100	6.22E-06	2.3	100
3	3.23E-06	1.3	100	3.68E-06	2.8	100	3.32E-06	1.9	100	3.46E-06	2.3	100
4	2.62E-06	1.3	100	2.98E-06	2.8	100	2.71E-06	1.9	100	2.87E-06	2.3	100
5	3.35E-06	1.3	100	3.79E-06	2.8	100	3.59E-06	1.9	100	3.78E-06	2.3	100
6	3.04E-06	1.3	100	3.41E-06	2.8	100	3.39E-06	1.9	100	3.51E-06	2.3	100
7	2.96E-06	1.3	100	3.34E-06	2.8	100	3.17E-06	1.9	100	3.33E-06	2.3	100
8	2.77E-06	1.3	100	3.14E-06	2.8	100	3.13E-06	1.9	100	3.28E-06	2.3	100
9	*1 1.64E-06	1.3	100	1.86E-06	2.8	100	1.74E-06	1.9	100	*1 1.83E-06	2.3	100
10	2.29E-06	1.3	100	*1 2.61E-06	2.9	100	*1 2.25E-06	1.9	100	2.41E-06	2.3	100
11	4.50E-06	1.3	100	5.08E-06	3.0	100	4.61E-06	1.9	100	4.90E-06	2.3	100
12	2.35E-06	1.3	100	2.65E-06	3.0	100	2.31E-06	1.9	100	2.52E-06	2.3	100
13	2.29E-06	1.3	100	2.56E-06	3.0	100	2.37E-06	1.9	100	2.57E-06	2.3	100
14	4.30E-06	1.3	100	4.89E-06	3.0	100	4.41E-06	1.9	100	4.75E-06	2.3	100
15	2.55E-06	1.3	100	2.83E-06	3.0	100	2.61E-06	1.9	100	2.82E-06	2.3	100
16	4.46E-06	1.3	100	5.07E-06	3.0	100	4.69E-06	1.9	100	5.01E-06	2.3	100
17	4.57E-06	1.3	100	5.10E-06	3.0	100	4.74E-06	1.9	100	4.98E-06	2.3	100
18	4.80E-06	1.3	100	5.34E-06	3.0	100	5.37E-06	1.9	100	5.76E-06	2.3	100
19	5.45E-06	1.3	100	6.25E-06	3.0	100	5.89E-06	1.9	100	6.21E-06	2.3	100
20	5.34E-06	1.3	100	6.12E-06	3.0	100	5.98E-06	1.9	100	6.23E-06	2.3	100
21	6.79E-06	1.3	100	7.66E-06	3.0	100	7.41E-06	1.9	100	7.83E-06	2.3	100
22	5.71E-06	1.3	100	6.46E-06	3.0	100	6.24E-06	1.9	100	6.64E-06	2.3	100
23	2.92E-06	1.3	100	3.25E-06	3.0	100	2.89E-06	1.9	100	3.06E-06	2.3	100
24	1.48E-06	1.3	100	1.60E-06	3.0	100	1.34E-06	1.9	100	1.51E-06	2.3	100
25	3.01E-06	1.3	100	3.32E-06	3.0	100	2.99E-06	1.9	100	3.22E-06	2.3	100
26	2.17E-06	1.3	100	2.35E-06	3.0	100	2.12E-06	1.9	100	2.38E-06	2.3	100
27	1.92E-06	1.3	100	2.09E-06	3.0	100	1.80E-06	1.9	100	2.01E-06	2.3	100
28	1.70E-06	1.3	100	1.85E-06	3.0	100	1.61E-06	1.9	100	1.80E-06	2.3	100
29	3.40E-06	1.3	100	3.79E-06	3.0	100	3.73E-06	1.9	100	4.05E-06	2.3	100
30	3.48E-06	1.3	100	3.84E-06	3.0	100	3.66E-06	1.9	100	3.99E-06	2.3	100
31												
1ヶ月値	3.56E-06	1.3	100	4.01E-06	2.9	100	3.76E-06	1.9	100	3.99E-06	2.3	100
最大値	1.42E-05	1.3	103	1.60E-05	3.0	102	1.57E-05	1.9	103	1.74E-05	2.3	102
最大値日時	11/22 06:02	11/01 00:01	11/28 09:09	11/22 05:57	11/10 10:32	11/01 00:05	11/22 05:29	11/01 00:01	11/17 07:41	11/22 05:25	11/01 00:01	11/01 06:37
最小値	0.00E+00	1.3	97	0.00E+00	2.8	98	0.00E+00	1.9	97	0.00E+00	2.3	98
最小値日時	11/09 11:30	11/01 00:01	11/06 00:41	11/10 10:32	11/01 00:01	11/01 04:44	11/10 09:42	11/01 00:01	11/01 08:44	11/09 11:10	11/01 00:01	11/01 02:42

*1:ろ紙交換

測定月報

測定日：2021/11

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シールド中央制御室			A020 シールド中央制御室		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.82E-06	5.3	100	7.22E-06	4.9	100	6.31E-06	1.9	100	7.60E-06	2.6	100
2	5.97E-06	5.3	100	6.31E-06	4.9	100	5.65E-06	1.9	100	*1 6.67E-06	2.6	100
3	3.54E-06	5.3	100	3.80E-06	4.9	100	3.24E-06	1.9	100	3.80E-06	2.6	100
4	2.86E-06	5.3	100	3.08E-06	4.9	100	2.62E-06	1.9	100	3.09E-06	2.6	100
5	3.57E-06	5.3	100	3.85E-06	4.9	100	3.40E-06	1.9	100	3.96E-06	2.6	100
6	3.44E-06	5.3	100	3.71E-06	4.9	100	3.10E-06	1.9	100	3.57E-06	2.6	100
7	3.36E-06	5.3	100	3.57E-06	4.9	100	3.02E-06	1.9	100	3.48E-06	2.6	100
8	3.13E-06	5.3	100	*3 3.30E-06	4.6	100	2.90E-06	1.9	100	3.38E-06	2.6	100
9	1.75E-06	5.3	100	1.81E-06	4.4	100	1.62E-06	1.9	100	1.81E-06	2.6	100
10	2.51E-06	5.3	100	2.57E-06	4.4	100	2.19E-06	1.9	100	2.50E-06	2.6	100
11	4.96E-06	5.3	100	5.07E-06	4.4	100	4.42E-06	1.9	100	5.08E-06	2.6	100
12	2.58E-06	5.3	100	2.64E-06	4.4	100	2.31E-06	1.9	100	2.65E-06	2.6	100
13	2.52E-06	5.3	100	2.54E-06	4.4	100	2.18E-06	1.9	100	2.57E-06	2.6	100
14	4.98E-06	5.3	100	5.01E-06	4.4	100	4.25E-06	1.9	100	4.92E-06	2.6	100
15	2.85E-06	5.3	100	2.84E-06	4.4	100	2.56E-06	1.9	100	2.98E-06	2.6	100
16	4.93E-06	5.3	100	5.09E-06	4.4	100	4.46E-06	1.9	100	5.25E-06	2.6	100
17	5.09E-06	5.3	100	5.22E-06	4.4	100	*1 4.39E-06	2.0	100	5.23E-06	2.6	100
18	5.74E-06	5.3	100	5.76E-06	4.4	100	4.66E-06	2.0	100	5.42E-06	2.6	100
19	6.19E-06	5.3	100	6.33E-06	4.4	100	5.40E-06	2.0	100	6.41E-06	2.6	100
20	6.24E-06	5.3	100	6.42E-06	4.4	100	5.39E-06	2.0	100	6.42E-06	2.6	100
21	7.64E-06	5.3	100	7.82E-06	4.4	100	6.91E-06	2.0	100	8.14E-06	2.6	100
22	6.30E-06	5.3	100	6.58E-06	4.4	100	5.94E-06	2.0	100	6.91E-06	2.6	100
23	3.25E-06	5.3	100	3.25E-06	4.4	100	2.80E-06	2.0	100	3.34E-06	2.6	100
24	*1 1.53E-06	5.4	100	1.55E-06	4.4	100	1.31E-06	2.0	100	1.59E-06	2.6	100
25	3.07E-06	5.4	100	3.34E-06	4.4	100	2.89E-06	2.0	100	3.43E-06	2.6	100
26	2.25E-06	5.4	100	2.33E-06	4.4	100	2.08E-06	2.0	100	2.48E-06	2.6	100
27	2.01E-06	5.4	100	2.09E-06	4.4	100	1.73E-06	2.0	100	2.07E-06	2.6	100
28	1.75E-06	5.4	100	1.83E-06	4.4	100	1.60E-06	2.0	100	1.93E-06	2.6	100
29	3.82E-06	5.4	100	4.02E-06	4.4	100	3.22E-06	2.0	100	*1 3.80E-06	2.7	100
30	3.92E-06	5.4	100	4.17E-06	4.4	100	3.28E-06	2.0	100	3.83E-06	2.7	100
31												
1ヶ月値	3.95E-06	5.3	100	4.11E-06	4.5	100	3.53E-06	1.9	100	4.14E-06	2.6	100
最大値	1.61E-05	5.4	102	1.75E-05	4.9	102	1.52E-05	2.0	103	1.74E-05	2.7	101
最大値日時	11/22 05:39	11/24 08:49	11/19 12:13	11/22 05:37	11/01 00:01	11/06 08:12	11/22 06:14	11/17 11:11	11/06 04:00	11/22 05:58	11/29 09:11	11/01 00:03
最小値	0.00E+00	5.3	98	0.00E+00	4.4	98	0.00E+00	1.9	97	0.00E+00	2.6	99
最小値日時	11/24 08:49	11/01 00:01	11/06 01:42	11/08 10:53	11/08 10:53	11/06 12:19	11/17 11:11	11/01 00:01	11/02 19:05	11/02 11:28	11/01 00:01	11/01 00:13

*1:ろ紙交換 *3:年次点検

測定月報

測定日：2021/11

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.64E-06	2.0	100	8.01E-06	2.5	100	7.85E-06	10.8	100	7.65E-06	15.2	100
2	5.91E-06	2.0	100	7.03E-06	2.5	100	7.18E-06	10.8	100	6.87E-06	15.2	100
3	3.44E-06	2.0	100	4.02E-06	2.5	100	4.47E-06	10.8	100	4.13E-06	15.2	100
4	2.78E-06	2.0	100	3.31E-06	2.5	100	3.77E-06	10.8	100	3.33E-06	15.2	100
5	3.70E-06	2.0	100	4.39E-06	2.5	100	4.43E-06	10.8	100	4.13E-06	15.2	100
6	3.48E-06	2.0	100	4.11E-06	2.5	100	4.29E-06	10.8	100	3.95E-06	15.2	100
7	3.37E-06	2.0	100	3.95E-06	2.5	100	4.13E-06	10.8	100	3.78E-06	15.2	100
8	3.08E-06	2.0	100	*3 3.53E-06	2.6	100	3.87E-06	10.8	100	3.56E-06	15.2	100
9	1.69E-06	2.0	100	1.75E-06	2.7	100	2.46E-06	10.8	100	1.95E-06	15.2	100
10	2.31E-06	2.0	100	2.41E-06	2.7	100	3.17E-06	10.8	100	2.74E-06	15.2	100
11	4.74E-06	2.0	100	4.96E-06	2.7	100	5.82E-06	10.8	100	5.47E-06	15.2	100
12	2.47E-06	2.0	100	2.58E-06	2.7	100	3.38E-06	10.8	100	2.94E-06	15.2	100
13	2.36E-06	2.0	100	2.51E-06	2.7	100	3.21E-06	10.8	100	2.85E-06	15.2	100
14	4.50E-06	2.0	100	4.78E-06	2.7	100	5.71E-06	10.8	100	5.31E-06	15.2	100
15	2.67E-06	2.0	100	2.89E-06	2.7	100	3.55E-06	10.8	100	*3 2.95E-06	14.5	100
16	4.66E-06	2.0	100	5.08E-06	2.7	100	5.87E-06	10.8	100	4.82E-06	13.8	100
17	4.69E-06	2.0	100	5.05E-06	2.7	100	5.81E-06	10.8	100	4.83E-06	13.8	100
18	5.08E-06	2.0	100	5.45E-06	2.7	100	6.17E-06	10.8	100	5.13E-06	13.8	100
19	5.66E-06	2.0	100	6.20E-06	2.7	100	7.06E-06	10.8	100	6.08E-06	13.8	100
20	5.93E-06	2.0	100	6.33E-06	2.7	100	7.09E-06	10.8	100	6.08E-06	13.8	100
21	7.25E-06	2.0	100	7.83E-06	2.7	100	8.29E-06	10.8	100	7.26E-06	13.8	100
22	6.12E-06	2.0	100	6.67E-06	2.7	100	7.07E-06	10.8	100	6.12E-06	13.8	100
23	2.92E-06	2.0	100	3.16E-06	2.7	100	3.85E-06	10.8	100	2.99E-06	13.8	100
24	*1 1.46E-06	2.1	100	1.53E-06	2.7	100	*1 1.86E-06	11.6	100	1.39E-06	13.8	100
25	3.06E-06	2.1	100	3.27E-06	2.7	100	3.35E-06	12.1	100	3.00E-06	13.8	100
26	2.20E-06	2.1	100	2.35E-06	2.7	100	2.40E-06	12.1	100	2.24E-06	13.8	100
27	1.90E-06	2.1	100	2.01E-06	2.7	100	2.10E-06	12.1	100	1.88E-06	13.8	100
28	1.72E-06	2.1	100	1.82E-06	2.7	100	1.85E-06	12.1	100	1.56E-06	13.8	100
29	6.04E-06	2.1	100	3.81E-06	2.7	100	3.77E-06	12.1	100	3.42E-06	13.8	100
30	3.60E-06	2.1	100	3.73E-06	2.7	100	4.16E-06	12.1	100	3.77E-06	13.8	100
31												
1ヶ月値	3.85E-06	2.0	100	4.15E-06	2.7	100	4.60E-06	11.1	100	4.07E-06	14.5	100
最大値	4.65E-04	2.1	102	1.84E-05	2.7	102	1.73E-05	12.1	102	1.59E-05	15.2	101
最大値日時	11/29 11:48	11/24 10:03	11/01 01:20	11/22 05:54	11/08 12:09	11/06 12:24	11/22 05:55	11/24 08:41	11/01 12:04	11/02 07:34	11/01 00:01	11/01 00:01
最小値	0.00E+00	2.0	96	0.00E+00	2.5	98	0.00E+00	10.8	98	0.00E+00	13.8	98
最小値日時	11/24 10:03	11/01 00:01	11/07 16:48	11/08 12:09	11/01 00:01	11/03 20:57	11/24 08:43	11/01 00:01	11/01 06:54	11/09 10:04	11/15 11:31	11/16 07:48

*3:年次点検 *1:ろ紙交換

測定月報

測定日：2021/11

(7/8)

日	モニタ											
	A027 1号機海側2、5m盤			A028 1号機海側2、5m盤			A029 3号機海側2、5m盤			A030 3号機海側2、5m盤		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	7.01E-06	3.6	100	7.06E-06	4.4	100	6.17E-06	2.3	100	6.47E-06	3.2	100
2	*1 6.41E-06	3.6	100	6.34E-06	4.4	100	5.44E-06	2.3	100	*1 5.71E-06	3.3	100
3	3.86E-06	3.6	100	3.87E-06	4.4	100	3.26E-06	2.3	100	3.50E-06	3.4	100
4	3.10E-06	3.6	100	3.14E-06	4.4	100	2.61E-06	2.3	100	2.76E-06	3.4	100
5	3.78E-06	3.6	100	3.79E-06	4.4	100	3.21E-06	2.3	100	3.45E-06	3.4	100
6	3.54E-06	3.6	100	3.56E-06	4.4	100	3.07E-06	2.3	100	3.23E-06	3.4	100
7	3.42E-06	3.6	100	3.45E-06	4.4	100	2.98E-06	2.3	100	3.14E-06	3.4	100
8	3.07E-06	3.6	100	3.17E-06	4.4	100	2.65E-06	2.3	100	2.74E-06	3.4	100
9	1.81E-06	3.6	100	1.88E-06	4.4	100	*1 1.65E-06	2.2	100	1.60E-06	3.4	100
10	2.65E-06	3.6	100	2.77E-06	4.4	100	2.37E-06	2.2	100	2.41E-06	3.4	100
11	5.13E-06	3.6	100	5.21E-06	4.4	100	4.48E-06	2.2	100	4.66E-06	3.4	100
12	2.74E-06	3.6	100	2.76E-06	4.4	100	2.40E-06	2.2	100	2.38E-06	3.4	100
13	2.56E-06	3.6	100	2.63E-06	4.4	100	2.23E-06	2.2	100	2.31E-06	3.4	100
14	5.03E-06	3.6	100	5.07E-06	4.4	100	4.34E-06	2.2	100	4.43E-06	3.4	100
15	2.99E-06	3.6	100	*3 2.81E-06	4.5	100	2.59E-06	2.2	100	2.65E-06	3.4	100
16	5.22E-06	3.6	100	4.36E-06	4.6	100	4.52E-06	2.2	100	4.72E-06	3.4	100
17	5.21E-06	3.6	100	4.38E-06	4.6	100	4.41E-06	2.2	100	4.72E-06	3.4	100
18	5.33E-06	3.6	100	4.56E-06	4.6	100	4.61E-06	2.2	100	4.79E-06	3.4	100
19	6.35E-06	3.6	100	5.44E-06	4.6	100	5.43E-06	2.2	100	5.60E-06	3.4	100
20	6.27E-06	3.6	100	5.41E-06	4.6	100	5.44E-06	2.2	100	5.78E-06	3.4	100
21	7.65E-06	3.6	100	6.57E-06	4.6	100	6.51E-06	2.2	100	6.85E-06	3.4	100
22	6.54E-06	3.6	100	5.57E-06	4.6	100	5.59E-06	2.2	100	5.87E-06	3.4	100
23	3.34E-06	3.6	100	2.86E-06	4.6	100	2.87E-06	2.2	100	3.02E-06	3.4	100
24	1.68E-06	3.6	100	1.41E-06	4.6	100	1.49E-06	2.2	100	1.49E-06	3.4	100
25	3.34E-06	3.6	100	2.83E-06	4.6	100	2.76E-06	2.2	100	2.89E-06	3.4	100
26	2.40E-06	3.6	100	2.06E-06	4.6	100	2.10E-06	2.2	100	2.17E-06	3.4	100
27	2.15E-06	3.6	100	1.85E-06	4.6	100	1.89E-06	2.2	100	1.95E-06	3.4	100
28	1.88E-06	3.6	100	1.57E-06	4.6	100	1.64E-06	2.2	100	1.71E-06	3.4	100
29	*1 3.81E-06	3.5	100	3.15E-06	4.6	100	3.29E-06	2.2	100	*1 3.49E-06	3.3	100
30	3.99E-06	3.4	100	3.32E-06	4.6	100	3.32E-06	2.2	100	3.55E-06	3.2	100
31												
1ヶ月値	4.07E-06	3.6	100	3.76E-06	4.5	100	3.51E-06	2.2	100	3.67E-06	3.4	100
最大値	1.56E-05	3.6	102	1.44E-05	4.6	102	1.30E-05	2.3	102	1.41E-05	3.4	102
最大値日時	11/22 05:28	11/01 00:01	11/01 03:59	11/02 08:48	11/15 12:02	11/15 23:34	11/22 05:32	11/01 00:01	11/02 01:57	11/22 05:25	11/02 10:10	11/28 11:00
最小値	0.00E+00	3.4	98	0.00E+00	4.4	98	0.00E+00	2.2	97	0.00E+00	3.2	98
最小値日時	11/02 10:04	11/29 08:32	11/01 23:31	11/15 12:02	11/01 00:01	11/01 00:45	11/09 10:18	11/09 10:03	11/08 07:44	11/02 10:11	11/01 00:01	11/01 04:24

*1: ろ紙交換 *3: 年次点検

測定月報

測定日：2021/11

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	6.46E-06	8.7	100	6.73E-06	6.8	100						
2	5.78E-06	8.7	100	5.98E-06	6.8	100						
3	3.51E-06	8.7	100	3.54E-06	6.8	100						
4	2.83E-06	8.7	100	2.83E-06	6.8	100						
5	3.58E-06	8.7	100	3.52E-06	6.8	100						
6	3.30E-06	8.7	100	3.29E-06	6.8	100						
7	3.18E-06	8.7	100	3.26E-06	6.8	100						
8	3.06E-06	8.7	100	3.11E-06	6.8	100						
9	1.67E-06	8.7	100	1.55E-06	6.8	100						
10	2.38E-06	8.7	100	2.32E-06	6.8	100						
11	4.68E-06	8.7	100	4.66E-06	6.8	100						
12	2.54E-06	8.7	100	2.48E-06	6.8	100						
13	2.43E-06	8.7	100	2.41E-06	6.8	100						
14	4.51E-06	8.7	100	4.66E-06	6.8	100						
15	2.71E-06	8.7	100	2.73E-06	6.8	100						
16	*1 4.64E-06	8.9	100	4.74E-06	6.8	100						
17	4.57E-06	9.0	100	*1 4.70E-06	6.9	100						
18	4.84E-06	9.0	100	4.79E-06	6.9	100						
19	5.69E-06	9.0	100	5.70E-06	6.9	100						
20	5.57E-06	9.0	100	5.54E-06	6.9	100						
21	6.98E-06	9.0	100	6.87E-06	6.9	100						
22	5.65E-06	9.0	100	5.61E-06	6.9	100						
23	2.87E-06	9.0	100	2.88E-06	6.9	100						
24	1.43E-06	9.0	100	1.38E-06	6.9	100						
25	3.04E-06	9.0	100	2.92E-06	6.9	100						
26	2.12E-06	9.0	100	2.12E-06	6.9	100						
27	1.90E-06	9.0	100	1.83E-06	6.9	100						
28	1.68E-06	9.0	100	1.64E-06	6.9	100						
29	3.38E-06	9.0	100	3.19E-06	6.9	100						
30	3.53E-06	9.0	100	3.41E-06	6.9	100						
31												
1ヶ月値	3.68E-06	8.8	100	3.68E-06	6.8	100						
最大値	1.56E-05	9.0	103	1.54E-05	6.9	102						
最大値日時	11/22 05:58	11/16 10:56	11/10 11:00	11/02 06:43	11/17 10:18	11/03 22:20						
最小値	0.00E+00	8.7	97	0.00E+00	6.8	98						
最小値日時	11/09 10:10	11/01 00:01	11/01 00:24	11/09 11:31	11/01 00:01	11/03 19:06						

*1:ろ紙交換