

構内連続ダストモニタ測定記録(2023 年 6 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

測定日：2023/06

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.37E-06	5.8	100	2.34E-06	1.1	100	2.39E-06	6.1	100	2.14E-06	6.1	100
2	1.12E-06	5.8	100	1.20E-06	1.1	100	1.23E-06	6.1	100	1.11E-06	6.1	100
3	2.46E-06	5.8	100	2.43E-06	1.1	100	2.71E-06	6.1	100	2.44E-06	6.1	100
4	3.06E-06	5.8	100	3.04E-06	1.1	100	3.12E-06	6.1	100	2.88E-06	6.1	100
5	3.30E-06	5.8	100	3.28E-06	1.1	100	3.50E-06	6.1	100	3.18E-06	6.1	100
6	5.09E-06	5.8	100	4.91E-06	1.1	100	5.47E-06	6.1	100	4.97E-06	6.1	100
7	5.37E-06	5.8	100	5.18E-06	1.1	100	5.51E-06	6.1	100	4.99E-06	6.1	100
8	6.48E-06	5.8	100	6.37E-06	1.1	100	7.26E-06	6.1	100	6.47E-06	6.1	100
9	9.20E-07	5.8	100	9.77E-07	1.1	100	9.17E-07	6.1	100	8.04E-07	6.1	100
10	2.97E-06	5.8	100	2.95E-06	1.1	100	2.88E-06	6.1	100	2.53E-06	6.1	100
11	4.86E-06	5.8	100	4.70E-06	1.1	100	4.95E-06	6.1	100	4.39E-06	6.1	100
12	1.64E-06	5.8	100	1.70E-06	1.1	100	1.72E-06	6.1	100	1.57E-06	6.1	100
13	1.32E-06	5.8	100	*1 1.36E-06	1.1	100	1.42E-06	6.1	100	1.24E-06	6.1	100
14	4.14E-06	5.8	100	3.96E-06	1.1	100	4.07E-06	6.1	100	3.67E-06	6.1	100
15	*1 2.25E-06	5.6	100	2.10E-06	1.1	100	*1 2.18E-06	6.2	100	2.03E-06	6.1	100
16	1.83E-06	5.5	100	1.67E-06	1.1	100	1.67E-06	6.3	100	1.59E-06	6.1	100
17	3.19E-06	5.5	100	2.99E-06	1.1	100	2.81E-06	6.3	100	2.64E-06	6.1	100
18	2.87E-06	5.5	100	2.62E-06	1.1	100	2.84E-06	6.3	100	2.70E-06	6.1	100
19	2.02E-06	5.5	100	1.85E-06	1.1	100	1.79E-06	6.3	100	*1 1.73E-06	6.2	100
20	2.90E-06	5.5	100	2.72E-06	1.1	100	2.82E-06	6.3	100	2.64E-06	6.2	100
21	3.30E-06	5.5	100	3.07E-06	1.1	100	3.18E-06	6.3	100	3.08E-06	6.2	100
22	1.21E-06	5.5	100	1.10E-06	1.1	100	9.96E-07	6.3	100	9.45E-07	6.2	100
23	2.85E-06	5.5	100	2.74E-06	1.1	100	2.76E-06	6.3	100	2.57E-06	6.2	100
24	4.20E-06	5.5	100	3.93E-06	1.1	100	3.40E-06	6.3	100	3.13E-06	6.2	100
25	4.45E-06	5.5	100	4.18E-06	1.1	100	3.97E-06	6.3	100	3.75E-06	6.2	100
26	4.46E-06	5.5	100	4.10E-06	1.1	100	3.93E-06	6.3	100	3.72E-06	6.2	100
27	7.13E-06	5.5	100	6.67E-06	1.1	100	6.82E-06	6.3	100	6.33E-06	6.2	100
28	6.57E-06	5.5	100	6.28E-06	1.1	100	6.37E-06	6.3	100	5.77E-06	6.2	100
29	3.14E-06	5.5	100	2.93E-06	1.1	100	3.04E-06	6.3	100	2.85E-06	6.2	100
30	7.42E-06	5.5	100	6.96E-06	1.1	100	7.32E-06	6.3	100	6.76E-06	6.2	100
31												
1ヶ月値	3.50E-06	5.6	100	3.34E-06	1.1	100	3.44E-06	6.2	100	3.16E-06	6.1	100
最大値	1.89E-05	5.8	102	1.78E-05	1.1	102	1.79E-05	6.3	101	1.64E-05	6.2	102
最大値日時	06/27 03:26	06/01 00:01	06/09 07:18	06/08 02:06	06/01 00:01	06/01 08:59	06/27 03:23	06/15 09:29	06/01 00:06	06/27 03:31	06/19 09:29	06/06 03:24
最小値	0.00E+00	5.5	98	0.00E+00	1.1	98	0.00E+00	6.1	99	0.00E+00	6.1	98
最小値日時	06/02 17:03	06/15 10:31	06/01 03:06	06/13 11:37	06/01 00:01	06/01 01:17	06/02 17:45	06/01 00:01	06/01 00:01	06/02 17:27	06/01 00:01	06/01 05:13

*1: ろ紙交換

測定月報

測定日：2023/06

(2/8)

日	モニタ											
	A005			A006			A007			A008		
	5/6号警備所前			5/6号警備所前			1号北側法面上(旧厚生棟)			1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.24E-06	0.9	100	2.17E-06	1.2	100	2.31E-06	7.1	100	2.26E-06	5.7	100
2	1.23E-06	0.9	100	1.15E-06	1.2	100	1.22E-06	7.1	100	1.18E-06	5.7	100
3	2.60E-06	0.9	100	2.56E-06	1.2	100	2.60E-06	7.1	100	2.61E-06	5.7	100
4	2.91E-06	0.9	100	2.85E-06	1.2	100	2.95E-06	7.1	100	2.95E-06	5.7	100
5	3.21E-06	0.9	100	3.15E-06	1.2	100	3.26E-06	7.1	100	3.21E-06	5.7	100
6	5.15E-06	0.9	100	4.97E-06	1.2	100	5.17E-06	7.1	100	5.14E-06	5.7	100
7	5.03E-06	0.9	100	4.96E-06	1.2	100	5.12E-06	7.1	100	5.06E-06	5.7	100
8	7.35E-06	0.9	100	7.23E-06	1.2	100	7.28E-06	7.1	100	7.38E-06	5.7	100
9	9.15E-07	0.9	100	8.05E-07	1.2	100	*1 8.17E-07	7.1	100	8.43E-07	5.7	100
10	2.38E-06	0.9	100	2.25E-06	1.2	100	2.43E-06	7.1	100	2.42E-06	5.7	100
11	4.28E-06	0.9	100	4.21E-06	1.2	100	4.25E-06	7.1	100	4.26E-06	5.7	100
12	1.66E-06	0.9	100	1.54E-06	1.2	100	1.55E-06	7.1	100	1.59E-06	5.7	100
13	1.30E-06	0.9	100	1.23E-06	1.2	100	1.27E-06	7.1	100	1.29E-06	5.7	100
14	3.83E-06	0.9	100	3.79E-06	1.2	100	3.77E-06	7.1	100	3.82E-06	5.7	100
15	2.12E-06	0.9	100	*1 2.10E-06	1.1	100	2.02E-06	7.1	100	2.09E-06	5.7	100
16	1.71E-06	0.9	100	1.66E-06	1.1	100	1.62E-06	7.1	100	1.68E-06	5.7	100
17	2.87E-06	0.9	100	2.77E-06	1.1	100	2.84E-06	7.1	100	2.90E-06	5.7	100
18	2.81E-06	0.9	100	2.75E-06	1.1	100	2.69E-06	7.1	100	2.75E-06	5.7	100
19	*1 1.74E-06	1.0	100	1.70E-06	1.1	100	1.63E-06	7.1	100	1.66E-06	5.7	100
20	2.48E-06	1.0	100	2.46E-06	1.1	100	2.53E-06	7.1	100	2.57E-06	5.7	100
21	2.95E-06	1.0	100	2.98E-06	1.1	100	3.06E-06	7.1	100	3.09E-06	5.7	100
22	1.03E-06	1.0	100	1.03E-06	1.1	100	1.02E-06	7.1	100	1.05E-06	5.7	100
23	2.77E-06	1.0	100	2.73E-06	1.1	100	2.62E-06	7.1	100	2.69E-06	5.7	100
24	2.95E-06	1.0	100	2.99E-06	1.1	100	3.01E-06	7.1	100	3.06E-06	5.7	100
25	3.82E-06	1.0	100	3.80E-06	1.1	100	3.76E-06	7.1	100	3.85E-06	5.7	100
26	3.81E-06	1.0	100	3.82E-06	1.1	100	3.80E-06	7.1	100	*1 3.82E-06	5.7	100
27	6.23E-06	1.0	100	6.20E-06	1.1	100	6.43E-06	7.1	100	6.42E-06	5.7	100
28	4.98E-06	1.0	100	4.95E-06	1.1	100	4.96E-06	7.1	100	5.00E-06	5.7	100
29	2.89E-06	1.0	100	2.84E-06	1.1	100	2.87E-06	7.1	100	2.84E-06	5.7	100
30	6.82E-06	1.0	100	6.80E-06	1.1	100	6.85E-06	7.1	100	6.82E-06	5.7	100
31												
1ヶ月値	3.20E-06	0.9	100	3.15E-06	1.1	100	3.19E-06	7.1	100	3.21E-06	5.7	100
最大値	1.64E-05	1.0	101	1.72E-05	1.2	102	1.73E-05	7.1	102	1.74E-05	5.7	102
最大値日時	06/08 08:40	06/19 10:11	06/01 00:03	06/07 23:44	06/01 00:01	06/01 07:02	06/27 03:24	06/01 00:01	06/01 01:00	06/08 08:45	06/01 00:01	06/01 17:20
最小値	0.00E+00	0.9	98	0.00E+00	1.1	98	0.00E+00	7.1	98	0.00E+00	5.7	98
最小値日時	06/19 10:11	06/01 00:01	06/01 03:44	06/15 11:02	06/15 11:00	06/01 07:48	06/02 18:02	06/01 00:01	06/01 05:33	06/02 18:00	06/01 00:01	06/01 09:03

*1: ろ紙交換

測定月報

測定日：2023/06

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.25E-06	5.4	100	2.44E-06	4.3	100	2.27E-06	2.2	100	2.15E-06	4.3	100
2	1.12E-06	5.4	100	1.30E-06	4.3	100	1.18E-06	2.2	100	1.07E-06	4.3	100
3	2.54E-06	5.4	100	2.75E-06	4.3	100	2.49E-06	2.2	100	2.38E-06	4.3	100
4	2.93E-06	5.4	100	3.15E-06	4.3	100	2.92E-06	2.2	100	2.81E-06	4.3	100
5	3.29E-06	5.4	100	3.44E-06	4.3	100	3.23E-06	2.2	100	3.11E-06	4.3	100
6	5.19E-06	5.4	100	5.40E-06	4.3	100	4.93E-06	2.2	100	4.81E-06	4.3	100
7	5.14E-06	5.4	100	5.52E-06	4.3	100	5.06E-06	2.2	100	4.98E-06	4.3	100
8	6.99E-06	5.4	100	7.46E-06	4.3	100	6.65E-06	2.2	100	6.70E-06	4.3	100
9	*1 8.79E-07	5.3	100	9.68E-07	4.3	100	8.72E-07	2.2	100	7.69E-07	4.3	100
10	2.52E-06	5.3	100	2.79E-06	4.3	100	2.61E-06	2.2	100	2.45E-06	4.3	100
11	4.37E-06	5.3	100	4.81E-06	4.3	100	4.45E-06	2.2	100	4.29E-06	4.3	100
12	1.64E-06	5.3	100	1.77E-06	4.3	100	1.61E-06	2.2	100	1.48E-06	4.3	100
13	1.34E-06	5.3	100	1.48E-06	4.3	100	1.36E-06	2.2	100	1.23E-06	4.3	100
14	3.80E-06	5.3	100	4.08E-06	4.3	100	3.74E-06	2.2	100	3.58E-06	4.3	100
15	2.07E-06	5.3	100	2.23E-06	4.3	100	2.01E-06	2.2	100	*1 1.90E-06	4.2	100
16	1.71E-06	5.3	100	1.85E-06	4.3	100	1.69E-06	2.2	100	1.64E-06	4.1	100
17	2.89E-06	5.3	100	3.13E-06	4.3	100	2.79E-06	2.2	100	2.72E-06	4.1	100
18	2.78E-06	5.3	100	2.96E-06	4.3	100	2.74E-06	2.2	100	2.60E-06	4.1	100
19	1.69E-06	5.3	100	1.79E-06	4.3	100	1.70E-06	2.2	100	1.63E-06	4.1	100
20	2.63E-06	5.5	100	2.90E-06	4.3	100	2.68E-06	2.2	100	2.58E-06	4.1	100
21	2.85E-06	5.6	100	3.30E-06	4.3	100	3.03E-06	2.2	100	2.89E-06	4.1	100
22	8.47E-07	5.6	100	1.09E-06	4.3	100	1.05E-06	2.2	100	1.02E-06	4.1	100
23	2.41E-06	5.6	100	2.88E-06	4.3	100	2.66E-06	2.2	100	2.52E-06	4.1	100
24	2.92E-06	5.6	100	3.46E-06	4.3	100	3.40E-06	2.2	100	3.30E-06	4.1	100
25	3.48E-06	5.6	100	4.11E-06	4.3	100	3.84E-06	2.2	100	3.74E-06	4.1	100
26	3.47E-06	5.6	100	*1 4.15E-06	4.2	100	*1 4.02E-06	2.1	100	3.79E-06	4.1	100
27	6.08E-06	5.6	100	7.03E-06	4.1	100	7.30E-06	2.1	100	6.36E-06	4.1	100
28	5.06E-06	5.6	100	5.92E-06	4.1	100	6.25E-06	2.1	100	5.46E-06	4.1	100
29	2.64E-06	5.6	100	3.16E-06	4.1	100	3.46E-06	2.1	100	2.83E-06	4.1	100
30	6.44E-06	5.6	100	7.37E-06	4.1	100	7.76E-06	2.1	100	6.77E-06	4.1	100
31												
1ヶ月値	3.13E-06	5.4	100	3.49E-06	4.3	100	3.31E-06	2.2	100	3.12E-06	4.2	100
最大値	3.03E-05	5.6	102	1.81E-05	4.3	101	1.84E-05	2.2	103	1.70E-05	4.3	102
最大値日時	06/09 09:59	06/20 12:07	06/11 19:02	06/07 23:34	06/01 00:01	06/01 00:11	06/27 03:41	06/01 00:01	06/17 23:02	06/08 02:02	06/01 00:01	06/01 01:06
最小値	0.00E+00	5.3	98	0.00E+00	4.1	98	0.00E+00	2.1	97	0.00E+00	4.1	98
最小値日時	06/02 18:03	06/09 09:59	06/01 14:46	06/26 12:20	06/26 12:20	06/02 18:22	06/26 11:39	06/26 11:39	06/01 03:10	06/02 17:53	06/15 10:43	06/01 02:55

*1: ろ紙交換

測定月報

測定日：2023/06

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.61E-06	0.8	100	2.44E-06	1.4	100	2.12E-06	1.9	100	2.29E-06	3.2	100
2	1.34E-06	0.8	100	1.21E-06	1.4	100	1.10E-06	1.9	100	1.22E-06	3.2	100
3	2.80E-06	0.8	100	2.71E-06	1.4	100	2.29E-06	1.9	100	2.48E-06	3.2	100
4	3.31E-06	0.8	100	3.11E-06	1.4	100	2.84E-06	1.9	100	3.03E-06	3.2	100
5	3.75E-06	0.8	100	3.49E-06	1.4	100	2.98E-06	1.9	100	3.23E-06	3.2	100
6	5.75E-06	0.8	100	5.38E-06	1.4	100	4.72E-06	1.9	100	5.07E-06	3.2	100
7	5.70E-06	0.8	100	5.47E-06	1.4	100	4.93E-06	1.9	100	5.32E-06	3.2	100
8	8.13E-06	0.8	100	7.75E-06	1.4	100	5.71E-06	1.9	100	6.14E-06	3.2	100
9	*1 1.02E-06	0.8	100	9.14E-07	1.4	100	8.64E-07	1.9	100	9.57E-07	3.2	100
10	2.91E-06	0.8	100	2.77E-06	1.4	100	2.72E-06	1.9	100	2.92E-06	3.2	100
11	5.08E-06	0.8	100	4.85E-06	1.4	100	4.49E-06	1.9	100	4.78E-06	3.2	100
12	1.87E-06	0.8	100	1.75E-06	1.4	100	1.54E-06	1.9	100	1.69E-06	3.2	100
13	1.55E-06	0.8	100	*1 1.49E-06	1.3	100	1.27E-06	1.9	100	1.39E-06	3.2	100
14	4.28E-06	0.8	100	4.13E-06	1.3	100	3.82E-06	1.9	100	4.07E-06	3.2	100
15	2.39E-06	0.8	100	2.31E-06	1.3	100	2.02E-06	1.9	100	*1 2.24E-06	3.1	100
16	2.00E-06	0.8	100	1.92E-06	1.3	100	1.61E-06	1.9	100	1.82E-06	3.1	100
17	3.23E-06	0.8	100	3.11E-06	1.3	100	2.63E-06	1.9	100	2.89E-06	3.1	100
18	3.03E-06	0.8	100	2.89E-06	1.3	100	2.55E-06	1.9	100	2.82E-06	3.1	100
19	1.88E-06	0.8	100	1.84E-06	1.3	100	1.80E-06	1.9	100	1.97E-06	3.1	100
20	2.85E-06	0.8	100	2.72E-06	1.3	100	2.80E-06	1.9	100	3.03E-06	3.1	100
21	3.42E-06	0.8	100	3.22E-06	1.3	100	3.00E-06	1.9	100	3.29E-06	3.1	100
22	1.15E-06	0.8	100	1.09E-06	1.3	100	1.01E-06	1.9	100	1.18E-06	3.1	100
23	2.96E-06	0.8	100	2.84E-06	1.3	100	2.54E-06	1.9	100	2.79E-06	3.1	100
24	4.01E-06	0.8	100	3.76E-06	1.3	100	3.69E-06	1.9	100	4.01E-06	3.1	100
25	4.34E-06	0.8	100	4.24E-06	1.3	100	4.07E-06	1.9	100	4.43E-06	3.1	100
26	4.32E-06	0.8	100	4.15E-06	1.3	100	*1 4.04E-06	1.9	100	4.22E-06	3.1	100
27	7.51E-06	0.8	100	7.35E-06	1.3	100	7.10E-06	1.8	100	7.04E-06	3.1	100
28	6.08E-06	0.8	100	5.92E-06	1.3	100	6.67E-06	1.8	100	6.62E-06	3.1	100
29	3.43E-06	0.8	100	3.28E-06	1.3	100	3.27E-06	1.8	100	3.11E-06	3.1	100
30	7.63E-06	0.8	100	7.45E-06	1.3	100	7.52E-06	1.8	100	7.27E-06	3.1	100
31												
1ヶ月値	3.68E-06	0.8	100	3.52E-06	1.3	100	3.26E-06	1.9	100	3.44E-06	3.1	100
最大値	1.95E-05	0.8	101	1.94E-05	1.4	101	1.76E-05	1.9	102	1.81E-05	3.2	101
最大値日時	06/27 03:18	06/01 00:01	06/01 00:14	06/27 03:23	06/01 00:01	06/01 00:14	06/27 03:36	06/01 00:01	06/01 01:47	06/27 03:29	06/01 00:01	06/01 00:20
最小値	0.00E+00	0.8	98	0.00E+00	1.3	98	0.00E+00	1.8	97	0.00E+00	3.1	98
最小値日時	06/09 10:15	06/01 00:01	06/13 04:42	06/13 11:21	06/13 11:21	06/22 23:06	06/26 12:10	06/26 12:10	06/27 03:41	06/15 10:01	06/15 10:01	06/01 20:09

*1: ろ紙交換

測定月報

測定日：2023/06

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シールド中央制御室			A020 シールド中央制御室		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.62E-06	4.7	100	2.62E-06	4.0	100	2.40E-06	2.3	100	2.30E-06	3.9	100
2	1.59E-06	4.7	100	1.49E-06	4.0	100	1.22E-06	2.3	100	1.10E-06	3.9	100
3	2.82E-06	4.7	100	2.80E-06	4.0	100	2.60E-06	2.3	100	2.42E-06	3.9	100
4	3.36E-06	4.7	100	3.34E-06	4.0	100	3.10E-06	2.3	100	2.90E-06	3.9	100
5	3.57E-06	4.7	100	3.59E-06	4.0	100	3.38E-06	2.3	100	3.17E-06	3.9	100
6	5.70E-06	4.7	100	5.78E-06	4.0	100	5.29E-06	2.3	100	4.99E-06	3.9	100
7	5.62E-06	4.7	100	5.71E-06	4.0	100	5.39E-06	2.3	100	5.06E-06	3.9	100
8	7.75E-06	4.7	100	8.00E-06	4.0	100	6.14E-06	2.3	100	6.91E-06	3.9	100
9	*1 1.14E-06	4.8	100	1.05E-06	4.0	100	*1 9.49E-07	2.2	100	8.38E-07	3.9	100
10	2.91E-06	4.9	100	2.95E-06	4.0	100	2.86E-06	2.2	100	2.53E-06	3.9	100
11	4.64E-06	4.9	100	4.82E-06	4.0	100	5.01E-06	2.2	100	4.46E-06	3.9	100
12	1.79E-06	4.9	100	1.83E-06	4.0	100	1.79E-06	2.2	100	1.61E-06	3.9	100
13	1.59E-06	4.9	100	*1 1.68E-06	3.9	100	1.50E-06	2.2	100	1.34E-06	3.9	100
14	4.11E-06	4.9	100	4.37E-06	3.9	100	4.25E-06	2.2	100	3.76E-06	3.9	100
15	2.28E-06	4.9	100	2.38E-06	3.9	100	2.28E-06	2.2	100	2.00E-06	3.9	100
16	1.91E-06	4.9	100	2.03E-06	3.9	100	1.87E-06	2.2	100	1.65E-06	3.9	100
17	3.42E-06	4.9	100	3.55E-06	3.9	100	3.25E-06	2.2	100	2.88E-06	3.9	100
18	3.23E-06	4.9	100	3.37E-06	3.9	100	2.94E-06	2.2	100	2.62E-06	3.9	100
19	1.84E-06	4.9	100	1.94E-06	3.9	100	1.94E-06	2.2	100	1.73E-06	3.9	100
20	2.79E-06	4.9	100	3.06E-06	3.9	100	2.81E-06	2.2	100	2.52E-06	3.9	100
21	3.33E-06	4.9	100	3.71E-06	3.9	100	3.34E-06	2.2	100	3.09E-06	3.9	100
22	1.33E-06	4.9	100	1.41E-06	3.9	100	1.15E-06	2.2	100	1.01E-06	3.9	100
23	2.89E-06	4.9	100	3.00E-06	3.9	100	2.89E-06	2.2	100	2.62E-06	3.9	100
24	3.36E-06	4.9	100	3.68E-06	3.9	100	3.93E-06	2.2	100	3.50E-06	3.9	100
25	4.12E-06	4.9	100	4.40E-06	3.9	100	4.31E-06	2.2	100	3.91E-06	3.9	100
26	4.23E-06	4.9	100	4.44E-06	3.9	100	4.30E-06	2.2	100	*1 4.08E-06	3.9	100
27	7.11E-06	4.9	100	7.54E-06	3.9	100	7.49E-06	2.2	100	7.43E-06	3.9	100
28	6.08E-06	4.9	100	6.37E-06	3.9	100	6.26E-06	2.2	100	6.09E-06	3.9	100
29	3.18E-06	4.9	100	3.34E-06	3.9	100	3.26E-06	2.2	100	3.31E-06	3.9	100
30	7.89E-06	4.9	100	8.28E-06	3.9	100	7.59E-06	2.2	100	7.60E-06	3.9	100
31												
1ヶ月値	3.61E-06	4.8	100	3.75E-06	3.9	100	3.50E-06	2.2	100	3.32E-06	3.9	100
最大値	1.83E-05	4.9	102	5.46E-05	4.0	109	1.91E-05	2.3	101	1.99E-05	3.9	103
最大値日時	06/27 03:34	06/09 11:26	06/27 00:36	06/13 10:08	06/01 00:01	06/13 10:08	06/27 02:30	06/01 00:01	06/01 00:02	06/27 03:04	06/01 00:01	06/25 07:55
最小値	0.00E+00	4.7	98	0.00E+00	3.9	99	0.00E+00	2.2	98	0.00E+00	3.9	97
最小値日時	06/09 11:30	06/01 00:01	06/10 07:05	06/13 10:09	06/13 10:08	06/01 00:18	06/09 10:25	06/09 10:25	06/01 18:01	06/19 09:44	06/01 00:01	06/30 08:12

*1:ろ紙交換

測定月報

測定日：2023/06

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.35E-06	1.6	100	2.30E-06	2.0	100	2.46E-06	12.3	100	2.17E-06	12.4	100
2	1.18E-06	1.6	100	1.18E-06	2.0	100	1.31E-06	12.3	100	9.82E-07	12.4	100
3	2.51E-06	1.6	100	2.47E-06	2.0	100	2.63E-06	12.3	100	2.27E-06	12.4	100
4	3.06E-06	1.6	100	3.01E-06	2.0	100	3.05E-06	12.3	100	2.69E-06	12.4	100
5	3.37E-06	1.6	100	3.26E-06	2.0	100	3.31E-06	12.3	100	2.96E-06	12.4	100
6	5.08E-06	1.6	100	4.97E-06	2.0	100	5.21E-06	12.3	100	4.82E-06	12.4	100
7	5.22E-06	1.6	100	5.15E-06	2.0	100	5.20E-06	12.3	100	4.74E-06	12.4	100
8	6.66E-06	1.6	100	6.40E-06	2.0	100	7.22E-06	12.3	100	6.83E-06	12.4	100
9	8.98E-07	1.6	100	8.74E-07	2.0	100	9.82E-07	12.3	100	*1 8.91E-07	12.1	100
10	2.86E-06	1.6	100	2.76E-06	2.0	100	2.65E-06	12.3	100	2.69E-06	11.9	100
11	4.71E-06	1.6	100	4.55E-06	2.0	100	4.47E-06	12.3	100	4.48E-06	11.9	100
12	1.70E-06	1.6	100	1.65E-06	2.0	100	1.69E-06	12.3	100	1.73E-06	11.9	100
13	1.37E-06	1.6	100	1.34E-06	2.0	100	*1 1.36E-06	12.7	100	1.53E-06	11.9	100
14	3.95E-06	1.6	100	3.85E-06	2.0	100	3.58E-06	12.9	100	3.80E-06	11.9	100
15	2.12E-06	1.6	100	*1 2.05E-06	2.1	100	1.93E-06	12.9	100	2.11E-06	11.9	100
16	1.70E-06	1.6	100	1.58E-06	2.1	100	1.56E-06	12.9	100	1.74E-06	11.9	100
17	2.91E-06	1.6	100	2.77E-06	2.1	100	2.93E-06	12.9	100	3.19E-06	11.9	100
18	2.81E-06	1.6	100	2.67E-06	2.1	100	2.75E-06	12.9	100	2.98E-06	11.9	100
19	*1 1.81E-06	1.7	100	1.74E-06	2.1	100	1.65E-06	12.9	100	1.89E-06	11.9	100
20	2.75E-06	1.7	100	2.68E-06	2.1	100	2.54E-06	12.9	100	2.80E-06	11.9	100
21	3.10E-06	1.7	100	3.05E-06	2.1	100	3.07E-06	12.9	100	3.30E-06	11.9	100
22	1.01E-06	1.7	100	1.02E-06	2.1	100	9.61E-07	12.9	100	1.19E-06	11.9	100
23	2.66E-06	1.7	100	2.63E-06	2.1	100	2.60E-06	12.9	100	2.80E-06	11.9	100
24	3.63E-06	1.7	100	3.65E-06	2.1	100	3.13E-06	12.9	100	3.32E-06	11.9	100
25	3.98E-06	1.7	100	3.98E-06	2.1	100	3.72E-06	12.9	100	3.95E-06	11.9	100
26	4.00E-06	1.7	100	4.01E-06	2.1	100	3.72E-06	12.9	100	3.96E-06	11.9	100
27	6.91E-06	1.7	100	6.76E-06	2.1	100	6.44E-06	12.9	100	6.61E-06	11.9	100
28	6.09E-06	1.7	100	6.03E-06	2.1	100	5.15E-06	12.9	100	5.32E-06	11.9	100
29	2.90E-06	1.7	100	2.86E-06	2.1	100	2.81E-06	12.9	100	3.04E-06	11.9	100
30	7.01E-06	1.7	100	7.00E-06	2.1	100	6.85E-06	12.9	100	7.01E-06	11.9	100
31												
1ヶ月値	3.34E-06	1.6	100	3.28E-06	2.1	100	3.23E-06	12.7	100	3.26E-06	12.0	100
最大値	1.81E-05	1.7	102	1.76E-05	2.1	102	1.70E-05	12.9	102	2.27E-05	12.4	101
最大値日時	06/08 02:39	06/19 10:36	06/07 00:28	06/27 03:33	06/15 10:16	06/01 00:17	06/27 03:33	06/13 09:58	06/01 02:17	06/09 11:51	06/01 00:01	06/01 00:24
最小値	0.00E+00	1.6	98	0.00E+00	2.0	97	0.00E+00	12.3	98	0.00E+00	11.9	98
最小値日時	06/19 10:36	06/01 00:01	06/02 17:00	06/15 10:16	06/01 00:01	06/08 23:02	06/02 16:39	06/01 00:01	06/01 12:00	06/02 10:55	06/09 11:51	06/02 04:05

*1:ろ紙交換

測定月報

測定日：2023/06

(7/8)

日	モニタ											
	A027			A028			A029			A030		
	1号機海側2、5m盤			1号機海側2、5m盤			3号機海側2、5m盤			3号機海側2、5m盤		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.21E-06	2.7	100	2.37E-06	3.8	100	2.32E-06	1.9	100	2.65E-06	1.7	100
2	1.18E-06	2.7	100	1.21E-06	3.8	100	1.20E-06	1.9	100	1.34E-06	1.7	100
3	2.59E-06	2.7	100	2.79E-06	3.8	100	2.68E-06	1.9	100	3.05E-06	1.7	100
4	2.91E-06	2.7	100	3.15E-06	3.8	100	2.95E-06	1.9	100	3.37E-06	1.7	100
5	3.16E-06	2.7	100	3.45E-06	3.8	100	3.29E-06	1.9	100	3.85E-06	1.7	100
6	5.03E-06	2.7	100	5.45E-06	3.8	100	5.09E-06	1.9	100	5.96E-06	1.7	100
7	4.71E-06	2.7	100	5.09E-06	3.8	100	4.76E-06	1.9	100	5.57E-06	1.7	100
8	7.09E-06	2.7	100	7.75E-06	3.8	100	7.34E-06	1.8	100	8.63E-06	1.7	100
9	8.38E-07	2.7	100	8.62E-07	3.8	100	8.76E-07	1.7	100	1.00E-06	1.7	100
10	2.36E-06	2.7	100	2.50E-06	3.8	100	2.29E-06	1.7	100	2.72E-06	1.7	100
11	4.00E-06	2.7	100	4.28E-06	3.8	100	3.92E-06	1.7	100	4.73E-06	1.7	100
12	1.50E-06	2.7	100	1.60E-06	3.8	100	1.55E-06	1.7	100	1.79E-06	1.7	100
13	1.25E-06	2.7	100	1.33E-06	3.8	100	1.29E-06	1.7	100	1.49E-06	1.7	100
14	3.55E-06	2.7	100	3.84E-06	3.8	100	3.62E-06	1.7	100	4.21E-06	1.7	100
15	2.01E-06	2.7	100	*1 2.17E-06	3.7	100	2.04E-06	1.7	100	2.36E-06	1.7	100
16	1.62E-06	2.7	100	1.80E-06	3.6	100	1.70E-06	1.7	100	2.00E-06	1.7	100
17	2.95E-06	2.7	100	3.21E-06	3.6	100	2.98E-06	1.7	100	3.51E-06	1.7	100
18	2.70E-06	2.7	100	2.92E-06	3.6	100	2.78E-06	1.7	100	3.28E-06	1.7	100
19	1.63E-06	2.7	100	1.78E-06	3.6	100	1.69E-06	1.7	100	1.93E-06	1.7	100
20	2.44E-06	2.7	100	2.58E-06	3.6	100	2.49E-06	1.7	100	2.93E-06	1.7	100
21	3.03E-06	2.7	100	3.24E-06	3.6	100	2.96E-06	1.7	100	3.49E-06	1.7	100
22	9.81E-07	2.7	100	1.10E-06	3.6	100	1.02E-06	1.7	100	1.17E-06	1.7	100
23	2.60E-06	2.7	100	2.84E-06	3.6	100	2.62E-06	1.7	100	3.07E-06	1.7	100
24	3.02E-06	2.7	100	3.30E-06	3.6	100	3.12E-06	1.7	100	3.72E-06	1.7	100
25	3.63E-06	2.7	100	3.94E-06	3.6	100	3.70E-06	1.7	100	4.38E-06	1.7	100
26	*1 3.76E-06	2.8	100	3.98E-06	3.6	100	3.62E-06	1.7	100	*1 4.47E-06	1.7	100
27	6.77E-06	2.8	100	6.63E-06	3.6	100	6.18E-06	1.7	100	8.04E-06	1.7	100
28	4.89E-06	2.8	100	4.83E-06	3.6	100	4.40E-06	1.7	100	5.82E-06	1.7	100
29	3.09E-06	2.8	100	2.90E-06	3.6	100	2.77E-06	1.7	100	3.79E-06	1.7	100
30	7.39E-06	2.8	100	7.07E-06	3.6	100	6.53E-06	1.7	100	8.78E-06	1.7	100
31												
1ヶ月値	3.16E-06	2.7	100	3.33E-06	3.7	100	3.12E-06	1.7	100	3.77E-06	1.7	100
最大値	1.75E-05	2.8	102	1.84E-05	3.8	102	1.70E-05	1.9	102	2.05E-05	1.7	102
最大値日時	06/27 03:05	06/26 10:22	06/03 19:05	06/08 08:29	06/01 00:01	06/03 02:01	06/08 08:26	06/01 00:01	06/02 19:33	06/27 02:49	06/01 00:01	06/03 18:45
最小値	0.00E+00	2.7	98	0.00E+00	3.6		0.00E+00	1.7	98	0.00E+00	1.7	98
最小値日時	06/03 01:20	06/01 00:01	06/01 07:17	06/03 01:27	06/15 10:12		06/08 10:17	06/08 10:17	06/02 05:46	06/26 10:27	06/01 00:01	06/01 12:59

*1: ろ紙交換

測定月報

測定日：2023/06

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	2.48E-06	7.9	100	2.37E-06	6.3	100						
2	1.20E-06	7.9	100	1.05E-06	6.3	100						
3	2.64E-06	7.9	100	2.56E-06	6.3	100						
4	3.15E-06	7.9	100	3.00E-06	6.3	100						
5	3.52E-06	7.9	100	3.30E-06	6.3	100						
6	5.42E-06	7.9	100	5.12E-06	6.3	100						
7	5.41E-06	7.9	100	5.13E-06	6.3	100						
8	7.89E-06	8.3	100	7.22E-06	6.3	100						
9	8.79E-07	8.7	100	8.19E-07	6.3	100						
10	2.73E-06	8.7	100	2.60E-06	6.3	100						
11	4.54E-06	8.7	100	4.30E-06	6.3	100						
12	1.72E-06	8.7	100	1.66E-06	6.3	100						
13	1.45E-06	8.7	100	1.35E-06	6.3	100						
14	3.87E-06	8.7	100	3.66E-06	6.3	100						
15	2.10E-06	8.7	100	*1 2.16E-06	6.0	100						
16	1.75E-06	8.7	100	1.90E-06	5.8	100						
17	3.37E-06	8.7	100	3.49E-06	5.8	100						
18	3.01E-06	8.7	100	3.05E-06	5.8	100						
19	1.87E-06	8.7	100	1.99E-06	5.8	100						
20	2.74E-06	8.7	100	2.87E-06	5.8	100						
21	3.27E-06	8.7	100	3.34E-06	5.8	100						
22	1.03E-06	8.7	100	1.18E-06	5.8	100						
23	2.76E-06	8.7	100	2.88E-06	5.8	100						
24	3.59E-06	8.7	100	3.67E-06	5.8	100						
25	4.15E-06	8.7	100	4.08E-06	5.8	100						
26	4.07E-06	8.7	100	4.14E-06	5.8	100						
27	7.07E-06	8.7	100	6.96E-06	5.8	100						
28	5.49E-06	8.7	100	5.39E-06	5.8	100						
29	3.16E-06	8.7	100	3.31E-06	5.8	100						
30	7.29E-06	8.7	100	7.30E-06	5.8	100						
31												
1ヶ月値	3.45E-06	8.5	100	3.39E-06	6.0	100						
最大値	1.87E-05	8.7	102	1.79E-05	6.3	102						
最大値日時	06/08 02:11	06/08 10:44	06/01 04:46	06/27 03:14	06/01 00:01	06/06 14:55						
最小値	0.00E+00	7.9	98	0.00E+00	5.8	98						
最小値日時	06/02 10:38	06/01 00:01	06/01 03:32	06/02 16:39	06/15 10:54	06/01 14:15						

*1: ろ紙交換