

瓦礫等収納容器点検結果(線量測定データ)

GM	メンバー

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 SS-00016✓	2024/12/2✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.26✓	—
2019 SS-00038✓	2024/12/2	6	F1-ICWBL-56	0.005	0.005	0.17✓	—
2019 FU-00185✓	2024/12/2	6	F1-ICWBL-56	0.005	0.005	0.063✓	—
2019 FU-00254✓	2024/12/2	6	F1-ICWBL-56	0.005	0.005	0.14✓	—
2019 FU-00341✓	2024/12/2✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.43✓	—
2018 FU-00020✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.27✓	—
2018 ZK-01883✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	1.06✓	—
2020 FU-00256✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.71✓	—
2021 SS-00143✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.89✓	—
2019 SS-00469✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.19✓	—
2018 FU-00021✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.023✓	—
KM-10106✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.69✓	—
2019 SS-00445✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.19✓	—
KM-00351✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.30✓	—
2019 FU-00153G✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.38✓	—
2020 SS-00043✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.28✓	—
2019 SS-00328✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.14✓	—
2019 FU-00259✓	2024/12/2	6	F1-ICWBL-89	0.004	0.004	0.85✓	—
2018 ZK-01795✓	2024/12/3✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.33✓	—
S062✓	2024/12/3	6	F1-ICWBL-56	0.005	0.005	0.25✓	—
2018 FU-00037✓	2024/12/3	6	F1-ICWBL-56	0.005	0.005	0.011✓	—
2019 FU-00164✓	2024/12/3	6	F1-ICWBL-56	0.005	0.005	0.017✓	—
2018 ZK-01797✓	2024/12/3	6	F1-ICWBL-56	0.005	0.005	0.17✓	—
2018 FU-00019✓	2024/12/3	6	F1-ICWBL-56	0.005	0.005	0.20✓	—
ZK-00671✓	2024/12/3✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.004✓	—
ZK-00260✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.004✓	—
ZK-00485✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.004✓	—
TB-264✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.004✓	—
ZK-00780✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.014✓	—
ZK-00463✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.004✓	—
ZK-00527✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.004✓	—
TB-220✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.004✓	—
TB-235✓	2024/12/3	6	F1-ICWBL-89	0.004	0.004	0.004✓	—
2019 FU-00184✓	2024/12/4✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.022✓	—
2019 FU-00278✓	2024/12/4	6	F1-ICWBL-56	0.005	0.005	0.65✓	—
ZK-00040✓	2024/12/4	6	F1-ICWBL-56	0.005	0.005	0.19✓	—
2019 FU-00174✓	2024/12/4	6	F1-ICWBL-56	0.005	0.005	0.018✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 FU-00222G	2024/12/4	6	F1-ICWBL-56	0.005	0.005	0.46	—
2019 FU-00274	2024/12/4	6	F1-ICWBL-56	0.005	0.005	0.42	—
2019 FU-00235G	2024/12/4	6	F1-ICWBL-56	0.005	0.005	0.89	—
2019 FU-00207G	2024/12/4	6	F1-ICWBL-56	0.005	0.005	0.41	—
2019 SS-00349	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.15	—
2019 SS-00299	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.18	—
2018 ZK-01486	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.29	—
2019 SS-00076	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.088	—
2019 SS-00574	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.78	—
2019 SS-00292	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.080	—
2019 FU-00173	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.004	—
2019 FU-00255	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.28	—
2019 SS-00263	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.43	—
2019 ZK-02594	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.54	—
2018 FU-00008	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.026	—
2019 FU-00179	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.042	—
2019 FU-00193G	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.11	—
2019 SS-00078	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.28	—
2019 SS-00267	2024/12/4	6	F1-ICWBL-89	0.004	0.004	0.34	—
2019 SS-00135	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.004	—
2019 FU-00185G	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.16	—
ZK-01390	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.27	—
2019 FU-00134	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.10	—
2019 FU-00020	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.038	—
2019 ZK-02984	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.98	—
2019 SS-00536	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.33	—
2019 FU-00194G	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.080	—
2018 FU-00132	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.40	—
2019 FU-00073	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.10	—
2019 FU-00101	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.28	—
2019 SS-00488	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.012	—
2019 SS-00258	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.060	—
2019 FU-00075	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.068	—
2018 FU-00048	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.43	—
2019 SS-00351	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.22	—
2019 SS-00125	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.15	—
2019 SS-00474	2024/12/5	6	F1-ICWBL-89	0.004	0.004	0.005	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 FU-00280 ✓	2024/12/6 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.45 ✓	—
2019 FU-00176 ✓	2024/12/6	6	F1-ICWBL-56	0.005	0.005	0.090 ✓	—
2019 SS-00289 ✓	2024/12/6	6	F1-ICWBL-56	0.005	0.005	0.23 ✓	—
2019 FU-00131 ✓	2024/12/6	6	F1-ICWBL-56	0.005	0.005	0.070 ✓	—
2018 FU-00053 ✓	2024/12/6	6	F1-ICWBL-56	0.005	0.005	0.27 ✓	—
2018 FU-00046 ✓	2024/12/6	6	F1-ICWBL-56	0.005	0.005	0.24 ✓	—
2019 ZK-02679 ✓	2024/12/6 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	1.11 ✓	—
2018 FU-00105 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.24 ✓	—
2019 ZK-02703 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.60 ✓	—
2018 FU-00106 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.21 ✓	—
2019 SS-00105 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.15 ✓	—
2019 ZK-02756 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.078 ✓	—
2019 SS-00132 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.015 ✓	—
2019 SS-00191 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.008 ✓	—
2019 ZK-02861 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.005 ✓	—
2019 ZK-02844 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2019 ZK-02872 ✓	2024/12/6	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2019 FU-00276 ✓	2024/12/7 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.17 ✓	—
2018 FU-00049 ✓	2024/12/7	6	F1-ICWBL-56	0.005	0.005	0.35 ✓	—
2019 ZK-02676 ✓	2024/12/7	6	F1-ICWBL-56	0.005	0.005	0.58 ✓	—
2018 FU-00108 ✓	2024/12/7	6	F1-ICWBL-56	0.005	0.005	0.17 ✓	—
2018 FU-00107 ✓	2024/12/7	6	F1-ICWBL-56	0.005	0.005	0.19 ✓	—
ZK-00038 ✓	2024/12/7	6	F1-ICWBL-56	0.005	0.005	0.45 ✓	—
2019 ZK-02646 ✓	2024/12/7	6	F1-ICWBL-56	0.005	0.005	0.50 ✓	—
2018 FU-00130 ✓	2024/12/7	6	F1-ICWBL-56	0.005	0.005	0.23 ✓	—
2019 FU-00264G ✓	2024/12/9 ✓	6 ✓	F1-ICWBL-56 ✓	0.005 ✓	0.005 ✓	0.15 ✓	—
2019 FU-00252 ✓	2024/12/9	6	F1-ICWBL-56	0.005	0.005	0.010 ✓	—
2019 SS-00336 ✓	2024/12/9	6	F1-ICWBL-56	0.005	0.005	0.045 ✓	—
2019 FU-00217G ✓	2024/12/9	6	F1-ICWBL-56	0.005	0.005	0.22 ✓	—
2019 SS-00311 ✓	2024/12/9	6	F1-ICWBL-56	0.005	0.005	0.12 ✓	—
2019 ZK-02636 ✓	2024/12/9	6	F1-ICWBL-56	0.005	0.005	0.12 ✓	—
2022 CT-00345 ✓	2024/12/11 ✓	6 ✓	F1-ICWBL-89 ✓	0.004 ✓	0.004 ✓	0.11 ✓	—
2019 SS-00484 ✓	2024/12/11	6	F1-ICWBL-89	0.004	0.004	0.004 ✓	—
2022 SK-01242 ✓	2024/12/11	6	F1-ICWBL-89	0.004	0.004	0.093 ✓	—
2019 ZK-02929 ✓	2024/12/11	6	F1-ICWBL-89	0.004	0.004	0.015 ✓	—
2022 SK-01246 ✓	2024/12/11	6	F1-ICWBL-89	0.004	0.004	0.14 ✓	—
2019 ZK-02912 ✓	2024/12/11	6	F1-ICWBL-89	0.004	0.004	0.10 ✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 SS-00282✓	2024/12/11✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.043✓	—
2018 FU-00044✓	2024/12/12✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.32✓	—
2018 FU-00050✓	2024/12/12	6	F1-ICWBL-56	0.005	0.005	0.24✓	—
2018 FU-00045✓	2024/12/12	6	F1-ICWBL-56	0.005	0.005	0.21✓	—
2018 FU-00056✓	2024/12/12	6	F1-ICWBL-56	0.005	0.005	0.36✓	—
2018 FU-00131✓	2024/12/12	6	F1-ICWBL-56	0.005	0.005	0.18✓	—
2019 SS-00205✓	2024/12/12✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.76✓	—
2019 SS-00312✓	2024/12/12	6	F1-ICWBL-89	0.004	0.004	0.015✓	—
2019 SS-00121✓	2024/12/12	6	F1-ICWBL-89	0.004	0.004	0.38✓	—
2019 SS-00104✓	2024/12/12	6	F1-ICWBL-89	0.004	0.004	1.38✓	—
2019 SS-00485✓	2024/12/12	6	F1-ICWBL-89	0.004	0.004	0.010✓	—
2018 FU-00054✓	2024/12/13✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.23✓	—
2020 SS-00042✓	2024/12/13	6	F1-ICWBL-89	0.004	0.004	0.58✓	—
2018 FU-00041✓	2024/12/13	6	F1-ICWBL-89	0.004	0.004	0.52✓	—
2019 FU-00265✓	2024/12/13	6	F1-ICWBL-89	0.004	0.004	0.23✓	—
2019 FU-00250G✓	2024/12/13	6	F1-ICWBL-89	0.004	0.004	0.45✓	—
2022 SS-00082✓	2024/12/13	6	F1-ICWBL-89	0.004	0.004	0.54✓	—
2022 FU-00073✓	2024/12/13	6	F1-ICWBL-89	0.004	0.004	0.25✓	—
2018 FU-00136✓	2024/12/13	6	F1-ICWBL-89	0.004	0.004	0.70✓	—
ZK-00657✓	2024/12/13✓	6✓	F1-ICWBL-99✓	0.002✓	0.002✓	0.060✓	—
TB-042✓	2024/12/13	6	F1-ICWBL-99	0.002	0.002	0.15✓	—
2019 FU-00161✓	2024/12/14✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.28✓	—
2019 FU-00269✓	2024/12/14	6	F1-ICWBL-56	0.005	0.005	0.15✓	—
2019 FU-00165✓	2024/12/16✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.22✓	—
2018 FU-00052✓	2024/12/16	6	F1-ICWBL-56	0.005	0.005	0.25✓	—
ZK-01352✓	2024/12/16	6	F1-ICWBL-56	0.005	0.005	0.13✓	—
2018 FU-00055✓	2024/12/16	6	F1-ICWBL-56	0.005	0.005	0.25✓	—
2018 FU-00135✓	2024/12/16	6	F1-ICWBL-56	0.005	0.005	0.20✓	—
2018 FU-00129✓	2024/12/16	6	F1-ICWBL-56	0.005	0.005	0.22✓	—
2019 FU-00169✓	2024/12/16✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.30✓	—
2019 FU-00172✓	2024/12/16	6	F1-ICWBL-89	0.004	0.004	0.043✓	—
2018 ZK-01411✓	2024/12/16	6	F1-ICWBL-89	0.004	0.004	0.23✓	—
ZK-01050✓	2024/12/16	6	F1-ICWBL-89	0.004	0.004	0.30✓	—
2019 FU-00113✓	2024/12/16	6	F1-ICWBL-89	0.004	0.004	0.81✓	—
2019 FU-00236G✓	2024/12/16	6	F1-ICWBL-89	0.004	0.004	0.46✓	—
2019 SS-00302✓	2024/12/16	6	F1-ICWBL-89	0.004	0.004	0.63✓	—
2018 FU-00134✓	2024/12/16	6	F1-ICWBL-89	0.004	0.004	0.68✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 FU-00211✓	2024/12/17✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.59✓	—
2019 FU-00133✓	2024/12/17	6	F1-ICWBL-56	0.005	0.005	0.31✓	—
2019 FU-00130✓	2024/12/17	6	F1-ICWBL-56	0.005	0.005	0.37✓	—
2019 FU-00155G✓	2024/12/17	6	F1-ICWBL-56	0.005	0.005	0.14✓	—
2019 ZK-02469✓	2024/12/17	6	F1-ICWBL-56	0.005	0.005	0.59✓	—
2019 FU-00150✓	2024/12/17	6	F1-ICWBL-56	0.005	0.005	0.13✓	—
2018 ZK-01450✓	2024/12/17✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.029✓	—
2019 FU-00227G✓	2024/12/17	6	F1-ICWBL-89	0.004	0.004	0.12✓	—
2019 FU-00123✓	2024/12/17	6	F1-ICWBL-89	0.004	0.004	0.16✓	—
2019 FU-00071✓	2024/12/17	6	F1-ICWBL-89	0.004	0.004	0.21✓	—
2022 FU-00164✓	2024/12/17	6	F1-ICWBL-89	0.004	0.004	0.16✓	—
2018 FU-00051✓	2024/12/17	6	F1-ICWBL-89	0.004	0.004	0.34✓	—
2021 SS-30182✓	2024/12/17	6	F1-ICWBL-89	0.004	0.004	0.13✓	—
2019 FU-00381✓	2024/12/18✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.11✓	—
2019 FU-00209G✓	2024/12/18	6	F1-ICWBL-56	0.005	0.005	0.12✓	—
2019 FU-00179G✓	2024/12/18	6	F1-ICWBL-56	0.005	0.005	0.053✓	—
2019 FU-00129✓	2024/12/18	6	F1-ICWBL-56	0.005	0.005	0.050✓	—
2019 FU-00120✓	2024/12/18	6	F1-ICWBL-56	0.005	0.005	0.090✓	—
2019 FU-00162G✓	2024/12/18	6	F1-ICWBL-56	0.005	0.005	0.057✓	—
2019 FU-00210G✓	2024/12/18✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.13✓	—
2022 FU-00077✓	2024/12/18	6	F1-ICWBL-89	0.004	0.004	0.34✓	—
2019 ZK-02744✓	2024/12/18	6	F1-ICWBL-89	0.004	0.004	0.25✓	—
ZK-01041✓	2024/12/18	6	F1-ICWBL-89	0.004	0.004	0.33✓	—
ZK-01094✓	2024/12/18	6	F1-ICWBL-89	0.004	0.004	0.15✓	—
2022 FU-00268✓	2024/12/18	6	F1-ICWBL-89	0.004	0.004	0.14✓	—
2020 SS-00311✓	2024/12/19✓	6✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.47✓	—
2019 FU-00256G✓	2024/12/19	6	F1-ICWBL-56	0.005	0.005	0.11✓	—
2019 FU-00068✓	2024/12/19	6	F1-ICWBL-56	0.005	0.005	0.30✓	—
2020 ZK-03320✓	2024/12/19	6	F1-ICWBL-56	0.005	0.005	0.42✓	—
2019 FU-00166G✓	2024/12/19✓	6✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.11✓	—
2022 FU-00088✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.19✓	—
ZK-01336✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.27✓	—
2019 SS-00160✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.13✓	—
2019 ZK-02509✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.17✓	—
2019 SS-00432✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.14✓	—
ZK-01037✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.11✓	—
ZK-01340✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.30✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2018 ZK-01437✓	2024/12/19✓	6 ✓	F1-ICWBL-89✓	0.004✓	0.004 ✓	0.22✓	—
2022 FU-00089✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.19✓	—
2019 FU-00055✓	2024/12/19	6	F1-ICWBL-89	0.004	0.004	0.56✓	—
2021 SS-30171✓	2024/12/20✓	6 ✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.14✓	—
2019 FU-00095✓	2024/12/20	6	F1-ICWBL-56	0.005	0.005	0.080✓	—
2019 FU-00244G✓	2024/12/20	6	F1-ICWBL-56	0.005	0.005	0.073✓	—
ZK-01014✓	2024/12/20	6	F1-ICWBL-56	0.005	0.005	0.16✓	—
2019 SS-00246✓	2024/12/20	6	F1-ICWBL-56	0.005	0.005	0.86✓	—
2019 FU-00168✓	2024/12/20	6	F1-ICWBL-56	0.005	0.005	0.16✓	—
2019 FU-00148✓	2024/12/20✓	6 ✓	F1-ICWBL-89✓	0.004✓	0.004✓	0.38✓	—
2019 ZK-02548✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.21✓	—
ZK-01015✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.063✓	—
2019 FU-00180G✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.091✓	—
KM-00369✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.15✓	—
2019 ZK-02902✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.20✓	—
KM-00290✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.48✓	—
2019 FU-00175✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.14✓	—
2019 SS-00081✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.81✓	—
2020 SS-00411✓	2024/12/20	6	F1-ICWBL-89	0.004	0.004	0.54✓	—
2020 SS-00317✓	2024/12/21✓	6 ✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.50✓	—
2020 SS-00068✓	2024/12/21	6	F1-ICWBL-56	0.005	0.005	0.45✓	—
2019 FU-00195G✓	2024/12/21	6	F1-ICWBL-56	0.005	0.005	0.38✓	—
2019 ZK-02838✓	2024/12/23✓	6 ✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.29✓	—
ZK-01054✓	2024/12/23	6	F1-ICWBL-56	0.005	0.005	0.18✓	—
2020 ZK-03329✓	2024/12/23	6	F1-ICWBL-56	0.005	0.005	0.30✓	—
2021 ZK-05068✓	2024/12/26✓	6 ✓	F1-ICWBL-56✓	0.005✓	0.005✓	0.20✓	—
2021 ZK-05073✓	2024/12/26	6	F1-ICWBL-56	0.005	0.005	0.27✓	—
2022 SK-00755✓	2024/12/26	6	F1-ICWBL-56	0.005	0.005	0.11✓	—
2020 ZK-04555✓	2024/12/26	6	F1-ICWBL-56	0.005	0.005	0.18✓	—
2020 ZK-03460✓	2024/12/26	6	F1-ICWBL-56	0.005	0.005	0.18✓	—
2021 SK-05072✓	2024/12/26	6	F1-ICWBL-56	0.005	0.005	0.29✓	—
2021 ZK-05070✓	2024/12/26	6	F1-ICWBL-56	0.005	0.005	0.090✓	—
2021 ZK-05069✓	2024/12/26	6	F1-ICWBL-56	0.005	0.005	0.20✓	—