

F1-GMAD-239 ✓	
機器効率:	30.9 %
採取効率:	10 %
B G:	80 cpm
換算定数:	$1.35E-02 \text{ Bq/cm}^2 \cdot \text{cpm}$
検出下限値:	$9.2E-01 \text{ Bq/cm}^2$

(1/2)

アクションレベル: 4Bq/cm²

No	測定場所	測定日	4/18		5/20		6/		7/		8/		9/		10/		11/		12/		1/		2/		3/		備 考
			Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	
1	正門警備所前		<0.92	80	<0.92	80																					
2	入退域管理棟前		<0.92	80	<0.92	80																					
3	新事務本館北東エリア		<0.92	80	<0.92	80																					
4	廃棄物倉庫北東エリア		<0.92	80	<0.92	80																					
5	企業棟[]エリア		<0.92	80	<0.92	80																					
6	企業センター(A棟)休憩所南東エリア		<0.92	80	<0.92	80																					
7	地下道東		<0.92	80	<0.92	80																					
8	桜通り横断歩道①		<0.92	80	<0.92	80																					
9	桜通り横断歩道②		<0.92	80	<0.92	80																					
10	排水処理装置建屋南西(南東)		<0.92	80	<0.92	80																					
11	車輛汚染検査所エリア		<0.92	80	<0.92	80																					
12	西門 厚生棟休憩所前		<0.92	80	<0.92	80																					
13	西門 研修棟休憩所前		<0.92	80	<0.92	80																					
14	新西門東		<0.92	80	<0.92	80																					
15	JAEA分析施設第一棟連絡通路		<0.92	80	<0.92	80																					
16	JAEA分析施設第一棟進入道路		<0.92	80	<0.92	80																					
17	西門 登録センター休憩所前		<0.92	80	<0.92	80																					
18	ふれあい交差点西エリア		<0.92	80	<0.92	80																					
19	中央交差点西エリア		<0.92	80	<0.92	80																					
20	休憩所周辺と免震重要棟周辺を結ぶ道路		<0.92	80	<0.92	80																					
21	ALPS装備交換所前		<0.92	80	<0.92	80																					
22	休憩所周辺と免震重要棟周辺を結ぶ歩道		<0.92	80	<0.92	80																					
23	免震重要棟出入口		<0.92	80	<0.92	80																					
24	免震重要棟南側出入口		<0.92	80	<0.92	80																					
25	免震重要棟前駐車場エリア		<0.92	80	<0.92	80																					
26	免震重要棟入口前		<0.92	80	<0.92	80																					
27	1～4号機出入管理所車両ゲート		<0.92	80	<0.92	80																					
28	1～4号機PP大熊通り車両ゲート		<0.92	80	<0.92	80																					
29	タンクエリア装備交換所前		<0.92	80	<0.92	80																					
30	五差路車両ゲート		<0.92	80	<0.92	80																					
31	1/2号開閉所車両ゲート		<0.92	80	<0.92	80																					
32	5号機タービン建屋前駐車場		<0.92	80	<0.92	80																					
33	5/6号サービス建屋入口前		<0.92	80	<0.92	80																					
34	6号機タービン建屋大物搬出入口前道路		<0.92	80	<0.92	80																					

アクションレベル: 4Bq/cm²

No	測定場所	測定日		4/18		5/20		6/		7/		8/		9/		10/		11/		12/		1/		2/		3/		備考
		Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	Bq/cm ²	cpm	
35	6号機T/B前駐車場	<0.92	80	<0.92	80																							
36	北護岸入口車両ゲート	<0.92	80	<0.92	80																							
37	雑固体焼却設備建屋前	<0.92	80	<0.92	80																							
38	土捨て休憩所前	<0.92	80	<0.92	80																							
39	増設雑固体廃棄物焼却設備建屋前	<0.92	80	<0.92	80																							
40	グリーンデッキ No.1(視察台進入歩道入口)	<0.92	80	<0.92	80																							
41	グリーンデッキ No.2(視察台進入歩道)	<0.92	80	<0.92	80																							
42	グリーンデッキ No.3(視察台駐車場南西)	<0.92	80	<0.92	80																							
43	グリーンデッキ No.4(視察台駐車場北西)	<0.92	80	<0.92	80																							
44	グリーンデッキ No.5(視察台駐車場北東)	<0.92	80	<0.92	80																							
45	グリーンデッキ No.6(視察台駐車場南東)	<0.92	80	<0.92	80																							
46	グリーンデッキ No.7(視察台手すり)	<0.92	80	<0.92	80																							
47	グリーンデッキ No.8(視察台床面)	<0.92	80	<0.92	80																							
48	グリーンデッキ No.9(視察台床面)	<0.92	80	<0.92	80																							
49	グリーンデッキ No.10(視察台手すり)	<0.92	80	<0.92	80																							
50	グリーンデッキ No.11(視察台床面)	<0.92	80	<0.92	80																							
51	グリーンデッキ No.12(視察台床面)	<0.92	80	<0.92	80																							
52	グリーンデッキ No.13(視察台手すり)	<0.92	80	<0.92	80																							
53	グリーンデッキ No.14(視察台手すり)	<0.92	80	<0.92	80																							
54	グリーンデッキ No.15(視察台床面)	<0.92	80	<0.92	80																							
55	ブルーデッキ No. 1(床面)	<0.92	80	<0.92	80																							
56	ブルーデッキ No. 2(グレーチング)	<0.92	80	<0.92	80																							
57	ブルーデッキ No. 3(手すり)	<0.92	80	<0.92	80																							
58	ブルーデッキ No. 4(手すり)	<0.92	80	<0.92	80																							
59	ブルーデッキ No. 5(手すり)	<0.92	80	<0.92	80																							
60	ブルーデッキ No. 6(手すり)	<0.92	80	<0.92	80																							
61	ブルーデッキ No. 7(手すり)	<0.92	80	<0.92	80																							
62	ブルーデッキ No. 8(手すり)	<0.92	80	<0.92	80																							
63	ブルーデッキ No. 9(グレーチング)	<0.92	80	<0.92	80																							
64	ブルーデッキ No. 10(グレーチング)	<0.92	80	<0.92	80																							
65	ブルーデッキ No. 11(手すり)	<0.92	80	<0.92	80																							
66	ブルーデッキ No. 12(手すり)	<0.92	80	<0.92	80																							
67	倒壊鉄塔見学エリア No. 1 (床面)	<0.92	80	<0.92	80																							
68	倒壊鉄塔見学エリア No. 2 (床面)	<0.92	80	<0.92	80																							
69	倒壊鉄塔見学エリア No. 3 (床面)	<0.92	80	<0.92	80																							
70	倒壊鉄塔見学エリア No. 4 (手すり)	<0.92	80	<0.92	80																							