

GM	メンバー

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2022 SS-00173	2025/12/2	6	F1-ICWBL-194	0.004	0.004	0.052	-
2021 貯留設備-001	2025/12/2	6	F1-ICWBL-194	0.004	0.004	0.18	-
2021 SS-30245	2025/12/2	6	F1-ICWBL-194	0.004	0.004	0.038	-
2022 SS-00214	2025/12/2	6	F1-ICWBL-194	0.004	0.004	0.009	-
2022 SS-00282	2025/12/4	6	F1-ICWBL-249	0.004	0.004	0.005	-
2021 SK-00314	2025/12/4	6	F1-ICWBL-249	0.004	0.004	0.13	-
2021 SS-40313	2025/12/4	6	F1-ICWBL-249	0.004	0.004	0.004	-
2020 ZK-03680	2025/12/4	6	F1-ICWBL-249	0.004	0.004	0.17	-
2021 SS-40160	2025/12/4	6	F1-ICWBL-249	0.004	0.004	0.004	-
2021 QD-00004	2025/12/4	6	F1-ICWBL-249	0.004	0.004	0.004	-
2021 SS-40315	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.004	-
2021 SS-40200	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.008	-
ZK-01167	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.029	-
2021 SS-30078	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.074	-
ZK-00949	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.004	-
2022 SS-00270	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.007	-
2021 QD-00008	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.004	-
2021 SS-40165	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.004	-
2020 ZK-03719	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.48	-
2022 SS-00277	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.004	-
2021 SS-30150	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.004	-
2019 ZK-02491	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.010	-
ZK-00990	2025/12/5	6	F1-ICWBL-194	0.004	0.004	0.017	-
TB-250	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.004	-
TB-191	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.013	-
2021 SS-40229	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.011	-
2022 SK-00424	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.008	-
2021 SS-30203	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.26	-
ZK-00619	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.078	-
2022 SK-00823	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.030	-
2022 SK-00999	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.038	-
ZK-00882	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.009	-
ZK-00586	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.009	-
2019 NS-00005	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.008	-
ZK-00553	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.007	-
2022 CT-00584	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.11	-



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2022 SK-01086	2025/12/8	6	F1-ICWBL-194	0.004	0.004	0.33	-
PMB-T-6	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.17	-
2019 SS-00170	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.46	-
2022 CT-00081	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.75	-
2022 SS-00272	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-40512	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.004	-
2019 NS-00231	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.008	-
ZK-01051	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00548	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.17	-
ZK-00624	2025/12/9	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-01159	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.008	-
2019 ZK-02572	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.013	-
2021 SS40461	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.015	-
ZK-00467	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.004	-
2019 FU-00198G	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.13	-
2019 FU-00212G	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.49	-
2021 SS-40428	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.008	-
2022 SK-00434	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.004	-
2022 SK-00444	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.004	-
2020 ZK-04535	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-40204	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 TA-00008	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.13	-
ZK-01056	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.070	-
2019 FU-00096	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.004	-
2022 SK-00458	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.004	-
2020 SS-00334	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.091	-
2021 SS-30255	2025/12/10	6	F1-ICWBL-58	0.004	0.004	0.14	-
2019 SS-00442	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.53	-
2021 SS-40524	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
2020 SS-00489	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.26	-
2020 ZK-03686	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.27	-
ZK-00615	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
2021 SS-40187	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
2021 SS-40029	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00741	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00514	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
TB-294	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-01197	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-01148	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00410	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00595	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.022	-
ZK-01162	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.007	-
ZK-00632	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-01109	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.004	-
2021 AB-00020	2025/12/11	6	F1-ICWBL-249	0.004	0.004	0.93	-
ZK-00890	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
2022 SK-01005	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.030	-
ZK-00660	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00570	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00508	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00480	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.038	-
2018 ZK-01557	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.023	-
S 8	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.19	-
2020 SS-00248	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.046	-
TB-189	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00727	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.007	-
ZK-00676	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.056	-
ZK-00852	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 ZK-04840	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
2022 SS-00069	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.030	-
2021 SS-40372	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00440	2025/12/12	6	F1-ICWBL-58	0.004	0.004	0.004	-
2020 ZK-03679	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.31	-
ZK-00576	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.080	-
ZK-00453	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-01034	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00427	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00645	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.088	-
ZK-01271	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.009	-
ZK-00698	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00413	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.006	-
ZK-01173	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.005	-



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
TB-300	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.021	-
ZK-00542	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.021	-
2021 FU-00179	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.028	-
2020 SS-00518	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.086	-
ZK-00456	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00566	2025/12/15	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00594	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.004	-
S 4	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.14	-
2022 SS-00081	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00426	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.004	-
2019 ZK-02243	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.004	-
2019 ZK-02380	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.44	-
ZK-01193	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.011	-
ZK-01020	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.008	-
2020 ZK-04043	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.31	-
2021 SS-40285	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.004	-
2022 SS-00004	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.020	-
2019 ZK-02487	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.021	-
KM-00005	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.004	-
KM-00280	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.27	-
2019 ZK-02439	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.68	-
2020 ZK-03380	2025/12/16	6	F1-ICWBL-58	0.004	0.004	0.015	-
2019 ZK-02614	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
2019 ZK-02156	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
2019 FU-00353	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-40063	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-40112	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-01246	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.041	-
2021 SS-40487	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-40527	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
2022 SS-00094	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.076	-
2021 処理設備-010	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
2022 SS-00043	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.010	-
2022 SK-00438	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00675	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00477	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
ZK-00737	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00677	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00434	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00999	2025/12/17	6	F1-ICWBL-58	0.004	0.004	0.042	-
ZK-00702	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.061	-
2021 SS-40489	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.004	-
2020 ZK-04556	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.010	-
2019 ZK-02410	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.68	-
2022 SK-00426	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00781	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.004	-
2020 SS-00279	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.48	-
KM-00279	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.018	-
2001 SST-00002	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.13	-
2021 SS-40493	2025/12/18	6	F1-ICWBL-58	0.004	0.004	0.007	-
ZK-00736	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00687	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.018	-
ZK-00423	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.28	-
2021 FU-00220	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.069	-
2021 SS-40502	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.39	-
ZK-00865	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
TB-132	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-01294	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.083	-
2021 SS-40231	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.010	-
2020 SS-00054	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.36	-
2020 SS-00430	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.038	-
ZK-00597	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.006	-
ZK-00489	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-01250	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00926	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
TB-104	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.008	-
ZK-00709	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00721	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.004	-
2020 ZK-03327	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.043	-
2021 SS-10237	2025/12/19	6	F1-ICWBL-249	0.004	0.004	0.058	-
ZK-00550	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.004	-
2020 FU-00203	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.13	-



瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2018 FU-00079	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.084	-
2021 SS-40464	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.012	-
2021 SS-40252	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.007	-
ZK-00692	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.006	-
ZK-00546	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.018	-
ZK-01044	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.009	-
2021 SK-00160	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.008	-
2022 CT-00080	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.13	-
2021 ZK-04860	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-40248	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.007	-
TB-218	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.004	-
ZK-00414	2025/12/22	6	F1-ICWBL-58	0.004	0.004	0.008	-
2021 ZK-04947	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.30	-
2020 SS-00088	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.66	-
2021 SS-40470	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.69	-
2021 SS-40400	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.68	-
2020 ZK-04536	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.064	-
2019 ZK-02816	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.31	-
ZK-01142	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.013	-
TB-265	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.004	-
2020 ZK-03472	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.41	-
2019 ZK-02957	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.004	-
2020 ZK-03555	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.056	-
2019 NS-00056	2025/12/23	6	F1-ICWBL-249	0.004	0.004	0.034	-
2019 FU-00239 G	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00558	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.008	-
TB-213	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.004	-
2019 ZK-03042	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.004	-
2021 SS-40123	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.004	-
ZK-00621	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.004	-
2019 ZK-02703	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.58	-
ZK-00750	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.017	-
2020 ZK-03571	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.049	-
ZK-00476	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.006	-
2022 CT-00044	2025/12/24	6	F1-ICWBL-249	0.004	0.004	0.13	-
2021 SS-10031	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.60	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m <sup>3</sup> )	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				$\gamma$	$\beta + \gamma$	$\gamma$	$\beta + \gamma$
2021 SS-40465	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.31	-
2021 SS-40392	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.61	-
2022 FU-00016	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.22	-
2021 SS-40530	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-30147	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.010	-
2021 SS-40121	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.004	-
2020 SS-00409	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.99	-
2021 SS-40113	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.004	-
2021 SS-30415	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.058	-
2019 ZK-03107	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.004	-
2019 SS-00238	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.11	-
2019 SS-00108	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.032	-
2021 FU-00127	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.53	-
2022 SK-00747	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.045	-
2020 SS-00087	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.53	-
2022 SK-01035	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.40	-
2021 SS-30042	2025/12/25	6	F1-ICWBL-58	0.004	0.004	0.095	-