

Analysis Results of the Air (Pu · Sr)

Place of Sampling	Date and Time of Sampling	Analysis Item			
		Pu-238 (Bq/cm ³)	Pu-239+240 (Bq/cm ³)	Sr-89 (Bq/cm ³)	Sr-90 (Bq/cm ³)
West gate of the Fukushima Daiichi	2025/10/03 05:28 ~ 2025/10/03 10:28	< 3.4E-11	< 3.2E-11	< 1.4E-08	< 4.5E-09

- Inequality sign (<: less than) indicates that measurement result is less than the detection limit (ND).
- “-” indicates that the item was not included in the measurement or the sampling was stopped.
- Values are expressed in exponential notation. For example, "3.1E+01" means "3.1×10¹" and equals 31. Similarly, "3.1E+00" means "3.1×10⁰" and equals 3.1, and "3.1E-01" means "3.1×10⁻¹" and equals 0.31.
- Analysed by Japan Chemical Analysis Center.