

Evaluation of the exposure dose of workers engaged in radiation work at
the Fukushima Daiichi Nuclear Power Station

August 28, 2026

Tokyo Electric Power Company Holdings, Inc.
Fukushima Daiichi D & D Engineering Company

TEPCO has been evaluating the exposure dose of workers who engaged in radiation work at the Fukushima Daiichi Nuclear Power Station under two types, internal and external exposure to radiation, and has submitted the evaluation results to the Ministry of Health, Labour and Welfare regularly.

TEPCO today submitted to the Ministry of Health, Labour and Welfare a report on the exposure dose evaluation the data of which are those we collected until the end of July 2026. Here is part of the report: the maximum value of the external exposure dose among the workers who engaged in the work at the power station in July was 5.96 mSv, and regarding the internal exposure dose, no significant value was measured.

Exposure Dose Distribution

1. Effective Dose from External Exposure

Table 1 shows the distribution of external exposure dose of workers who were involved in radiation work at the Fukushima Daiichi Nuclear Power Station for the past three months.

Table 1. External Exposure Dose

Dose Ranges (mSv)	May 2026			June 2026			July 2026		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 100	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	0	0	0	0	0	0	0	0
5-10	0	18	18	0	24	24	0	2	2
1-5	9	339	348	12	408	420	6	320	326
1 or less	981	6527	7508	1060	6754	7814	989	6863	7852
Total	990	6884	7874	1072	7186	8258	995	7185	8180
Maximum (mSv)	2.4	8.4	8.4	3.0	7.0	7.0	2.90	5.96	5.96
Average (mSv)	0.04	0.19	0.18	0.06	0.24	0.21	0.05	0.16	0.15

• The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.

2. Sum of External and Internal Exposure Dose (Effective Dose)

Table 2 shows the distribution of cumulative exposure dose of workers who are involved in radiation work at Fukushima Daiichi for five years, starting on April 1, 2026. Table 3 shows the distribution of cumulative exposure dose in the fiscal year of 2026. Two different periods of time are shown in the Table 2: from April 1, 2026 to June 30, 2026 and from April 1, 2026 to July 31, 2026, and in the Table 3: from April 1, 2026 to June 30, 2026 and from April 1, 2026 to July 31, 2026, for comparison.

Table 2. Cumulative Exposure Dose for Five Years

Dose Ranges (mSv)	April 2026 - June 2026			April 2026 - July 2026			Difference		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 100	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	23	23	0	42	42	0	19	19
5-10	1	175	176	4	252	256	3	77	80
1-5	39	848	887	53	1042	1095	14	194	208
1 or less	1218	7238	8456	1256	7352	8608	38	114	152
Total	1258	8284	9542	1313	8688	10001	55	404	459
Maximum (mSv)	5.2	13.8	13.8	5.60	13.8	13.8	-	-	-
Average (mSv)	0.13	0.54	0.49	0.17	0.65	0.59	-	-	-

• The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.

• No significant internal exposure has been reported since October 2011.

Table 3. Cumulative Exposure Dose in the Fiscal Year of 2026

Dose Ranges (mSv)	April 2026 - June 2026			April 2026 - July 2026			Difference		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 100	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	23	23	0	42	42	0	19	19
5-10	1	175	176	4	252	256	3	77	80
1-5	39	848	887	53	1042	1095	14	194	208
1 or less	1218	7238	8456	1256	7352	8608	38	114	152
Total	1258	8284	9542	1313	8688	10001	55	404	459
Maximum (mSv)	5.2	13.8	13.8	5.60	13.8	13.8	-	-	-
Average (mSv)	0.13	0.54	0.49	0.17	0.65	0.59	-	-	-

• The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.

3. Sum of External and Internal Exposure Dose of Workers Exposed to Especially High Radiation (Effective Dose)

Table 4 shows the distribution of cumulative exposure dose of workers exposed to especially high radiation.*1

Table 4. Cumulative Exposure Dose (workers exposed to especially high radiation)

Dose Ranges (mSv)	March 2011 - September 2015
Above 100	1
75-100	191
50-75	233
20-50	267
10-20	186
5-10	129
1-5	145
1 or less	51
Total	1203
Maximum (mSv)	102.69
Average (mSv)	36.49

(Since October 2015, TEPCO Holdings has opted not to report to the Labour Standards Inspection Office about workers exposed to especially high radiation.)

*1. Workers exposed to especially high radiation means workers who are involved in operations in which they could be exposed to the emergency exposure dose limit (100 mSv), which is stipulated in "Ordinance on Prevention of Ionizing Radiation Hazards, Chapter 7." In more detail, they are workers engaged in the work to maintain the function of the cooling facility to cool down the reactor facility or the spent fuel tank in the reactor facility, the steam turbine and its related facilities or the surrounding area where the radiation doses exceed 0.1 mSv/h. Or they are workers who would engage in keeping running the function to control or prevent the release of a large number of radioactive materials should it be likely to occur due to malfunction or damage of the reactor facility.

So far workers who have worked as "workers exposed to especially high radiation" are all TEPCO employees.

*2. The figures in the cumulative data during the period from March 2011 to September 2015 in Table 4 above include the numbers of workers who have been reported to work as “workers exposed to especially high radiation” at least once.

*3. The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.

*4. The figure shown in the dose range, “Above 100mSv,” in the cumulative data during the period from March 2011 to September 2015 is the figure when the March 2011 data of the internal exposure dose were reevaluated in July 2013.

4. Equivalent Dose

Table 5 and Table 6 show equivalent dose to the skin and the lens of the eye of the workers, respectively, who were involved in radiation work at the Fukushima Daiichi Nuclear Power Station for the past three months.

Table 5. Equivalent Dose to the Skin

Dose Ranges (mSv)	May 2026			June 2026			July 2026		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 500	0	0	0	0	0	0	0	0	0
300-500	0	0	0	0	0	0	0	0	0
250-300	0	0	0	0	0	0	0	0	0
200-250	0	0	0	0	0	0	0	0	0
150-200	0	0	0	0	0	0	0	0	0
100-150	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	0	0	0	2	2	0	0	0
5-10	0	28	28	0	42	42	0	4	4
1-5	10	409	419	12	487	499	6	340	346
1 or less	980	6447	7427	1060	6655	7715	989	6841	7830
Total	990	6884	7874	1072	7186	8258	995	7185	8180
Maximum (mSv)	2.4	9.7	9.7	3.0	10.4	10.4	2.89	6.47	6.47
Average (mSv)	0.05	0.24	0.21	0.07	0.29	0.26	0.05	0.18	0.16

• The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.

• Equivalent dose is a measure of the radiation dose to organs and tissues, and the equivalent dose limit to the skin is 500 mSv/year (the emergency exposure dose limit is 1 Sv).

• Equivalent dose to the skin is measured at a depth of 70 micrometers from the skin surface. When the equivalent dose is measured with a dosimeter other than the one put on around the chest and the abdomen, for example, a finger dosimeter, the maximum measurement value is counted as the equivalent dose.

Table 6. Equivalent Dose to the Lens of the Eye

Dose Ranges (mSv)	May 2026			June 2026			July 2026		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 150	0	0	0	0	0	0	0	0	0
100-150	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	0	0	0	0	0	0	0	0
5-10	0	24	24	0	29	29	0	4	4
1-5	10	354	364	12	425	437	6	340	346
1 or less	980	6506	7486	1060	6732	7792	989	6841	7830
Total	990	6884	7874	1072	7186	8258	995	7185	8180
Maximum (mSv)	2.4	9.9	9.9	3.0	7.6	7.6	2.89	6.47	6.47
Average (mSv)	0.05	0.20	0.18	0.06	0.25	0.23	0.05	0.18	0.16

- The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.
- Equivalent dose is a measure of the radiation dose to organs and tissues, and the equivalent dose limit to the lens of the eye is 50 mSv/year and 100 mSv/5 years (the emergency exposure dose limit is 300 mSv). The equivalent dose limit to the lens of the eye before April 1, 2021 was 150mSv/year (the emergency exposure dose limit was 300 mSv).
- The equivalent dose to the lens of the eye is measured at a depth of 1 centimeter for neutron ray, 3 millimeters for X-ray, gamma ray and beta ray from the skin surface. However, as for X-ray, gamma ray and beta ray, it is measured at a depth of 1 centimeter or 70 micrometer when deemed appropriate with consideration for radiation type and energy type (since April, 2021).

5. Cumulative Equivalent Dose

Table 7 and Table 8 show the distribution of cumulative equivalent dose to the skin and the lens of the eye of the workers, respectively, who were involved in radiation work at the Fukushima Daiichi Nuclear Power Station during two different periods of time, from April 1, 2026 to June 30, 2026 and from April 1, 2026 to July 31, 2026 for comparison.

Table 9 shows the distribution of cumulative exposure dose for five years, starting on April 1, 2026: from April 1, 2026 to June 30, 2026 and from April 1, 2026 to July 31, 2026 for comparison.

Table 7. Equivalent Dose to the Skin

Dose Ranges (mSv)	April 2026 - June 2026			April 2026 - July 2026			Difference		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 500	0	0	0	0	0	0	0	0	0
300-500	0	0	0	0	0	0	0	0	0
250-300	0	0	0	0	0	0	0	0	0
200-250	0	0	0	0	0	0	0	0	0
150-200	0	0	0	0	0	0	0	0	0
100-150	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	58	58	0	88	88	0	30	30
5-10	1	248	249	4	308	312	3	60	63
1-5	40	876	916	54	1070	1124	14	194	208
1 or less	1217	7102	8319	1255	7222	8477	38	120	158
Total	1258	8284	9542	1313	8688	10001	55	404	459
Maximum (mSv)	5.9	19.0	19.0	6.29	19.71	19.71	-	-	-
Average (mSv)	0.14	0.67	0.60	0.17	0.78	0.70	-	-	-

- The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.

- Equivalent dose is a measure of the radiation dose to organs and tissues, and the equivalent dose limit to the skin is 500 mSv/year (the emergency exposure dose limit is 1 Sv).

- Equivalent dose to the skin is measured at a depth of 70 micrometers from the skin surface. When the equivalent dose is measured with a dosimeter other than the one put on around the chest and the abdomen, for example, a finger dosimeter, the maximum measurement value is counted as the equivalent dose.

Table 8. Equivalent Dose to the Lens of the Eye

Dose Ranges (mSv)	April 2026 - June 2026			April 2026 - July 2026			Difference		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 150	0	0	0	0	0	0	0	0	0
100-150	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	28	28	0	47	47	0	19	19
5-10	1	197	198	4	282	286	3	85	88
1-5	40	853	893	54	1056	1110	14	203	217
1 or less	1217	7206	8423	1255	7303	8558	38	97	135
Total	1258	8284	9542	1313	8688	10001	55	404	459
Maximum (mSv)	5.2	16.5	16.5	5.69	16.5	16.5	-	-	-
Average (mSv)	0.14	0.57	0.51	0.17	0.69	0.62	-	-	-

- The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.
- Equivalent dose is a measure of the radiation dose to organs and tissues, and the equivalent dose limit to the lens of the eye is 50 mSv/year and 100 mSv/5 years (the emergency exposure dose limit is 300 mSv).
- The equivalent dose to the lens of the eye is measured at a depth of 1 centimeter for neutron ray, 3 millimeters for X-ray, gamma ray and beta ray from the skin surface. However, as for X-ray, gamma ray and beta ray, it is measured at a depth of 1 centimeter or 70 micrometer when deemed appropriate with consideration for radiation type and energy type.

Table 9. Equivalent Dose to the Lens of the Eye: Cumulative Exposure Dose for Five Years

Dose Ranges (mSv)	April 2026 - June 2026			April 2026 - July 2026			Difference		
	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total	TEPCO Employees	Contractors	Total
Above 100	0	0	0	0	0	0	0	0	0
75-100	0	0	0	0	0	0	0	0	0
50-75	0	0	0	0	0	0	0	0	0
20-50	0	0	0	0	0	0	0	0	0
10-20	0	28	28	0	47	47	0	19	19
5-10	1	197	198	4	282	286	3	85	88
1-5	40	853	893	54	1056	1110	14	203	217
1 or less	1217	7206	8423	1255	7303	8558	38	97	135
Total	1258	8284	9542	1313	8688	10001	55	404	459
Maximum (mSv)	5.2	16.5	16.5	5.69	16.5	16.5	-	-	-
Average (mSv)	0.14	0.57	0.51	0.17	0.69	0.62	-	-	-

- The values of the exposure dose and the number of the workers in the table above are subject to change, because there are cases that APD data are replaced with monthly dose data measured by integral dosimeters. Or the dose data of workers who wore only an integral dosimeter (ex., workers who entered only the Seismic Isolation Building) need to be updated in the table after the publication of the data.
- Equivalent dose is a measure of the radiation dose to organs and tissues, and the equivalent dose limit to the lens of the eye is 50 mSv/year and 100 mSv/5 years (the emergency exposure dose limit is 300 mSv).
- The equivalent dose to the lens of the eye is measured at a depth of 1 centimeter for neutron ray, 3 millimeters for X-ray, gamma ray and beta ray from the skin surface. However, as for X-ray, gamma ray and beta ray, it is measured at a depth of 1 centimeter or 70 micrometer when deemed appropriate with consideration for radiation type and energy type.