

Radiological Impact Assessment Report
Regarding the Discharge of ALPS Treated Water
into the Sea
(Design stage / Revised version)

April 2022

Tokyo Electric Power Company Holdings, Inc.

(This page is intentionally left blank)

Executive summary

This report compiles the results of the assessment of the radiological impacts on humans and the environment resulting from the discharge of the water treated by the Advanced Liquid Processing System (Multi-Nuclide Removal Facility, hereinafter called “ALPS”) (hereinafter, the water called “ALPS treated water”) from the Fukushima Daiichi Nuclear Power Station (hereinafter “FDNPS”) into the sea in accordance with the standards and guidelines established by internationally recognized organizations such as International Atomic Energy Agency (hereinafter called “IAEA”) and International Commission on Radiological Protection (hereinafter called “ICRP”).

This report first describes how contaminated water has been generated, managed, treated, and stored as a result of the accident of FDNPS following the Great East Japan Earthquake in 2011, and what on-going efforts are to ensure public and environmental safety (Chapter 1).

Next, the report describes how several proposals for handling of ALPS treated water have been discussed among experts for more than six years since the potential risk associated the storage of contaminated water became apparent in 2013 (Chapter 2), the purpose of this assessment (Chapter 3), the concept of this assessment (Chapter 4), and the mechanism to removal of the target nuclides by ALPS and the overview of the ALPS treated water discharge facility (Chapter 5), respectively.

Subsequent chapters 6 and 7 describe the assessment of the radiological impacts on humans and marine plants and animals. Each chapter details the concepts of source term, modeling of diffusion and transfer in seawater, exposure pathways, and establishment of representative persons and reference animals and plants, which are the main components of radiological impact assessment. The results of the sea diffusion simulation indicate that the concentration of radioactive materials exceeds the background level only within a few kilometers of sea area around the FDNPS because the discharged ALPS treated water is quickly advected and diffused by tidal currents, etc. (Details can be found in “the Summary of Evaluation” and chapter 6-1-3.(1) “Diffusion simulation result”).

The results of the assessment of the radiological impacts obtained by in-house and external experts based on the above-mentioned reasonable and conservative assumption indicate that (1) in the case of discharge of ALPS treated water from the seabed approximately 1km offshore from the FDNPS, the foreseeable radiological impact on the people who are most likely to be affected in the vicinity of the discharge point is sufficiently small, that is approximately 1/30,000 to 1/3,000 of Japanese safety standard set according to the international guidelines; (2) the impact on plants and animals inhabiting in 10km x 10km sea area around the FDNPS is only about 1/500,000 to 1/20,000 of the lower limit of the level proposed by ICRP as the threshold range beyond which there is concern that some impact may occur on the corresponding plants and animals (derived consideration reference level); and (3) the impact on areas far from the discharge point (transboundary impact) was evaluated undetectably low. This indicates that advanced water treatment by ALPS and the discharge plan to effectively use the period of time required for decommissioning will restrain the impacts on humans and marine plants and

animals, and the impacts will be well within Japan's regulatory standard in accordance with the internationally established safety guidelines.

Chapter 8 describes the considerations related to uncertainties in the assessments described above. It concludes that considering uncertainties does not impair the conservatism of the assessment.

Chapter 9 describes the monitoring plan to be implemented in conjunction with the discharge of ALPS treated water into the sea. This includes an enhanced and expanded monitoring plan that includes increased sampling points, target of measurement and frequency. This monitoring plan is regarded as appropriate based on the results of the radiological impact assessment conducted up to Chapter 7.

In preparing this report, TEPCO has invited external experts from domestic institutes and universities to review and obtain comments in three field of human radiation protection, environmental protection, and ocean diffusion calculation.

The assessments in this report were conducted on the based on the information available at the design stage of the plan regarding to the discharge into the sea. After the original report was published last November, this report was reviewed and revised based on the progress of our study, opinions received through the public comment survey, reviews by the IAEA experts, and discussions with the Nuclear Regulation Authority. TEPCO plans to further review the assessment and revise this report as necessary to reflect the progress of studies on design and implementation including rigorous selection of target nuclides for measurement, opinions from various sectors, and the knowledge obtained through cross-checks by third-party assessments, etc. and to reflect in the plan and other necessary items respectively.

Before discharging ALPS treated water, TEPCO will analyze the radionuclides contained in the ALPS treated water which is pre-diluted and publish the results. In addition, during the initial period of the water discharge into the sea, TEPCO will also directly confirm the conditions of mixing and dilution prior to the discharge into the sea, and publish the results. Moreover, for discharge into the sea, the plan is to start the discharge with a small amount of discharge, while monitoring the impact on the surrounding environment, etc. In the unlikely event of a malfunction of the dilution facility due to trouble, power failure, or other reasons, or if abnormal value is detected by monitoring enhanced and expanded after the start of discharge, TEPCO will stop discharging until it is confirmed that the conditions have been established for safe discharge and will make every effort to ensure the safety of human and marine plants and animals.

Table of Contents

| | |
|---|------------|
| Executive summary | ES-i |
| Overview of the assessment | Overview-i |
| 1. Background..... | 1 |
| 2. Consideration of handling of ALPS treated water | 4 |
| 3. Objectives of the assessment..... | 7 |
| 4. Concept of assessment..... | 8 |
| (1) Dose constraints | 8 |
| (2) About tritium | 9 |
| (3) Assessment of migration and accumulation of nuclides other than tritium | 10 |
| 5. Properties of ALPS treated water, etc. and discharge method..... | 13 |
| 5-1. Properties of ALPS treated water, etc..... | 13 |
| 5-2. Discharge method | 15 |
| 5-3. Facilities for discharge..... | 18 |
| 5-3-1. Overview of the facilities for discharge | 18 |
| 5-3-2. Measurement/confirmation facility..... | 20 |
| 5-3-3. Transfer facility | 21 |
| 5-3-4. Dilution facility | 22 |
| 5-3-5. Discharge facility (related facility)..... | 23 |
| 6. Assessment of protection of humans (general public) | 27 |
| 6-1. Exposure assessment under normal conditions | 27 |
| 6-1-1. Assessment procedure | 27 |
| 6-1-2. Assessment method | 28 |
| (1) Source term (annual discharge amount of each nuclide)..... | 28 |
| (2) Modeling of diffusion and transfer after discharge | 38 |
| (3) Setting of exposure pathways | 42 |
| a. External exposure | 43 |
| b. Internal exposure | 48 |
| (4) Setting of the representative person subject to the exposure assessment..... | 70 |
| (5) Dose assessment method | 74 |
| 6-1-3. Assessment result..... | 75 |
| (1) Diffusion simulation result..... | 75 |
| (2) Concentration of each nuclide used for the assessment in the seawater | 86 |
| (3) Exposure assessment result | 93 |
| 6-2. Potential exposure assessment..... | 98 |
| 6-2-1. Assessment method | 98 |
| (1) Identification and selection of potential exposure scenarios | 98 |
| (2) Source term (daily discharge amount of each nuclide) | 100 |

| | | |
|--------|---|-----|
| (3) | Modeling of diffusion and transfer, and exposure pathway | 112 |
| (4) | Setting of the representative person | 113 |
| (5) | Dose assessment method | 113 |
| 6-2-2. | Assessment result..... | 114 |
| (1) | Concentration in the seawater used for the assessment | 114 |
| (2) | Exposure assessment result | 122 |
| 7. | Assessment regarding environmental protection | 123 |
| 7-1. | Concept of assessment..... | 123 |
| 7-1-1. | Assessment procedure | 123 |
| 7-2. | Assessment method..... | 124 |
| 7-2-1. | Source term | 124 |
| 7-2-2. | Modeling of diffusion and transfer after discharge | 124 |
| (1) | Selection of the migration model | 124 |
| (2) | Assessment of advection and diffusion in the sea area | 124 |
| 7-2-3. | Setting of exposure pathways | 124 |
| 7-2-4. | Selection of reference plants and animals (organisms to be assessed) | 127 |
| 7-2-5. | Dose assessment | 127 |
| 7-3. | Assessment result..... | 137 |
| 7-3-1. | Concentration in the seawater used for the assessment | 137 |
| 7-3-2. | Exposure assessment result | 145 |
| 8. | Discussion about the uncertainty of the assessment | 146 |
| 8-1. | Uncertainty included in the selection of the source term..... | 146 |
| 8-1-1. | Uncertainty of the composition of nuclide (epistemic uncertainty) | 146 |
| 8-1-2. | Uncertainty of analysis (aleatory uncertainty)..... | 147 |
| 8-1-3. | Summary of the uncertainty of the source term..... | 147 |
| 8-2. | Uncertainty of modeling of diffusion and transfer in the environment..... | 155 |
| 8-2-1. | Uncertainty of meteorological and oceanographic data, etc. (aleatory uncertainty) | 155 |
| 8-2-2. | Uncertainty of the simulation model itself (epistemic uncertainty)..... | 155 |
| 8-2-3. | Uncertainty in the selection of migration pathways (epistemic uncertainty) | 155 |
| 8-2-4. | Uncertainty in the concentration factor of seafood and the distribution coefficient of seabed sediment (epistemic uncertainty) | 156 |
| 8-3. | Uncertainty in the setting of exposure pathways..... | 156 |
| 8-3-1. | Uncertainty in the selection of exposure pathways (epistemic uncertainty) | 156 |
| 8-4. | Uncertainty in the selection of the representative person | 158 |
| 8-4-1. | Uncertainty in the actual life of the representative person (aleatory uncertainty) ... | 158 |
| 8-4-2. | Uncertainty in the selection of the representative pathway (epistemic uncertainty) | 158 |
| 8-4-3. | Uncertainty depending on the range of the sea area to be assessed (epistemic uncertainty) | 159 |
| 8-5. | Summary about uncertainty..... | 159 |

| | | |
|--------|--|-----|
| 9. | Monitoring to be performed in response to discharge of ALPS treated water into the sea | 161 |
| 9-1. | Analytical capability in the Fukushima Daiichi Nuclear Power Station | 161 |
| 9-1-1. | Analytical capability in terms of facilities..... | 161 |
| 9-1-2. | Analytical capability in terms of competence..... | 163 |
| 9-1-3. | Our management and supervision | 166 |
| 9-2. | Monitoring within the premises of the Fukushima Daiichi Nuclear Power Station | 168 |
| 9-2-1. | Source monitoring..... | 169 |
| 9-2-2. | Monitoring at the discharge vertical shaft (upper-stream storage) | 175 |
| 9-2-3. | Monitoring in seawater piping | 176 |
| 9-3. | Monitoring outside of the premises of the Fukushima Daiichi Nuclear Power Station | 179 |
| 9-3-1. | Sea area monitoring around the Fukushima Daiichi Nuclear Power Station by TEPCO..... | 180 |
| 9-3-2. | Monitoring by the government and Fukushima prefecture..... | 186 |
| (1) | Previous sea area monitoring performed by the government and Fukushima..... | 186 |
| a. | Seawater | 186 |
| b. | Seabed sediment | 187 |
| c. | Marine organisms..... | 187 |
| (2) | Sea area monitoring enhanced and expanded by the government in response to discharge of ALPS treated water | 187 |
| a. | Seawater..... | 187 |
| b. | Marine biota | 189 |
| (3) | Seawater monitoring enhanced and expanded by Fukushima prefecture in response to discharge of ALPS treated water | 191 |
| (4) | Cooperation with the IAEA for sea area monitoring by the government and IAEA marine monitoring | 193 |
| 9-4. | Actions to be taken in case of abnormalities..... | 194 |
| 9-5. | Summary of monitoring | 195 |
| 10. | Summary..... | 196 |
| | References..... | 197 |
| | Terms | 199 |
| | Preparation member..... | 201 |

Attachment

| | |
|-----------------|---|
| Attachment I | Rationale behind the selection of nuclides subject to removal by ALPS |
| Attachment II | Properties of ALPS treated water, etc. |
| Attachment III | Impact of the organically bound tritium in the exposure assessment of tritium |
| Attachment IV | Analysis on the period of discharge of ALPS treated water |
| Attachment V | Impacts of intake and discharge of diluted water on outside |
| Attachment VI | Transfer pathways and exposure pathways |
| Attachment VII | Validity of the diffusion simulation |
| Attachment VIII | Difference in the diffusion area by discharge location |
| Attachment IX | Contribution to the undetected nuclides in the source term based on the measured value |
| Attachment X | Breakdown of the exposure assessment result by nuclide |
| Attachment XI | Conservativeness of the external exposure dose conversion factor (Comparison with the dose conversion factor of FGR-15) |
| Attachment XII | Impact of the assessment range of concentrations in seawater used for the assessment of exposures |

References

- Reference A Site boundary dose assessment of Fukushima Daiichi and the regulatory concentration limit in the Japanese laws
- Reference B Timeline of consideration of each disposal method of ALPS treated water
- Reference C Setting of Management Values and Exposure Assessment of Hypothetical ALPS Treated Water
- Reference D Assessment result of environmental impacts including other elements than radiation related to discharge of ALPS treated water
- Reference E State of consultation with domestic and foreign stakeholders

(This page is intentionally left blank)

Overview of the assessment

We conducted the dose assessment for humans in respect of the planned discharge, as described in the IAEA safety standard document GSG-9 “Regulatory Control of Radioactive Discharges to the Environment” [1] (hereinafter called “GSG-9”) as well as conducted the dose assessment of potential exposure¹ and environmental protection, which is out of scope of the assessment under GSG-9, based on the current consideration of the discharge method of ALPS treated water into the sea. The specific procedure of the assessment follows the IAEA safety standard document GSG-10 “Prospective Radiological Environmental Impact Assessment for Facilities and Activities” [2] (hereinafter called “GSG-10”). The result of this assessment finds that advanced water treatment by ALPS and the discharge plan that effectively utilizes the decade-long decommissioning period will restrain the impact of discharge of ALPS treated water into the sea on humans and marine plants and animals, and will keep within the domestic safety standard determined in accordance with the internationally established safety guidelines.

In compiling this report, in-house experts with knowledge on the radiological impact assessments were selected and assigned, and external experts were invited as members to submit their opinions in three fields of human radiation protection, environmental protection, and marine diffusion calculation.

In this report, the contents conducted by the government on handling of ALPS treated water and enhancement and expansion of future monitoring are also taken into account.

Assessment of radioactive nuclides and diffusion

The nuclides to be assessed are a total of 64 nuclides including tritium (H-3), carbon 14 (C-14), and 62 nuclides subject to removal by ALPS (for the rationale behind the procedure to estimate radioactive materials contained in contaminated water and select 62 nuclides as nuclides subject to removal by ALPS, see Attachment I “Rationale behind the selection of nuclides subject to removal by ALPS”). The nuclide composition of ALPS treated water differs for each tank groups² depending on the composition and concentrations of radioactive materials in contaminated water before treatment, and lifetime of each adsorbent at the time of treatment in ALPS, etc. Therefore, the nuclide compositions of ALPS treated water used for the assessment were the nuclide compositions of the three tank groups in which measurement and assessment of 64 nuclides had actually been completed (for details, see 6-1-2.(1)).

¹ Potential exposure: Exposure caused by possible events in operation or events or possible events sequences including accidents of radiation sources or failures and operation mistakes of equipment. It was considered for the future.

² Multiple tank groups used in connection. Usually, 1 tank group consists of about 8 to 10 tanks.

According to the Japanese regulatory standard based on the internationally recognized guidelines specified by ICRP [3], it is stipulated that the sum of the ratios of concentrations to the regulatory concentration limits³, which are the regulatory standards, (hereinafter called “the sum of the ratios to regulatory concentrations limits”⁴) should be less than 1 after dilution with a large amount of seawater at the discharging point. However, we have decided to minimize the amount of radioactive materials discharged into the environment as possible by appropriately treating nuclides other than tritium using water treatment facilities including ALPS, and reducing the sum of the ratios to regulatory concentrations limits less than 1 before dilution. In other words, we will not only confirm that the results of the individual assessments of radioactive nuclides such as cesium 137 (Cs-137) and iodine 129 (I-129) are below the regulatory standards, but also manage to ensure never to exceed the regulatory standards even when the overall effect of the overlapping effects of all those multiple radionuclides is taken into account.

Tritium is an isotope of hydrogen. In most cases, it exists as the molecule, which is one of the two hydrogen atoms in normal water molecule (H₂O) replaced by one tritium atom (HTO in chemical formula). The tritium concentration in the water stored in the tanks exceeds 60,000 Becquerel⁵ (Bq)/L, which is the regulatory standard value (regulatory concentration limit), even after treatment by ALPS, etc., and tritium is almost impossible to remove, so the water shall be diluted until it meets the regulatory standard. In addition to strict compliance with regulatory standards to protect the public, the government required us to ensure that the tritium concentration of ALPS treated water at the point of discharge does not exceed 1,500Bq/L⁶, which is much sufficiently lower compared to the level of regulatory concentration limit, in order to dispel any concerns of consumers and others and to control reputational effects to the maximum extent possible. In “TEPCO Holdings’ Action in Response to Government’s Policy on the Handling of the ALPS Treated Water from the Fukushima Daiichi Nuclear Power Station” (hereinafter called “TEPCO’s Action in response to Government’s Policy,”) we stipulated that we shall keep the tritium concentration in the discharged water less than 1,500Bq/L and set the upper limit of the annual discharge amount

³ The regulatory concentration limit is the standard of discharge of radioactive waste into the sea set for each radioactive nuclide in “Pronouncement which set the dose limit based on the regulations such as the Regulations on Business of Smelting of Nuclear Source Materials or Nuclear Fuel Materials.” If a person drinks 2L of water equivalent to the regulatory concentration limit every day all their life (for 70 years in the case of an adult), the annual exposure dose will be 1 mSv/year.

⁴ Sum of the ratios to the regulatory concentration limits [34], which are legal concentration limits specified for each nuclide in the case that multiple radioactive materials, are contained. If multiple radioactive materials are contained, the sum of the ratio to the concentrations to the regulatory concentration limit specified for each nuclide by laws must be less than 1.

⁵ Unit indicating the amount of radiation. Becquerel is the number of nuclei whose radioactive nuclide changes into another one by radioactive disintegration in one second.

⁶ It is set to the same value as the operation target value of the discharge concentration of the groundwater bypass and subdrain, through which water has been discharged. This value has been described in “Implementation plan III 3.2.1 Management of radioactive waste, etc.” and permitted by the Nuclear Regulation Authority.

The tritium concentration of 1,500Bq/L is 1/40 of the regulatory concentration limit of 60,000Bq/L and about 1/7 of 10,000Bq/L, which is the WHO Guidelines for Drinking Water Quality.

22 TBq⁷ (2.2E+13Bq)⁸. To keep the tritium concentration in the discharged water less than 1,500Bq/L, the ALPS treated water shall be diluted with seawater at least 100 times or more (at most 1,400 times or more considering the maximum measured tritium concentration of approximately 2.16 million Bq/L in the water stored in the tank measured so far) before discharge.

The concentration of nuclides other than tritium in the ALPS treated water is already below the regulatory standard even before the dilution. The concentration will be further reduced by dilution with seawater. Therefore, the sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium in discharged water after seawater dilution is less than 0.01, and the impact of radiation will be further reduced (for details, see 5-2).

The diffusion calculation for the discharged water into the sea area was executed by the model of the sea area near the FDNPS using a high resolution, based on the model [4] whose reproducibility had been verified by the reproduction calculation of the cesium concentration in the seawater after the accident of the FDNPS (for details, see 6-1-2.(2)). For the assessment, only the radiation amount per unit time of tritium released (flow rate and concentration are not considered) is used in the diffusion calculations. Therefore, the effect of dilution is not considered in this assessment.

In this assessment, the concentration of radioactive materials in seawater does not take into account the decrease in dissolved concentration through absorbance of radionuclides to seabed and other materials. On the other hand, the concentration of radionuclides in fish, shellfish and seabed sediment assumed to be in equilibrium with the concentration in seawater after the adsorption, etc. (no further adsorption occurs). Also it is assessed using concentration coefficient and concentration ratio including the impact to the food chain. In reality, it takes a long period of time for radionuclides in seawater, fish and shellfish and seabed sediment to reach an equilibrium, however by using conservative assumptions mentioned above, this model verifies that there is no further increase in exposure to humans, fish and shellfish even if the discharge continues for a long time. This assessment actually verified the impact for a year of discharge of ALPS treated water, and it can also verify accumulation of radioactive materials in the environment for long term discharge (For details, see 4.(3)).

Human exposure pathways

In the setting of exposure pathways, they are roughly divided into external exposures and internal exposures. In line with previous practice, etc.⁹, external exposures were assessed

⁷ Target discharge control value of the FDNPS before the accident.

⁸ E+XX means the XXth power of 10. 2.2E+13 indicates 2.2×10¹³.

⁹ Handbook for Determining Environmental Impacts of Decommissioning Work, etc. For details, see Chapter 6.

assuming the following five pathways: (1) external exposure from the sea surface, (2) external exposure from ship hulls, (3) external exposure under water during swimming, etc., (4) external exposure from beach sands, and (5) external exposure from fishing nets. Internal exposure was assessed assuming the following three pathways: (6) internal exposure from ingestion of seawater, (7) internal exposure from inhalation of seawater spray, and (8) internal exposure from ingestion of seafood (for details, see 6-1-2.(3)).

The exposure pathway to human is set with an assumption of a representative person in vicinity of the discharge point who are considered most affective. For the living habits and characteristics of the representative person for some exposure pathways should be used the highest group (e.g. 95 percentile value) from some lifestyle data distribution, etc. However, in considering current situation around FDNPS, we have instead assumed the representative persons are engaged in fishing for 120 days a year (2,880 hours), of which they work near fishing nets for 80 days (1,920 hours), stay on the seashore for 500 hours, and swim for 96 hours, according to “Dose Assessment to the General Public in the Safety Review of Commercial Light Water Reactor Facilities” [5]. Following the preconditions, the ingestion amount of seafood was investigated for two cases based on the ingestion amount data from “National Health and Nutrition Survey in Japan in 2019” [6] for each of (1) person who ingest an average amount of seafood and (2) person who ingest more seafood than average (one fifth of the amount of an adult for an infant, and half of the amount of an adult for child under school age) (for details, see 6-1-2.(4)).

The result of the assessments was compared with the dose limit¹⁰ of 1mSv/year for the general public, and the dose constraint¹¹ of 0.05 mSv/year established by the Nuclear Regulation Authority, and the sum of internal and external exposure was below both the public dose limit and the dose constraint in all cases¹². The dose limit of 1 mSv/year is the internationally recognized standard of public exposure (for details, see 6-1-3).

In addition, the potential exposure assessment based on the IAEA safety standard¹³, which was also conducted, assumed that (1) in case of leakage from the piping, a piping rupture occurs near the ocean and all the ALPS Treated Water about 10,000 m³ in one group of tanks at the facility for measurement and confirmation of water is discharged from north breakwater into the ocean for 20days without being diluted, as well as (2) the case of massive leakage from tanks, all three groups of tanks for measurement and confirmation are

¹⁰ Dose limit: Effective dose or equivalent dose to a person which must not be exceeded in the planned exposure situation (GSR Part 3).

¹¹ Dose constraint: Predictive value of individual dose related to radiation sources used as a parameter for the optimization of protection and safety at the radiation source in planned exposure situation. It is useful as the boundary for setting of the range of options in optimization. For public exposure, this is a value related to the radiation source established or approved by the government or regulatory body considering the dose from planned handling of all radiation sources under control (GSR Part 3).

¹² The dose limit is the limit for the total of the exposure amount of an individual from all related acts subject to the regulations. The dose constraint is used as the limit value of the dose from a specific radiation source related to a planned act.

¹³ GSG-10

damaged simultaneously due to great earthquake, etc. and of 30,000 m³ of ALPS treated water is discharged into the sea in a single day. In this case, the migration pathways and exposure pathways of this case shall be the same as for normal exposure excluding for the discharge location near the north breakwater. The exposure time of leakage from piping is conservatively set to about one month (27 days), and about one week (8 days) in the case of huge earthquake. As a result, even in such cases, the effective dose of potential exposure was significantly smaller compared to the standard of the accident assessment shown in the IAEA safety standard¹³ (for details, see 6-2).

Impact on marine plants and animals

As the assessment of environmental protection, we also assessed the protection of plants and animals during normal operation of the facility for discharging ALPS treated water according to the procedure shown in Annex I of the IAEA safety standard¹³. As the composition of nuclides in ALPS treated water used in the assessment, three cases based on the measured values were adopted in the same way as the human exposure assessment. As the plants and animals to be assessed, the standard flatfish (left-eyed and right-eyed flounders), the standard crabs (*Ovalipes punctatus* and *Portunus trituberculatus*) and the standard brown seaweeds (*Sargassum* and *Eisenia bicyclis*) were selected from the list of standard animals and plants¹⁴ indicated by the guideline of ICRP. The dose was assessed by the method shown by ICRP and the dose rate in the habitat of the standard animals and plants was compared with the derived consideration reference level (DCRL)¹⁵. As a result, all dose rates in the habitats of the standard animals and plants are much less than the lower limit value of the derived consideration reference level (for details, see Chapter 7). Just for a precaution, the evaluation results of environmental impact from the factors other than radioactive materials from the ALPS treated water reveal that there is no severe pollution or no serious and hazardous changes to the environment (for details, see Reference D "Assessment result of environmental impacts including other elements than radiation related to discharge of ALPS treated water").

Changes in response to new information and the result of monitoring

The assessment described in this report was conducted based on the information available at this point in time during the design stage of the plan for discharge into the sea. After the original report was issued last November, and revised based on the assessment reflecting

¹⁴ Standard animals and plants: Specific types of animals and plants assumed in order to associate radiation exposure from the environment with the dose and impact.

¹⁵ Derived consideration reference level (DCRL): Range of the dose rates within a range of one digit specified for each species advocated by ICRP. Dose rate level at which the impact has to be considered if is exceeded.

the comments received from the public, comments pointed out by the Nuclear Regulation Authority, the findings of review by the IAEA, etc. We are planning to revise this report further in order to reflect findings obtained through consideration of design and operation associated with the plan, opinions from various sectors, reviews by experts of the IAEA, cross-checks by third-party assessments, etc., and to modify the planned discharge program and its implementation as necessary.

Before discharging ALPS treated water, we will analyze the radionuclides contained in the ALPS treated water before dilution, and publish the results. In addition, during the initial period of the water discharge into the sea, we will also directly confirm the conditions of mixing and dilution before discharge into the sea and publish the results. Moreover, for discharge into the sea, TEPCO will carefully start the discharge with a small amount while monitoring the impact on the surrounding environment, etc. In case that the dilution facility fails due to malfunction, power failure, or other reasons, or if abnormal value is detected by monitoring after the start of discharge, TEPCO will stop discharge until it is confirmed that the conditions for safe discharge of the ALPS treated water have been securely re-established, and make every effort to ensure the safety of human and marine plants and animals.

This report concludes that the result of the assessment according to internationally recognized documents shows that exposure from radioactive materials contained in ALPS treated water discharged from the FDNPS is sufficiently lower than the dose limit, the dose constraint and the derived consideration reference level.

1. Background

At the FDNPS, which experienced an unprecedented accident in the event of the Great East Japan Earthquake in 2011, it has been continued to inject of cooling water into the reactor in order to cool the damaged reactor and nuclear fuel since the accident. The injected water contacts so-called fuel debris, which is fuel overheated, damaged, and molten in the event of the accident, and then solidified together with surrounding structures, passes through the reactor pressure vessel and reactor containment vessel damaged by the accident, and finally got stagnant on the lowest floor of the reactor building as building stagnant water (hereinafter called “stagnant water”). According to the previous investigation, it has turned out that stagnant water contains damaged fuel and structures of reactor core due to the damage in the event of the accident, or a high volume of water-derived radioactive materials, which are reactor coolants. From the viewpoint of prevention of diffusion of radioactive materials into the environment, it is especially necessary to prevent leakage of stagnant water outside the building.

On the other hand, seawater entered the basement floor of the building due to the tsunami, which was the direct cause of the accident, and then became stagnant water. In addition, rainwater has been entering the building through the ceiling damaged due to debris scattered by the hydrogen explosion of the reactor buildings that occurred in Units 1, 3, and 4 in the event of the accident. Moreover, the underground water level around the building is kept a little higher than the stagnant water level to prevent leakage of stagnant water mentioned above, which cause a little amount of groundwater to enter the building. It is considered that all of such water is mixed with the cooling water mentioned above and becomes new contaminated water.

Currently, by multilayered countermeasures¹⁶, we manage to prevent leakage of contaminated water out of the building and also reduce the daily generated amount from about 540 m³ (as of May 2014) to about 140 m³ (as of 2020), and we are aiming to further reduce the daily generated amount to less than 100 m³ by 2025. The contaminated water which will be generated in future must be treated in the same way and discharged appropriately.

¹⁶ Examples of multilayered countermeasures:

- a To reduce the generated amount of contaminated water, contaminated water pumped and purified by the cesium adsorption device and desalinated by the reverse osmosis membrane device is reused as cooling water used to cool the nuclear fuel damaged by the accident.
- b In addition, the amount of groundwater entering the building is controlled. Specifically, the groundwater level near the building is kept low by pumping groundwater from uplands and the area adjacent to the building, installing land-side impermeable walls (frozen soil walls) around the building, etc.
- c To prevent leakage of contaminated water generated in the building to outside the system, the contaminated water level in the building is kept a little lower than the groundwater level outside the building by pumping contaminated water in the building.
- d Pumped contaminated water is stored in tanks installed on uplands after treatment by water treatment facilities which consist of the cesium adsorption device, ALPS, etc., in order to prevent contamination and reduce the dose.

Contaminated water is purified by the cesium adsorption equipments¹⁷ and ALPS, which can remove 62 nuclides, and stored in tanks on the site. ALPS treatment makes the sum of the ratios to regulatory concentrations limits of nuclides other than tritium less than 1 (water in which the sum of the ratios to regulatory concentrations limits of nuclides other than tritium is less than 1 is called “ALPS treated water.” Water in which the sum of the ratios to regulatory concentrations limits is not less than 1 even after treatment is called “treated water to be purified.” “ALPS treated water” and “treated water to be purified” are collectively called “ALPS treated water, etc.”) (See Reference A “Site boundary dose assessment of Fukushima Daiichi Nuclear Power Station and the regulatory concentration limit in the Japanese laws”). As of January 2022, there are 1,047 tanks that store strontium treated water (water before ALPS treatment)¹⁸ and ALPS treated water, etc., and the stored amount is about 1.29 million m³, while the capacity is about 1.37 million m³. Although it is necessary to carefully examine the effect of the measures to control the generation of contaminated water and prediction of the amount of contaminated water generated, the planned capacity is expected to reach after the summer of 2023.

As shown in “Mid- to Long-Term Roadmap towards Decommissioning of the Fukushima Daiichi Nuclear Power Station” [7] revised by the government at the ministerial meeting on decommissioning and contaminated water measures (current “the ministerial meeting on decommissioning, contaminated water and treated water measures”) in December, 2019, decommissioning at the FDNPS is a continuous risk reduction activity to protect people and the environment from risks associated with radioactive materials manifested by the accident. In the long-term process toward decommissioning of the FDNPS for several decades, it is necessary to deal with the issues with greater radiation risks such as extraction of fuel debris and securing temporary storage locations of spent fuel, and it is essential to steadily reduce total risks from medium- to long-term viewpoints in order to appropriately deal with these issues.

The requirement to reduce the overall risks with the view of medium- to long-term views is the same in handling the contaminated water problem. So far, we have been steadily reducing the risks to the dose of less than 1 mSv/year, which is the dose limit for general public recommended by the ICRP in Publication 60 issued in 1990, for additional exposure dose associated with decommissioning on the site boundary by controlling the amount of contaminated water generated containing large amount of radioactive materials through so-called multi-layered countermeasures, and by removing radioactive materials contained in contaminated water through water treatment facilities including ALPS. In order to safely and steadily proceed with the decades-long decommissioning, it is necessary to continue to steadily reduce overall risk at the FDNPS by removing as much radioactive material as

¹⁷ Equipments to purify contaminated water by adsorbing cesium and strontium.

¹⁸ Water with most of the cesium and strontium removed before purification by ALPS.

possible using water treatment facilities including ALPS, implementing discharge in a safe manner that does not substantially affect humans and plants and animals, and appropriately storing spent fuels in temporary storage in dry cask to be installed in the future.

2. Consideration of handling of ALPS treated water

The details are as described in Reference B “Timeline of consideration of each disposal method of ALPS treated water,” the method of handling of contaminated water and ALPS treated water, etc., has been discussed for several years initially with the Ministerial Conference of Contaminated Water, Treated Water and Decommissioning issues, the government, the IAEA, municipal administrations, local residents and experts. In 2013, the government established the Tritiated Water Taskforce under the Committee on Countermeasures for Contaminated Water Treatment, with participation of nine members of experts from the fields such as nuclear, environmental science, radiology, radiation biology, fish chemistry in addition to members from Nuclear Regulation Authority and related ministries. The Taskforce conducted technical studies on the five disposal methods (geosphere injection, discharge into the sea, vapor release, hydrogen release, and underground burial), which were proposed based on the scientific knowledge on tritium and the preceding cases [8]¹⁹. In addition, since 2016, the Sub-committee on Handling of ALPS Treated Water has been established with 13 members of experts from the fields of such as nuclear, geological engineering, sociology, environmental science, agriculture, radiation biology, radiation science, fish chemistry as well as members from related ministries, to conduct a comprehensive deliberations, including social viewpoints such as reputation damage based on the results of the Tritiated Water Taskforce [9]. The Sub-committee on Handling ALPS Treated Water compiled the report in February 2020, in which it examined five disposal methods from various perspective, including monitoring feasibility. The Sub-committee then stated that the methods of geosphere injection, hydrogen release and underground burial have many issues as realistic option in terms of regulatory, technology and time schedule, while the methods of the discharge into the sea and the vapor release are considered as more realistic options. The conclusion was that in comparison to the vapor release, the method of the water discharge into the sea has already established regarding the amount of release. Furthermore, the ease of handling of discharge facilities and the way of monitoring should be conducted. In accordance with these reasons, the Sub-committee also pointed out the limited room for expansion of tanks for long-term storage and the increased risk of leakage due to natural disasters and deterioration, and concluded that discharge of ALPS treated water into the sea ensure the steady implementation. In addition, the Government of Japan has Hosted the decommissioning review missions by the IAEA five times from 2013 to 2021 and has incorporated their opinions into considerations. The decommissioning review missions by the IAEA have pointed out the importance of the disposal plan for ALPS treated water. In the IAEA’s report in 2015, IAEA assessed that storage in tanks was “at best a temporary measure while a more sustainable

¹⁹ Discussion on continuation of tank storage was included.

solution was needed²⁰.” Subsequently, in the IAEA’s report in 2019, it was stated that “a decision on the disposition path for the stored ALPS treated water containing tritium and other radionuclides, after further treatment as needed, must be taken urgently²¹.”

In addition, in the report of the IAEA following-up review for the progress decommissioning of FDNPS in 2020, also assessed the technical aspects of the report of the Sub-committee, as being “based on a sufficiently comprehensive analysis and sound scientific and technical basis²².”

Moreover, after the report was compiled in the Sub-committee on the Handling of ALPS Treated Water, the government held the Meeting to hear the Opinions of Related Parties on the Handling of ALPS Treated Water and widely solicited for opinions including those in writing. As a result, among the submitted opinions, some expressed concerns about the impact of discharge of ALPS treated water into the sea on the surrounding environment, etc. Based on these considerations and opinions, the government announced the Basic Policy to handling ALPS treated water into the sea upon securing the safety as “Basic Policy on handling of ALPS treated water at the Tokyo Electric Power Company Holdings’ Fukushima Daiichi Nuclear Power Station” (April 13, 2021, the Ministerial Conference of Contaminated Water, Treated Water and Decommissioning, hereinafter called “Basic Policy”) [10].

Considering the Basic Policy, on April 16th of the same year, we announced “TEPCO’s Action in response to Government’s Policy” [11] which include the following approach:

- Regarding the discharge of the ALPS treated water into the sea, we will ensure the safety of the public, surrounding environment as well as agricultural, forestry and fishery products through compliance with safety standards based on relevant laws and legislations. We will take further measures based on international standards and practices to confirm the safety of the water to be discharged.
 - To ensure the safety of the public and surrounding environment, we will surely comply with regulatory standards and relevant laws for concentration of tritium and other radioactive materials in the water to be discharged, which are set based on international recognized methods (e.g. International Commission on Radiological Protection (ICRP) publication).
 - With regard to the radiological impact of the discharge on the humans and the environment under the condition indicated in the Basic Policy and international recognized method, we will assess its safety and publish the results prior to starting

²⁰ Mission Report, IAEA International Peer Review Mission on Mid-And-Long-Term Roadmap Towards the Decommissioning of TEPCO’s Fukushima Daiichi Nuclear Power Station Units 1-4, issued 13 May, 2015, p. 13, <https://www.iaea.org/sites/default/files/missionreport130515.pdf>

²¹ Mission Report, IAEA International Peer Review Mission on Mid-And-Long-Term Roadmap Towards the Decommissioning of TEPCO’s Fukushima Daiichi Nuclear Power Station Units 1-4, issued 31 January, 2019, p. 8, <https://www.iaea.org/sites/default/files/19/01/missionreport-310119.pdf>

²² Review Report IAEA Follow-up Review of Progress Made on Management of ALPS Treated Water and the Report of the Subcommittee on Handling of ALPS treated water at TEPCO’s Fukushima Daiichi Nuclear Power Station, issued 2 April, 2020, p. 6, <https://www.meti.go.jp/press/2020/04/20200402002/20200402002-2.pdf>

the necessary procedure for approval by Nuclear Regulation Authority. Additionally, we will receive reviews by experts such as those of International Atomic Energy Agency (IAEA) and others. (The original report was issued in November 2021. We will publish the results including this revision and continue to receive reviews by experts of IAEA, etc.)

3. Objectives of the assessment

The objective of this Radiological Impact Assessment is as follows.

Objective 1: Evaluate the impact of radiation on humans and the environment in the case of our disposal of ALPS treated water by the internationally recognized method (IAEA safety standard and ICRP recommendation).

Objective 2: Announce the result of the assessment inside and outside Japan and consider the method to minimize the risks associated with disposal by making revisions, etc., as needed considering opinions from related parties.

4. Concept of assessment

This report was drafted assuming a dose assessment of the representative person by planned discharge shown in GSG-9, but the specific assessment method was based on GSG-10 and we also assessed potential exposure and environmental protection, which is not required in GSG-9.

The following shows the concepts of the assumptions in the assessment and the evaluation method.

(1) Dose constraints

The Japanese nuclear regulation system does not specifically set any dose constraints²³ and instead sets a target dose value of 0.05 mSv/year for the general public outside the surrounding monitoring area of light water reactor for power generation in normal operation.

On February 16, 2022, the Nuclear Regulation Authority issued the “Concept and Assessment Guidelines for Verifications in the Radiological Impact Assessment,” which says that “it must be verified that the estimated result of the representative person is small when compared to the fluctuation range of the annual radiation dose in humans in the region are exposed to through their living habits, etc., that is less than 50 μSv/year. The value of 50 μSv/year is the target dose for commercial light water reactors in normal operation, which corresponds to the dose constraint set in the IAEA Safety Standards.” [12]. In this assessment, “Determine appropriate constraints” in GSG-9 Fig.3, “Steps in setting discharge limits, indicating those responsible.” corresponds to it and the target dose value of 50μSv/year = 0.05mSv/year as the dose constraint value.

However, the annual total amount of tritium contained in ALPS treated water actually discharged into the sea was specified in the Basic Policy of the Government of Japan before the assessment by this report, etc., in order to keep it below the discharge control value of 22 TBq/year (2.2E+13Bq/year) of the FDNPS before the accident from the viewpoints of various factors, such as the risk optimization of the whole of decommissioning, the effect of natural decay of radioactive materials expected during land storage of ALPS treated water, the leakage risk and occupational exposure during long-term storage, the plan to complete disposal of ALPS treated water before the completion of decommissioning, and the policy to dispel even little of the concerns of stakeholders. As shown in “TEPCO’s Action in response to Government’s Policy” (April 2021) above, we set the annual discharge amount of tritium to 22 TBq/year (2.2E+13Bq/year) as an evaluation condition of this report and assessed the impact of radiation.

The relationship between the dose constraint and the annual discharge amount of tritium of 22 TBq/year (2.2E+13Bq/year) is discussed in 6-1-3.

²³ See footnote No.12.

(2) About tritium

A part of tritiated water (HTO) is converted to organically bound tritium (OBT) by plants and animals, etc., in the environment.

The following shows the effective dose factor in the case of ingestion of tritium [13].

| | |
|-----------------|---------------|
| Tritiated water | 1.8E-11 Sv/Bq |
| OBT | 4.2E-11 Sv/Bq |

The effective dose factor of tritiated water reflects conversion of a part of tritium to OBT in the body after a human ingests tritium. As shown in Table II-9-1 and II-9-2 in chapter II-6 "Water quality other than radioactive materials" of Attachment II "Properties of ALPS treated water, etc.," the ALPS treated water to be discharged contains almost no organic matter and almost the whole of it is considered to be tritiated water when discharged, so the case of directly drinking seawater or inhaling seawater spray is assessed by the effective dose factor of tritiated water.

On the other hand, as with humans, a part of tritiated water is converted to OBT when ingested by plants and animals. If OBT is ingested directly through seafood, etc., the effective dose factor of OBT is applied, so for the ingestion of seafood, the effective dose factor is used after correction assuming that 10% of tritium ingested is OBT. Specifically, we used adult: 2.0E-11Sv/Bq, child under school age: 3.5E-11Sv/Bq, and infant: 7.0E-11Sv/Bq as the corrected effective dose coefficient of tritium for the exposure assessment of ingestion of seafood.

In monitoring of fish, we performed near the FDNPS, no OBT was detected and no event of concentration of tritium compared with the tritium concentration in the seawater in the surrounding area was observed. In addition, there is a general understanding that no evidence for biological concentration of OBT from HTO has been found in international studies [14]²⁴.

²⁴ For example, "Tritium and the environment," which was issued by Institute for Radiological Protection and Nuclear Safety in France in 2012 [14] says "To date, no phenomenon of tritium bioaccumulation has been observed in marine organisms on the French Channel coast. This observation leads to the conclusion that discharge from nuclear industry, led by the spent fuel processing plant in La Hague, are overwhelmingly in the form of HTO."

For OBT, see Attachment III “Impact of the organically bound tritium in the exposure assessment of tritium.”

(3) Assessment of migration and accumulation of nuclides other than tritium


The assessment of this report assumed that nuclides other than tritium was advected and diffused while dissolved in the seawater. A part of discharged nuclides is adsorbed to suspended particles in the seawater, seabed sediment, hulls, beach sand, and fishing nets, or advected or concentrated in marine organisms depending on the chemical forms of radioactive materials, etc., so the disposition in the environment is assumed not to be the same as that of tritium. As for this trend, the higher the distribution factor to seabed sediment, etc., or biological concentration factor the element has, the more significant the concentration decrease in the seawater side and the concentration increase in the soil and organism side may become because of more significant migration from the seawater to the soil and organisms.

However, ALPS treated water to be discharged is purified by coagulating sedimentation, adsorption, filtration, etc., and contains almost no impurities, so even if it is adsorbed to suspended particles, it will be unlikely that a lot of sediment is generated, and only a limited amount of seawater directly contacts the seabed sediment, etc., which means that initially the amount of radioactive materials adsorbed to seabed sediment is much smaller than the total amount of discharged radioactive materials. Therefore, while the decrease in the concentration in the seawater caused by adsorption to the seabed sediment in diffusion is not considered from the viewpoint of model simplification, considerations have been made so that such differences in the disposition in the environment need not be considered, by assuming that adsorption has proceeded until the concentration in the seawater reaches the equilibrium state as for adsorption to seabed sediment, etc., and biological concentration, which proceeds in the long term in reality, and setting both of them conservatively. This is shown in Figure 4-1.

For advection and diffusion in the sea, we also verified that annual variation was small, by simulated calculation of seven years


Thanks to these considerations, we can assess accumulation of radioactive materials in the environment due to long-term discharge, though this assessment is performed for just one year. Thus, the peak dose value is considered not higher than the value in this assessment.

Accumulation process in seabed sediment, etc. in actual phenomena




If discharge into the sea starts, advection and diffusion of radioactive materials discharged from the discharge outlet supplies radioactive materials, which increases the concentration in the seawater.

Supply of radioactive materials by advection and diffusion
=> Adsorption to suspended particles and adsorption and deposition on seabed sediment




Due to a rise in the concentration, some of the supplied radioactive materials are adsorbed to seabed sediment, suspended particles, etc. As a result, the radioactive material concentration in the seawater drops and the radioactive material concentrations in seabed sediment, suspended particles, etc., rises and reaches the equilibrium states depending on the distribution factors.

Supply of radioactive materials by advection and diffusion
=> Rise in the concentration



Then, more radioactive materials are discharged and the radioactive material concentration in the seawater rises.

Supply of radioactive materials by advection and diffusion
=> Rise in the concentration => Adsorption and deposition on seabed sediment



Some of the radioactive materials are adsorbed near seabed sediment, suspended particles, etc., the concentration in the seawater side drops, and the concentrations in seabed sediment and suspended particles rises and reaches equilibrium. Long-term repetition of this process raises the radioactive material concentrations in seabed sediment, suspended particles, etc., as well as the radioactive material concentration in the seawater, which reaches the equilibrium state.


| | | |
|----------------------|--|--|
| Model of this report |  <p>It is assumed that adsorption occurs but the concentration in the seawater does not drop.</p> <p>Balanced adsorption and separation</p> <p>adsorption</p> <p>separation</p> <p>It is assumed that adsorption on seabed sediment, etc., which instantaneously reaches the concentration at which there is no room for further adsorption (=equilibrium state) occurs</p> | <p>In this assessment, if radioactive materials are supplied due to advection and diffusion, radioactive materials will be accumulated instantaneously up to the equilibrium state, and the concentrations in seabed sediment, etc. set along with the concentration in the seawater.</p> <p>On the other hand, the concentration in the seawater was assumed not to drop even in the event of adsorption in seabed sediment, etc.</p> <p>This simulates the state that the seawater, seabed sediment, etc., reaches the equilibrium states (balance of adsorption and desorption) due to long-term continuation of discharge and no more adsorption occurs.</p> |
|----------------------|--|--|

Figure 4-1 Actual accumulation process in seabed sediment, etc., and model in this report (image)

5. Properties of ALPS treated water, etc. and discharge method

5-1. Properties of ALPS treated water, etc.

ALPS treated water, etc., of about 1.28 million m³ currently stored in tanks is water purified by ALPS (excluding strontium treated water), which is designed to be able to remove 62 nuclides excluding tritium and C-14 among the radioactive nuclides contained in contaminated water. Contaminated water newly generated during the period of discharge into the sea has to be treated appropriately by ALPS, etc., in the same manner and discharged into the sea. The rationale behind the selection of 62 nuclides subject to removal by ALPS is shown in Attachment I “Rationale behind the selection of nuclides subject to removal by ALPS” and the mechanism to remove radioactive materials from contaminated water is shown in Attachment II “Properties of ALPS treated water, etc.”

ALPS can purify 62 radioactive materials other than tritium and C-14 up to less than 1 of sum of the ratios to regulatory concentrations limits, but about 70% of ALPS treated water (based on the breakdown of the tank groups fully filled with water by December 31, 2019) is so-called “treated water to be purified,” which contains more radioactive materials other than tritium than the standard applicable to discharge into the environment (sum of the ratios to regulatory concentrations limits of less than 1) due to the treatment before performance improvement in the early stage of the treatment plan, priority on the treatment amount for reduction of additional exposure dose on the site boundary, etc. Such treated water to be purified, which is yet to be purified sufficiently, is surely purified until the sum of the ratios to regulatory concentrations limits of radioactive materials other than tritium becomes less than 1 before discharge (secondary treatment) and then discharged as ALPS treated water. Table 5-1-1 shows the regulatory concentration limit of tritium, C-14, and 62 nuclides subject to removal by ALPS.

As for the secondary treatment by ALPS, we conducted a secondary treatment performance verification test for a total of 2,000 m³ of two tank groups since September 2020 and verified that the sum of the ratios to regulatory concentrations limits of nuclides excluding tritium in each tank group can be reduced to less than 1 [15]. The water quality of ALPS treated water, etc., including the result of the secondary treatment performance verification test, is shown in Attachment II “Properties of ALPS treated water, etc.”

The targets in this report include not only about 1.28 m³ of ALPS treated water, etc., already stored in the FDNPS, but also contaminated water generated even after discharge into the sea is started, because such water is planned to be discharged into the sea as ALPS treated water after the purification by water treatment facilities including ALPS.

**Table 5-1-1 Regulatory concentration limits of
62 nuclides subject to removal by ALPS, tritium, and C-14**

| | Target nuclides (physical half-life) | Regulatory concentration limit (Bq/L) | | Target nuclides (physical half-life) | Regulatory concentration limit (Bq/L) |
|----|---|--|----|---|--|
| 1 | H-3 (about 12 years) | 6.0E+04 | 33 | Te-129m (about 34 days) | 3.0E+02 |
| 2 | C-14 (about 5700 years) | 2.0E+03 | 34 | I-129 (about 16 million years) | 9.0E+00 |
| 3 | Mn-54 (about 310 days) | 1.0E+03 | 35 | Cs-134 (about 2.1 years) | 6.0E+01 |
| 4 | Fe-59 (about 44 days) | 4.0E+02 | 36 | Cs-135 (about 2.3 million years) | 6.0E+02 |
| 5 | Co-58 (about 71 days) | 1.0E+03 | 37 | Cs-136 (about 13 days) | 3.0E+02 |
| 6 | Co-60 (about 5.3 years) | 2.0E+02 | 38 | Cs-137 (about 30 years) | 9.0E+01 |
| 7 | Ni-63 (about 100 years) | 6.0E+03 | 39 | Ba-137m (about 2.6 minutes) | 8.0E+05 |
| 8 | Zn-65 (about 240 days) | 2.0E+02 | 40 | Ba-140 (about 13 days) | 3.0E+02 |
| 9 | Rb-86 (about 19 days) | 3.0E+02 | 41 | Ce-141 (about 33 days) | 1.0E+03 |
| 10 | Sr-89 (about 51 days) | 3.0E+02 | 42 | Ce-144 (about 280 days) | 2.0E+02 |
| 11 | Sr-90 (about 29 years) | 3.0E+01 | 43 | Pr-144 (about 17 minutes) | 2.0E+04 |
| 12 | Y-90 (about 64 hours) | 3.0E+02 | 44 | Pr-144m (about 7.2 minutes) | 4.0E+04 |
| 13 | Y-91 (about 59 days) | 3.0E+02 | 45 | Pm-146 (about 5.5 years) | 9.0E+02 |
| 14 | Nb-95 (about 35 days) | 1.0E+03 | 46 | Pm-147 (about 2.6 years) | 3.0E+03 |
| 15 | Tc-99 (about 210,000 years) | 1.0E+03 | 47 | Pm-148 (about 5.4 days) | 3.0E+02 |
| 16 | Ru-103 (about 39 days) | 1.0E+03 | 48 | Pm-148m (about 41 days) | 5.0E+02 |
| 17 | Ru-106 (about 370 days) | 1.0E+02 | 49 | Sm-151 (about 90 years) | 8.0E+03 |
| 18 | Rh-103m (about 56 minutes) | 2.0E+05 | 50 | Eu-152 (about 14 years) | 6.0E+02 |
| 19 | Rh-106 (about 30 seconds) | 3.0E+05 | 51 | Eu-154 (about 8.6 years) | 4.0E+02 |
| 20 | Ag-110m (about 250 days) | 3.0E+02 | 52 | Eu-155 (about 4.8 years) | 3.0E+03 |
| 21 | Cd-113m (about 14 years) | 4.0E+01 | 53 | Gd-153 (about 240 days) | 3.0E+03 |
| 22 | Cd-115m (about 45 days) | 3.0E+02 | 54 | Tb-160 (about 72 days) | 5.0E+02 |
| 23 | Sn-119m (about 290 days) | 2.0E+03 | 55 | Pu-238 (about 88 years) | 4.0E+00 |
| 24 | Sn-123 (about 130 days) | 4.0E+02 | 56 | Pu-239 (about 24,000 years) | 4.0E+00 |
| 25 | Sn-126 (about 230,000 years) | 2.0E+02 | 57 | Pu-240 (about 6600 years) | 4.0E+00 |
| 26 | Sb-124 (about 60 days) | 3.0E+02 | 58 | Pu-241 (about 14 years) | 2.0E+02 |
| 27 | Sb-125 (about 2.8 years) | 8.0E+02 | 59 | Am-241 (about 430 years) | 5.0E+00 |
| 28 | Te-123m (about 120 days) | 6.0E+02 | 60 | Am-242m (about 140 years) | 5.0E+00 |
| 29 | Te-125m (about 57 days) | 9.0E+02 | 61 | Am-243 (about 7400 years) | 5.0E+00 |
| 30 | Te-127 (about 9.4 hours) | 5.0E+03 | 62 | Cm-242 (about 160 days) | 6.0E+01 |
| 31 | Te-127m (about 110 days) | 3.0E+02 | 63 | Cm-243 (about 29 years) | 6.0E+00 |
| 32 | Te-129 (about 70 minutes) | 1.0E+04 | 64 | Cm-244 (about 18 years) | 7.0E+00 |

* The half-lives are indicated 2-digit accuracy using ICRP Publication 107 "Nuclear Decay Data for Dosimetric Calculations" [16]

5-2. Discharge method

The following shows the policy on the method of discharge into the sea following “TEPCO’s Action in response to Government’s Policy.”

- The design and operation of the facilities necessary for discharge into the sea shall comply with laws and get the necessary permissions from the Nuclear Regulation Authority.
- The amount of radioactive materials excluding tritium in treated water will be reduced by repeating secondary treatment prior to the discharge until the concentration before dilution surely falls below the regulatory standard value related to safety (until the sum of the ratios to regulatory concentrations limits of nuclides other than tritium becomes less than 1). We shall not discharge treated water of which sum of the ratios to regulatory concentrations limits of radioactive materials excluding tritium before dilution is not less than 1.
- Before dilution and discharge, we shall measure and assess the concentration of the radioactive materials in ALPS treated water (tritium, 62 nuclides, and C-14) and announce the results of the measurement and assessment every time, as well as perform third-party measurement, assessment, announcement, etc., and announce the results.
- After that, tritium, which is difficult to exclude, is diluted with a massive amount of seawater (to be determined depending on the tritium concentration in the treated water to be discharged; about 100 to 1,400 times or more) before discharge, in order to meet the standard of the safety regulations of the government (regulatory concentration limit) set to reduce the impact on the environment immediately after discharge (at site boundary), dispel concerns of consumers, etc., as much as possible, and minimize reputation damage. Thanks to this, the sum of the ratios to regulatory concentrations limits of radioactive materials other than tritium becomes less than 0.01. Besides, in actual operation, two sea water transfer pumps are enough to dilute the ALPS treated water to be discharged by setting the concentration limit of tritium before dilution below 1 million Bq/L.
- The tritium concentration of discharged water shall be sufficiently lower than 60,000Bq/L, which is the standard of the safety standards of the government (regulatory concentration limit), and 10,000Bq/L, which is the WHO Guidelines for Drinking Water Quality: specifically, less than 1,500Bq/L as with the operation target of the currently applied discharge concentration of the groundwater bypass, subdrain, etc.
- Discharge into the sea shall be started carefully with a small amount. The soundness of facilities, the transfer procedure of ALPS treated water, measurement process of the concentration of radioactive materials, assessment of dilution of tritium in discharged water, the state of diffusion into the sea, etc., shall be verified.
- If the transfer facility or dilution facility does not function as planned due to malfunction, power failure, etc., we will stop the discharge immediately. If any abnormal value is

detected in sea area monitoring, we will stop discharge and investigate the state. When resuming discharge, confirm the safety of discharge.

- The upper limit of the annual discharge amount of tritium, which cannot be removed by ALPS, shall be 22 TBq (2.2E+13Bq) per year, which is the discharge control value of the FDNPS before the accident, for the time being. Moreover, we shall minimize the discharge amount as well as secure the site for facilities necessary for decommissioning by preferentially discharging water with a low tritium concentration and waiting for natural decay based on the half-life for water with a high concentration. Attachment IV “Analysis on the period of discharge of ALPS treated water” shows the simulation result related to discharge of ALPS treated water assuming that discharge will be started in FY 2023 and completed in FY 2051.

Table 5-2-1 shows the specific items to be implemented as shown in “TEPCO’s Action in response to Government’s Policy.”

Table 5-2-1 Specific items to be implemented

| | |
|--|---|
| Secondary treatment of treated water to be purified | <ul style="list-style-type: none"> • The amount of radioactive materials excluding tritium in treated water to be purified to be discharged into the environment is reduced by secondary treatment by ALPS, etc., to ensure that radioactive materials other than tritium surely falls below the regulatory standard value related to safety (until the sum of the ratios to regulatory concentrations limits of nuclides other than tritium becomes less than 1). |
| Analysis of ALPS treated water | <ul style="list-style-type: none"> • Before dilution and discharge, we shall announce the measurement and assessment results of the concentration of radioactive materials of 62 nuclides (nuclides subject to removal by ALPS) and C-14 every time, as well as perform third-party measurement, assessment, announcement, etc. |
| Dilution and discharge (including emergency actions) | <ul style="list-style-type: none"> • Tritium, which is difficult to remove, is diluted with a sufficient amount of seawater (100 or more times) before discharge so that the concentration will be sufficiently lower than the regulatory concentration limit. Thanks to this, the sum of the ratios to regulatory concentrations limits of nuclides other than tritium in discharged water becomes less than 0.01. <ul style="list-style-type: none"> - The tritium concentration shall be the same as the operation target of the discharge concentration of the groundwater bypass, subdrain, etc. (less than 1,500Bq/L). • The upper limit of the annual discharge amount of tritium shall be 22 TBq (2.2E+13Bq) per year, which is the discharge control value at FDNPS before the accident, for the time being. The annual discharge amount of tritium is reviewed as needed based on the progress of decommissioning. • If the transfer facility or dilution facility does not function as planned due to a failure, outage, etc., stop the discharge immediately. • If any abnormal value is detected in sea area monitoring, stop discharge and investigate the state. When resuming discharge, confirm the safety of discharge. |
| Sea area monitoring | <ul style="list-style-type: none"> • Sea area monitoring is started according to the plan enhanced since about one year before the scheduled date to start discharge. • Monitoring of seawater, fish, and seaweeds are enhanced. <ul style="list-style-type: none"> - Tritium is intensively measured and assessed in addition to the past measurement and assessment focusing on Cs-137. |

| | |
|--|--|
| | <ul style="list-style-type: none"> - The measurement sample continued to be seawater but the sampled amount of fish and seaweeds are increased. • The radioactivity measurement result at the time of discharge is announced. - Third-party analysis, announcement, etc., are considered. |
|--|--|

In addition, management values before dilution are set voluntarily for further reduction of the impact of radiation on the environment for eight nuclides with relative impacts of human exposure due to concentration in fish, etc., with the same ratio to regulatory concentration limit as management before discharge of ALPS treated water. The consideration of management values is shown in Reference C “Setting of Management Values and Exposure Assessment of Hypothetical ALPS Treated Water.” Table 5-2-2 shows the nuclides subject to management and the management values. If the concentration of any of these eight nuclides exceeds the management value as a result of analysis in the measurement/confirmation facility before discharge, the water shall not be discharged but subject to secondary treatment. These eight nuclides will be reviewed as needed, together with the review result of nuclides subject to measurement, which will be conducted prior to discharge.

Table 5-2-2 Management values (before dilution)

| Target nuclide | Regulatory concentration limit (Bq/L) | Operation management value (Bq/L) | Ratio to regulatory concentration limit |
|----------------|---------------------------------------|-----------------------------------|---|
| C-14 | 2.0E+03 | 5.0E+02 | 2.5E-01 |
| Fe-59 | 4.0E+02 | 2.0E-01 | 5.0E-04 |
| Ag-110m | 3.0E+02 | 6.0E-02 | 2.0E-04 |
| Cd-113m | 4.0E+01 | 2.0E-01 | 5.0E-03 |
| Cd-115m | 3.0E+02 | 4.0E+00 | 1.3E-02 |
| Sn-119m | 2.0E+03 | 6.0E+01 | 3.0E-02 |
| Sn-123 | 4.0E+02 | 8.0E+00 | 2.0E-02 |
| Sn-126 | 2.0E+02 | 4.0E-01 | 2.0E-03 |

5-3. Facilities for discharge

“TEPCO’s Action in response to Government’s Policy” shows a conceptual diagram of the facilities for discharging into the sea (Figure 5-3-1), but the assessment was performed reflecting the state of consideration of the facilities for discharge shown below by the following design clarification.

5-3-1. Overview of the facilities for discharge

The facilities for discharge into the sea mainly consist of “the measurement/confirmation facility” to verify the radioactive material concentration of ALPS treated water before dilution, “the dilution facility” which consists of seawater transfer piping and discharge vertical shaft (upper-stream storage) including the seawater transfer pump and seawater pipe header to pump and discharge seawater for dilution, “the transfer facility” which consists of the treated water transfer pump and treated water transfer piping and valves to transfer ALPS treated water from the measurement/confirmation facility to the seawater piping, and “the discharge facility (related facility)” which consists of the discharge tunnel and discharge outlet.

After confirming the water, of which radioactive materials have been removed by ALPS up to a sufficiently low concentration, is so-called “ALPS treated water” (water whose sum of the ratios to regulatory concentrations limits of nuclides other than tritium is verified to be less than 1), and then diluted with a large amount of seawater 100 or more times.

The water to be discharged is received by the measurement/confirmation facility, the radioactive material concentration is homogenized by circulation and stirring, and then it is verified by sampling and analysis that the water is ALPS treated water. The verified water is transferred to the dilution facility by the transfer facility, mixed with a large amount of seawater pumped with the seawater transfer pump through the Unit 5 intake channel by the dilution facility, and drained to the discharge facility after dilution of the tritium concentration up to less than 1,500Bq/L.

The details of each facility are shown in the following pages. Figure 5-3-1 shows the conceptual diagram of the discharge facility. Figure 5-3-2 shows the big picture of the facility for discharge into the sea and related facilities.

Conceptual diagram of facilities for releasing ALPS treated water into the sea




Figure 5-3-1 Conceptual diagram of facilities for discharging ALPS treated water into the sea





Figure 5-3-2 Overview of facilities for discharging into the sea and related facilities

5-3-2. Measurement/confirmation facility

For the measurement/confirmation facility, we will use 30 out of 35 tanks installed in the K4 tank areas in the center of the site 33.5 m above sea level near ALPS. To sample and analyze homogenized water, use 10 tanks, whose total capacity is about 10,000 m³, as 1 group, and install a stirring device in each tank and a circulation device in each tank group. Since we have to deal with three purposes, namely receiving, measurement/confirmation, and discharge, set up three tanks groups and operate them on a rotation basis. Figure 5-3-3 shows the schematic diagram of the measurement/confirmation facility. This figure also outlines the operation of the measurement/confirmation facility.


(1) Receiving process

The ALPS treated water in ALPS treated water storage tanks, etc., is received by an empty tank group.




(2) Measurement/confirmation process

After the water quality of the tank group is homogenized by agitating equipment and circulation pump, sampling is carried out to confirm whether the discharge standard is satisfied.




(3) Discharge process

After confirming that the discharge criteria are satisfied, the ALPS treated water is transferred to the dilution facility by the transfer facility.



K4 area tank group: 35 tanks



| | Group A | Group B | Group C |
|-----------|--------------------------|--------------------------|--------------------------|
| 1st cycle | Receiving | - | - |
| 2nd cycle | Measurement/confirmation | Receiving | - |
| 3rd cycle | Discharge | Measurement/confirmation | Receiving |
| 4th cycle | Receiving | Discharge | Measurement/confirmation |
| ... | Measurement/confirmation | Receiving | Discharge |

Figure 5-3-3 Schematic diagram of measurement/confirmation facilities

5-3-3. Transfer facility

The transfer facility is mainly composed of ALPS treated water transfer pump and transfer piping, etc.

In the transfer facility, the ALPS treated water transfer pump consists of two units, namely operating unit and spare unit, and is installed in the ALPS transfer facility building near the measurement/confirmation facility to transfer ALPS treated water from the tanks of the measurement/confirmation facility 33.5 m above sea level to the dilution facility. Install a radiation detector to detect gamma rays for emergency isolation in the building in order to prevent water from being discharged without sufficient purification.

In the transfer facility, the transfer piping is installed to connect the measurement/confirmation facility 33.5 m above sea level to the seawater piping 2.5 m above sea level. Install an emergency isolation valve in two points in the transfer piping to enable to stop transfer of ALPS treated water in the event of an abnormality. One point is set before the injection part of the seawater piping in order to minimize the discharge amount of ALPS treated water in the event of an abnormality. The other point is set in the ALPS electrical equipment room set up inside the seawall to be newly constructed 11.5m above sea level in preparation for cases that the former emergency isolation valve does not work due to water immersion, etc., caused by the expected Japan Trench tsunami. In the same room, a flowmeter to measure the flow rate of ALPS treated water to be transferred to the seawater pipe header and the flow rate adjustment valve to adjust the flow rate as specified are installed.

Figure 5-3-4 shows the schematic diagram of the transfer facility




Figure 5-3-4 Schematic diagram of the transfer facility

5-3-4. Dilution facility

The dilution facility consists of a seawater transfer pump, seawater piping (including header), and a discharge shaft (upstream water tank) with the purpose of diluting the ALPS treated water with seawater, transferring it to the discharge shaft (upstream water tank), and discharging it to the discharge facility (related facility). Dilution is done by injecting ALPS treated water into the seawater pipe header and mixing it.

The dilution facility is installed in a location 2.5 m above sea level in the sea side of Units 5/6. A flowmeter is installed in the seawater transfer piping to ensure that the tritium concentration is less than 1,500Bq/L by dilution with a high volume of water (100 or more times). For the seawater transfer pump, the intake channel for the existing Unit 5 circulation water pump is reused. Conservatively, three pumps are installed. The capacity of the seawater transfer pump shall be about 170, 000 m³/day/unit, at which the flowrate of the seawater transfer pump can be measured, in order to enable sufficient dilution with seawater. Figure 5-3-5 shows the schematic diagram of the dilution facility.




Figure 5-3-5 Schematic diagram of the dilution facility

As mentioned above, because dilution is performed by injecting ALPS treated water into the seawater pipe header and mixing it; the mixing behavior in the seawater piping of ALPS treated water was calculated, the expected dilution effect was assessed, the maximum mass concentration on the cross section of the concentration assessment at the seawater piping outlet of injected water was assessed to be 0.28%, and it was concluded that the water was diluted about 357 times.

5-3-5. Discharge facility (related facility)


In this discharge of ALPS treated water into the sea, as a result of optimization of the design process, the water diluted and mixed with a large amount of seawater is discharged not through the existing discharge outlet installed on the coast to the north of the northern breakwater, but through the discharge outlet installed on the seabed about 1 km off the coast of the FDNPS (See Figures 5-3-6 to 5-3-7).

The discharge facility consists of the discharge vertical shaft (down-stream storage), discharge tunnel, and discharge outlet, and is designed to transfer water flowing out over the partition wall (weir which separates the upper-stream storage from the down-stream storage) in the discharge vertical shaft to the outlet, which is approximately 1 km away, by making use of the head between water in the discharge vertical shaft (down-stream storage) and the sea surface. The discharge tunnel passes through bedrock to minimize the leakage risk and improve seismic resistance.

This proposal has the following advantages compared with the proposal to use the existing discharge outlet.

- Compared with water intake inside and outside the port using the existing intake and discharge facilities, water inside the port, of which radioactive material concentration is higher than that of water outside the port, is not discharged. To take water outside the port, isolation from the inside of the port is secured with a partition weir in the south side of the Unit 5 intake gate, and a part of the permeation prevention work of the north breakwater of the port is removed. Attachment V “Impacts of intake and discharge of diluted water on outside” shows discussion about the impact of the radioactive material concentration in the port. As a result of the exposure assessment, the assessment results of both water intake inside and outside the port was much smaller than the dose limit and target dose value, but it turned out that the external impact of water intake outside the port is smaller.
- Since discharged water is diffused offshore, seawater is hard to recirculate (hard to be taken again as seawater for dilution).
- The impact on fishing is reduced by setting the position of the discharge outlet within “area where common fishery rights are not set” where fishing is not done on a daily basis.
- As a result of a geological investigation, a stable bedrock is exposed on the seabed, so construction can be performed safely and steadily (See Figure 5-3-8).

Figures 5-3-9 shows the overview of the structure of the discharge vertical shaft (upper-stream storage/down-stream storage) in the water discharge tunnel side. Figure 5-3-10 shows the image of the discharge outlet, which is the discharge tunnel outlet. Figure 5-3-11 shows its sectional view.



Source: the Geographical Survey Institute map (national land electronic website) revised by Tokyo Electric Power Company Holdings Corporation
<https://maps.gsi.go.jp/#13/37.422730/141.044970/&base=std&ls=std&disp=1&vs=c1j0h0k0l0u0t0z0r0s0m0f1>

Figure 5-3-6 Discharge location map




Figure 5-3-7 General view of the intake and discharge facilities




Figure 5-3-8 Plane view of assumed geology




Figure 5-3-9 Schematic diagram of the discharge vertical shaft (upper-stream storage/down-stream storage)




Figure 5-3-10 Image drawing of discharge outlet




Figure 5-3-11 Section view of the discharge outlet

6. Assessment of protection of humans (general public)

6-1. Exposure assessment under normal conditions

6-1-1. Assessment procedure

We assess the dose of the representative person in order to verify the risk from the viewpoint of radiation protection for human based on the current consideration situation. The specific procedure of the assessment is as shown in the procedure of Figure 6-1-1 shown in GSG-10.




Figure 6-1-1 Exposure assessment procedure (prepared from GSG-10)

²⁵ In this assessment, the source term means the annual discharge amount (total amount) of each nuclide contained in the ALPS treated water discharged into the sea in a certain period (e.g. one year).

6-1-2. Assessment method

(1) Source term (annual discharge amount of each nuclide)

The target nuclides of the radioactive impact assessment related to discharge into the sea of ALPS treated water are a total of 64 nuclides: tritium, C-14, and 62 nuclides subject to removal by ALPS (Table 5-1-1). In “TEPCO’s Action in response to Government’s Policy,” the upper limit of the annual discharge amount of tritium is set to 22 TBq (2.2E+13Bq), which is the discharge control value of the FDNPS before the accident, for the time being.

The discharge amount of 63 nuclides other than tritium is calculated by the product of the composition of nuclides in ALPS treated water (concentration of each nuclide) and the annual discharge volume of water. Though the composition of nuclides in ALPS treated water varies among tank groups, it is to be set using the compositions of nuclides of three tank groups, namely K4, J1-C, and J1-G, of which the analysis results of all of the 64 nuclides are available.

- i. K4 tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.29)
- ii. J1-C tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.35)
- iii. J1-G tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.22)

The water in the K4 tank group has been treated by one treatment process using the performance of ALPS to make the sum of the ratios to regulatory concentrations limits less than 1, as described in b.2016 of II-7. “Reason for generation of treated water to be purified” of Attachment II “Properties of ALPS treated water, etc.”

On the other hand, the water in the J1-C and J1-G tank groups has been treated while the operating rate of ALPS was high and stored as treated water to be purified because the sum of the ratios to regulatory concentrations limits did not fall below 1 after the first treatment by ALPS. The tank groups were selected as groups with a higher concentration (J1-C tank group; the sum of the ratios to regulatory concentrations limits before secondary treatment is about 2,400) and with a lower concentration (J1-G tank group; the sum of the ratios to regulatory concentrations limits before secondary treatment is about 390). Secondary treatment was performed for each of them and the sums of the ratios to regulatory concentrations limits of both of them were much less than 1 after secondary treatment.

We compared the concentration of the 7 major nuclides²⁶ and Tc-99 of these three tank groups with the measurement results of the tank groups in which the sum of the ratios to regulatory concentrations limits other than tritium is estimated to be less than 1 from the analysis result of the tank groups currently used for storage of water. Figure 6-1-2 shows the result. Though I-129 varies in the three tank groups as well as the other tank groups, the concentrations of the other nuclides are normal in the analysis results of the other tank groups as well. The reason why the three tank groups have lower Cs-134 result, the detection limits of the three tank groups were 0.1 Bq/L, while the detection limits of many other tank groups were from 0.1 to 0.2 Bq/L. Cs-134, a short half-life nuclide, of most tank groups were nevertheless undetected.

In addition, tritium and C-14, which are not subject to removal by ALPS, were compared with the measurement results of all tank groups. The comparison result is shown in Figure 6-1-3. The concentration of C-14 is also normal in the analysis results of the other tank groups.

Based on these comparisons, the compositions of the nuclides of the three tank groups are considered typical as the composition of concentrations in ALPS treated water.

These source terms include uncertainties, which is described in chapter 8.

The 62 nuclides to removal by ALPS had been selected from fission products derived from fuel in the reactors of Unit 1 to 3 and the corrosion products derived from water retained in operating nuclear reactors. However, a gap found later between sum of the measured radioactive concentration of the 7 major nuclides of ALPS treated water and measured gross beta. Examinations has identified Tc-99 and C-14 as the cause of the gap and C-14 has been added into the required nuclides to be measured.

On the other hands, abundance of some nuclides may be sufficiently small at present due to enough decay, because of using inventory data of one year after the earthquake to select 62 nuclides for removal targets by ALPS.

In light of the above circumstances, for discharging ALPS treated water into the sea, the selection of target nuclides for measurement will be carried out after thorough verification once again, in which case this assessment will be revised. New target nuclides may be added, but the revision of the target nuclides for measurement is expected to have almost no impact on the exposure assessment, because it was verified that the sum of the measured radioactive concentration of 7 major nuclides, Tc-99 and C-14 of ALPS treated water is not differ from the measured gross beta as to suspect the existence of nuclides other than the current 64 nuclides, and because the nuclides to be added as targets for measurement are expected to have only a small impact on the human body due to low-energy radiation.

²⁶ Seven nuclides which are significantly detected in the process of ALPS treatment at the facility inlet and outlet (Cs-134, Cs-147, Co-60, Sb-125, Ru-106, Sr-90, I-129)




Figure 6-1-2 Concentration distribution of the seven major nuclides and Tc-99 in the analysis result of ALPS treated water (as of the end of March 2021), and comparison among the three tank groups

- * The analysis results in which the sum of the ratios to regulatory concentrations limits of the 7 major nuclides is less than 0.59 (for 80 tanks) (excluding secondary treatment test water)
- * The vertical axis indicates the number of tanks (counted as the detection limit if not detected)
- * Values are measured values at the times and no half-life correction is considered.




Figure 6-1-3 Concentration distribution of tritium and C-14 in the analysis result of ALPS treated water, etc. (as of the end of March 2021) and comparison among the three tank groups

- * The analysis results of the tank group (189 tanks for tritium and 81 tanks for C-14) are plotted (excluding secondary treatment test water)
- * The vertical axis indicates the number of tanks (counted as the detection limit if not detected)
- * Values are measured values at the times and no half-life correction is considered.

On the other hand, the tritium concentration of stored ALPS treated water, etc., varies as shown in Figure 6-1-3, so the assumed annual discharge volume of treated water depends on the concentration of tritium contained in ALPS treated water to be discharged. The annual discharge volume of water is in inverse proportion to the tritium concentration; the lower the tritium concentration is, the greater the annual discharge amount of 63 nuclides other than tritium becomes. The relationships are as shown in the following equation.

$$S_i = V \times C_i = \frac{S_{H-3}}{C_{H-3}} \times C_i$$

where

- S_i : Annual radioactivity amount of discharged nuclide i (Bq)
- V : Annual discharge volume of ALPS treated water (L)
- C_i : Concentration of nuclide i contained in the ALPS treated water discharged (Bq/L)
- S_{H-3} : Annual radioactivity amount of tritium discharged
(= 22 TBq (2.2E+13Bq))
- C_{H-3} : Concentration of tritium contained in the ALPS treated water discharged (Bq/L)

Among them the values of C_i and C_{H-3} are given by the definition of each nuclide's compositions in this assessment, which means that the annual discharge amount of each nuclide is uniquely determined from the concentration of tritium of the nuclide's compositions.

The source term using the analysis result of each tank group is set by the following procedure. In actual discharge, the source term varies among tank groups, but this assessment assumes that it does not vary throughout the year for simplification of the model.

Tables 6-1-1 to 6-1-3 show the concentration, annual discharge volume of water, and annual discharge amount of each nuclide based on these settings.

- (1) The annual discharge amount of tritium shall be the upper limit: 22 TBq (2.2E+13Bq).
- (2) The annual discharge volume of water is calculated from (1) and the tritium concentration.
- (3) The annual discharge amount of each nuclide is calculated from the concentration of 63 nuclides and the product of the annual discharge amount calculated in (2). Some of the nuclides below the detection limit value have short half-lives or have already decayed because more than 11 years have elapsed since the accident, but conservatively they are assumed to exist at the detection limit.

Actually, when ALPS treated water is discharged, the sum of the ratios to regulatory concentrations limits of nuclides other than tritium becomes less than 0.01 because as shown in 5-2, the water is diluted with seawater 100 or more times before discharge into the sea so that the tritium concentration falls below 1,500Bq/L, which is the target value of the groundwater bypass and subdrain.

Table 6-1-1 Source term based on the nuclide composition of measured values (K4 tank group) (annual discharge amount)

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---|
| H-3 | 1.9E+05 | 1.2E+08 | 2.2E+13 | <ul style="list-style-type: none"> • For the annual discharge amount of tritium, the upper limit value of the annual discharge amount is used • Dilute with seawater 100 or more times before discharge so that the tritium concentration becomes less than 1,500Bq/L |
| C-14 | 1.5E+01 | | 1.7E+09 | |
| Mn-54 | 6.7E-03 | | 7.8E+05 | |
| Fe-59 | 1.7E-02 | | 2.0E+06 | |
| Co-58 | 8.0E-03 | | 9.3E+05 | |
| Co-60 | 4.4E-01 | | 5.1E+07 | |
| Ni-63 | 2.2E+00 | | 2.5E+08 | |
| Zn-65 | 1.5E-02 | | 1.7E+06 | |
| Rb-86 | 1.9E-01 | | 2.2E+07 | |
| Sr-89 | 1.0E-01 | | 1.2E+07 | |
| Sr-90 | 2.2E-01 | | 2.5E+07 | |
| Y-90 | 2.2E-01 | | 2.5E+07 | |
| Y-91 | 2.2E+00 | | 2.5E+08 | |

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---------|
| Nb-95 | 1.0E-02 | | 1.2E+06 | |
| Tc-99 | 7.0E-01 | | 8.1E+07 | |
| Ru-103 | 1.0E-02 | | 1.2E+06 | |
| Ru-106 | 1.6E+00 | | 1.9E+08 | |
| Rh-103m | 1.0E-02 | | 1.2E+06 | |
| Rh-106 | 1.6E+00 | | 1.9E+08 | |
| Ag-110m | 5.6E-03 | | 6.5E+05 | |
| Cd-113m | 1.8E-02 | | 2.1E+06 | |
| Cd-115m | 6.4E-01 | | 7.4E+07 | |
| Sn-119m | 1.7E-01 | | 2.0E+07 | |
| Sn-123 | 1.2E+00 | | 1.4E+08 | |
| Sn-126 | 2.7E-02 | | 3.1E+06 | |
| Sb-124 | 9.5E-03 | | 1.1E+06 | |
| Sb-125 | 3.3E-01 | | 3.8E+07 | |
| Te-123m | 9.2E-03 | | 1.1E+06 | |
| Te-125m | 3.3E-01 | | 3.8E+07 | |
| Te-127 | 3.2E-01 | | 3.7E+07 | |
| Te-127m | 3.2E-01 | | 3.7E+07 | |
| Te-129 | 8.1E-02 | | 9.4E+06 | |
| Te-129m | 3.2E-01 | | 3.7E+07 | |
| I-129 | 2.1E+00 | | 2.4E+08 | |
| Cs-134 | 4.5E-02 | | 5.2E+06 | |
| Cs-135 | 2.5E-06 | | 2.9E+02 | |
| Cs-136 | 3.0E-02 | | 3.5E+06 | |
| Cs-137 | 4.2E-01 | | 4.9E+07 | |
| Ba-137m | 4.2E-01 | | 4.9E+07 | |
| Ba-140 | 9.5E-02 | | 1.1E+07 | |
| Ce-141 | 2.5E-02 | | 2.9E+06 | |
| Ce-144 | 6.3E-02 | | 7.3E+06 | |
| Pr-144 | 6.3E-02 | | 7.3E+06 | |
| Pr-144m | 6.3E-02 | | 7.3E+06 | |
| Pm-146 | 9.8E-02 | | 1.1E+07 | |
| Pm-147 | 1.9E-01 | | 2.2E+07 | |
| Pm-148 | 5.0E-01 | | 5.8E+07 | |
| Pm-148m | 8.4E-03 | | 9.7E+05 | |
| Sm-151 | 9.0E-04 | | 1.0E+05 | |
| Eu-152 | 2.8E-02 | | 3.2E+06 | |
| Eu-154 | 1.2E-02 | | 1.4E+06 | |
| Eu-155 | 3.3E-02 | | 3.8E+06 | |

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---------|
| Gd-153 | 3.2E-02 | | 3.7E+06 | |
| Tb-160 | 2.8E-02 | | 3.2E+06 | |
| Pu-238 | 6.3E-04 | | 7.3E+04 | |
| Pu-239 | 6.3E-04 | | 7.3E+04 | |
| Pu-240 | 6.3E-04 | | 7.3E+04 | |
| Pu-241 | 2.8E-02 | | 3.2E+06 | |
| Am-241 | 6.3E-04 | | 7.3E+04 | |
| Am-242m | 3.9E-05 | | 4.5E+03 | |
| Am-243 | 6.3E-04 | | 7.3E+04 | |
| Cm-242 | 6.3E-04 | | 7.3E+04 | |
| Cm-243 | 6.3E-04 | | 7.3E+04 | |
| Cm-244 | 6.3E-04 | | 7.3E+04 | |

Table 6-1-2 Source term based on the nuclide composition of measured values (J1-C tank group) (annual discharge amount)

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---|
| H-3 | 8.2E+05 | 2.7E+07 | 2.2E+13 | <ul style="list-style-type: none"> • For the annual discharge amount of tritium, the upper limit value of the annual discharge amount is used • Dilute with seawater 100 or more times before discharge so that the tritium concentration becomes less than 1,500Bq/L |
| C-14 | 1.8E+01 | | 4.8E+08 | |
| Mn-54 | 3.8E-02 | | 1.0E+06 | |
| Fe-59 | 8.7E-02 | | 2.3E+06 | |
| Co-58 | 4.1E-02 | | 1.1E+06 | |
| Co-60 | 3.3E-01 | | 8.9E+06 | |
| Ni-63 | 8.5E+00 | | 2.3E+08 | |
| Zn-65 | 9.4E-02 | | 2.5E+06 | |
| Rb-86 | 5.0E-01 | | 1.3E+07 | |
| Sr-89 | 5.4E-02 | | 1.4E+06 | |
| Sr-90 | 3.6E-02 | | 9.7E+05 | |
| Y-90 | 3.6E-02 | | 9.7E+05 | |
| Y-91 | 1.7E+01 | | 4.6E+08 | |
| Nb-95 | 5.0E-02 | | 1.3E+06 | |
| Tc-99 | 1.2E+00 | | 3.2E+07 | |
| Ru-103 | 5.3E-02 | | 1.4E+06 | |
| Ru-106 | 1.4E+00 | | 3.8E+07 | |
| Rh-103m | 5.3E-02 | | 1.4E+06 | |
| Rh-106 | 1.4E+00 | | 3.8E+07 | |
| Ag-110m | 4.3E-02 | | 1.2E+06 | |
| Cd-113m | 8.5E-02 | 2.3E+06 | | |

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---------|
| Cd-115m | 2.7E+00 | | 7.2E+07 | |
| Sn-119m | 4.2E+01 | | 1.1E+09 | |
| Sn-123 | 6.6E+00 | | 1.8E+08 | |
| Sn-126 | 2.9E-01 | | 7.8E+06 | |
| Sb-124 | 9.7E-02 | | 2.6E+06 | |
| Sb-125 | 2.3E-01 | | 6.2E+06 | |
| Te-123m | 9.2E-02 | | 2.5E+06 | |
| Te-125m | 2.3E-01 | | 6.2E+06 | |
| Te-127 | 4.7E+00 | | 1.3E+08 | |
| Te-127m | 4.9E+00 | | 1.3E+08 | |
| Te-129 | 6.2E-01 | | 1.7E+07 | |
| Te-129m | 1.4E+00 | | 3.8E+07 | |
| I-129 | 1.2E+00 | | 3.2E+07 | |
| Cs-134 | 7.6E-02 | | 2.0E+06 | |
| Cs-135 | 1.2E-06 | | 3.2E+01 | |
| Cs-136 | 4.7E-02 | | 1.3E+06 | |
| Cs-137 | 1.9E-01 | | 5.1E+06 | |
| Ba-137m | 1.9E-01 | | 5.1E+06 | |
| Ba-140 | 2.0E-01 | | 5.4E+06 | |
| Ce-141 | 2.6E-01 | | 7.0E+06 | |
| Ce-144 | 5.7E-01 | | 1.5E+07 | |
| Pr-144 | 5.7E-01 | | 1.5E+07 | |
| Pr-144m | 5.7E-01 | | 1.5E+07 | |
| Pm-146 | 6.7E-02 | | 1.8E+06 | |
| Pm-147 | 8.0E-01 | | 2.1E+07 | |
| Pm-148 | 2.3E-01 | | 6.2E+06 | |
| Pm-148m | 4.8E-02 | | 1.3E+06 | |
| Sm-151 | 1.1E-02 | | 3.0E+05 | |
| Eu-152 | 2.8E-01 | | 7.5E+06 | |
| Eu-154 | 1.1E-01 | | 3.0E+06 | |
| Eu-155 | 3.4E-01 | | 9.1E+06 | |
| Gd-153 | 2.6E-01 | | 7.0E+06 | |
| Tb-160 | 1.4E-01 | | 3.8E+06 | |
| Pu-238 | 3.3E-02 | | 8.9E+05 | |
| Pu-239 | 3.3E-02 | | 8.9E+05 | |
| Pu-240 | 3.3E-02 | | 8.9E+05 | |
| Pu-241 | 1.2E+00 | | 3.2E+07 | |
| Am-241 | 3.3E-02 | | 8.9E+05 | |
| Am-242m | 5.9E-04 | | 1.6E+04 | |

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---------|
| Am-243 | 3.3E-02 | | 8.9E+05 | |
| Cm-242 | 3.3E-02 | | 8.9E+05 | |
| Cm-243 | 3.3E-02 | | 8.9E+05 | |
| Cm-244 | 3.3E-02 | | 8.9E+05 | |

Table 6-1-3 Source term based on the nuclide composition of measured values (J1-G tank group) (annual discharge amount)

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---|
| H-3 | 2.7E+05 | 8.1E+07 | 2.2E+13 | <ul style="list-style-type: none"> For the annual discharge amount of tritium, the upper limit value of the annual discharge amount is used Dilute with seawater 100 or more times before discharge so that the tritium concentration becomes less than 1,500Bq/L |
| C-14 | 1.6E+01 | | 1.3E+09 | |
| Mn-54 | 3.8E-02 | | 3.1E+06 | |
| Fe-59 | 7.2E-02 | | 5.9E+06 | |
| Co-58 | 3.7E-02 | | 3.0E+06 | |
| Co-60 | 2.3E-01 | | 1.9E+07 | |
| Ni-63 | 8.8E+00 | | 7.2E+08 | |
| Zn-65 | 8.0E-02 | | 6.5E+06 | |
| Rb-86 | 4.7E-01 | | 3.8E+07 | |
| Sr-89 | 4.5E-02 | | 3.7E+06 | |
| Sr-90 | 3.2E-02 | | 2.6E+06 | |
| Y-90 | 3.2E-02 | | 2.6E+06 | |
| Y-91 | 1.2E+01 | | 9.8E+08 | |
| Nb-95 | 4.7E-02 | | 3.8E+06 | |
| Tc-99 | 1.3E+00 | | 1.1E+08 | |
| Ru-103 | 5.1E-02 | | 4.2E+06 | |
| Ru-106 | 4.8E-01 | | 3.9E+07 | |
| Rh-103m | 5.1E-02 | | 4.2E+06 | |
| Rh-106 | 4.8E-01 | | 3.9E+07 | |
| Ag-110m | 4.0E-02 | | 3.3E+06 | |
| Cd-113m | 8.6E-02 | | 7.0E+06 | |
| Cd-115m | 2.3E+00 | | 1.9E+08 | |
| Sn-119m | 4.0E+01 | | 3.3E+09 | |
| Sn-123 | 6.3E+00 | | 5.1E+08 | |
| Sn-126 | 1.5E-01 | | 1.2E+07 | |
| Sb-124 | 8.4E-02 | | 6.8E+06 | |
| Sb-125 | 1.4E-01 | | 1.1E+07 | |
| Te-123m | 6.7E-02 | | 5.5E+06 | |
| Te-125m | 1.4E-01 | | 1.1E+07 | |

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---------|
| Te-127 | 4.3E+00 | | 3.5E+08 | |
| Te-127m | 4.5E+00 | | 3.7E+08 | |
| Te-129 | 5.9E-01 | | 4.8E+07 | |
| Te-129m | 1.2E+00 | | 9.8E+07 | |
| I-129 | 3.3E-01 | | 2.7E+07 | |
| Cs-134 | 6.7E-02 | | 5.5E+06 | |
| Cs-135 | 2.1E-06 | | 1.7E+02 | |
| Cs-136 | 3.6E-02 | | 2.9E+06 | |
| Cs-137 | 3.3E-01 | | 2.7E+07 | |
| Ba-137m | 3.3E-01 | | 2.7E+07 | |
| Ba-140 | 1.7E-01 | | 1.4E+07 | |
| Ce-141 | 1.2E-01 | | 9.8E+06 | |
| Ce-144 | 5.5E-01 | | 4.5E+07 | |
| Pr-144 | 5.5E-01 | | 4.5E+07 | |
| Pr-144m | 5.5E-01 | | 4.5E+07 | |
| Pm-146 | 6.3E-02 | | 5.1E+06 | |
| Pm-147 | 7.2E-01 | | 5.9E+07 | |
| Pm-148 | 4.5E-01 | | 3.7E+07 | |
| Pm-148m | 4.1E-02 | | 3.3E+06 | |
| Sm-151 | 1.0E-02 | | 8.1E+05 | |
| Eu-152 | 1.9E-01 | | 1.5E+07 | |
| Eu-154 | 1.0E-01 | | 8.1E+06 | |
| Eu-155 | 1.8E-01 | | 1.5E+07 | |
| Gd-153 | 1.9E-01 | | 1.5E+07 | |
| Tb-160 | 1.4E-01 | | 1.1E+07 | |
| Pu-238 | 2.8E-02 | | 2.3E+06 | |
| Pu-239 | 2.8E-02 | | 2.3E+06 | |
| Pu-240 | 2.8E-02 | | 2.3E+06 | |
| Pu-241 | 1.0E+00 | | 8.1E+07 | |
| Am-241 | 2.8E-02 | | 2.3E+06 | |
| Am-242m | 5.1E-04 | | 4.2E+04 | |
| Am-243 | 2.8E-02 | | 2.3E+06 | |
| Cm-242 | 2.8E-02 | | 2.3E+06 | |
| Cm-243 | 2.8E-02 | | 2.3E+06 | |
| Cm-244 | 2.8E-02 | | 2.3E+06 | |

(2) Modeling of diffusion and transfer after discharge

(1) Selection of the migration model

As the migration model of radioactive materials discharged into the sea, the following was selected referring to GSG-10, domestic cases, etc. For the timeline of selection, etc., see Attachment VI “Transfer pathways and exposure pathways other than the assessment targets.”

i. Advection and diffusion by tidal currents, etc.

Advection and diffusion in the sea were selected because the water will be discharged into the sea.

ii. Advection and diffusion by tidal currents, etc. -> Adhesion to hulls

Adhesion to hulls is selected because ships sail for fishing, etc., in the sea.

iii. Advection and diffusion by tidal currents, etc. -> Adhesion to seabed sediment and beach sand

Selected because radioactive materials will be advected and diffused by tidal currents, etc., and migrate to seabed sediment, beach sand, etc.

iv. Advection and diffusion by tidal currents, etc. -> Adhesion to fishing nets

Migration to fishing nets is selected because radioactive materials will be advected and diffused by tidal currents, etc., and adhered to fishing nets used in the surrounding area.

v. Advection and diffusion by tidal currents -> Resuspension to air by seawater spray

Selected because radioactive materials will be advected and diffused by tidal currents, etc., and seawater spray will occur due to waves, etc., at beaches.

vi. Advection and diffusion by tidal currents, etc. -> Intake and concentration by marine organisms such as fish

Selected because radioactive materials will be advected and diffused by tidal currents, etc., and migrate to and concentrate in fish.

(2) Assessment of advection and diffusion in the sea area

For the calculation of diffusion of radioactive materials in the sea area, the area sea model “ROMS: Regional Ocean Modeling System” applied to off-shore of Fukushima by Central Research Institute of Electric Power Industry (CRIEPI) is used. This model was verified to have high reproducibility by reproduction calculation of the cesium concentration in the seawater from actual past meteorological and oceanographic data and comparison with actual data for diffusion of cesium leaked into the sea due to the Accident at the FDNPS (Tsumune et al., 2020) [4], and also used in “TEPCO Draft Study Responding to the Subcommittee Report on Handling ALPS Treated Water,” [17] which was issued on March 24, 2020. The concentration was calculated from the model of the sea area near the FDNPS at high resolution in order to set the discharge point and the

FDNPS port facilities more correctly. It was verified that higher resolution improved the reproducibility of the concentration in the seawater of cesium leaked due to the accident at the FDNPS. Attachment VII "Validity of the diffusion simulation" shows discussion about the validity of diffusion simulation.

In this report, the concentration in the seawater was calculated from this model in the case of discharge of a total of 22 TBq ($2.2E+13$ Bq) of tritium per year at an even pace throughout the year, and those of the other nuclides were calculated by proportionate calculation of the annual discharge amount with tritium.

In this model, tritium equivalent to the discharge rate is added to the mesh including the discharge point so that it instantaneously spreads evenly in the mesh. Due to the characteristics of the model, dilution of ALPS treated water with the seawater and the promotion effect of the discharge flow velocity on mixing dilution are not considered, so it may be different from the contribution distribution in the actual discharge near the discharge outlet, but there is considered to be no significant difference in the case of diffusion away from the discharge outlet.

This can also be verified by comparing the diffusion simulation results with different discharge points, shown in Attachment VIII "Difference in the diffusion area by discharge location." The annual mean concentration in the 10 km × 10 km area when ALPS treated water is discharged from the unit 5/6 discharge outlet on the sea surface is higher only by 20% than the concentration when ALPS treated water is discharged from an outlet on the seabed 1 km off the coast.

The following shows the major calculation conditions.

Flow data of the sea area

- For the advection term of the flow and tracer as a setting of ROMS (term representing migration with the flow velocity), third-order upwind difference and MPDATA, respectively, were used; for the harmonic viscosity and diffusion terms, fourth-order central difference. The horizontal viscosity and diffusion coefficients are set to $5.0 \text{ m}^2/\text{s}$. For the vertical viscosity and diffusion, the K-profile parameterization mixing (KPP) model (Large et al., 1994) is used and the minimum limit value of the vertical viscosity and diffusion coefficients are set $10^{-5} \text{ m}^2/\text{s}$ and $10^{-6} \text{ m}^2/\text{s}$, respectively.
- For the drive force of the sea surface, we used the result of reanalysis (wind velocity, short wave, long wave, atmospheric pressure, ambient temperature, humidity, and precipitation) with a short-term weather prediction system (Numerical Weather Forecasting and Analysis System (NuWFAS), Hashimoto et al., 2010) [18], which interpolate the short-term weather prediction of the Japan Meteorological Agency (JMA-GSM) using the mesoscale weather model (Weather Research and Forecasting model (WRF), Skamarock, et al, 2008 [19]). The time resolution of the output of NuWFAS is about 1 hour and the horizontal

resolution is 5 km, so in the simulation, the result with the time and horizontal direction interpolated was given.

- As the original data of the boundary conditions and data assimilation (nudging)²⁷, we used the results (water temperature, salt content, and sea surface height) of the reanalysis data of tidal currents updated in real-time (Japan Coastal Ocean Prediction Experiment 2 (JCOPE2, Miyazawa et al., 2009)²⁸ [20].
- Since the off-shore of Fukushima, which is a mixed area of Oyashio and Kuroshio (a cold current from north and a warm current from south, respectively) is affected by the mesoscale vortex, data assimilation (nudging) was applied which mitigates the simulation result into the reanalysis result of the water temperature and salt content by JCOPE2 (The mitigation factor is a daily reciprocal) for the purpose of reproducing complex behavior such as the mesoscale vortex.
- The drive force by tide was set by interpolating the result (8-divided tide: M2, S2, N2, K2, K1, O1, P1, Q1) of the global tide model (TPXO; Egbert and Erofeeva, 2002) as the tidal level, the tidal ellipse, and their phases near the open boundary. Since the resolution of the result of TPXO is $0.25^\circ \times 0.25^\circ$, it is likely that the tidal level amplitude and phase associated with synthesis of reflected wave near the coast cannot be set correctly near the boundary. To correct the tidal components of the boundary, harmonic analysis to resolve each tidal level component for the simulation result at the tidal observation points of JMA (Ofunato, Ayukawa, Onahama, and Choshi) was performed to compare tidal level observation data to adjust the scales and phases of the tidal level and tide of the boundary conditions. Actually, the difference between the simulation and observation results was averaged, and adjustments were made with the averaged difference.

Range of the model (See Figure 6-1-4)

Resolution (overall): North-south about 925 m x East-west about 735 m (about 1 km), 30 vertical layers

Resolution (adjacent area): North-south about 185 m x East-west about 147 m (about 200 m), 30 vertical layers

Model range: The resolution of the sea area surrounded by the blue and red lines is improved in stages from a mesh of about 1 km mesh so that the sea area where the red and blue batches of the northern latitude of 35.30 to 39.71 degrees, the eastern longitude of 140.30 to 143.50 degrees (490 km x 270 km), and north-south about 22.5 km x east-west about 8.4 km around the FDNPS get crossed becomes a 200-m mesh

²⁷ Data assimilation: Method to incorporate actual data in numerical simulation.

²⁸ JCOPE2: Tidal current prediction model developed by JAMSTEC to ascertain the variations of the Kuroshio/Kuroshio Extension, the Oyashio current, the mesoscale vortex, etc., in the northwestern Pacific Ocean.




Figure 6-1-4 Range of the model and water depth distribution

(In the right figure, the resolution of the sea area where the red and blue hatches get crossed is improved into a 200-m mesh)




Figure 6-1-5 Section view of the seabed up to 10 km offshore and vertical division on the model

(3) Setting of exposure pathways

A total of eight exposure pathways are selected based on the existing assessments, GSG-10, etc.²⁹: five external exposure pathways and three internal exposure pathways. The following shows the concept of selection. In revising the report, we clarified the beach assessment point described below and added ingestion of seawater and inhalation of seawater spray as express pathways related to beaches.

(1) External exposure from sea surface

Selected as an exposure pathway because external exposure may occur from radiation from radioactive materials in the seawater during offshore navigation by ship or offshore work.

(2) External exposure from hulls

Selected as an exposure pathway because external exposure may occur from radiation from radioactive materials that have migrated from the seawater to hulls (deck) during offshore navigation by ship or offshore work.

(3) Underwater external exposure during swimming, etc.

Selected as an exposure pathway because external exposure may occur from radiation from radioactive materials in the surrounding seawater during swimming, etc.

(4) External exposure from beach sand

Selected as an exposure pathway because external exposure may occur from radiation from radioactive materials that have moved from seawater to beach sand.

(5) External exposure from fishing nets

Selected as an exposure pathway because external exposure may occur from radiation from radioactive materials that have migrated from the seawater to fishing nets because fishing nets are used in the seawater for fishing.

²⁹ IAEA-TECDOC-1759, "Determining the Suitability of Materials for Disposal at Sea under the London Convention 1972 and London Protocol 1996: A Radiological Assessment Procedure" (2015)

(6) Internal exposure from ingestion of seawater

Selected as an exposure pathway because internal exposure may occur from radiation from radioactive materials in the seawater due to accidental ingestion of seawater.

(7) Internal exposure from inhalation of seawater spray

Selected as an exposure pathway because internal exposure may occur from radiation from radioactive materials in the seawater due to inhalation of seawater spray caused by waves on beaches.

(8) Internal exposure from ingestion of seafood

Selected as an exposure pathway because internal exposure may occur from ingestion of seafood that radioactive materials in the seawater have moved to and concentrated.

The following shows the assessment model and used parameters of each exposure pathway.

a. External exposure

(1) External exposure from sea surface

Assess the external exposure from radioactive materials in the seawater during swimming and offshore work by the model shown in Figure 6-1-6.

Equation (6-1-1) shows the calculation equation of the effective dose D_1 (mSv/year) from radiation from the sea surface.

$$D_1 = \sum_i (K_1)_i \cdot (x_1)_i \cdot t_1 \quad (6-1-1)$$

where

$(K_1)_i$ is the effective dose conversion factor from gamma radiation from nuclide i from sea surface ((mSv/h)/(Bq/L))

$(x_1)_i$ is the concentration of nuclide i in seawater (Bq/L)

t_1 is the annual exposure time (h/year)

For the effective dose conversion factor³⁰ from the gamma rays from the sea surface, the value in the Handbook for Determining Environmental Impacts of Decommissioning Work [21] (hereinafter called “Decommissioning Handbook”) was used. For the calculation of the dose conversion factor for the effective dose, the simple shielding calculation code QAD-CGGP2 is used using the point attenuation nuclear integration method. For β and γ nuclides and α nuclides not shown in the Decommissioning Handbook, conservatively, the highest values, Co-60 and Am-243, respectively were used (Table 6-1-5).

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.




Figure 6-1-6 Assessment model of exposure from the sea surface in the decommissioning handbook

(2) External exposure from hulls

Assess the external exposure from radioactive materials that have migrated from the seawater to hulls during offshore work such as movement by ship by the model shown in Figure 6-1-7.

Equations (6-1-2) and (6-1-3) show the calculation equation of the effective dose D_2 (mSv/year) from hulls.

$$D_2 = \sum_i (K_2)_i \cdot (S_2)_i \cdot t_2 \quad (6-1-2)$$

$$(S_2)_i = (F_2)_i \cdot (x_2)_i \quad (6-1-3)$$

where

$(K_2)_i$ is the effective dose conversion factor from gamma radiation from nuclide i from hulls ((mSv/h)/(Bq/m²))

$(S_2)_i$ is the contamination density of nuclide i in hulls (Bq/m²)

t_2 is the annual exposure time (h/year)

$(F_2)_i$ is the migration factor of nuclide i from seawater to hulls ((Bq/m²)/(Bq/L))

$(x_2)_i$ is the concentration of nuclide i in seawater (Bq/L)

³⁰ Radiation dose per hour (mSv/h) from radiation from radioactive materials contained in the seawater ingested by those working above the sea surface when any radioactive materials are contained in the seawater at a concentration of 1Bq/L, as shown in the model of Figure 6-1-6.

For the effective dose conversion factor³¹ from the gamma rays from radioactive materials adhered to hulls, the value of the Decommissioning Handbook was used. For the calculation of the dose conversion factor for the effective dose, the simple shielding calculation code QAD-CGGP2 is used using the point attenuation nuclear integration method. For β and γ nuclides and α nuclides not shown in the Decommissioning Handbook, conservatively, the highest values, Co-60 and Am-243, respectively were used (Table 6-1-6). The factor of migration to hulls³² was assumed to be constantly in the equilibrium state with the concentration in the seawater at $100((\text{Bq}/\text{m}^2)/(\text{Bq}/\text{L}))$ according to “Application for the Designation of Reprocessing Business of Rokkasho Plant” (Japan Nuclear Fuel Service, 1989). [22]

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.




Figure 6-1-7 Assessment model of exposure from hulls in the decommissioning handbook

(3) Underwater external exposure during swimming, etc.

Assess the external exposure from gamma rays from radioactive materials in the surrounding seawater during swimming and underwater work by the submersion model³³.

Equation (6-1-4) shows the calculation equation of the effective dose D_3 (mSv/year) from radiation during swimming and underwater work.

$$D_3 = \sum_i (K_3)_i \cdot (x_3)_i \cdot t_3 \quad (6-1-4)$$

where

$(K_3)_i$ is the effective dose conversion factor from gamma radiation from nuclide i from seawater ((mSv/h)/(Bq/L))

$(x_3)_i$ is the concentration of nuclide i in seawater (Bq/L)

t_3 is the annual swimming time (h/year)

³¹ Radiation dose ingested by people on ships from radiation emitted from radioactive materials that have migrated from the seawater to hulls; evaluated by the model of Figure 6-1-7; and shown as a coefficient for the deposit density of radioactive materials adhered to hulls.

³² Degree of adhesion of radioactive materials to what contacts the seawater if the concentration of radioactive materials contained in the seawater is 1Bq/L, shown as radiation per unit area.

³³ Model to calculate exposure from radiation from the surrounding radioactive materials.

For the effective dose conversion factor from the gamma rays in the seawater, the value of the Decommissioning Handbook was used. For β and γ nuclides and α nuclides not shown in the Decommissioning Handbook, conservatively, the highest values, Co-60 and Am-243, respectively were used (Table 6-1-7).

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.

(4) External exposure from beach sand

Assess the external exposure from radioactive materials migrated from seawater to beach sand while staying on a beach by the model shown in Figure 6-1-8.

Equation (6-1-5) shows the calculation equation of the effective dose D_4 (mSv/year) from the gamma radiation from beach sand.

$$D_4 = \sum_i (K_4)_i \cdot (x_4)_i \cdot (F_4)_i \cdot t_4 \quad (6-1-5)$$

where

$(K_4)_i$ is the effective dose conversion factor from gamma radiation from nuclide i from beach sand ((mSv/h)/(Bq/kg))

$(x_4)_i$ is the concentration of nuclide i in seawater (Bq/L)

$(F_4)_i$ is the migration factor of nuclide i from seawater to beaches ((Bq/kg)/(Bq/L))

t_4 is the annual exposure time (h/year)

For the effective dose conversion factor from the gamma rays from beach sand, the value of the Decommissioning Handbook was used. For the calculation of the dose conversion factor for the effective dose, the simple shielding calculation code QAD-CGGP2 is used using the point attenuation nuclear integration method. For β and γ nuclides and α nuclides not shown in the Decommissioning Handbook, conservatively, the highest values, Co-60 and Am-243, respectively were used (Table 6-1-8). The migration factor of nuclides to beaches is assumed to constantly in the equilibrium state with the concentration in the seawater at 1,000((Bq/kg)/(Bq/L)) for all nuclides based on "Dose Assessment to the General Public in the Safety Review of Commercial Light Water Reactor Facilities."

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.




Figure 6-1-8 Assessment model of exposure from beach sand in the decommissioning handbook

(5) External exposure from fishing nets

Assess external exposure from radioactive materials that have migrated from the seawater to fishing nets and adhered to fishing nets when they are placed on a ship or ground during fishing work, by the model shown in Figure 6-1-9.

Equations (6-1-6) and (6-1-7) show the calculation equation of the effective dose D_5 (mSv/year) from radioactive materials adhered to fishing nets.

$$D_5 = \sum_i (K_5)_i \cdot (S_5)_i \cdot t_5 \quad (6-1-6)$$

$$(S_5)_i = (F_5)_i \cdot (x_5)_i \quad (6-1-7)$$

where

- $(K_5)_i$ is the effective dose conversion factor from gamma radiation from nuclide i from fishing nets ((mSv/h)/(Bq/kg))
- $(S_5)_i$ is the concentration of nuclide i on fishing nets (Bq/kg)
- t_5 is the annual exposure time (h/year)
- $(F_5)_i$ is the migration factor of nuclide i from seawater to fishing nets ((Bq/kg)/(Bq/L))
- $(x_5)_i$ is the concentration of nuclide i in seawater (Bq/L)

For the effective dose conversion factor, the value of the Decommissioning Handbook was used. For the calculation of the dose conversion factor for the effective dose, the simple shielding calculation code QAD-CGGP2 is used using the point attenuation nuclear integration method. For β and γ nuclides and α nuclides not shown in the Decommissioning Handbook, conservatively, the highest values, Co-60 and Am-243, respectively were used (Table 6-1-9). The factor of migration to fishing nets was assumed to be constantly in the equilibrium state with the concentration in the seawater at 4,000((Bq/kg)/(Bq/L)) for all nuclides other than tritium according to "Application for the Designation of Reprocessing Business of Rokkasho Plant."

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.




Figure 6-1-9 Assessment model of exposure from fishing nets in the decommissioning handbook

b. Internal exposure

(6) Internal exposure from ingestion of water

Accidental ingestion of seawater while swimming in the sea may happen; therefore, assess internal exposure from ingestion of water while swimming.

Equation (6-1-8) shows the calculation equation of the effective dose D_6 (mSv/year) from radioactive materials from ingestion of water.

$$D_6 = \sum_i t_6 \cdot Hs \cdot (x_6)_i \cdot (K_F^{50})_i \quad (6-1-8)$$

where

t_6 is the annual swimming time (h/year)

Hs is the seawater intake rate during swimming and conservatively set to 0.2L/h for adult and child under school age

$(x_6)_i$ is the concentration of nuclide i in seawater (Bq/L)

$(K_F^{50})_i$ is the committed effective dose factor from ingestion of nuclide i ((mSv)/(Bq))

For the committed effective dose factor from ingestion, the factor specified in Table III.2D. "Members of the Public: Committed Effective Dose per Unit Intake e(g) via ingestion (Sv/Bq)" of the IAEA No. GSR Part 3 "Radiation Protection and Safety of Radiation Sources: International Basic Safety Standards" (hereinafter called "GSR Part 3") was used (Table 6-1-10).

Infant was excluded from the assessment targets because it rarely swims.

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.

(7) Internal exposure from inhalation of seawater spray

Internal exposure from inhalation of seawater spray is assessed because seawater spray caused by waves is considered to be inhaled at beaches. The assessment procedure is based on the IAEA-TECDOC-1759 “Determining the Suitability of Materials for Disposal at Sea under the London Convention 1972 and London Protocol 1996: A Radiological Assessment Procedure” [23] (hereinafter called “TECDOC-1759”). Equation (6-1-9) shows the calculation equation of the effective dose D_7 (mSv/year) from radioactive materials from inhalation of seawater spray.

$$D_7 = 10^3 \cdot \sum_i t_7 \cdot R_s \cdot \frac{C_s}{\rho_w} (x_7)_i \cdot (K_h^{50})_i \quad (6-1-9)$$

where

- t_7 is the annual beach stay time (h/year)
- R_s is the respiration rate, and 0.925 m³/h, 0.363 m³/h, and 0.119 m³/h are used for adult, child under school age, and infant, respectively, according to “Guidelines for the Assessment of Dose Target Values Around Light Water Reactor Facilities” [24].
- C_s is the air concentration of seawater spray (kg/m³) and the recommended value of TECDOC-1759, 1.0E-02kg/m³, is used
- ρ_w is the density of seawater and 1.0E+03 kg/m³ is used.
- $(x_7)_i$ is the concentration of nuclide i in seawater (Bq/L)
- $(K_h^{50})_i$ is the committed effective dose factor from inhalation of nuclide i (mSv/Bq)
- 10^3 is the factor converted to the unit (10³L/m³)

For the committed effective dose factor from inhalation, the factor specified in Table III.2E. “Members of the Public: Committed Effective Dose per Unit Intake e(g) via inhalation (Sv/Bq)” of GSR Part 3 was used, but only for tritium, the one specified in Table III.2G. “Inhalation: Committed Effective Dose per Unit Intake e(g) (Sv/Bq) for soluble or reactive gases and vapours” was used. (Table 6-1-11).

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.

(8) Internal exposure from ingestion of seafood

Internal exposure from ingestion of radioactive materials that have migrated from the seawater to marine organisms through ingestion of seafood is assessed.

Equations (6-1-10) and (6-1-11) show the calculation equation of the effective dose D_8 (mSv/year) from ingestion of seafood

$$D_8 = \sum_k \sum_i (K_F^{50})_i \cdot H_{ki} \quad (6-1-10)$$

$$H_{ki} = 365 \cdot 10^{-3} \cdot (x_8)_i \cdot (CF)_{ki} \cdot F_k \cdot W_k \cdot f_{ki} \quad (6-1-11)$$

where

$(K_F^{50})_i$ is the committed effective dose factor from ingestion of nuclide i
(mSv/Bq)

H_{ki} is the ingestion rate (Bq/year) of nuclide i through ingestion of seafood k

(x_8) Concentration of nuclide i in seawater (Bq/L)

$(CF)_{ki}$ is the concentration factor of nuclide i to seafood k ((Bq/kg)/(Bq/L))³⁴

F_k is the market dilution factor³⁵

W_k is the ingestion amount of seafood k (g/day)

f_{ki} is the decay ratio of nuclide i from catching to ingestion of seafood k

$365 \cdot 10^{-3}$ is the factor converted to the unit (365 days/year, 10^{-3} kg/g)

The committed effective dose coefficient from ingestion is the same as that from ingestion of water during swimming (Table 6-1-10).

For the concentration factor of seafood³⁶, the factor specified in IAEA Technical Reports Series No.422 "Sediment Distribution Coefficients and Concentration Factors for Biota in the Marine Environment" [25] (hereinafter called "TRS-422") and UCRL-50564 Rev.1 "CONCENTRATION FACTORS OF CHEMICAL ELEMENTS IN EDIBLE AQUATIC ORGANISMS" [26] (hereinafter called "UCRL-50564 Rev.1") was used (Table 6-1-12).

Actually, market dilution which must occur during market distribution of seafood from other production areas and decay of nuclides from catching to ingestion of seafood were ignored to secure conservativeness.

The concentration in the seawater used for the assessment and the annual exposure time are set by the characteristics of representative persons.

³⁴ Expedient factor indicating the relationship between the radioactive nuclide concentration in marine organisms (per wet weight) in marine organisms (in principle, edible parts) and the radioactive nuclide concentration in the seawater in the environment where such organisms live, which is used for the assessment model for migration to organisms (IAEA, 2004).

³⁵ Generally, it is extremely rare that all foods are local products, and products caught in other places not affected by discharge of radioactive materials considered are distributed together. This reduces the impact of discharge of radioactive materials to the environment to be performed, so it is instructed to set and assess the percentage of intake (market dilution factor) for each food, but conservatively all products are assumed to be caught in the sea area in question without considering market dilution in this assessment.

³⁶ Radioactive materials are ingested in organisms which live for a long time in the seawater containing radioactive materials depending on the types of elements, and it reaches equilibrium at a certain concentration. This refers to the ratio of the concentration of the radioactive materials in the seawater in the surrounding environment to the equilibrium concentration of radioactive materials in organisms.

**Table 6-1-5 Dose conversion factor for the effective dose of radiation from the sea surface
(Decommissioning handbook [21] and others are shown in remarks)**

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/L)) | Remarks |
|---------|--|--|
| H-3 | 0.0E+00 | Defined 0 due to pure β nuclide |
| C-14 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Mn-54 | 1.7E-07 | |
| Fe-59 | 3.2E-11 | |
| Co-58 | 2.0E-07 | |
| Co-60 | 5.0E-07 | |
| Ni-63 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Zn-65 | 1.2E-07 | |
| Rb-86 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-89 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-90 | 1.6E-09 | |
| Y-90 | - | Contained in the parent nuclide Sr-90 |
| Y-91 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Nb-95 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tc-99 | 1.5E-11 | |
| Ru-103 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ru-106 | 4.5E-08 | |
| Rh-103m | - | Contained in the parent nuclide Ru-103 |
| Rh-106 | - | Contained in the parent nuclide Ru-106 |
| Ag-110m | 5.0E-07 | Conservatively set to the same value as that of Co-60 |
| Cd-113m | 7.4E-11 | |
| Cd-115m | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-119m | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-123 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-126 | 1.1E-08 | |
| Sb-124 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sb-125 | 8.7E-08 | |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/L)) | Remarks |
|---------|--|--|
| Te-123m | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-125m | 6.6E-09 | |
| Te-127 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-127m | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-129 | - | Contained in the parent nuclide Te-129m |
| Te-129m | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| I-129 | 4.6E-09 | |
| Cs-134 | 3.1E-07 | |
| Cs-135 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-136 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-137 | 1.2E-07 | |
| Ba-137m | - | Contained in the parent nuclide Cs-137 |
| Ba-140 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-141 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-144 | 1.3E-08 | |
| Pr-144 | - | Contained in the parent nuclide Ce-144 |
| Pr-144m | - | Contained in the parent nuclide Ce-144 |
| Pm-146 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-147 | 8.2E-12 | |
| Pm-148 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-148m | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sm-151 | 1.7E-12 | |
| Eu-152 | 2.3E-07 | |
| Eu-154 | 2.5E-07 | |
| Eu-155 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/L)) | Remarks |
|---------|--|---|
| Gd-153 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tb-160 | 5.0E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pu-238 | 4.7E-11 | |
| Pu-239 | 2.6E-11 | |
| Pu-240 | 4.6E-11 | |
| Pu-241 | 2.9E-08 | |
| Am-241 | 4.6E-09 | |
| Am-242m | 3.1E-09 | |
| Am-243 | 4.4E-08 | |
| Cm-242 | 4.8E-11 | |
| Cm-243 | 4.4E-08 | Conservatively, the same value as that of Am-243 is set because no value is given to this nuclide in the source |
| Cm-244 | 4.5E-11 | |

Table 6-1-6 Dose conversion factor for the effective dose of radiation from hulls (Decommissioning handbook [21] and others are shown in remarks)

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/m ²)) | Remarks |
|---------|--|--|
| H-3 | 0.0E+00 | Defined 0 due to pure β nuclide |
| C-14 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Mn-54 | 1.4E-09 | |
| Fe-59 | 4.2E-12 | |
| Co-58 | 1.6E-09 | |
| Co-60 | 3.5E-09 | |
| Ni-63 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Zn-65 | 1.0E-09 | |
| Rb-86 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-89 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-90 | 5.8E-11 | |
| Y-90 | - | Contained in the parent nuclide Sr-90 |
| Y-91 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Nb-95 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tc-99 | 2.8E-12 | |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/m ²)) | Remarks |
|---------|--|--|
| Ru-103 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ru-106 | 4.0E-10 | |
| Rh-103m | - | Contained in the parent nuclide Ru-103 |
| Rh-106 | - | Contained in the parent nuclide Ru-106 |
| Ag-110m | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cd-113m | 7.2E-12 | |
| Cd-115m | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-119m | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-123 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-126 | 2.3E-10 | |
| Sb-124 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sb-125 | 8.3E-10 | |
| Te-123m | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-125m | 4.4E-10 | |
| Te-127 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-127m | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-129 | - | Contained in the parent nuclide Te-129m |
| Te-129m | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| I-129 | 3.0E-10 | |
| Cs-134 | 2.4E-09 | |
| Cs-135 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-136 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-137 | 9.5E-10 | |
| Ba-137m | - | Contained in the parent nuclide Cs-137 |
| Ba-140 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/m ²)) | Remarks |
|---------|--|---|
| Ce-141 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-144 | 1.6E-10 | |
| Pr-144 | - | Contained in the parent nuclide Ce-144 |
| Pr-144m | - | Contained in the parent nuclide Ce-144 |
| Pm-146 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-147 | 1.9E-12 | |
| Pm-148 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-148m | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sm-151 | 8.7E-13 | |
| Eu-152 | 1.8E-09 | |
| Eu-154 | 1.8E-09 | |
| Eu-155 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Gd-153 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tb-160 | 3.5E-09 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pu-238 | 1.1E-10 | |
| Pu-239 | 3.9E-11 | |
| Pu-240 | 1.0E-10 | |
| Pu-241 | 7.7E-10 | |
| Am-241 | 2.0E-10 | |
| Am-242m | 8.3E-10 | |
| Am-243 | 1.1E-09 | |
| Cm-242 | 1.1E-10 | |
| Cm-243 | 1.1E-09 | Conservatively, the same value as that of Am-243 is set because no value is given to this nuclide in the source |
| Cm-244 | 1.0E-10 | |

Table 6-1-7 Dose conversion factor for the effective dose of radiation from seawater during swimming and underwater work (Decommissioning handbook [21] and others are shown in remarks)

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/L)) | Remarks |
|---------|--|--|
| H-3 | 0.0E+00 | |
| C-14 | 0.0E+00 | |
| Mn-54 | 4.8E-07 | |
| Fe-59 | 6.8E-07 | |
| Co-58 | 4.7E-07 | |
| Co-60 | 1.4E-06 | |
| Ni-63 | 0.0E+00 | |
| Zn-65 | 3.3E-07 | |
| Rb-86 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-89 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-90 | 7.2E-13 | |
| Y-90 | - | Contained in the parent nuclide Sr-90 |
| Y-91 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Nb-95 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tc-99 | 4.0E-13 | |
| Ru-103 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ru-106 | 1.2E-07 | |
| Rh-103m | - | Contained in the parent nuclide Ru-103 |
| Rh-106 | - | Contained in the parent nuclide Ru-106 |
| Ag-110m | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cd-113m | 4.2E-11 | |
| Cd-115m | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-119m | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-123 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-126 | 3.2E-08 | |
| Sb-124 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/L)) | Remarks |
|---------|--|--|
| Sb-125 | 2.5E-07 | |
| Te-123m | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-125m | 2.0E-08 | |
| Te-127 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-127m | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-129 | - | Contained in the parent nuclide Te-129m |
| Te-129m | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| I-129 | 1.4E-08 | |
| Cs-134 | 9.0E-07 | |
| Cs-135 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-136 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-137 | 3.4E-07 | |
| Ba-137m | - | Contained in the parent nuclide Cs-137 |
| Ba-140 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-141 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-144 | 2.8E-08 | |
| Pr-144 | - | Contained in the parent nuclide Ce-144 |
| Pr-144m | - | Contained in the parent nuclide Ce-144 |
| Pm-146 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-147 | 2.5E-12 | |
| Pm-148 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-148m | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sm-151 | 8.3E-12 | |
| Eu-152 | 6.6E-07 | |
| Eu-154 | 6.4E-07 | |
| Eu-155 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/L)) | Remarks |
|---------|--|---|
| Gd-153 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tb-160 | 1.4E-06 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pu-238 | 1.1E-09 | |
| Pu-239 | 5.2E-10 | |
| Pu-240 | 9.9E-10 | |
| Pu-241 | 8.1E-08 | |
| Am-241 | 1.9E-08 | |
| Am-242m | 1.4E-08 | |
| Am-243 | 1.4E-07 | |
| Cm-242 | 1.1E-09 | |
| Cm-243 | 1.4E-07 | Conservatively, the same value as that of Am-243 is set because no value is given to this nuclide in the source |
| Cm-244 | 9.0E-10 | |

**Table 6-1-8 Dose conversion factor for the effective dose of radiation from beach sand
(Decommissioning handbook [21] and others are shown in remarks)**

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/kg)) | Remarks |
|---------|---|--|
| H-3 | 0.0E+00 | Defined 0 due to pure β nuclide |
| C-14 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Mn-54 | 1.6E-07 | |
| Fe-59 | 1.6E-11 | |
| Co-58 | 1.9E-07 | |
| Co-60 | 4.7E-07 | |
| Ni-63 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Zn-65 | 1.1E-07 | |
| Rb-86 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-89 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-90 | 1.2E-09 | |
| Y-90 | - | Contained in the parent nuclide Sr-90 |
| Y-91 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Nb-95 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/kg)) | Remarks |
|---------|---|--|
| Tc-99 | 6.3E-12 | |
| Ru-103 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ru-106 | 4.3E-08 | |
| Rh-103m | - | Contained in the parent nuclide Ru-103 |
| Rh-106 | - | Contained in the parent nuclide Ru-106 |
| Ag-110m | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cd-113m | 4.1E-11 | |
| Cd-115m | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-119m | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-123 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-126 | 5.2E-09 | |
| Sb-124 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sb-125 | 8.3E-08 | |
| Te-123m | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-125m | 1.9E-09 | |
| Te-127 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-127m | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-129 | - | Contained in the parent nuclide Te-129m |
| Te-129m | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| I-129 | 1.3E-09 | |
| Cs-134 | 3.1E-07 | |
| Cs-135 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-136 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-137 | 1.2E-07 | |
| Ba-137m | - | Contained in the parent nuclide Cs-137 |
| Ba-140 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/kg)) | Remarks |
|---------|---|---|
| Ce-141 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-144 | 1.0E-08 | |
| Pr-144 | - | Contained in the parent nuclide Ce-144 |
| Pr-144m | - | Contained in the parent nuclide Ce-144 |
| Pm-146 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-147 | 3.5E-12 | |
| Pm-148 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-148m | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sm-151 | 6.3E-13 | |
| Eu-152 | 2.1E-07 | |
| Eu-154 | 2.3E-07 | |
| Eu-155 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Gd-153 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tb-160 | 4.7E-07 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pu-238 | 3.6E-11 | |
| Pu-239 | 2.1E-11 | |
| Pu-240 | 3.5E-11 | |
| Pu-241 | 2.0E-08 | |
| Am-241 | 1.7E-09 | |
| Am-242m | 2.0E-09 | |
| Am-243 | 3.1E-08 | |
| Cm-242 | 3.7E-11 | |
| Cm-243 | 3.1E-08 | Conservatively, the same value as that of Am-243 is set because no value is given to this nuclide in the source |
| Cm-244 | 3.6E-11 | |

Table 6-1-9 Dose conversion factor for the effective dose of radiation from fishing nets

(Decommissioning handbook [21] and others are shown in remarks)

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/kg)) | Remarks |
|---------|---|--|
| H-3 | 0.0E+00 | Defined 0 due to pure β nuclide |
| C-14 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Mn-54 | 3.2E-08 | |
| Fe-59 | 2.2E-12 | |
| Co-58 | 3.7E-08 | |
| Co-60 | 9.9E-08 | |
| Ni-63 | 0.0E+00 | Defined 0 due to pure β nuclide |
| Zn-65 | 2.3E-08 | |
| Rb-86 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-89 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sr-90 | 2.1E-10 | |
| Y-90 | - | Contained in the parent nuclide Sr-90 |
| Y-91 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Nb-95 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tc-99 | 7.9E-13 | |
| Ru-103 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ru-106 | 8.2E-09 | |
| Rh-103m | - | Contained in the parent nuclide Ru-103 |
| Rh-106 | - | Contained in the parent nuclide Ru-106 |
| Ag-110m | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cd-113m | 5.9E-12 | |
| Cd-115m | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-119m | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-123 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sn-126 | 7.0E-10 | |
| Sb-124 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/kg)) | Remarks |
|---------|---|--|
| Sb-125 | 1.5E-08 | |
| Te-123m | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-125m | 2.3E-10 | |
| Te-127 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-127m | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Te-129 | - | Contained in the parent nuclide Te-129m |
| Te-129m | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| I-129 | 1.6E-10 | |
| Cs-134 | 5.9E-08 | |
| Cs-135 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-136 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Cs-137 | 2.2E-08 | |
| Ba-137m | - | Contained in the parent nuclide Cs-137 |
| Ba-140 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-141 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Ce-144 | 2.0E-09 | |
| Pr-144 | - | Contained in the parent nuclide Ce-144 |
| Pr-144m | - | Contained in the parent nuclide Ce-144 |
| Pm-146 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-147 | 4.2E-13 | |
| Pm-148 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pm-148m | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Sm-151 | 5.8E-14 | |
| Eu-152 | 4.3E-08 | |
| Eu-154 | 4.7E-08 | |
| Eu-155 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |

| Nuclide | Dose conversion factor for the effective dose ((mSv/h)/(Bq/kg)) | Remarks |
|---------|---|---|
| Gd-153 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Tb-160 | 9.9E-08 | Conservatively, the same value as that of Co-60 is set because no value is given to this nuclide in the source |
| Pu-238 | 1.7E-12 | |
| Pu-239 | 1.9E-12 | |
| Pu-240 | 1.8E-12 | |
| Pu-241 | 3.1E-09 | |
| Am-241 | 2.1E-10 | |
| Am-242m | 2.7E-10 | |
| Am-243 | 4.8E-09 | |
| Cm-242 | 1.8E-12 | |
| Cm-243 | 4.8E-09 | Conservatively, the same value as that of Am-243 is set because no value is given to this nuclide in the source |
| Cm-244 | 2.1E-12 | |

Table 6-1-10 Effective dose factor of ingestion (GSR Part 3 [13])

| Target nuclide | Effective dose factor (mSv/Bq) | | | Remarks |
|-----------------------|--------------------------------|------------------------|---------|--|
| | Adult | Child under school age | Infant | |
| H-3 (THO) | 1.8E-08 | 3.1E-08 | 6.4E-08 | Used for the assessment of ingestion of water |
| H-3 (considering OBT) | 2.0E-08 | 3.5E-08 | 7.0E-08 | Used for the assessment of ingestion of seafood assuming that 10% of tritium to be ingested is OBT |
| C-14 | 5.8E-07 | 9.9E-07 | 1.4E-06 | |
| Mn-54 | 7.1E-07 | 1.9E-06 | 5.4E-06 | |
| Fe-59 | 1.8E-06 | 7.5E-06 | 3.9E-05 | |
| Co-58 | 7.4E-07 | 2.6E-06 | 7.3E-06 | |
| Co-60 | 3.4E-06 | 1.7E-05 | 5.4E-05 | |
| Ni-63 | 1.5E-07 | 4.6E-07 | 1.6E-06 | |
| Zn-65 | 3.9E-06 | 9.7E-06 | 3.6E-05 | |
| Rb-86 | 2.8E-06 | 9.9E-06 | 3.1E-05 | |
| Sr-89 | 2.6E-06 | 8.9E-06 | 3.6E-05 | |
| Sr-90 | 2.8E-05 | 4.7E-05 | 2.3E-04 | Including the impact of the progeny nuclide |
| Y-90 | 2.7E-06 | 1.0E-05 | 3.1E-05 | |
| Y-91 | 2.4E-06 | 8.8E-06 | 2.8E-05 | |
| Nb-95 | 5.8E-07 | 1.8E-06 | 4.6E-06 | |

| Target nuclide | Effective dose factor (mSv/Bq) | | | Remarks |
|----------------|-----------------------------------|------------------------------|---------|---|
| | Adult | Child under school age | Infant | |
| Tc-99 | 6.4E-07 | 2.3E-06 | 1.0E-05 | |
| Ru-103 | 7.3E-07 | 2.4E-06 | 7.1E-06 | Including the impact of the progeny nuclide |
| Ru-106 | 7.0E-06 | 2.5E-05 | 8.4E-05 | Including the impact of the progeny nuclide |
| Rh-103m | 3.8E-09 | 1.3E-08 | 4.7E-08 | |
| Rh-106 | - | - | - | Independent intake is not considered because the half-life is short enough (about 30 seconds). |
| Ag-110m | 2.8E-06 | 7.8E-06 | 2.4E-05 | |
| Cd-113m | 2.3E-05 | 3.9E-05 | 1.2E-04 | |
| Cd-115m | 3.3E-06 | 9.7E-06 | 4.1E-05 | |
| Sn-119m | 3.4E-07 | 1.3E-06 | 4.1E-06 | |
| Sn-123 | 2.1E-06 | 7.8E-06 | 2.5E-05 | |
| Sn-126 | 4.7E-06 | 1.6E-05 | 5.0E-05 | |
| Sb-124 | 2.5E-06 | 8.4E-06 | 2.5E-05 | |
| Sb-125 | 1.1E-06 | 3.4E-06 | 1.1E-05 | |
| Te-123m | 1.4E-06 | 4.9E-06 | 1.9E-05 | |
| Te-125m | 8.7E-07 | 3.3E-06 | 1.3E-05 | |
| Te-127 | 1.7E-07 | 6.2E-07 | 1.5E-06 | |
| Te-127m | 2.3E-06 | 9.5E-06 | 4.1E-05 | |
| Te-129 | 6.3E-08 | 2.1E-07 | 7.5E-07 | |
| Te-129m | 3.0E-06 | 1.2E-05 | 4.4E-05 | Including the impact of the progeny nuclide |
| I-129 | 1.1E-04 | 1.7E-04 | 1.8E-04 | |
| Cs-134 | 1.9E-05 | 1.3E-05 | 2.6E-05 | |
| Cs-135 | 2.0E-06 | 1.7E-06 | 4.1E-06 | |
| Cs-136 | 3.0E-06 | 6.1E-06 | 1.5E-05 | |
| Cs-137 | 1.3E-05 | 9.6E-06 | 2.1E-05 | Including the impact of the progeny nuclide |
| Ba-137m | - | - | - | Independent intake is not considered because the half-life is short enough (about 2.6 minutes). |
| Ba-140 | 2.6E-06 | 9.2E-06 | 3.2E-05 | |
| Ce-141 | 7.1E-07 | 2.6E-06 | 8.1E-06 | |
| Ce-144 | 5.2E-06 | 1.9E-05 | 6.6E-05 | Including the impact of the progeny nuclide |
| Pr-144 | 5.0E-08 | 1.7E-07 | 6.4E-07 | |
| Pr-144m | - | - | - | Independent intake is not considered because the half-life is short enough (about 7.2 minutes). |
| Pm-146 | 9.0E-07 | 2.8E-06 | 1.0E-05 | |

| Target nuclide | Effective dose factor (mSv/Bq) | | | Remarks |
|----------------|-----------------------------------|------------------------------|---------|---------|
| | Adult | Child under school age | Infant | |
| Pm-147 | 2.6E-07 | 9.6E-07 | 3.6E-06 | |
| Pm-148 | 2.7E-06 | 9.7E-06 | 3.0E-05 | |
| Pm-148m | 1.7E-06 | 5.5E-06 | 1.5E-05 | |
| Sm-151 | 9.8E-08 | 3.3E-07 | 1.5E-06 | |
| Eu-152 | 1.4E-06 | 4.1E-06 | 1.6E-05 | |
| Eu-154 | 2.0E-06 | 6.5E-06 | 2.5E-05 | |
| Eu-155 | 3.2E-07 | 1.1E-06 | 4.3E-06 | |
| Gd-153 | 2.7E-07 | 9.4E-07 | 2.9E-06 | |
| Tb-160 | 1.6E-06 | 5.4E-06 | 1.6E-05 | |
| Pu-238 | 2.3E-04 | 3.1E-04 | 4.0E-03 | |
| Pu-239 | 2.5E-04 | 3.3E-04 | 4.2E-03 | |
| Pu-240 | 2.5E-04 | 3.3E-04 | 4.2E-03 | |
| Pu-241 | 4.8E-06 | 5.5E-06 | 5.6E-05 | |
| Am-241 | 2.0E-04 | 2.7E-04 | 3.7E-03 | |
| Am-242m | 1.9E-04 | 2.3E-04 | 3.1E-03 | |
| Am-243 | 2.0E-04 | 2.7E-04 | 3.6E-03 | |
| Cm-242 | 1.2E-05 | 3.9E-05 | 5.9E-04 | |
| Cm-243 | 1.5E-04 | 2.2E-04 | 3.2E-03 | |
| Cm-244 | 1.2E-04 | 1.9E-04 | 2.9E-03 | |

Table 6-1-11 Effective dose factor of inhalation (GSR Part 3 [13])

| Target nuclide | Effective dose factor (mSv/Bq) | | | Remarks |
|----------------|-----------------------------------|------------------------------|---------|--|
| | Adult | Child under school age | Infant | |
| H-3 | 1.8E-08 | 3.1E-08 | 6.4E-08 | The conversion factor of tritium vapor is used |
| C-14 | 5.8E-06 | 1.1E-05 | 1.9E-05 | |
| Mn-54 | 1.5E-06 | 3.8E-06 | 7.5E-06 | |
| Fe-59 | 4.0E-06 | 8.1E-06 | 2.1E-05 | |
| Co-58 | 2.1E-06 | 4.5E-06 | 9.0E-06 | |
| Co-60 | 3.1E-05 | 5.9E-05 | 9.2E-05 | |
| Ni-63 | 1.3E-06 | 2.7E-06 | 4.8E-06 | |
| Zn-65 | 2.2E-06 | 5.7E-06 | 1.5E-05 | |
| Rb-86 | 9.3E-07 | 3.4E-06 | 1.2E-05 | |
| Sr-89 | 7.9E-06 | 1.7E-05 | 3.9E-05 | |

| Target nuclide | Effective dose factor (mSv/Bq) | | | Remarks |
|----------------|-----------------------------------|------------------------------|---------|---|
| | Adult | Child under school age | Infant | |
| Sr-90 | 1.6E-04 | 2.7E-04 | 4.2E-04 | Including the impact of the progeny nuclide |
| Y-90 | 1.5E-06 | 4.2E-06 | 1.3E-05 | |
| Y-91 | 8.9E-06 | 1.9E-05 | 4.3E-05 | |
| Nb-95 | 1.8E-06 | 3.6E-06 | 7.7E-06 | |
| Tc-99 | 1.3E-05 | 2.4E-05 | 4.1E-05 | |
| Ru-103 | 3.0E-06 | 6.0E-06 | 1.3E-05 | Including the impact of the progeny nuclide |
| Ru-106 | 6.6E-05 | 1.4E-04 | 2.6E-04 | Including the impact of the progeny nuclide |
| Rh-103m | 2.7E-09 | 6.7E-09 | 2.0E-08 | |
| Rh-106 | - | - | - | Independent intake is not considered because the half-life is short enough (about 30 seconds). |
| Ag-110m | 1.2E-05 | 2.6E-05 | 4.6E-05 | |
| Cd-113m | 1.1E-04 | 1.8E-04 | 3.0E-04 | |
| Cd-115m | 7.7E-06 | 1.7E-05 | 4.6E-05 | |
| Sn-119m | 2.2E-06 | 4.7E-06 | 1.0E-05 | |
| Sn-123 | 8.1E-06 | 1.8E-05 | 4.0E-05 | |
| Sn-126 | 2.8E-05 | 6.2E-04 | 1.2E-04 | |
| Sb-124 | 8.6E-06 | 1.8E-05 | 3.9E-05 | |
| Sb-125 | 1.2E-05 | 2.4E-05 | 4.2E-05 | |
| Te-123m | 5.1E-06 | 9.8E-06 | 2.0E-05 | |
| Te-125m | 4.2E-06 | 7.8E-06 | 1.7E-05 | |
| Te-127 | 1.4E-07 | 3.9E-07 | 1.2E-06 | |
| Te-127m | 9.8E-06 | 2.0E-05 | 4.1E-05 | |
| Te-129 | 3.9E-08 | 1.0E-07 | 3.5E-07 | |
| Te-129m | 7.9E-06 | 1.7E-05 | 3.8E-05 | Including the impact of the progeny nuclide |
| I-129 | 3.6E-05 | 6.1E-05 | 7.2E-05 | |
| Cs-134 | 2.0E-05 | 4.1E-05 | 7.0E-05 | |
| Cs-135 | 8.6E-06 | 1.6E-05 | 2.7E-05 | |
| Cs-136 | 2.8E-06 | 6.0E-06 | 1.5E-05 | |
| Cs-137 | 3.9E-05 | 7.0E-05 | 1.1E-04 | Including the impact of the progeny nuclide |
| Ba-137m | - | - | - | Independent intake is not considered because the half-life is short enough (about 2.6 minutes). |
| Ba-140 | 5.8E-06 | 1.2E-05 | 2.9E-05 | |
| Ce-141 | 3.8E-06 | 7.1E-06 | 1.6E-05 | |
| Ce-144 | 5.3E-05 | 1.4E-04 | 3.6E-04 | Including the impact of the progeny nuclide |

| Target nuclide | Effective dose factor (mSv/Bq) | | | Remarks |
|----------------|-----------------------------------|------------------------------|---------|---|
| | Adult | Child under school age | Infant | |
| Pr-144 | 1.8E-08 | 5.2E-08 | 1.9E-07 | |
| Pr-144m | - | - | - | Independent intake is not considered because the half-life is short enough (about 7.2 minutes). |
| Pm-146 | 2.1E-05 | 3.9E-05 | 6.4E-05 | |
| Pm-147 | 5.0E-06 | 1.1E-05 | 2.1E-05 | |
| Pm-148 | 2.2E-06 | 5.5E-06 | 1.5E-05 | |
| Pm-148m | 5.7E-06 | 1.2E-05 | 2.5E-05 | |
| Sm-151 | 4.0E-06 | 6.7E-06 | 1.1E-05 | |
| Eu-152 | 4.2E-05 | 7.0E-05 | 1.1E-04 | |
| Eu-154 | 5.3E-05 | 9.7E-05 | 1.6E-04 | |
| Eu-155 | 6.9E-06 | 1.4E-05 | 2.6E-05 | |
| Gd-153 | 2.1E-06 | 6.5E-06 | 1.5E-05 | |
| Tb-160 | 7.0E-06 | 1.5E-05 | 3.2E-05 | |
| Pu-238 | 1.1E-01 | 1.4E-01 | 2.0E-01 | |
| Pu-239 | 1.2E-01 | 1.5E-01 | 2.1E-01 | |
| Pu-240 | 1.2E-01 | 1.5E-01 | 2.1E-01 | |
| Pu-241 | 2.3E-03 | 2.6E-03 | 2.8E-03 | |
| Am-241 | 9.6E-02 | 1.2E-01 | 1.8E-01 | |
| Am-242m | 9.2E-02 | 1.1E-01 | 1.6E-01 | |
| Am-243 | 9.6E-02 | 1.2E-01 | 1.8E-01 | |
| Cm-242 | 5.9E-03 | 1.2E-02 | 2.7E-02 | |
| Cm-243 | 6.9E-02 | 9.5E-02 | 1.6E-01 | |
| Cm-244 | 5.7E-02 | 8.3E-02 | 1.5E-01 | |

**Table 6-1-12 Concentration factor for seafood
(TRS-422 [25] and others are shown in remarks)**

| Target Nuclide | Concentration factor ((Bq/kg)/(Bq/L)) | | | Remarks |
|----------------|---------------------------------------|--------------|----------|---------|
| | Fish | Invertebrate | Seaweeds | |
| H-3 | 1.0E+00 | 1.0E+00 | 1.0E+00 | |
| C-14 | 2.0E+04 | 2.0E+04 | 1.0E+04 | |
| Mn-54 | 1.0E+03 | 5.0E+04 | 6.0E+03 | |
| Fe-59 | 3.0E+04 | 5.0E+05 | 2.0E+04 | |
| Co-58 | 7.0E+02 | 2.0E+04 | 6.0E+03 | |
| Co-60 | 7.0E+02 | 2.0E+04 | 6.0E+03 | |
| Ni-63 | 1.0E+03 | 2.0E+03 | 2.0E+03 | |
| Zn-65 | 1.0E+03 | 8.0E+04 | 2.0E+03 | |

| Target Nuclide | Concentration factor ((Bq/kg)/(Bq/L)) | | | Remarks |
|----------------|---------------------------------------|--------------|----------|---|
| | Fish | Invertebrate | Seaweeds | |
| Rb-86 | 9.0E+00 | 1.7E+01 | 1.7E+01 | Excerpted from UCRL-50564 Rev.1 |
| Sr-89 | 3.0E+00 | 1.0E+01 | 1.0E+01 | |
| Sr-90 | 3.0E+00 | 1.0E+01 | 1.0E+01 | |
| Y-90 | - | - | - | Equilibrium state with the parent nuclide Sr-90 |
| Y-91 | 2.0E+01 | 1.0E+03 | 1.0E+03 | |
| Nb-95 | 3.0E+01 | 1.0E+03 | 3.0E+03 | |
| Tc-99 | 8.0E+01 | 5.0E+02 | 3.0E+04 | |
| Ru-103 | 2.0E+00 | 5.0E+02 | 2.0E+03 | |
| Ru-106 | 2.0E+00 | 5.0E+02 | 2.0E+03 | |
| Rh-103m | - | - | - | Equilibrium state with the parent nuclide Ru-103 |
| Rh-106 | - | - | - | Equilibrium state with the parent nuclide Ru-106 |
| Ag-110m | 1.0E+04 | 6.0E+04 | 5.0E+03 | |
| Cd-113m | 5.0E+03 | 8.0E+04 | 2.0E+04 | |
| Cd-115m | 5.0E+03 | 8.0E+04 | 2.0E+04 | |
| Sn-119m | 5.0E+05 | 5.0E+05 | 2.0E+05 | |
| Sn-123 | 5.0E+05 | 5.0E+05 | 2.0E+05 | |
| Sn-126 | 5.0E+05 | 5.0E+05 | 2.0E+05 | |
| Sb-124 | 6.0E+02 | 3.0E+02 | 2.0E+01 | |
| Sb-125 | 6.0E+02 | 3.0E+02 | 2.0E+01 | |
| Te-123m | 1.0E+03 | 1.0E+03 | 1.0E+04 | |
| Te-125m | 1.0E+03 | 1.0E+03 | 1.0E+04 | |
| Te-127 | 1.0E+03 | 1.0E+03 | 1.0E+04 | |
| Te-127m | 1.0E+03 | 1.0E+03 | 1.0E+04 | |
| Te-129 | - | - | - | Equilibrium state with the parent nuclide Te-129m |
| Te-129m | 1.0E+03 | 1.0E+03 | 1.0E+04 | |
| I-129 | 9.0E+00 | 1.0E+01 | 1.0E+04 | |
| Cs-134 | 1.0E+02 | 6.0E+01 | 5.0E+01 | |
| Cs-135 | 1.0E+02 | 6.0E+01 | 5.0E+01 | |
| Cs-136 | 1.0E+02 | 6.0E+01 | 5.0E+01 | |
| Cs-137 | 1.0E+02 | 6.0E+01 | 5.0E+01 | |
| Ba-137m | - | - | - | Equilibrium state with the parent nuclide Cs-137 |
| Ba-140 | 1.0E+01 | 1.0E+01 | 7.0E+01 | |
| Ce-141 | 5.0E+01 | 2.0E+03 | 5.0E+03 | |
| Ce-144 | 5.0E+01 | 2.0E+03 | 5.0E+03 | |
| Pr-144 | - | - | - | Equilibrium state with the parent nuclide Ce-144 |

| Target Nuclide | Concentration factor ((Bq/kg)/(Bq/L)) | | | Remarks |
|----------------|---------------------------------------|--------------|----------|--|
| | Fish | Invertebrate | Seaweeds | |
| Pr-144m | - | - | - | Equilibrium state with the parent nuclide Ce-144 |
| Pm-146 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Pm-147 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Pm-148 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Pm-148m | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Sm-151 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Eu-152 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Eu-154 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Eu-155 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Gd-153 | 3.0E+02 | 7.0E+03 | 3.0E+03 | |
| Tb-160 | 6.0E+01 | 3.0E+03 | 2.0E+03 | |
| Pu-238 | 1.0E+02 | 3.0E+03 | 4.0E+03 | |
| Pu-239 | 1.0E+02 | 3.0E+03 | 4.0E+03 | |
| Pu-240 | 1.0E+02 | 3.0E+03 | 4.0E+03 | |
| Pu-241 | 1.0E+02 | 3.0E+03 | 4.0E+03 | |
| Am-241 | 1.0E+02 | 1.0E+03 | 8.0E+03 | |
| Am-242m | 1.0E+02 | 1.0E+03 | 8.0E+03 | |
| Am-243 | 1.0E+02 | 1.0E+03 | 8.0E+03 | |
| Cm-242 | 1.0E+02 | 1.0E+03 | 5.0E+03 | |
| Cm-243 | 1.0E+02 | 1.0E+03 | 5.0E+03 | |
| Cm-244 | 1.0E+02 | 1.0E+03 | 5.0E+03 | |

* For invertebrates, the value of molluscs (excluding cephalopods) was used.


(4) Setting of the representative person subject to the exposure assessment

(1) Situation around the FDNPS

According to GSG-9, the living habits and characteristics of the representative person for some of the exposure pathways should be based on the highest group from the distribution of the living habit data (e.g. 95 percentile value), etc.

However, as shown in Figure 6-1-10, in the area around the FDNPS, measures to prevent the general public from living in the area are taken by setting Difficult-to-Return Zones set in response to the accident, installing intermediate storage facilities surrounding the land side of the FDNPS, etc. In addition, fishing industry in Fukushima is yet in the middle of reconstruction.

This situation is expected to improve gradually thanks to the lifting of the setting of Difficult-to-Return Zones, mitigation of residence site restriction, etc., but it is not desirable as a future prediction to make judgment based on the current data, so no assessment shall be performed based on the actual data of the current situation and instead an assessment shall be performed using the data used for the safety review of the existing reactor facilities, etc. We will consider the adoption of the actual data about living habits and characteristics of the representative person which will be accumulated in the future as the reconstruction of this area will proceed.



Source: Support for victims of the nuclear accident of the Ministry of Economy, Trade and Industry (Regarding evacuation orders) Prepared by Tokyo Electric Power Company Holdings, Inc. based on the map of the area surrounding Difficult-to-Return Zones (from R2.12.10) <https://www.meti.go.jp/earthquake/nuclear/kin-kyu.html>

Figure 6-1-10 Condition of Difficult-to-Return Zones, etc. around the FDNPS

(2) Characteristics of the representative person

The characteristics of the representative person subject to exposure assessment was set as follows according to “Dose Assessment to the General Public in the Safety Review of Commercial Light Water Reactor Facilities,” etc.

- Engage in fishing 120 days (2,880 hours) a year, of which 80 days (1,920 hours) are spent near fishing nets.
- Stay at the beach 500 hours a year and swim for 96 hours.

The ingestion of seafood was set based on classification into fish (total of the fishery product (excluding shellfish, squid, octopus, shrimp, and crab) and processed fishery products), invertebrates (total of shellfish, squid, octopus, shrimp, and crab), and seaweeds (algae) extracting the data of ingestion of fishery products, processed fishery products, and algae from “National Health and Nutrition Survey (2019)”³⁷ of the Ministry of Health, Labour and Welfare, which is the latest large-scale survey result regarding ingestion of foods of the entire Japanese people. It was decided to assess the ingestion of seafood considering three age groups (adult, child under school age, and infant) in the following two cases.

i. Individual who ingests the average amount of seafood

The average ingestion amount of those who are aged 20 or older is used as the value of adult. 1/2 and 1/5 of the value of adult are used as the values of child under school age (assumed to be aged 5 or older) and infant (assumed to be aged 1), respectively, based on “Guidelines for the Assessment of Dose Target Values Around Light Water Reactor Facilities” [24].

ii. Persons who ingests the large amount of seafood

The value of adult is set to the average ingestion of those who are aged 20 or older plus twice the value of the standard deviation. Those of child under school age and infant are set to 1/2 and 1/5, respectively, of the value of adult.

Tables 6-1-13 and 6-1-14 show the set ingestion of seafood.

For external exposure, no age group is set because ICRP Publication 101a “Assessing Dose of the Representative Person for the Purpose of the Radiation Protection of the Public” [27] stipulates “It is generally recognized that for external exposure in the environment, there is little variability in dose per unit of exposure with age.”

³⁷ In 2020 and 2021, the survey itself was not performed due to the novel coronavirus.

The assessment points related to exposure and the seawater concentration used for the assessment are as follows.

i. External exposure from sea surface and external exposure from hulls

The nearest ports to the south and north of the FDNPS is 5 km or more away from the FDNPS. Fishing is widely performed by ships from fishing ports in the sea area, including the area around the FDNPS centering on the fishing ports. In the assessment, conservatively, fishing is assumed to be performed within 5 km to the north and south and 10 km off the coast of the FDNPS (range of 10 km × 10 km around the FDNPS (Figure 6-1-11)). The concentration in the seawater used for the assessment is the annual average concentration on the sea surface (top layer) within 10 km × 10 km around the FDNPS, including areas where no fishing is conducted on a daily basis.

ii. External exposure from seawater during swimming, etc., external exposure from beach sand, internal exposure from ingestion of water, and internal exposure from inhalation of seawater spray

All of these were assumed as exposure while staying on a beach. The coastline around the FDNPS is a Difficult-to-Return Zone and intermediate storage facilities are installed there, but there is a beach in the habitable area in the north side. Therefore, the assessment point is set to the nearby beach to the north of the FDNPS and the concentration in the seawater is set to the annual average concentration in the seawater (all layers) in front of the beach. Since the water depth is less than 5m near the coast, mixing of the upper and lower layers is remarkable, so that there is little difference between the concentration on the sea surface and the average concentration of all layers.

iii. External exposure from fishing nets and internal exposure from ingestion of seafood

It is considered that radioactive materials will migrate from seawater to fishing nets at the time of fishing. In addition, fish are caught by fishing and delivered to the dinner table as seafood. Therefore, fishing is performed only within the range of 10 km × 10 km around the FDNPS for point of assessment as with i. conservatively, but fish are found from the surface layer to the bottom layer and fishing nets are used at depths appropriate for the fish to be caught, so the concentration in the seawater is the annual average concentration in the seawater (all layers) in front of the beach.

The specific calculation method of the concentration in the seawater is shown in 6-1-3.(1) to (3).

**Table 6-1-13 Ingestion of persons who ingest the average amount of seafood (g/day)
(Set based on the National Health and Nutrition Survey in Japan in 2019 (Ministry of Health, Labour and Welfare) [6])**

| | Fish | Invertebrate | Seaweeds |
|------------------------|------|--------------|----------|
| Adult | 58 | 10 | 11 |
| Child under school age | 29 | 5.1 | 5.3 |
| Infant | 12 | 2.0 | 2.1 |

**Table 6-1-14 Ingestion of persons who consume a large amount of seafood (g/day)
(Set based on the National Health and Nutrition Survey in Japan in 2019 (Ministry of Health, Labour and Welfare) [6])**

| | Fish | Invertebrate | Seaweeds |
|------------------------|------|--------------|----------|
| Adult | 190 | 62 | 52 |
| Child under school age | 97 | 31 | 26 |
| Infant | 39 | 12 | 10 |




Figure 6-1-11 Point to determine concentrations in seawater used for the assessment of exposures in normal conditions

Source: Geographical Survey Institute (Electronic Map Web) and support for victims of the nuclear accident of the Ministry of Economy, Trade and Industry (Regarding evacuation orders) Prepared by Tokyo Electric Power Company Holdings, Inc. based on the map of the area surrounding Difficult-to-Return Zones (from R2.12.10)
<https://maps.gsi.go.jp/#13/37.422730/141.044970/&base=std&ls=std&disp=1&vs=c1j0h0k0l0u0t0z0r0s0m0f1>

(5) Dose assessment method

Exposure is calculated by the assessment method set in 6-1-2.(3).

The calculation result is compared with the dose limit of 1 mSv/year for the general public, and the dose target of 0.05 mSv/year for domestic nuclear power plants, which is deemed to be equivalent to the dose constraint by the Nuclear Regulation Authority, as shown in 4.(1).

6-1-3. Assessment result

(1) Diffusion simulation result

The tritium concentration in the seawater after advection and diffusion was calculated using the model shown in 6-1-2.(2) assuming discharge of a total of 22 TBq ($2.2E+13$ Bq) of tritium per year at an even pace throughout the year from the seabed about 1 km off the coast of the FDNPS. The calculation based on the meteorological and oceanographic conditions was performed for two years: 2014 and 2019. Though there is no large difference between the results of the two years, we decided to use the calculation result based on the meteorological and oceanographic conditions of 2019, in which the average concentration around the FDNPS is higher, for the assessment. Figures 6-1-12 to 6-1-16 show the calculation result. Figures 6-1-12 and 6-1-13 show the annual average concentrations of the sea surfaces of a wide area and the area around the FDNPS, respectively. The range of concentrations over 1Bq/L on the sea surface is about 3 km around the FDNPS.

Figures 6-1-14 and 6-1-15 diagrammatically show the annual average concentrations in the seawater with east-west and north-south sectional views, respectively. The stored water amount of the assessed cell near the discharge point of the seabed is large, so the concentration is assessed to be about 30Bq/L and immediately drop in the area around the power station.

Figure 6-1-16 shows the average concentration distribution diagram of the sea surface in each season. The range of concentrations over 1Bq/L on the sea surface has more seasonal variation than in Figure 6-1-12, but it is limited to the area around the FDNPS.


Figures 6-1-17 and 6-1-18 diagrammatically show the daily average concentrations on the sea surface throughout the year, which are expanded the most to the north, south, and east, respectively.

Attachment VIII "Difference in the diffusion range in the discharge position" shows the comparison between the discharge from the coast compared in the consideration of the discharge method and the calculation result.

To verify the impact of the variation of meteorological and oceanographic data between years, simulation calculation was performed using the meteorological and oceanographic data of 2015 to 2018 and 2020. Table 6-1-15 and Figure 6-1-19 show the calculation results of 7 years from 2014 and 2020. The calculation of the seven years is not a continuous calculation of the seven years but a collection of calculations of individual years, but the flow in the sea area changes on a daily basis and no accumulation trend is observed. On the other hand, the annual variation of the average concentration and diffusion range within 10 km × 10 km from the FDNPS is so small that there is no problem with using the calculation result of 2019 for a long-term assessment.


We also verified the concentration on the boundary of the calculation area from the calculation result of seven years mentioned above. As a result, it turned out that the maximum value of daily average concentrations on the boundary of the calculation area was $1.0E-02$ Bq/L. The maximum annual mean concentration was up to $1.6 E-04$ Bq/L (2015, top layer), measured at the eastern boundary of the region. This concentration is 3 to 4 orders of

magnitude lower than the tritium concentration in the sea water in the sea area around Japan (about 0.1 to 1Bq/L) and 2 to 3 orders of magnitude lower than the assessment result of 10 km × 10 km around the FDNPS, and no large variation in the concentration between years is observed, so the scale of the calculation area is sufficient and the impact of radiation outside the calculation area of this assessment is sufficiently small. Table 6-1-16 shows the maximum concentration on the model boundary of each assessment year.



Detailed concentration classification in the left figure

Figure 6-1-12 Distribution of annual mean concentration on the sea surface
 (Discharge tritium $2.2E+13$ Bq constantly throughout the year)



Detailed concentration classification in the left figure

Figure 6-1-13 Distribution of annual mean concentration on the sea surface (expanded diagram of neighborhood)
 (Discharge tritium $2.2E+13$ Bq constantly throughout the year)




Figure 6-1-14 Distribution of annual mean concentration on the sea surface (east-west section view of the discharge position)

(Discharge tritium $2.2E+13$ Bq constantly throughout the year)




Figure 6-1-15 Distribution of annual mean concentration on the sea surface (north-south section view of the discharge position)

(Discharge tritium $2.2E+13$ Bq constantly throughout the year)




Figure 6-1-16(1) Average concentration distribution diagram of the sea surface in each season
 (Average of January to March)








Figure 6-1-16(2) Average concentration distribution diagram of the sea surface in each season
 (Average of April to June)



Expanded area surrounding the power plant in the left figure


Figure 6-1-16(3) Average concentration distribution diagram of the sea surface in each season (Average of July to September)




Expanded area surrounding the power plant in the left figure

Figure 6-1-16(4) Average concentration distribution diagram of the sea surface in each season (Average of October to December)

20190827



20190827




Detailed concentration classification in the left figure


Figure 6-1-17(1) Distribution of daily mean concentration on the sea surface

(When the range of 0.1 Bq/L extends to the northernmost point)

20191027



20191027




Detailed concentration classification in the left figure


Figure 6-1-17(2) Distribution of daily mean concentration on the sea surface

(When the range of 0.1 Bq/L extends to the southernmost point)

20190806




20190806




Detailed concentration classification
in the left figure

Figure 6-1-17(3) Distribution of daily mean concentration on the sea surface
(When the range of 0.1 Bq/L extends to the easternmost point)

20190521




20190521




Detailed concentration classification
in the left figure

Figure 6-1-18(1) Distribution of daily mean concentration on the sea surface
(When the range of 1 Bq/L extends to the easternmost point)

20190211




20190211




Detailed concentration classification
in the left figure

Figure 6-1-18(2) Distribution of daily mean concentration on the sea surface
(When the range of 1 Bq/L extends to the southernmost point)

20190829



20190829



Detailed concentration classification
in the left figure

Figure 6-1-18(3) Distribution of daily mean concentration on the sea surface
(When the range of 1 Bq/L extends to the easternmost point)




Figure 6-1-19 Range of the annual average concentration of 0.1Bq/L between 2014 and 2020

Table 6-1-15 Calculation result of the annual average concentration within the range of 10 km × 10 km between 2014 and 2020

| Year | Annual average concentration within 10 km × 10 km around the FDNPS (Bq/L) | | |
|--------------------|---|-----------|--------------|
| | All layers | Top layer | Bottom layer |
| 2014 | 4.8E-02 | 1.0E-01 | 5.0E-02 |
| 2015 | 4.9E-02 | 9.6E-02 | 5.3E-02 |
| 2016 | 4.9E-02 | 9.6E-02 | 5.3E-02 |
| 2017 | 5.8E-02 | 1.2E-01 | 6.3E-02 |
| 2018 | 5.0E-02 | 1.1E-01 | 5.4E-02 |
| 2019 | 5.6E-02 | 1.2E-01 | 6.0E-02 |
| 2020 | 5.4E-02 | 1.1E-01 | 6.0E-02 |
| Mean | 5.2E-02 | 1.1E-01 | 5.6E-02 |
| Standard deviation | 3.8E-03 | 9.3E-03 | 4.4E-03 |

Table 6-1-16 Maximum concentration on the boundary of the calculation area (all of the north, east, and south sides)

| Year | Concentration (Bq/L) | Coordinate | | |
|------|----------------------|---|---|---|
| | | East - West (0: West boundary, 460: East boundary) | North - South (0: South boundary, 658: North boundary) | Depth (0: Bottom layer, 29: Top layer) |
| 2014 | 1.1E-04 | 460 (East boundary) | 80 | 23 |
| 2015 | 2.6E-04 | 460 (East boundary) | 145 | 29 |
| 2016 | 1.4E-04 | 460 (East boundary) | 318 | 25 |
| 2017 | 2.4E-04 | 460 (East boundary) | 224 | 23 |
| 2018 | 1.9E-04 | 460 (East boundary) | 150 | 29 |
| 2019 | 1.6E-04 | 460 (East boundary) | 181 | 28 |
| 2020 | 1.9E-04 | 460 (East boundary) | 232 | 28 |

(2) Concentration of each nuclide used for the assessment in the seawater

The concentration of the other nuclides was calculated from the ratio of tritium to the annual discharge amount of the other nuclides in the source term based on the assessment result of advection and diffusion to tritium.

Table 6-1-17 shows the concentration of tritium in the seawater within 10 km × 10 km around the FDNPS and at the beach assessment point to the north of the FDNPS (annual discharge amount) in the case of the annual discharge amount of 22 TBq (2.2E+13Bq) of tritium. The change rate of the concentration of 2019 from the concentration of 2014 is about 20%.

Though the impact of annual variation is small, we decided to use the concentration of 2019, which is higher, for the exposure assessment.

Tables 6-1-18 to 20 show this result and the radioactive material concentration in the seawater for the assessment calculated from the annual discharge amount of each nuclide shown in Tables 6-1-1 to 6-1-3.

Table 6-1-17 Tritium concentration in the seawater in the case of the annual tritium discharge amount of 2.2E+13Bq

| | Depth | Calculation result (Bq/L) | | | Concentration for assessment (Bq/L) |
|--|------------|---|---|----------------|-------------------------------------|
| | | Meteorological and oceanographic data of 2014 | Meteorological and oceanographic data of 2019 | Difference (%) | |
| Annual average concentration within 10 km × 10 km around the FDNPS | All layers | 4.8E-02 | 5.6E-02 | 17 | 5.6E-02 |
| | Top layer | 1.0E-01 | 1.2E-01 | 20 | 1.2E-01 |
| Annual average concentration of the beach assessment point | All layers | 7.2E-01 | 8.8E-01 | 22 | 8.8E-01 |

**Table 6-1-18 Concentration in the seawater used for the assessment
(Source term based on the composition of nuclides in the K4 tank group)**

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|------------------------------|--|--|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layer | Beach assessment point Average of all layers |
| H-3 | 2.2E+13 | 5.6E-02 | 1.2E-01 | 8.8E-01 |
| C-14 | 1.7E+09 | 4.4E-06 | 9.5E-06 | 6.9E-05 |
| Mn-54 | 7.8E+05 | 2.0E-09 | 4.2E-09 | 3.1E-08 |
| Fe-59 | 2.0E+06 | 5.0E-09 | 1.1E-08 | 7.9E-08 |
| Co-58 | 9.3E+05 | 2.4E-09 | 5.1E-09 | 3.7E-08 |
| Co-60 | 5.1E+07 | 1.3E-07 | 2.8E-07 | 2.0E-06 |
| Ni-63 | 2.5E+08 | 6.5E-07 | 1.4E-06 | 1.0E-05 |
| Zn-65 | 1.7E+06 | 4.4E-09 | 9.5E-09 | 6.9E-08 |
| Rb-86 | 2.2E+07 | 5.6E-08 | 1.2E-07 | 8.8E-07 |
| Sr-89 | 1.2E+07 | 2.9E-08 | 6.3E-08 | 4.6E-07 |
| Sr-90 | 2.5E+07 | 6.5E-08 | 1.4E-07 | 1.0E-06 |
| Y-90 | 2.5E+07 | 6.5E-08 | 1.4E-07 | 1.0E-06 |
| Y-91 | 2.5E+08 | 6.5E-07 | 1.4E-06 | 1.0E-05 |
| Nb-95 | 1.2E+06 | 2.9E-09 | 6.3E-09 | 4.6E-08 |
| Tc-99 | 8.1E+07 | 2.1E-07 | 4.4E-07 | 3.2E-06 |
| Ru-103 | 1.2E+06 | 2.9E-09 | 6.3E-09 | 4.6E-08 |
| Ru-106 | 1.9E+08 | 4.7E-07 | 1.0E-06 | 7.4E-06 |
| Rh-103m | 1.2E+06 | 2.9E-09 | 6.3E-09 | 4.6E-08 |
| Rh-106 | 1.9E+08 | 4.7E-07 | 1.0E-06 | 7.4E-06 |
| Ag-110m | 6.5E+05 | 1.7E-09 | 3.5E-09 | 2.6E-08 |
| Cd-113m | 2.1E+06 | 5.3E-09 | 1.1E-08 | 8.3E-08 |
| Cd-115m | 7.4E+07 | 1.9E-07 | 4.0E-07 | 3.0E-06 |
| Sn-119m | 2.0E+07 | 5.0E-08 | 1.1E-07 | 7.9E-07 |
| Sn-123 | 1.4E+08 | 3.5E-07 | 7.6E-07 | 5.6E-06 |
| Sn-126 | 3.1E+06 | 8.0E-09 | 1.7E-08 | 1.3E-07 |
| Sb-124 | 1.1E+06 | 2.8E-09 | 6.0E-09 | 4.4E-08 |
| Sb-125 | 3.8E+07 | 9.7E-08 | 2.1E-07 | 1.5E-06 |
| Te-123m | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Te-125m | 3.8E+07 | 9.7E-08 | 2.1E-07 | 1.5E-06 |
| Te-127 | 3.7E+07 | 9.4E-08 | 2.0E-07 | 1.5E-06 |
| Te-127m | 3.7E+07 | 9.4E-08 | 2.0E-07 | 1.5E-06 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|------------------------------|--|--|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layer | Beach assessment point Average of all layers |
| Te-129 | 3.7E+07 | 9.4E-08 | 2.0E-07 | 1.5E-06 |
| Te-129m | 3.7E+07 | 9.4E-08 | 2.0E-07 | 1.5E-06 |
| I-129 | 2.4E+08 | 6.2E-07 | 1.3E-06 | 9.7E-06 |
| Cs-134 | 5.2E+06 | 1.3E-08 | 2.8E-08 | 2.1E-07 |
| Cs-135 | 2.9E+02 | 7.4E-13 | 1.6E-12 | 1.2E-11 |
| Cs-136 | 3.5E+06 | 8.8E-09 | 1.9E-08 | 1.4E-07 |
| Cs-137 | 4.9E+07 | 1.2E-07 | 2.7E-07 | 1.9E-06 |
| Ba-137m | 4.9E+07 | 1.2E-07 | 2.7E-07 | 1.9E-06 |
| Ba-140 | 1.1E+07 | 2.8E-08 | 6.0E-08 | 4.4E-07 |
| Ce-141 | 2.9E+06 | 7.4E-09 | 1.6E-08 | 1.2E-07 |
| Ce-144 | 7.3E+06 | 1.9E-08 | 4.0E-08 | 2.9E-07 |
| Pr-144 | 7.3E+06 | 1.9E-08 | 4.0E-08 | 2.9E-07 |
| Pr-144m | 7.3E+06 | 1.9E-08 | 4.0E-08 | 2.9E-07 |
| Pm-146 | 1.1E+07 | 2.9E-08 | 6.2E-08 | 4.5E-07 |
| Pm-147 | 2.2E+07 | 5.6E-08 | 1.2E-07 | 8.8E-07 |
| Pm-148 | 5.8E+07 | 1.5E-07 | 3.2E-07 | 2.3E-06 |
| Pm-148m | 9.7E+05 | 2.5E-09 | 5.3E-09 | 3.9E-08 |
| Sm-151 | 1.0E+05 | 2.7E-10 | 5.7E-10 | 4.2E-09 |
| Eu-152 | 3.2E+06 | 8.3E-09 | 1.8E-08 | 1.3E-07 |
| Eu-154 | 1.4E+06 | 3.5E-09 | 7.6E-09 | 5.6E-08 |
| Eu-155 | 3.8E+06 | 9.7E-09 | 2.1E-08 | 1.5E-07 |
| Gd-153 | 3.7E+06 | 9.4E-09 | 2.0E-08 | 1.5E-07 |
| Tb-160 | 3.2E+06 | 8.3E-09 | 1.8E-08 | 1.3E-07 |
| Pu-238 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |
| Pu-239 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |
| Pu-240 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |
| Pu-241 | 3.2E+06 | 8.3E-09 | 1.8E-08 | 1.3E-07 |
| Am-241 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |
| Am-242m | 4.5E+03 | 1.1E-11 | 2.5E-11 | 1.8E-10 |
| Am-243 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |
| Cm-242 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |
| Cm-243 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------------------|------------------------------|--|--|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layer | Beach assessment point Average of all layers |
| Cm-244 | 7.3E+04 | 1.9E-10 | 4.0E-10 | 2.9E-09 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | During swimming From beach sand Ingestion of seawater Inhalation of seawater spray |

**Table 6-1-19 Concentration in the seawater used for the assessment
(Source term based on the composition of nuclides in the J1-C tank group)**

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|------------------------------|--|---|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layers | Beach assessment point Average of all layers |
| H-3 | 2.2E+13 | 5.6E-02 | 1.2E-01 | 8.8E-01 |
| C-14 | 4.8E+08 | 1.2E-06 | 2.6E-06 | 1.9E-05 |
| Mn-54 | 1.0E+06 | 2.6E-09 | 5.6E-09 | 4.1E-08 |
| Fe-59 | 2.3E+06 | 5.9E-09 | 1.3E-08 | 9.3E-08 |
| Co-58 | 1.1E+06 | 2.8E-09 | 6.0E-09 | 4.4E-08 |
| Co-60 | 8.9E+06 | 2.3E-08 | 4.8E-08 | 3.5E-07 |
| Ni-63 | 2.3E+08 | 5.8E-07 | 1.2E-06 | 9.1E-06 |
| Zn-65 | 2.5E+06 | 6.4E-09 | 1.4E-08 | 1.0E-07 |
| Rb-86 | 1.3E+07 | 3.4E-08 | 7.3E-08 | 5.4E-07 |
| Sr-89 | 1.4E+06 | 3.7E-09 | 7.9E-09 | 5.8E-08 |
| Sr-90 | 9.7E+05 | 2.5E-09 | 5.3E-09 | 3.9E-08 |
| Y-90 | 9.7E+05 | 2.5E-09 | 5.3E-09 | 3.9E-08 |
| Y-91 | 4.6E+08 | 1.2E-06 | 2.5E-06 | 1.8E-05 |
| Nb-95 | 1.3E+06 | 3.4E-09 | 7.3E-09 | 5.4E-08 |
| Tc-99 | 3.2E+07 | 8.2E-08 | 1.8E-07 | 1.3E-06 |
| Ru-103 | 1.4E+06 | 3.6E-09 | 7.8E-09 | 5.7E-08 |
| Ru-106 | 3.8E+07 | 9.6E-08 | 2.0E-07 | 1.5E-06 |
| Rh-103m | 1.4E+06 | 3.6E-09 | 7.8E-09 | 5.7E-08 |
| Rh-106 | 3.8E+07 | 9.6E-08 | 2.0E-07 | 1.5E-06 |
| Ag-110m | 1.2E+06 | 2.9E-09 | 6.3E-09 | 4.6E-08 |
| Cd-113m | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Cd-115m | 7.2E+07 | 1.8E-07 | 4.0E-07 | 2.9E-06 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|------------------------------|--|---|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layers | Beach assessment point Average of all layers |
| Sn-119m | 1.1E+09 | 2.9E-06 | 6.1E-06 | 4.5E-05 |
| Sn-123 | 1.8E+08 | 4.5E-07 | 9.7E-07 | 7.1E-06 |
| Sn-126 | 7.8E+06 | 2.0E-08 | 4.2E-08 | 3.1E-07 |
| Sb-124 | 2.6E+06 | 6.6E-09 | 1.4E-08 | 1.0E-07 |
| Sb-125 | 6.2E+06 | 1.6E-08 | 3.4E-08 | 2.5E-07 |
| Te-123m | 2.5E+06 | 6.3E-09 | 1.3E-08 | 9.9E-08 |
| Te-125m | 6.2E+06 | 1.6E-08 | 3.4E-08 | 2.5E-07 |
| Te-127 | 1.3E+08 | 3.2E-07 | 6.9E-07 | 5.0E-06 |
| Te-127m | 1.3E+08 | 3.3E-07 | 7.2E-07 | 5.3E-06 |
| Te-129 | 3.8E+07 | 9.6E-08 | 2.0E-07 | 1.5E-06 |
| Te-129m | 3.8E+07 | 9.6E-08 | 2.0E-07 | 1.5E-06 |
| I-129 | 3.2E+07 | 8.2E-08 | 1.8E-07 | 1.3E-06 |
| Cs-134 | 2.0E+06 | 5.2E-09 | 1.1E-08 | 8.2E-08 |
| Cs-135 | 3.2E+01 | 8.2E-14 | 1.8E-13 | 1.3E-12 |
| Cs-136 | 1.3E+06 | 3.2E-09 | 6.9E-09 | 5.0E-08 |
| Cs-137 | 5.1E+06 | 1.3E-08 | 2.8E-08 | 2.0E-07 |
| Ba-137m | 5.1E+06 | 1.3E-08 | 2.8E-08 | 2.0E-07 |
| Ba-140 | 5.4E+06 | 1.4E-08 | 2.9E-08 | 2.1E-07 |
| Ce-141 | 7.0E+06 | 1.8E-08 | 3.8E-08 | 2.8E-07 |
| Ce-144 | 1.5E+07 | 3.9E-08 | 8.3E-08 | 6.1E-07 |
| Pr-144 | 1.5E+07 | 3.9E-08 | 8.3E-08 | 6.1E-07 |
| Pr-144m | 1.5E+07 | 3.9E-08 | 8.3E-08 | 6.1E-07 |
| Pm-146 | 1.8E+06 | 4.6E-09 | 9.8E-09 | 7.2E-08 |
| Pm-147 | 2.1E+07 | 5.5E-08 | 1.2E-07 | 8.6E-07 |
| Pm-148 | 6.2E+06 | 1.6E-08 | 3.4E-08 | 2.5E-07 |
| Pm-148m | 1.3E+06 | 3.3E-09 | 7.0E-09 | 5.2E-08 |
| Sm-151 | 3.0E+05 | 7.5E-10 | 1.6E-09 | 1.2E-08 |
| Eu-152 | 7.5E+06 | 1.9E-08 | 4.1E-08 | 3.0E-07 |
| Eu-154 | 3.0E+06 | 7.5E-09 | 1.6E-08 | 1.2E-07 |
| Eu-155 | 9.1E+06 | 2.3E-08 | 5.0E-08 | 3.6E-07 |
| Gd-153 | 7.0E+06 | 1.8E-08 | 3.8E-08 | 2.8E-07 |
| Tb-160 | 3.8E+06 | 9.6E-09 | 2.0E-08 | 1.5E-07 |
| Pu-238 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------------------|------------------------------|--|---|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layers | Beach assessment point Average of all layers |
| Pu-239 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |
| Pu-240 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |
| Pu-241 | 3.2E+07 | 8.2E-08 | 1.8E-07 | 1.3E-06 |
| Am-241 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |
| Am-242m | 1.6E+04 | 4.0E-11 | 8.6E-11 | 6.3E-10 |
| Am-243 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |
| Cm-242 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |
| Cm-243 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |
| Cm-244 | 8.9E+05 | 2.3E-09 | 4.8E-09 | 3.5E-08 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | During swimming From beach sand Ingestion of seawater Inhalation of seawater spray |

**Table 6-1-20 Concentration in the seawater used for the assessment
(Source term based on the composition of nuclides in the J1-G tank group)**

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|------------------------------|--|---|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layers | Beach assessment point Average of all layers |
| H-3 | 2.2E+13 | 5.6E-02 | 1.2E-01 | 8.8E-01 |
| C-14 | 1.3E+09 | 3.3E-06 | 7.1E-06 | 5.2E-05 |
| Mn-54 | 3.1E+06 | 7.9E-09 | 1.7E-08 | 1.2E-07 |
| Fe-59 | 5.9E+06 | 1.5E-08 | 3.2E-08 | 2.3E-07 |
| Co-58 | 3.0E+06 | 7.7E-09 | 1.6E-08 | 1.2E-07 |
| Co-60 | 1.9E+07 | 4.8E-08 | 1.0E-07 | 7.5E-07 |
| Ni-63 | 7.2E+08 | 1.8E-06 | 3.9E-06 | 2.9E-05 |
| Zn-65 | 6.5E+06 | 1.7E-08 | 3.6E-08 | 2.6E-07 |
| Rb-86 | 3.8E+07 | 9.7E-08 | 2.1E-07 | 1.5E-06 |
| Sr-89 | 3.7E+06 | 9.3E-09 | 2.0E-08 | 1.5E-07 |
| Sr-90 | 2.6E+06 | 6.6E-09 | 1.4E-08 | 1.0E-07 |
| Y-90 | 2.6E+06 | 6.6E-09 | 1.4E-08 | 1.0E-07 |
| Y-91 | 9.8E+08 | 2.5E-06 | 5.3E-06 | 3.9E-05 |
| Nb-95 | 3.8E+06 | 9.7E-09 | 2.1E-08 | 1.5E-07 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|------------------------------|--|---|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layers | Beach assessment point Average of all layers |
| Tc-99 | 1.1E+08 | 2.7E-07 | 5.8E-07 | 4.2E-06 |
| Ru-103 | 4.2E+06 | 1.1E-08 | 2.3E-08 | 1.7E-07 |
| Ru-106 | 3.9E+07 | 1.0E-07 | 2.1E-07 | 1.6E-06 |
| Rh-103m | 4.2E+06 | 1.1E-08 | 2.3E-08 | 1.7E-07 |
| Rh-106 | 3.9E+07 | 1.0E-07 | 2.1E-07 | 1.6E-06 |
| Ag-110m | 3.3E+06 | 8.3E-09 | 1.8E-08 | 1.3E-07 |
| Cd-113m | 7.0E+06 | 1.8E-08 | 3.8E-08 | 2.8E-07 |
| Cd-115m | 1.9E+08 | 4.8E-07 | 1.0E-06 | 7.5E-06 |
| Sn-119m | 3.3E+09 | 8.3E-06 | 1.8E-05 | 1.3E-04 |
| Sn-123 | 5.1E+08 | 1.3E-06 | 2.8E-06 | 2.1E-05 |
| Sn-126 | 1.2E+07 | 3.1E-08 | 6.7E-08 | 4.9E-07 |
| Sb-124 | 6.8E+06 | 1.7E-08 | 3.7E-08 | 2.7E-07 |
| Sb-125 | 1.1E+07 | 2.9E-08 | 6.2E-08 | 4.6E-07 |
| Te-123m | 5.5E+06 | 1.4E-08 | 3.0E-08 | 2.2E-07 |
| Te-125m | 1.1E+07 | 2.9E-08 | 6.2E-08 | 4.6E-07 |
| Te-127 | 3.5E+08 | 8.9E-07 | 1.9E-06 | 1.4E-05 |
| Te-127m | 3.7E+08 | 9.3E-07 | 2.0E-06 | 1.5E-05 |
| Te-129 | 9.8E+07 | 2.5E-07 | 5.3E-07 | 3.9E-06 |
| Te-129m | 9.8E+07 | 2.5E-07 | 5.3E-07 | 3.9E-06 |
| I-129 | 2.7E+07 | 6.8E-08 | 1.5E-07 | 1.1E-06 |
| Cs-134 | 5.5E+06 | 1.4E-08 | 3.0E-08 | 2.2E-07 |
| Cs-135 | 1.7E+02 | 4.4E-13 | 9.3E-13 | 6.8E-12 |
| Cs-136 | 2.9E+06 | 7.5E-09 | 1.6E-08 | 1.2E-07 |
| Cs-137 | 2.7E+07 | 6.8E-08 | 1.5E-07 | 1.1E-06 |
| Ba-137m | 2.7E+07 | 6.8E-08 | 1.5E-07 | 1.1E-06 |
| Ba-140 | 1.4E+07 | 3.5E-08 | 7.6E-08 | 5.5E-07 |
| Ce-141 | 9.8E+06 | 2.5E-08 | 5.3E-08 | 3.9E-07 |
| Ce-144 | 4.5E+07 | 1.1E-07 | 2.4E-07 | 1.8E-06 |
| Pr-144 | 4.5E+07 | 1.1E-07 | 2.4E-07 | 1.8E-06 |
| Pr-144m | 4.5E+07 | 1.1E-07 | 2.4E-07 | 1.8E-06 |
| Pm-146 | 5.1E+06 | 1.3E-08 | 2.8E-08 | 2.1E-07 |
| Pm-147 | 5.9E+07 | 1.5E-07 | 3.2E-07 | 2.3E-06 |
| Pm-148 | 3.7E+07 | 9.3E-08 | 2.0E-07 | 1.5E-06 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------------------|------------------------------|--|---|---|
| | | Within 10 km × 10 km Average of all layers | Within 10 km × 10 km Average of the top layers | Beach assessment point Average of all layers |
| Pm-148m | 3.3E+06 | 8.5E-09 | 1.8E-08 | 1.3E-07 |
| Sm-151 | 8.1E+05 | 2.1E-09 | 4.4E-09 | 3.3E-08 |
| Eu-152 | 1.5E+07 | 3.9E-08 | 8.4E-08 | 6.2E-07 |
| Eu-154 | 8.1E+06 | 2.1E-08 | 4.4E-08 | 3.3E-07 |
| Eu-155 | 1.5E+07 | 3.7E-08 | 8.0E-08 | 5.9E-07 |
| Gd-153 | 1.5E+07 | 3.9E-08 | 8.4E-08 | 6.2E-07 |
| Tb-160 | 1.1E+07 | 2.9E-08 | 6.2E-08 | 4.6E-07 |
| Pu-238 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Pu-239 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Pu-240 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Pu-241 | 8.1E+07 | 2.1E-07 | 4.4E-07 | 3.3E-06 |
| Am-241 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Am-242m | 4.2E+04 | 1.1E-10 | 2.3E-10 | 1.7E-09 |
| Am-243 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Cm-242 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Cm-243 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Cm-244 | 2.3E+06 | 5.8E-09 | 1.2E-08 | 9.1E-08 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | During swimming From beach sand Ingestion of seawater Inhalation of seawater spray |

(3) Exposure assessment result

Tables 6-1-21 to 22 show the result of the exposure assessments of the following three cases using the concentrations in the seawater shown in Tables 6-1-18 to 6-1-20.

Source term based on the measured composition of nuclides

- i. K4 tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.29)
- ii. J1-C tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.35)
- iii. J1-G tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.22)

The result of human exposure assessment is 0.00003 (3E-05) to 0.0004 (4E-04) mSv/year. In all cases, the results were much smaller than the dose limit of 1 mSv/year for the general public and the dose target of 0.05 mSv/year for domestic nuclear power plants, which is equivalent to the dose constraint value.

The assessment in the source term based on the measured value was assessed assuming that nuclides below the detection limits (undetected nuclides) were contained at the detection limits, so the assessment result is considered to be conservative. Attachment IX

“Contribution to the undetected nuclides in the source term based on the measured value” shows the contribution of undetected nuclides in the assessment result.

Even in the exposure assessment of infant, of which the assessed value of internal exposure is high because the effective dose factor is large, the assessment result of internal exposure is 0.000029 (2.9E-05) mSv/year to 0.00071 (7.1E-04) mSv/year. This result is much lower than the dose limit of 1mSv/year as well as the target dose value of 0.05mSv/year, which is equivalent to the dose constraint.

Attachment X “Breakdown of the exposure assessment result by nuclide” shows the nuclide-specific breakdown of these assessment results.

In terms of the basic concept of radiation protection³⁸, which is to make every effort to reduce exposure as low as reasonably achievable while also considering social and economical balance, optimization of radiation protection does not necessarily equal to the minimization of exposure. Radiation protection is optimized to the extent that it does not exceed the dose constraint, so the upper limit of annual discharge amount calculated from “the annual discharge amount of treated water”, “Dose constraints”, and “Exposure assessment result by the source term” is shown below.

For example, if the calculation is performed the annual discharge amount of tritium from the assessment result of the J1-G tank group of which value of the exposure assessment result is the largest among the source terms based on the measured values, the result is as follows considering the dose constraint is 0.05mSv/year and the exposure assessment result based on the source term of the J1-G tank group (if the ingestion of seafood is large amount) is 4E-04mSv/year:

$$2.2\text{E}+13(\text{Bq}/\text{year}) \times 0.05 (\text{mSv}/\text{year}) \div 0.0004(\text{mSv}/\text{year}) = 2.7\text{E}+15(\text{Bq}/\text{year}) = \underline{2,700 \text{ TBq}/\text{year}}$$

³⁸ The principle of “ALARA” (As Low As Reasonably Achievable), which means radiation can be utilized with optimizing exposure as low as reasonably achievable when benefits from a practice with the radiation outweigh risks by the exposure

As the same calculation, if the calculation is performed using the assessment result of the K4 tank group of which value of the exposure assessment result is the smallest, the result is as follows:

$$2.2\text{E}+13(\text{Bq/year}) \times 0.05 (\text{mSv/year}) \div 0.00003(\text{mSv/year}) = 3.6\text{E}+16(\text{Bq/year}) = \underline{36 \text{ PBq/year}} \\ (\underline{36,000 \text{ TBq/year}})$$

The actual discharge amount will be determined setting the minimum value of 2,700 TBq (source term: J1-C tank group, seafood ingestion: large amount) as the limit value, which is the lowest value depends on source term and seafood ingestion at a result of optimization of radiation protection.

On the other hand, the Basic Policy of the government in April 2021 stipulates “The total annual amount of tritium to be discharged will be at a level below the operational target value¹⁰ for tritium discharge of the Fukushima Daiichi NPS before the accident (22 TBq/year).” This is a policy-making decision with consideration of the viewpoint of risk optimization of the whole decommissioning process as well as ALPS treated water, the effect of natural decay of radioactive materials expected to occur during land storage of ALPS treated water, leakage risk and occupational exposure during long-term storage, and social acceptance such as understanding from stakeholders. Based on this circumstance, we set the annual discharge amount of tritium 22 TBq/year (2.2E+13Bq/year) in accordance with above mentioned “TEPCO’s Action in response to Government’s Policy,” and assessed radiological impact.

In accordance with the Basic Policy of the government, the annual discharge amount of tritium is to be reviewed periodically below the dose constraint, by closely examining the circumstances of contaminated water generation and tritium concentration of newly generated ALPS treated water, and paying sufficient attention to the optimization including viewpoint of stakeholders.

Table 6-1-21 Results of human exposures assessment

| Assessed case | Source term | Source term based on measured values | | | | | |
|------------------------------|----------------------|--------------------------------------|---------|---------------------|---------|----------------------|---------|
| | | i. K4 tank group | | ii. J1-C tank group | | iii. J1-G tank group | |
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| External exposure (mSv/year) | Sea surface | 6.5E-09 | | 1.7E-08 | | 4.7E-08 | |
| | Hull | 4.8E-09 | | 1.2E-08 | | 3.3E-08 | |
| | During swimming | 4.5E-09 | | 1.2E-08 | | 3.2E-08 | |
| | Beach sand | 7.8E-06 | | 2.1E-05 | | 5.6E-05 | |
| | Fishing net | 1.6E-06 | | 4.3E-06 | | 1.2E-05 | |
| Internal exposure (mSv/year) | Ingestion of water | 3.3E-07 | | 3.1E-07 | | 3.2E-07 | |
| | Inhalation of spray | 9.3E-08 | | 2.0E-07 | | 4.0E-07 | |
| | Ingestion of seafood | 1.5E-05 | 6.1E-05 | 2.8E-05 | 1.1E-04 | 7.9E-05 | 3.0E-04 |
| Total (mSv/year) | | 3E-05 | 7E-05 | 5E-05 | 1E-04 | 1E-04 | 4E-04 |

Table 6-1-22 Results of internal exposures assessment by age

| Assessed case | Source term | Source term based on measured values | | | | | |
|--|------------------------|--------------------------------------|---------|---------------------|---------|----------------------|---------|
| | | i. K4 tank group | | ii. J1-C tank group | | iii. J1-G tank group | |
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| Internal exposure from ingestion of water (mSv/year) | Adult | 3.3E-07 | | 3.1E-07 | | 3.2E-07 | |
| | Child under school age | 5.7E-07 | | 5.4E-07 | | 5.5E-07 | |
| | Infant | - | | - | | - | |
| Internal exposure from inhalation of spray (mSv/year) | Adult | 9.3E-08 | | 2.0E-07 | | 4.0E-07 | |
| | Child under school age | 6.2E-08 | | 1.1E-07 | | 2.2E-07 | |
| | Infant | 4.0E-08 | | 6.5E-08 | | 1.2E-07 | |
| Internal exposure from ingestion of seafood (mSv/year) | Adult | 1.5E-05 | 6.1E-05 | 2.8E-05 | 1.1E-04 | 7.9E-05 | 3.0E-04 |
| | Child under school age | 2.4E-05 | 9.4E-05 | 5.1E-05 | 2.0E-04 | 1.5E-04 | 5.6E-04 |
| | Infant | 2.9E-05 | 1.1E-04 | 6.7E-05 | 2.5E-04 | 1.9E-04 | 7.1E-04 |

6-2. Potential exposure assessment

Potential exposure was assessed according to the assessment procedure of potential exposure shown in GSG-10 (Figure 6-2-1).




Figure 6-2-1. Assessment procedure of potential exposures

6-2-1. Assessment method

(1) Identification and selection of potential exposure scenarios

The facilities for discharging ALPS treated water into the sea are measurement/confirmation facility, transfer facility, dilution facility, and discharge facility. The target facilities contain two types of radioactive water: diluted and undiluted ALPS treated water. Therefore, unintentional discharge of ALPS treated water into the ocean is defined as the top event, and the following three types of specific abnormal events are defined:

- (1) Discharge radioactive materials with defective measurement/ confirmation
- (2) Discharge with insufficient seawater dilution
- (3) Leakage from facilities

In the design, to prevent these:

For (1)

- Set up interlock for discharge
- Duplication of tank valves
- Comparison with the analysis by a third-party institution
- Homogenization of samples by stirring and circulation equipment

For (2)

- Surveillance of the dilution rate based on the flow rate
- Set up interlock to stop discharge when the seawater flow rate is abnormal
- Installation of double emergency isolation valves

For (3)

- Stop in the event of earthquake
- Implementation of periodic patrol inspection
- Connection between the polyethylene pipes shall be a fusion structure.
- Installation of a leakage detector and weir in the flange
- Installation of a water level gauge in the receiving tank

Thanks to these and other measures, the unintentional discharge amount of ALPS treated water in the event of a single failure is limited to about 1.2 m³ at the most.

As for (1) and (2), discharge is prevented or mitigated by design and operation, but as for (3) leakage from facilities, there remains a possibility of occurrence caused by external events beyond design assumptions, etc., so we selected scenarios.

As mentioned at the beginning, the facilities for discharging ALPS treated water into the sea are measurement/confirmation facility, transfer facility, dilution facility, and discharge facility. Among these facilities, dilution facility and discharge facility are facilities containing ALPS treated water after dilution and the risk of exposure from leakage is negligible.

On the other hand, the measurement/confirmation facility mainly consists of tanks for measurement and confirmation, pumps, piping, and valves, and the transfer facility mainly consists of pumps, piping, and valves. As scenarios of leakage from these facilities, we selected case 1: leakage from piping, and case 2: leakage from tanks as the severest event, as follows.

- Case 1 Leakage from piping

In the case of leakage from piping, the flow rate of ALPS treated water is considered to be the same as in normal conditions, but the water flows into the sea without dilution. As the severest scenario of leakage from piping, selected is the event of leakage of the whole amount of the maximum flow rate in the normal operation (500 m³/day) from near the north breakwater due to piping rupture near the sea. In addition, in reality, leakage is considered to stop on the following day because the flow rate is monitored constantly and a patrol inspection is performed every day, but here it is assumed that leakage was overlooked and continued for 20 days until one tank series for measurement/confirmation of 10,000 m³ became empty.

- Case 2 Leakage from tanks

As the severest scenario, selected is the event of leakage of ALPS treated water of 30,000 m³ per day into the sea due to damage of all of the 3 tank groups for measurement/confirmation caused by an enormous earthquake, etc. In reality, it is conceivable that some of ALPS treated water may remain in the tanks and weirs or penetrate into the ground within the site, but it was decided that the whole volume would flow into the sea in this case.

(2) Source term (daily discharge amount of each nuclide)

Case 1 (Piping rupture)

Leaked ALPS treated water is the one which is usually discharged after dilution, and the source term was calculated from the product of the composition of nuclides based on the measured value and the maximum daily discharge volume of water (500 m³/day). Tables 6-2-1 to 6-2-3 show the source term used for the assessment.

Table 6-2-1 Source term based on the nuclide composition of measured values (K4 tank group) (Case 1)

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| H-3 | 1.9E+05 | 5.0E+05 | 9.5E+10 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---|
| C-14 | 1.5E+01 | | 7.5E+06 | <ul style="list-style-type: none"> The daily discharge amount was calculated from the product of the maximum value of the daily discharge volume of water in normal operation, 500 m³, and the concentrations of each nuclide |
| Mn-54 | 6.7E-03 | | 3.4E+03 | |
| Fe-59 | 1.7E-02 | | 8.5E+03 | |
| Co-58 | 8.0E-03 | | 4.0E+03 | |
| Co-60 | 4.4E-01 | | 2.2E+05 | |
| Ni-63 | 2.2E+00 | | 1.1E+06 | |
| Zn-65 | 1.5E-02 | | 7.5E+03 | |
| Rb-86 | 1.9E-01 | | 9.5E+04 | |
| Sr-89 | 1.0E-01 | | 5.0E+04 | |
| Sr-90 | 2.2E-01 | | 1.1E+05 | |
| Y-90 | 2.2E-01 | | 1.1E+05 | |
| Y-91 | 2.2E+00 | | 1.1E+06 | |
| Nb-95 | 1.0E-02 | | 5.0E+03 | |
| Tc-99 | 7.0E-01 | | 3.5E+05 | |
| Ru-103 | 1.0E-02 | | 5.0E+03 | |
| Ru-106 | 1.6E+00 | | 8.0E+05 | |
| Rh-103m | 1.0E-02 | | 5.0E+03 | |
| Rh-106 | 1.6E+00 | | 8.0E+05 | |
| Ag-110m | 5.6E-03 | | 2.8E+03 | |
| Cd-113m | 1.8E-02 | | 9.0E+03 | |
| Cd-115m | 6.4E-01 | | 3.2E+05 | |
| Sn-119m | 1.7E-01 | | 8.5E+04 | |
| Sn-123 | 1.2E+00 | | 6.0E+05 | |
| Sn-126 | 2.7E-02 | | 1.4E+04 | |
| Sb-124 | 9.5E-03 | | 4.8E+03 | |
| Sb-125 | 3.3E-01 | | 1.7E+05 | |
| Te-123m | 9.2E-03 | | 4.6E+03 | |
| Te-125m | 3.3E-01 | | 1.7E+05 | |
| Te-127 | 3.2E-01 | | 1.6E+05 | |
| Te-127m | 3.2E-01 | | 1.6E+05 | |
| Te-129 | 8.1E-02 | | 4.1E+04 | |
| Te-129m | 3.2E-01 | | 1.6E+05 | |
| I-129 | 2.1E+00 | | 1.1E+06 | |
| Cs-134 | 4.5E-02 | | 2.3E+04 | |
| Cs-135 | 2.5E-06 | | 1.3E+00 | |
| Cs-136 | 3.0E-02 | | 1.5E+04 | |
| Cs-137 | 4.2E-01 | | 2.1E+05 | |
| Ba-137m | 4.2E-01 | | 2.1E+05 | |
| Ba-140 | 9.5E-02 | | 4.8E+04 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Ce-141 | 2.5E-02 | | 1.3E+04 | |
| Ce-144 | 6.3E-02 | | 3.2E+04 | |
| Pr-144 | 6.3E-02 | | 3.2E+04 | |
| Pr-144m | 6.3E-02 | | 3.2E+04 | |
| Pm-146 | 9.8E-02 | | 4.9E+04 | |
| Pm-147 | 1.9E-01 | | 9.5E+04 | |
| Pm-148 | 5.0E-01 | | 2.5E+05 | |
| Pm-148m | 8.4E-03 | | 4.2E+03 | |
| Sm-151 | 9.0E-04 | | 4.5E+02 | |
| Eu-152 | 2.8E-02 | | 1.4E+04 | |
| Eu-154 | 1.2E-02 | | 6.0E+03 | |
| Eu-155 | 3.3E-02 | | 1.7E+04 | |
| Gd-153 | 3.2E-02 | | 1.6E+04 | |
| Tb-160 | 2.8E-02 | | 1.4E+04 | |
| Pu-238 | 6.3E-04 | | 3.2E+02 | |
| Pu-239 | 6.3E-04 | | 3.2E+02 | |
| Pu-240 | 6.3E-04 | | 3.2E+02 | |
| Pu-241 | 2.8E-02 | | 1.4E+04 | |
| Am-241 | 6.3E-04 | | 3.2E+02 | |
| Am-242m | 3.9E-05 | | 2.0E+01 | |
| Am-243 | 6.3E-04 | | 3.2E+02 | |
| Cm-242 | 6.3E-04 | 3.2E+02 | | |
| Cm-243 | 6.3E-04 | 3.2E+02 | | |
| Cm-244 | 6.3E-04 | 3.2E+02 | | |

Table 6-2-2 Source term based on the nuclide composition of measured values (J1-C tank group) (Case 1)

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---|
| H-3 | 8.2E+05 | 5.0E+05 | 4.1E+11 | <ul style="list-style-type: none"> The daily discharge amount was calculated from the product of the maximum value of the daily discharge volume of water in normal operation, 500 m³, and the concentrations of each nuclide |
| C-14 | 1.8E+01 | | 9.0E+06 | |
| Mn-54 | 3.8E-02 | | 1.9E+04 | |
| Fe-59 | 8.7E-02 | | 4.4E+04 | |
| Co-58 | 4.1E-02 | | 2.1E+04 | |
| Co-60 | 3.3E-01 | | 1.7E+05 | |
| Ni-63 | 8.5E+00 | | 4.3E+06 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Zn-65 | 9.4E-02 | | 4.7E+04 | |
| Rb-86 | 5.0E-01 | | 2.5E+05 | |
| Sr-89 | 5.4E-02 | | 2.7E+04 | |
| Sr-90 | 3.6E-02 | | 1.8E+04 | |
| Y-90 | 3.6E-02 | | 1.8E+04 | |
| Y-91 | 1.7E+01 | | 8.5E+06 | |
| Nb-95 | 5.0E-02 | | 2.5E+04 | |
| Tc-99 | 1.2E+00 | | 6.0E+05 | |
| Ru-103 | 5.3E-02 | | 2.7E+04 | |
| Ru-106 | 1.4E+00 | | 7.0E+05 | |
| Rh-103m | 5.3E-02 | | 2.7E+04 | |
| Rh-106 | 1.4E+00 | | 7.0E+05 | |
| Ag-110m | 4.3E-02 | | 2.2E+04 | |
| Cd-113m | 8.5E-02 | | 4.3E+04 | |
| Cd-115m | 2.7E+00 | | 1.4E+06 | |
| Sn-119m | 4.2E+01 | | 2.1E+07 | |
| Sn-123 | 6.6E+00 | | 3.3E+06 | |
| Sn-126 | 2.9E-01 | | 1.5E+05 | |
| Sb-124 | 9.7E-02 | | 4.9E+04 | |
| Sb-125 | 2.3E-01 | | 1.2E+05 | |
| Te-123m | 9.2E-02 | | 4.6E+04 | |
| Te-125m | 2.3E-01 | | 1.2E+05 | |
| Te-127 | 4.7E+00 | | 2.4E+06 | |
| Te-127m | 4.9E+00 | | 2.5E+06 | |
| Te-129 | 6.2E-01 | | 3.1E+05 | |
| Te-129m | 1.4E+00 | | 7.0E+05 | |
| I-129 | 1.2E+00 | | 6.0E+05 | |
| Cs-134 | 7.6E-02 | | 3.8E+04 | |
| Cs-135 | 1.2E-06 | | 6.0E-01 | |
| Cs-136 | 4.7E-02 | | 2.4E+04 | |
| Cs-137 | 1.9E-01 | | 9.5E+04 | |
| Ba-137m | 1.9E-01 | | 9.5E+04 | |
| Ba-140 | 2.0E-01 | | 1.0E+05 | |
| Ce-141 | 2.6E-01 | | 1.3E+05 | |
| Ce-144 | 5.7E-01 | | 2.9E+05 | |
| Pr-144 | 5.7E-01 | | 2.9E+05 | |
| Pr-144m | 5.7E-01 | | 2.9E+05 | |
| Pm-146 | 6.7E-02 | | 3.4E+04 | |
| Pm-147 | 8.0E-01 | | 4.0E+05 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Pm-148 | 2.3E-01 | | 1.2E+05 | |
| Pm-148m | 4.8E-02 | | 2.4E+04 | |
| Sm-151 | 1.1E-02 | | 5.5E+03 | |
| Eu-152 | 2.8E-01 | | 1.4E+05 | |
| Eu-154 | 1.1E-01 | | 5.5E+04 | |
| Eu-155 | 3.4E-01 | | 1.7E+05 | |
| Gd-153 | 2.6E-01 | | 1.3E+05 | |
| Tb-160 | 1.4E-01 | | 7.0E+04 | |
| Pu-238 | 3.3E-02 | | 1.7E+04 | |
| Pu-239 | 3.3E-02 | | 1.7E+04 | |
| Pu-240 | 3.3E-02 | | 1.7E+04 | |
| Pu-241 | 1.2E+00 | | 6.0E+05 | |
| Am-241 | 3.3E-02 | | 1.7E+04 | |
| Am-242m | 5.9E-04 | | 3.0E+02 | |
| Am-243 | 3.3E-02 | | 1.7E+04 | |
| Cm-242 | 3.3E-02 | | 1.7E+04 | |
| Cm-243 | 3.3E-02 | | 1.7E+04 | |
| Cm-244 | 3.3E-02 | | 1.7E+04 | |

Table 6-2-3 Source term based on the nuclide composition of measured values (J1-G tank group) (Case 1)

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---|
| H-3 | 2.7E+05 | 5.0E+05 | 1.4E+11 | <ul style="list-style-type: none"> The daily discharge amount was calculated from the product of the maximum value of the daily discharge volume of water in normal operation, 500 m³, and the concentrations of each nuclide |
| C-14 | 1.6E+01 | | 8.0E+06 | |
| Mn-54 | 3.8E-02 | | 1.9E+04 | |
| Fe-59 | 7.2E-02 | | 3.6E+04 | |
| Co-58 | 3.7E-02 | | 1.9E+04 | |
| Co-60 | 2.3E-01 | | 1.2E+05 | |
| Ni-63 | 8.8E+00 | | 4.4E+06 | |
| Zn-65 | 8.0E-02 | | 4.0E+04 | |
| Rb-86 | 4.7E-01 | | 2.4E+05 | |
| Sr-89 | 4.5E-02 | | 2.3E+04 | |
| Sr-90 | 3.2E-02 | | 1.6E+04 | |
| Y-90 | 3.2E-02 | | 1.6E+04 | |
| Y-91 | 1.2E+01 | | 6.0E+06 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Nb-95 | 4.7E-02 | | 2.4E+04 | |
| Tc-99 | 1.3E+00 | | 6.5E+05 | |
| Ru-103 | 5.1E-02 | | 2.6E+04 | |
| Ru-106 | 4.8E-01 | | 2.4E+05 | |
| Rh-103m | 5.1E-02 | | 2.6E+04 | |
| Rh-106 | 4.8E-01 | | 2.4E+05 | |
| Ag-110m | 4.0E-02 | | 2.0E+04 | |
| Cd-113m | 8.6E-02 | | 4.3E+04 | |
| Cd-115m | 2.3E+00 | | 1.2E+06 | |
| Sn-119m | 4.0E+01 | | 2.0E+07 | |
| Sn-123 | 6.3E+00 | | 3.2E+06 | |
| Sn-126 | 1.5E-01 | | 7.5E+04 | |
| Sb-124 | 8.4E-02 | | 4.2E+04 | |
| Sb-125 | 1.4E-01 | | 7.0E+04 | |
| Te-123m | 6.7E-02 | | 3.4E+04 | |
| Te-125m | 1.4E-01 | | 7.0E+04 | |
| Te-127 | 4.3E+00 | | 2.2E+06 | |
| Te-127m | 4.5E+00 | | 2.3E+06 | |
| Te-129 | 5.9E-01 | | 3.0E+05 | |
| Te-129m | 1.2E+00 | | 6.0E+05 | |
| I-129 | 3.3E-01 | | 1.7E+05 | |
| Cs-134 | 6.7E-02 | | 3.4E+04 | |
| Cs-135 | 2.1E-06 | | 1.1E+00 | |
| Cs-136 | 3.6E-02 | | 1.8E+04 | |
| Cs-137 | 3.3E-01 | | 1.7E+05 | |
| Ba-137m | 3.3E-01 | | 1.7E+05 | |
| Ba-140 | 1.7E-01 | | 8.5E+04 | |
| Ce-141 | 1.2E-01 | | 6.0E+04 | |
| Ce-144 | 5.5E-01 | | 2.8E+05 | |
| Pr-144 | 5.5E-01 | | 2.8E+05 | |
| Pr-144m | 5.5E-01 | | 2.8E+05 | |
| Pm-146 | 6.3E-02 | | 3.2E+04 | |
| Pm-147 | 7.2E-01 | | 3.6E+05 | |
| Pm-148 | 4.5E-01 | | 2.3E+05 | |
| Pm-148m | 4.1E-02 | | 2.1E+04 | |
| Sm-151 | 1.0E-02 | | 5.0E+03 | |
| Eu-152 | 1.9E-01 | | 9.5E+04 | |
| Eu-154 | 1.0E-01 | | 5.0E+04 | |
| Eu-155 | 1.8E-01 | | 9.0E+04 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Gd-153 | 1.9E-01 | | 9.5E+04 | |
| Tb-160 | 1.4E-01 | | 7.0E+04 | |
| Pu-238 | 2.8E-02 | | 1.4E+04 | |
| Pu-239 | 2.8E-02 | | 1.4E+04 | |
| Pu-240 | 2.8E-02 | | 1.4E+04 | |
| Pu-241 | 1.0E+00 | | 5.0E+05 | |
| Am-241 | 2.8E-02 | | 1.4E+04 | |
| Am-242m | 5.1E-04 | | 2.6E+02 | |
| Am-243 | 2.8E-02 | | 1.4E+04 | |
| Cm-242 | 2.8E-02 | | 1.4E+04 | |
| Cm-243 | 2.8E-02 | | 1.4E+04 | |
| Cm-244 | 2.8E-02 | | 1.4E+04 | |

Case 2 (Tank damage)

Leaked ALPS treated water is the one which is usually discharged after dilution, and the source term was calculated from the product of the composition of nuclides based on the measured value and the daily discharge volume of water (30,000 m³/day). Tables 6-2-4 to 6-2-6 show the source term used for the assessment.

Table 6-2-4 Source term based on the nuclide composition of measured values (K4 tank group) (Case 2)

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|--|
| H-3 | 1.9E+05 | 3.0E+07 | 5.7E+12 | <ul style="list-style-type: none"> It was assumed that all of 3 tank groups for measurement/confirmation were damaged and whole capacity (30,000 m³) leaked in 1 day The daily discharge amount was calculated from the product of the daily discharge volume of water, 30,000 m³, and the nuclide concentration |
| C-14 | 1.5E+01 | | 4.5E+08 | |
| Mn-54 | 6.7E-03 | | 2.0E+05 | |
| Fe-59 | 1.7E-02 | | 5.1E+05 | |
| Co-58 | 8.0E-03 | | 2.4E+05 | |
| Co-60 | 4.4E-01 | | 1.3E+07 | |
| Ni-63 | 2.2E+00 | | 6.6E+07 | |
| Zn-65 | 1.5E-02 | | 4.5E+05 | |
| Rb-86 | 1.9E-01 | | 5.7E+06 | |
| Sr-89 | 1.0E-01 | | 3.0E+06 | |
| Sr-90 | 2.2E-01 | | 6.6E+06 | |
| Y-90 | 2.2E-01 | | 6.6E+06 | |
| Y-91 | 2.2E+00 | | 6.6E+07 | |
| Nb-95 | 1.0E-02 | | 3.0E+05 | |
| Tc-99 | 7.0E-01 | | 2.1E+07 | |
| Ru-103 | 1.0E-02 | | 3.0E+05 | |
| Ru-106 | 1.6E+00 | | 4.8E+07 | |
| Rh-103m | 1.0E-02 | | 3.0E+05 | |
| Rh-106 | 1.6E+00 | | 4.8E+07 | |
| Ag-110m | 5.6E-03 | | 1.7E+05 | |
| Cd-113m | 1.8E-02 | | 5.4E+05 | |
| Cd-115m | 6.4E-01 | | 1.9E+07 | |
| Sn-119m | 1.7E-01 | | 5.1E+06 | |
| Sn-123 | 1.2E+00 | | 3.6E+07 | |
| Sn-126 | 2.7E-02 | | 8.1E+05 | |
| Sb-124 | 9.5E-03 | | 2.9E+05 | |
| Sb-125 | 3.3E-01 | | 9.9E+06 | |
| Te-123m | 9.2E-03 | | 2.8E+05 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Te-125m | 3.3E-01 | | 9.9E+06 | |
| Te-127 | 3.2E-01 | | 9.6E+06 | |
| Te-127m | 3.2E-01 | | 9.6E+06 | |
| Te-129 | 8.1E-02 | | 2.4E+06 | |
| Te-129m | 3.2E-01 | | 9.6E+06 | |
| I-129 | 2.1E+00 | | 6.3E+07 | |
| Cs-134 | 4.5E-02 | | 1.4E+06 | |
| Cs-135 | 2.5E-06 | | 7.5E+01 | |
| Cs-136 | 3.0E-02 | | 9.0E+05 | |
| Cs-137 | 4.2E-01 | | 1.3E+07 | |
| Ba-137m | 4.2E-01 | | 1.3E+07 | |
| Ba-140 | 9.5E-02 | | 2.9E+06 | |
| Ce-141 | 2.5E-02 | | 7.5E+05 | |
| Ce-144 | 6.3E-02 | | 1.9E+06 | |
| Pr-144 | 6.3E-02 | | 1.9E+06 | |
| Pr-144m | 6.3E-02 | | 1.9E+06 | |
| Pm-146 | 9.8E-02 | | 2.9E+06 | |
| Pm-147 | 1.9E-01 | | 5.7E+06 | |
| Pm-148 | 5.0E-01 | | 1.5E+07 | |
| Pm-148m | 8.4E-03 | | 2.5E+05 | |
| Sm-151 | 9.0E-04 | | 2.7E+04 | |
| Eu-152 | 2.8E-02 | | 8.4E+05 | |
| Eu-154 | 1.2E-02 | | 3.6E+05 | |
| Eu-155 | 3.3E-02 | | 9.9E+05 | |
| Gd-153 | 3.2E-02 | | 9.6E+05 | |
| Tb-160 | 2.8E-02 | | 8.4E+05 | |
| Pu-238 | 6.3E-04 | | 1.9E+04 | |
| Pu-239 | 6.3E-04 | | 1.9E+04 | |
| Pu-240 | 6.3E-04 | | 1.9E+04 | |
| Pu-241 | 2.8E-02 | | 8.4E+05 | |
| Am-241 | 6.3E-04 | | 1.9E+04 | |
| Am-242m | 3.9E-05 | | 1.2E+03 | |
| Am-243 | 6.3E-04 | | 1.9E+04 | |
| Cm-242 | 6.3E-04 | | 1.9E+04 | |
| Cm-243 | 6.3E-04 | | 1.9E+04 | |
| Cm-244 | 6.3E-04 | | 1.9E+04 | |

Table 6-2-5 Source term based on the nuclide composition of measured values (J1-C tank group) (Case 2)

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|--|
| H-3 | 8.2E+05 | 3.0E+07 | 2.5E+13 | <ul style="list-style-type: none"> • It was assumed that all of 3 tank groups for measurement/confirmation were damaged and whole capacity (30,000 m³) leaked in 1 day • The daily discharge amount was calculated from the product of the daily discharge volume of water, 30,000 m³, and the nuclide concentration |
| C-14 | 1.8E+01 | | 5.4E+08 | |
| Mn-54 | 3.8E-02 | | 1.1E+06 | |
| Fe-59 | 8.7E-02 | | 2.6E+06 | |
| Co-58 | 4.1E-02 | | 1.2E+06 | |
| Co-60 | 3.3E-01 | | 9.9E+06 | |
| Ni-63 | 8.5E+00 | | 2.6E+08 | |
| Zn-65 | 9.4E-02 | | 2.8E+06 | |
| Rb-86 | 5.0E-01 | | 1.5E+07 | |
| Sr-89 | 5.4E-02 | | 1.6E+06 | |
| Sr-90 | 3.6E-02 | | 1.1E+06 | |
| Y-90 | 3.6E-02 | | 1.1E+06 | |
| Y-91 | 1.7E+01 | | 5.1E+08 | |
| Nb-95 | 5.0E-02 | | 1.5E+06 | |
| Tc-99 | 1.2E+00 | | 3.6E+07 | |
| Ru-103 | 5.3E-02 | | 1.6E+06 | |
| Ru-106 | 1.4E+00 | | 4.2E+07 | |
| Rh-103m | 5.3E-02 | | 1.6E+06 | |
| Rh-106 | 1.4E+00 | | 4.2E+07 | |
| Ag-110m | 4.3E-02 | | 1.3E+06 | |
| Cd-113m | 8.5E-02 | | 2.6E+06 | |
| Cd-115m | 2.7E+00 | | 8.1E+07 | |
| Sn-119m | 4.2E+01 | | 1.3E+09 | |
| Sn-123 | 6.6E+00 | | 2.0E+08 | |
| Sn-126 | 2.9E-01 | | 8.7E+06 | |
| Sb-124 | 9.7E-02 | | 2.9E+06 | |
| Sb-125 | 2.3E-01 | | 6.9E+06 | |
| Te-123m | 9.2E-02 | | 2.8E+06 | |
| Te-125m | 2.3E-01 | | 6.9E+06 | |
| Te-127 | 4.7E+00 | | 1.4E+08 | |
| Te-127m | 4.9E+00 | | 1.5E+08 | |
| Te-129 | 6.2E-01 | | 1.9E+07 | |
| Te-129m | 1.4E+00 | | 4.2E+07 | |
| I-129 | 1.2E+00 | 3.6E+07 | | |
| Cs-134 | 7.6E-02 | 2.3E+06 | | |
| Cs-135 | 1.2E-06 | 3.6E+01 | | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Cs-136 | 4.7E-02 | | 1.4E+06 | |
| Cs-137 | 1.9E-01 | | 5.7E+06 | |
| Ba-137m | 1.9E-01 | | 5.7E+06 | |
| Ba-140 | 2.0E-01 | | 6.0E+06 | |
| Ce-141 | 2.6E-01 | | 7.8E+06 | |
| Ce-144 | 5.7E-01 | | 1.7E+07 | |
| Pr-144 | 5.7E-01 | | 1.7E+07 | |
| Pr-144m | 5.7E-01 | | 1.7E+07 | |
| Pm-146 | 6.7E-02 | | 2.0E+06 | |
| Pm-147 | 8.0E-01 | | 2.4E+07 | |
| Pm-148 | 2.3E-01 | | 6.9E+06 | |
| Pm-148m | 4.8E-02 | | 1.4E+06 | |
| Sm-151 | 1.1E-02 | | 3.3E+05 | |
| Eu-152 | 2.8E-01 | | 8.4E+06 | |
| Eu-154 | 1.1E-01 | | 3.3E+06 | |
| Eu-155 | 3.4E-01 | | 1.0E+07 | |
| Gd-153 | 2.6E-01 | | 7.8E+06 | |
| Tb-160 | 1.4E-01 | | 4.2E+06 | |
| Pu-238 | 3.3E-02 | | 9.9E+05 | |
| Pu-239 | 3.3E-02 | | 9.9E+05 | |
| Pu-240 | 3.3E-02 | | 9.9E+05 | |
| Pu-241 | 1.2E+00 | | 3.6E+07 | |
| Am-241 | 3.3E-02 | | 9.9E+05 | |
| Am-242m | 5.9E-04 | | 1.8E+04 | |
| Am-243 | 3.3E-02 | | 9.9E+05 | |
| Cm-242 | 3.3E-02 | | 9.9E+05 | |
| Cm-243 | 3.3E-02 | | 9.9E+05 | |
| Cm-244 | 3.3E-02 | | 9.9E+05 | |

Table 6-2-6 Source term based on the nuclide composition of measured values (J1-G tank group) (Case 2)

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|--|
| H-3 | 2.7E+05 | 3.0E+07 | 8.1E+12 | • It was assumed that all of 3 tank groups for measurement/confirmation were |
| C-14 | 1.6E+01 | | 4.8E+08 | |
| Mn-54 | 3.8E-02 | | 1.1E+06 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---|
| Fe-59 | 7.2E-02 | | 2.2E+06 | damaged and whole capacity (30,000 m ³) leaked in 1 day • The daily discharge amount was calculated from the product of the daily discharge volume of water, 30,000 m ³ , and the nuclide concentration |
| Co-58 | 3.7E-02 | | 1.1E+06 | |
| Co-60 | 2.3E-01 | | 6.9E+06 | |
| Ni-63 | 8.8E+00 | | 2.6E+08 | |
| Zn-65 | 8.0E-02 | | 2.4E+06 | |
| Rb-86 | 4.7E-01 | | 1.4E+07 | |
| Sr-89 | 4.5E-02 | | 1.4E+06 | |
| Sr-90 | 3.2E-02 | | 9.6E+05 | |
| Y-90 | 3.2E-02 | | 9.6E+05 | |
| Y-91 | 1.2E+01 | | 3.6E+08 | |
| Nb-95 | 4.7E-02 | | 1.4E+06 | |
| Tc-99 | 1.3E+00 | | 3.9E+07 | |
| Ru-103 | 5.1E-02 | | 1.5E+06 | |
| Ru-106 | 4.8E-01 | | 1.4E+07 | |
| Rh-103m | 5.1E-02 | | 1.5E+06 | |
| Rh-106 | 4.8E-01 | | 1.4E+07 | |
| Ag-110m | 4.0E-02 | | 1.2E+06 | |
| Cd-113m | 8.6E-02 | | 2.6E+06 | |
| Cd-115m | 2.3E+00 | | 6.9E+07 | |
| Sn-119m | 4.0E+01 | | 1.2E+09 | |
| Sn-123 | 6.3E+00 | | 1.9E+08 | |
| Sn-126 | 1.5E-01 | | 4.5E+06 | |
| Sb-124 | 8.4E-02 | | 2.5E+06 | |
| Sb-125 | 1.4E-01 | | 4.2E+06 | |
| Te-123m | 6.7E-02 | | 2.0E+06 | |
| Te-125m | 1.4E-01 | | 4.2E+06 | |
| Te-127 | 4.3E+00 | | 1.3E+08 | |
| Te-127m | 4.5E+00 | | 1.4E+08 | |
| Te-129 | 5.9E-01 | | 3.6E+07 | |
| Te-129m | 1.2E+00 | | 3.6E+07 | |
| I-129 | 3.3E-01 | | 9.9E+06 | |
| Cs-134 | 6.7E-02 | | 2.0E+06 | |
| Cs-135 | 2.1E-06 | | 6.3E+01 | |
| Cs-136 | 3.6E-02 | | 1.1E+06 | |
| Cs-137 | 3.3E-01 | | 9.9E+06 | |
| Ba-137m | 3.3E-01 | | 9.9E+06 | |
| Ba-140 | 1.7E-01 | | 5.1E+06 | |
| Ce-141 | 1.2E-01 | | 3.6E+06 | |

| Target nuclide | Nuclide concentration (Bq/L) | Daily discharge volume of water (L/day) | Daily discharge amount (Bq/day) | Remarks |
|----------------|------------------------------|---|---------------------------------|---------|
| Ce-144 | 5.5E-01 | | 1.7E+07 | |
| Pr-144 | 5.5E-01 | | 1.7E+07 | |
| Pr-144m | 5.5E-01 | | 1.7E+07 | |
| Pm-146 | 6.3E-02 | | 1.9E+06 | |
| Pm-147 | 7.2E-01 | | 2.2E+07 | |
| Pm-148 | 4.5E-01 | | 1.4E+07 | |
| Pm-148m | 4.1E-02 | | 1.2E+06 | |
| Sm-151 | 1.0E-02 | | 3.0E+05 | |
| Eu-152 | 1.9E-01 | | 5.7E+06 | |
| Eu-154 | 1.0E-01 | | 3.0E+06 | |
| Eu-155 | 1.8E-01 | | 5.4E+06 | |
| Gd-153 | 1.9E-01 | | 5.7E+06 | |
| Tb-160 | 1.4E-01 | | 4.2E+06 | |
| Pu-238 | 2.8E-02 | | 8.4E+05 | |
| Pu-239 | 2.8E-02 | | 8.4E+05 | |
| Pu-240 | 2.8E-02 | | 8.4E+05 | |
| Pu-241 | 1.0E+00 | | 3.0E+07 | |
| Am-241 | 2.8E-02 | | 8.4E+05 | |
| Am-242m | 5.1E-04 | | 1.5E+04 | |
| Am-243 | 2.8E-02 | | 8.4E+05 | |
| Cm-242 | 2.8E-02 | | 8.4E+05 | |
| Cm-243 | 2.8E-02 | | 8.4E+05 | |
| Cm-244 | 2.8E-02 | | 8.4E+05 | |

(3) Modeling of diffusion and transfer, and exposure pathway

In the assessment of potential exposure, the location of discharge into the sea changes from 1 km offshore to the coast, but these discharge destinations are the same sea area and diffusion and advection are assumed as same as those of the normal exposure, so the migration pathways are the same as those of the normal exposure set in 6-1-2.(2). Though the same model is also used for simulation, the calculation result based on discharge from near the Unit 5/6 discharge outlets was used because it is the leakage from the coast. The target regions, sea areas, and migration pathways are the same, so exposure pathways are the same as those of the normal exposure.

(4) Setting of the representative person

For the representative person subject to the potential exposure assessment, the region, sea area, migration pathways, and exposure pathways are the same, so the same characteristics as 6-1-2.(4) are applied. After leakage of ALPS treated water, diffusion dilution proceeds due to tidal currents and the concentration immediately drops, but exposure was assumed to continue for one week even after the end of leakage considering the case that the flow velocity continues to be small for 3 to 4 days. Conservatively, the concentration in the seawater is assumed to continue to be the same during such a period. For each case, the exposure time, etc., was set by a time proportion calculation of the exposure continuation period from the annual operation hours, etc. The set exposure time, etc., are as shown in Table 6-2-7.

Table 6-2-7 Exposure time of the representative person used for the potential exposure assessment, etc.

| Item | Case 1 (27 days) | Case 2 (8 days) |
|-----------------------------------|---|--|
| Operation hours on a ship | 210 hours | 63 hours |
| Swimming time | 7.1 hours | 2.1 hours |
| Coastline stay time | 37 hours | 11 hours |
| Operation hours near fishing nets | 140 hours | 42 hours |
| Ingestion of seafood | Ingestion of persons who consume a large amount of seafood in 27 days | Ingestion of persons who consume a large amount of seafood in 8 days |

The exposure assessment point is near the beach assessment point to the north of the FDNPS used for the normal exposure, and conservatively the concentration in the seawater near the beach assessment point was used for all pathways.

(5) Dose assessment method

The exposure amount of the representative person is compared with 5mSv, which is the typical decision criteria for simple assessment based on conservatively defined potential exposure scenarios for facilities and activities as described in 5.69 of GSG-10.

6-2-2. Assessment result

(1) Concentration in the seawater used for the assessment

The concentration in the seawater is the concentration near the beach assessment point to the north of the FDNPS calculated based on the result of simulation of the case of discharge from the Unit 5/6 discharge outlets of a total of 22 TBq (2.2E+13Bq) of tritium per year at an even pace throughout the year (equivalent to 6.0E+10Bq/day) as follows.

- Case 1 (Piping rupture)

We calculated the 20 days moving average of the daily average tritium concentration at the assessment point from the simulation results of tritium of 2014 and 2019, and then calculated the maximum value of each year. Table 6-2-8 shows the result. We selected the result of 2014, of which concentration is higher, 5.6Bq/L from the results of the two years.

Since this concentration assumed the daily discharge amount of tritium 6.0E+10Bq/day, we calculated the concentration of each nuclide by comparing the daily discharge amount of each nuclide in Tables 6-2-1 to 3. Tables 6-2-9 to 6-2-11 show the concentration of each nuclide used for the assessment.

- Case 2 (Tank damage)

From the simulation results of tritium of 2014 and 2019, we calculated the maximum daily average tritium concentration of each year at the assessment point. Table 6-2-8 shows the result. We selected the higher result, namely 15Bq/L in 2014, from the results of two years. Since this concentration assumed the daily discharge amount of tritium 6.0E+10Bq/day, we calculated the concentration of each nuclide by comparing the daily discharge amount of each nuclide in Tables 6-2-4 to 6. Tables 6-2-9 to 6-2-11 show the concentration of each nuclide used for the assessment.

**Table 6-2-8 Concentration of tritium in the seawater near the beach assessment point on which the potential exposure assessment is based
(Calculated daily average concentration from a simulation of the case of discharge from the Unit 5 and 6 discharge outlets at an even pace throughout the year of a total of 22 TBq (2.2E+13Bq) per year)**

| Assessment year | Case 1 (Piping rupture) | Case 2 (Tank damage) |
|-----------------|---|---|
| | Maximum value of the 20-day moving average concentration (Bq/L) | Maximum value of the daily average concentration (Bq/L) |
| 2014 | 5.6 | 15 |
| 2019 | 5.5 | 12 |

Table 6-2-9 Concentration in the seawater used for the assessment (Source term based on the composition of nuclides in the K4 tank group)

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| H-3 | 9.5E+10 | 8.8E+00 | 5.7E+12 | 1.4E+03 |
| C-14 | 7.5E+06 | 7.0E-04 | 4.5E+08 | 1.1E-01 |
| Mn-54 | 3.4E+03 | 3.1E-07 | 2.0E+05 | 5.0E-05 |
| Fe-59 | 8.5E+03 | 7.9E-07 | 5.1E+05 | 1.3E-04 |
| Co-58 | 4.0E+03 | 3.7E-07 | 2.4E+05 | 6.0E-05 |
| Co-60 | 2.2E+05 | 2.0E-05 | 1.3E+07 | 3.3E-03 |
| Ni-63 | 1.1E+06 | 1.0E-04 | 6.6E+07 | 1.6E-02 |
| Zn-65 | 7.5E+03 | 7.0E-07 | 4.5E+05 | 1.1E-04 |
| Rb-86 | 9.5E+04 | 8.8E-06 | 5.7E+06 | 1.4E-03 |
| Sr-89 | 5.0E+04 | 4.6E-06 | 3.0E+06 | 7.5E-04 |
| Sr-90 | 1.1E+05 | 1.0E-05 | 6.6E+06 | 1.6E-03 |
| Y-90 | 1.1E+05 | 1.0E-05 | 6.6E+06 | 1.6E-03 |
| Y-91 | 1.1E+06 | 1.0E-04 | 6.6E+07 | 1.6E-02 |
| Nb-95 | 5.0E+03 | 4.6E-07 | 3.0E+05 | 7.5E-05 |
| Tc-99 | 3.5E+05 | 3.3E-05 | 2.1E+07 | 5.2E-03 |
| Ru-103 | 5.0E+03 | 4.6E-07 | 3.0E+05 | 7.5E-05 |
| Ru-106 | 8.0E+05 | 7.4E-05 | 4.8E+07 | 1.2E-02 |
| Rh-103m | 5.0E+03 | 4.6E-07 | 3.0E+05 | 7.5E-05 |
| Rh-106 | 8.0E+05 | 7.4E-05 | 4.8E+07 | 1.2E-02 |
| Ag-110m | 2.8E+03 | 2.6E-07 | 1.7E+05 | 4.2E-05 |
| Cd-113m | 9.0E+03 | 8.4E-07 | 5.4E+05 | 1.3E-04 |
| Cd-115m | 3.2E+05 | 3.0E-05 | 1.9E+07 | 4.8E-03 |
| Sn-119m | 8.5E+04 | 7.9E-06 | 5.1E+06 | 1.3E-03 |
| Sn-123 | 6.0E+05 | 5.6E-05 | 3.6E+07 | 9.0E-03 |
| Sn-126 | 1.4E+04 | 1.3E-06 | 8.1E+05 | 2.0E-04 |
| Sb-124 | 4.8E+03 | 4.4E-07 | 2.9E+05 | 7.1E-05 |
| Sb-125 | 1.7E+05 | 1.5E-05 | 9.9E+06 | 2.5E-03 |
| Te-123m | 4.6E+03 | 4.3E-07 | 2.8E+05 | 6.9E-05 |
| Te-125m | 1.7E+05 | 1.5E-05 | 9.9E+06 | 2.5E-03 |
| Te-127 | 1.6E+05 | 1.5E-05 | 9.6E+06 | 2.4E-03 |

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| Te-127m | 1.6E+05 | 1.5E-05 | 9.6E+06 | 2.4E-03 |
| Te-129 | 4.1E+04 | 3.8E-06 | 2.4E+06 | 6.0E-04 |
| Te-129m | 1.6E+05 | 1.5E-05 | 9.6E+06 | 2.4E-03 |
| I-129 | 1.1E+06 | 9.8E-05 | 6.3E+07 | 1.6E-02 |
| Cs-134 | 2.3E+04 | 2.1E-06 | 1.4E+06 | 3.4E-04 |
| Cs-135 | 1.3E+00 | 1.2E-10 | 7.5E+01 | 1.9E-08 |
| Cs-136 | 1.5E+04 | 1.4E-06 | 9.0E+05 | 2.2E-04 |
| Cs-137 | 2.1E+05 | 2.0E-05 | 1.3E+07 | 3.1E-03 |
| Ba-137m | 2.1E+05 | 2.0E-05 | 1.3E+07 | 3.1E-03 |
| Ba-140 | 4.8E+04 | 4.4E-06 | 2.9E+06 | 7.1E-04 |
| Ce-141 | 1.3E+04 | 1.2E-06 | 7.5E+05 | 1.9E-04 |
| Ce-144 | 3.2E+04 | 2.9E-06 | 1.9E+06 | 4.7E-04 |
| Pr-144 | 3.2E+04 | 2.9E-06 | 1.9E+06 | 4.7E-04 |
| Pr-144m | 3.2E+04 | 2.9E-06 | 1.9E+06 | 4.7E-04 |
| Pm-146 | 4.9E+04 | 4.6E-06 | 2.9E+06 | 7.3E-04 |
| Pm-147 | 9.5E+04 | 8.8E-06 | 5.7E+06 | 1.4E-03 |
| Pm-148 | 2.5E+05 | 2.3E-05 | 1.5E+07 | 3.7E-03 |
| Pm-148m | 4.2E+03 | 3.9E-07 | 2.5E+05 | 6.3E-05 |
| Sm-151 | 4.5E+02 | 4.2E-08 | 2.7E+04 | 6.7E-06 |
| Eu-152 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Eu-154 | 6.0E+03 | 5.6E-07 | 3.6E+05 | 9.0E-05 |
| Eu-155 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |
| Gd-153 | 1.6E+04 | 1.5E-06 | 9.6E+05 | 2.4E-04 |
| Tb-160 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Pu-238 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |
| Pu-239 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |
| Pu-240 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |
| Pu-241 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Am-241 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |
| Am-242m | 2.0E+01 | 1.8E-09 | 1.2E+03 | 2.9E-07 |
| Am-243 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |
| Cm-242 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |
| Cm-243 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| Cm-244 | 3.2E+02 | 2.9E-08 | 1.9E+04 | 4.7E-06 |

Table 6-2-10 Concentration in the seawater used for the assessment (Source term based on the composition of nuclides in the J1-C tank group)

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| H-3 | 4.1E+11 | 3.8E+01 | 2.5E+13 | 6.1E+03 |
| C-14 | 9.0E+06 | 8.4E-04 | 5.4E+08 | 1.3E-01 |
| Mn-54 | 1.9E+04 | 1.8E-06 | 1.1E+06 | 2.8E-04 |
| Fe-59 | 4.4E+04 | 4.0E-06 | 2.6E+06 | 6.5E-04 |
| Co-58 | 2.1E+04 | 1.9E-06 | 1.2E+06 | 3.1E-04 |
| Co-60 | 1.7E+05 | 1.5E-05 | 9.9E+06 | 2.5E-03 |
| Ni-63 | 4.3E+06 | 3.9E-04 | 2.6E+08 | 6.3E-02 |
| Zn-65 | 4.7E+04 | 4.4E-06 | 2.8E+06 | 7.0E-04 |
| Rb-86 | 2.5E+05 | 2.3E-05 | 1.5E+07 | 3.7E-03 |
| Sr-89 | 2.7E+04 | 2.5E-06 | 1.6E+06 | 4.0E-04 |
| Sr-90 | 1.8E+04 | 1.7E-06 | 1.1E+06 | 2.7E-04 |
| Y-90 | 1.8E+04 | 1.7E-06 | 1.1E+06 | 2.7E-04 |
| Y-91 | 8.5E+06 | 7.9E-04 | 5.1E+08 | 1.3E-01 |
| Nb-95 | 2.5E+04 | 2.3E-06 | 1.5E+06 | 3.7E-04 |
| Tc-99 | 6.0E+05 | 5.6E-05 | 3.6E+07 | 9.0E-03 |
| Ru-103 | 2.7E+04 | 2.5E-06 | 1.6E+06 | 4.0E-04 |
| Ru-106 | 7.0E+05 | 6.5E-05 | 4.2E+07 | 1.0E-02 |
| Rh-103m | 2.7E+04 | 2.5E-06 | 1.6E+06 | 4.0E-04 |
| Rh-106 | 7.0E+05 | 6.5E-05 | 4.2E+07 | 1.0E-02 |
| Ag-110m | 2.2E+04 | 2.0E-06 | 1.3E+06 | 3.2E-04 |
| Cd-113m | 4.3E+04 | 3.9E-06 | 2.6E+06 | 6.3E-04 |
| Cd-115m | 1.4E+06 | 1.3E-04 | 8.1E+07 | 2.0E-02 |
| Sn-119m | 2.1E+07 | 2.0E-03 | 1.3E+09 | 3.1E-01 |

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| Sn-123 | 3.3E+06 | 3.1E-04 | 2.0E+08 | 4.9E-02 |
| Sn-126 | 1.5E+05 | 1.3E-05 | 8.7E+06 | 2.2E-03 |
| Sb-124 | 4.9E+04 | 4.5E-06 | 2.9E+06 | 7.2E-04 |
| Sb-125 | 1.2E+05 | 1.1E-05 | 6.9E+06 | 1.7E-03 |
| Te-123m | 4.6E+04 | 4.3E-06 | 2.8E+06 | 6.9E-04 |
| Te-125m | 1.2E+05 | 1.1E-05 | 6.9E+06 | 1.7E-03 |
| Te-127 | 2.4E+06 | 2.2E-04 | 1.4E+08 | 3.5E-02 |
| Te-127m | 2.5E+06 | 2.3E-04 | 1.5E+08 | 3.7E-02 |
| Te-129 | 3.1E+05 | 2.9E-05 | 1.9E+07 | 4.6E-03 |
| Te-129m | 7.0E+05 | 6.5E-05 | 4.2E+07 | 1.0E-02 |
| I-129 | 6.0E+05 | 5.6E-05 | 3.6E+07 | 9.0E-03 |
| Cs-134 | 3.8E+04 | 3.5E-06 | 2.3E+06 | 5.7E-04 |
| Cs-135 | 6.0E-01 | 5.6E-11 | 3.6E+01 | 9.0E-09 |
| Cs-136 | 2.4E+04 | 2.2E-06 | 1.4E+06 | 3.5E-04 |
| Cs-137 | 9.5E+04 | 8.8E-06 | 5.7E+06 | 1.4E-03 |
| Ba-137m | 9.5E+04 | 8.8E-06 | 5.7E+06 | 1.4E-03 |
| Ba-140 | 1.0E+05 | 9.3E-06 | 6.0E+06 | 1.5E-03 |
| Ce-141 | 1.3E+05 | 1.2E-05 | 7.8E+06 | 1.9E-03 |
| Ce-144 | 2.9E+05 | 2.6E-05 | 1.7E+07 | 4.3E-03 |
| Pr-144 | 2.9E+05 | 2.6E-05 | 1.7E+07 | 4.3E-03 |
| Pr-144m | 2.9E+05 | 2.6E-05 | 1.7E+07 | 4.3E-03 |
| Pm-146 | 3.4E+04 | 3.1E-06 | 2.0E+06 | 5.0E-04 |
| Pm-147 | 4.0E+05 | 3.7E-05 | 2.4E+07 | 6.0E-03 |
| Pm-148 | 1.2E+05 | 1.1E-05 | 6.9E+06 | 1.7E-03 |
| Pm-148m | 2.4E+04 | 2.2E-06 | 1.4E+06 | 3.6E-04 |
| Sm-151 | 5.5E+03 | 5.1E-07 | 3.3E+05 | 8.2E-05 |
| Eu-152 | 1.4E+05 | 1.3E-05 | 8.4E+06 | 2.1E-03 |
| Eu-154 | 5.5E+04 | 5.1E-06 | 3.3E+06 | 8.2E-04 |
| Eu-155 | 1.7E+05 | 1.6E-05 | 1.0E+07 | 2.5E-03 |
| Gd-153 | 1.3E+05 | 1.2E-05 | 7.8E+06 | 1.9E-03 |
| Tb-160 | 7.0E+04 | 6.5E-06 | 4.2E+06 | 1.0E-03 |
| Pu-238 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| Pu-239 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |
| Pu-240 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |
| Pu-241 | 6.0E+05 | 5.6E-05 | 3.6E+07 | 9.0E-03 |
| Am-241 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |
| Am-242m | 3.0E+02 | 2.7E-08 | 1.8E+04 | 4.4E-06 |
| Am-243 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |
| Cm-242 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |
| Cm-243 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |
| Cm-244 | 1.7E+04 | 1.5E-06 | 9.9E+05 | 2.5E-04 |

Table 6-2-11 Concentration in the seawater used for the assessment (Source term based on the composition of nuclides in the J1-G tank group)

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| H-3 | 1.4E+11 | 1.3E+01 | 8.1E+12 | 2.0E+03 |
| C-14 | 8.0E+06 | 7.4E-04 | 4.8E+08 | 1.2E-01 |
| Mn-54 | 1.9E+04 | 1.8E-06 | 1.1E+06 | 2.8E-04 |
| Fe-59 | 3.6E+04 | 3.3E-06 | 2.2E+06 | 5.4E-04 |
| Co-58 | 1.9E+04 | 1.7E-06 | 1.1E+06 | 2.8E-04 |
| Co-60 | 1.2E+05 | 1.1E-05 | 6.9E+06 | 1.7E-03 |
| Ni-63 | 4.4E+06 | 4.1E-04 | 2.6E+08 | 6.6E-02 |
| Zn-65 | 4.0E+04 | 3.7E-06 | 2.4E+06 | 6.0E-04 |
| Rb-86 | 2.4E+05 | 2.2E-05 | 1.4E+07 | 3.5E-03 |
| Sr-89 | 2.3E+04 | 2.1E-06 | 1.4E+06 | 3.4E-04 |
| Sr-90 | 1.6E+04 | 1.5E-06 | 9.6E+05 | 2.4E-04 |
| Y-90 | 1.6E+04 | 1.5E-06 | 9.6E+05 | 2.4E-04 |
| Y-91 | 6.0E+06 | 5.6E-04 | 3.6E+08 | 9.0E-02 |
| Nb-95 | 2.4E+04 | 2.2E-06 | 1.4E+06 | 3.5E-04 |

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| Tc-99 | 6.5E+05 | 6.0E-05 | 3.9E+07 | 9.7E-03 |
| Ru-103 | 2.6E+04 | 2.4E-06 | 1.5E+06 | 3.8E-04 |
| Ru-106 | 2.4E+05 | 2.2E-05 | 1.4E+07 | 3.6E-03 |
| Rh-103m | 2.6E+04 | 2.4E-06 | 1.5E+06 | 3.8E-04 |
| Rh-106 | 2.4E+05 | 2.2E-05 | 1.4E+07 | 3.6E-03 |
| Ag-110m | 2.0E+04 | 1.9E-06 | 1.2E+06 | 3.0E-04 |
| Cd-113m | 4.3E+04 | 4.0E-06 | 2.6E+06 | 6.4E-04 |
| Cd-115m | 1.2E+06 | 1.1E-04 | 6.9E+07 | 1.7E-02 |
| Sn-119m | 2.0E+07 | 1.9E-03 | 1.2E+09 | 3.0E-01 |
| Sn-123 | 3.2E+06 | 2.9E-04 | 1.9E+08 | 4.7E-02 |
| Sn-126 | 7.5E+04 | 7.0E-06 | 4.5E+06 | 1.1E-03 |
| Sb-124 | 4.2E+04 | 3.9E-06 | 2.5E+06 | 6.3E-04 |
| Sb-125 | 7.0E+04 | 6.5E-06 | 4.2E+06 | 1.0E-03 |
| Te-123m | 3.4E+04 | 3.1E-06 | 2.0E+06 | 5.0E-04 |
| Te-125m | 7.0E+04 | 6.5E-06 | 4.2E+06 | 1.0E-03 |
| Te-127 | 2.2E+06 | 2.0E-04 | 1.3E+08 | 3.2E-02 |
| Te-127m | 2.3E+06 | 2.1E-04 | 1.4E+08 | 3.4E-02 |
| Te-129 | 3.0E+05 | 2.7E-05 | 1.8E+07 | 4.4E-03 |
| Te-129m | 6.0E+05 | 5.6E-05 | 3.6E+07 | 9.0E-03 |
| I-129 | 1.7E+05 | 1.5E-05 | 9.9E+06 | 2.5E-03 |
| Cs-134 | 3.4E+04 | 3.1E-06 | 2.0E+06 | 5.0E-04 |
| Cs-135 | 1.1E+00 | 9.8E-11 | 6.3E+01 | 1.6E-08 |
| Cs-136 | 1.8E+04 | 1.7E-06 | 1.1E+06 | 2.7E-04 |
| Cs-137 | 1.7E+05 | 1.5E-05 | 9.9E+06 | 2.5E-03 |
| Ba-137m | 1.7E+05 | 1.5E-05 | 9.9E+06 | 2.5E-03 |
| Ba-140 | 8.5E+04 | 7.9E-06 | 5.1E+06 | 1.3E-03 |
| Ce-141 | 6.0E+04 | 5.6E-06 | 3.6E+06 | 9.0E-04 |
| Ce-144 | 2.8E+05 | 2.6E-05 | 1.7E+07 | 4.1E-03 |
| Pr-144 | 2.8E+05 | 2.6E-05 | 1.7E+07 | 4.1E-03 |
| Pr-144m | 2.8E+05 | 2.6E-05 | 1.7E+07 | 4.1E-03 |
| Pm-146 | 3.2E+04 | 2.9E-06 | 1.9E+06 | 4.7E-04 |
| Pm-147 | 3.6E+05 | 3.3E-05 | 2.2E+07 | 5.4E-03 |

| Target nuclide | Case 1 (Piping rupture) | | Case 2 (Tank damage) | |
|----------------|---------------------------------|--|---------------------------------|--|
| | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) | Daily discharge amount (Bq/day) | Concentration in the seawater near the beach assessment point (Bq/L) |
| Pm-148 | 2.3E+05 | 2.1E-05 | 1.4E+07 | 3.4E-03 |
| Pm-148m | 2.1E+04 | 1.9E-06 | 1.2E+06 | 3.1E-04 |
| Sm-151 | 5.0E+03 | 4.6E-07 | 3.0E+05 | 7.5E-05 |
| Eu-152 | 9.5E+04 | 8.8E-06 | 5.7E+06 | 1.4E-03 |
| Eu-154 | 5.0E+04 | 4.6E-06 | 3.0E+06 | 7.5E-04 |
| Eu-155 | 9.0E+04 | 8.4E-06 | 5.4E+06 | 1.3E-03 |
| Gd-153 | 9.5E+04 | 8.8E-06 | 5.7E+06 | 1.4E-03 |
| Tb-160 | 7.0E+04 | 6.5E-06 | 4.2E+06 | 1.0E-03 |
| Pu-238 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Pu-239 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Pu-240 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Pu-241 | 5.0E+05 | 4.6E-05 | 3.0E+07 | 7.5E-03 |
| Am-241 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Am-242m | 2.6E+02 | 2.4E-08 | 1.5E+04 | 3.8E-06 |
| Am-243 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Cm-242 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Cm-243 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |
| Cm-244 | 1.4E+04 | 1.3E-06 | 8.4E+05 | 2.1E-04 |

(2) Exposure assessment result

Table 6-2-12 shows the potential exposure result calculated using the concentration in the seawater calculated in (1). The result is 0.0007 (7E-04) mSv to 0.3(3E-01) mSv, which falls below 5mSv, which is the standard at the time of accident.

Table 6-2-12 Results of the potential exposure assessment

| Assessed case | Source term | Case 1 (Piping rupture) | | | Case 2 (Tank damage) | | |
|-------------------------|----------------------|-------------------------|-----------------|-----------------|----------------------|-----------------|-----------------|
| | | K4 tank group | J1-C tank group | J1-G tank group | K4 tank group | J1-C tank group | J1-G tank group |
| | Ingestion of seafood | Large | Large | Large | Large | Large | Large |
| External exposure (mSv) | Sea surface | 3.5E-08 | 4.0E-07 | 3.6E-07 | 1.7E-06 | 1.9E-05 | 1.7E-05 |
| | Hull | 2.5E-08 | 2.8E-07 | 2.5E-07 | 1.2E-06 | 1.4E-05 | 1.2E-05 |
| | During swimming | 3.3E-09 | 3.8E-08 | 3.4E-08 | 1.6E-07 | 1.8E-06 | 1.6E-06 |
| | Beach sand | 5.8E-06 | 6.7E-05 | 5.9E-05 | 2.8E-04 | 3.2E-03 | 2.8E-03 |
| | Fishing net | 1.8E-05 | 2.1E-04 | 1.9E-04 | 8.9E-04 | 1.0E-02 | 9.1E-03 |
| Internal exposure (mSv) | Ingestion of water | 2.4E-07 | 9.9E-07 | 3.3E-07 | 1.2E-05 | 4.7E-05 | 1.6E-05 |
| | Inhalation of spray | 6.9E-08 | 6.4E-07 | 4.2E-07 | 3.3E-06 | 3.1E-05 | 2.0E-05 |
| | Ingestion of seafood | 7.1E-04 | 5.4E-03 | 4.9E-03 | 3.4E-02 | 2.6E-01 | 2.4E-01 |
| Total (mSv) | | 7E-04 | 6E-03 | 5E-03 | 4E-02 | 3E-01 | 2E-01 |

7. Assessment regarding environmental protection


The assessment method of environmental protection is as shown in GSG -10 Annex I. In this report, environmental protection was assessed according to the procedure of GSG -10 Annex I.

7-1. Concept of assessment

The assessment for protection of plants and animals in the normal operation is performed according to GSG -10 Annex I.

7-1-1. Assessment procedure

The assessment is performed according to the procedure shown in Figure 7-1.



**Figure 7-1 Environmental protection assessment procedure
(prepared from GSG-10)**

³⁹ Reference animals and plants: Specific types of animals and plants assumed in order to associate radiation exposure from the environment with the dose and impact.

⁴⁰ Derived consideration reference level (DCRL): Range of the dose rates within a range of one digit specified for each species advocated by ICRP. Dose rate level at which the impact has to be considered if is exceeded.

7-2. Assessment method

7-2-1. Source term

Use the same source term as the one shown in 6-1-2.(1) Source term.

7-2-2. Modeling of diffusion and transfer after discharge

(1) Selection of the migration model

As the migration model of radioactive materials discharged into the sea, the following was selected from the migration model of human exposure assessment, considering habitat environment of marine plants and animals, referring to GSG-10.

- i. Advection and diffusion by tidal currents, etc.
Selected because advection and diffusion will occur after discharge into the sea.
- ii. Advection and diffusion by tidal currents, etc. -> Migration to seabed sediment
Selected because ALPS treated water will migrate to seabed sediment, etc., due to advection and diffusion caused by tidal currents, etc., after discharge into the sea.
- iii. Advection and diffusion by tidal currents, etc. -> Intake and concentration by marine plants and animals such as fish
Selected because migration to and concentration in fish, etc. will occur after discharge into the sea.

(2) Assessment of advection and diffusion in the sea area

The same model as that for the human protection assessment is used.

7-2-3. Setting of exposure pathways

The following pathways were selected according to GSG -10 Annex I-21.

- i. Internal exposure from radioactive materials ingested or inhaled by plants and animals
- ii. External exposure from the surrounding seawater
- iii. External exposure from the surrounding seabed sediment

The following shows the specific assessment method.

- (1) Internal exposure from radioactive materials ingested or inhaled by plants and animals
Equation (7-1) shows the calculation equation of the absorbed dose rate D_{int} (mGy/day) of radiation from radioactive materials ingested from the seawater by standard animals and plants.

$$D_{int} = \sum_i (DCF_{int})_{ki} \cdot (x_9)_i \cdot (CR)_{ki} \quad (7-1)$$

where

- $(DCF_{int})_{ki}$ is the internal exposure dose conversion factor to marine plants and animals k of nuclide i ((mGy/day)/(Bq/kg))
- $(x_9)_i$ is the concentration of nuclide i in seawater (Bq/L)
- $(CR)_{ki}$ is the ration of the concentration in the seawater to marine plants and animals k in nuclide i ((Bq/kg)/(Bq/L))

(2) External exposure from the seawater and seabed sediment

The absorbed dose rate $D_{ext,sw}$ (mGy/day) of plants and animals surrounded by the seawater is calculated by equation (7-2).

$$D_{ext,sw} = \sum_i (DCF_{ext})_{ki} \cdot \frac{(x_9)_i}{\rho_w} \quad (7-2)$$

where

- $(DCF_{ext})_{ki}$ is the external exposure dose conversion factor to marine plants and animals k of nuclide i ((mGy/day)/(Bq/kg))
- $(x_9)_i$ is the concentration of nuclide i in seawater (Bq/L)
- ρ_w is the density of seawater (kg/L)

Similarly, the absorbed dose rate $D_{ext,sed}$ (mGy/day) of plants and animals surrounded by seabed sediment is calculated by equation (7-3).

$$D_{ext,sed} = \sum_i (DCF_{ext})_{ki} \cdot (x_9)_i \cdot (K_d)_i \quad (7-3)$$

where

- $(DCF_{ext})_{ki}$ is the external exposure dose conversion factor to marine plants and animals k of nuclide i ((mGy/day)/(Bq/kg))
- $(x_9)_i$ is the concentration of nuclide i in seawater (Bq/L)
- $(K_d)_i$ is the concentration distribution coefficient from seawater to sediment of nuclide i ((Bq/kg)/(Bq/L))

External exposure in the case of exposure from the seawater and seabed sediment D_{ext} is the total of both, but plants and animals that live on the seabed are exposed to half each of the seawater of upper half and the seabed sediment of the lower half, respectively, so it is calculated by Equation (7-4).

$$D_{ext}=0.5 \cdot D_{ext,sw}+0.5 \cdot D_{ext,sed} \quad (7-4)$$

The internal and external exposure dose conversion factors to plants and animals⁴¹ is excerpted from ICRP Publication 136 “Dose Coefficients for Non-human Biota Environmentally Exposed to Radiation”(ICRP,2017) [29] (hereinafter called “ICRP pub.136”) and the BiotaDC program of ICRP [30] (See Tables 7-2-1 and 7-2-2). Only the dose conversion factor of Sn-126 could not be calculated by BiotaDC, so conservatively the values of Ru-106 and Ag-110m are used for the internal and external exposure dose conversion factors, respectively.

The concentration ratios of plants and animals and the seawater⁴² are excerpted from ICRP Publication 114 “Environmental Protection : Transfer Parameters for Reference Animals and Plants”(ICRP,2009) [31] (hereinafter called “ICRP pub.114”) and IAEA Technical report series No.479 “Handbook of Parameter Values for the Prediction of Radionuclide Transfer to Wildlife” (hereinafter called “TRS-479”). For the elements not shown here, the concentration factors of TRS-422 [25] are excerpted (See Table 7-2-3). For the concentration distribution coefficients of the seawater and seabed sediment, those specified in 2.3.OCEAN MARGIN K_d s of TRS-422 are used (See Table 7-2-4).

⁴¹ Dose conversion factor to plants and animals: Value set for simplified calculations of internal and external exposure doses to organism by radioactive nuclides in the environment.

⁴² Concentration ratio (CR): The ratio of the radioactive nuclides in aquatic organisms living in hydrosphere to the underwater concentration in the environment for the assessment of radiation exposure to plants and animals from the environment (ICPR, 2009). Unlike the concentration factor, it is not limited to the edible part.

7-2-4. Selection of reference plants and animals (organisms to be assessed)

Small seaweed beds mainly consisting of *Eisenia bicyclis*, which is a perennial marine alga, are distributed on the coast of Fukushima, in which the FDNPS is located [32]. There is no special sea area like a habitat of a marine plant or animal designated as a protected species around the FDNPS [33] so the following plants and animals are selected as those clarified in ICRP Pub.136.

- Reference flat fish (Left-eyed and right-eyed flounders widely inhabit in the sea area around the FDNPS)
- Reference crabs ((*Ovalipes punctatus* and *Portunus trituberculatus* widely inhabit in the sea area around the FDNPS)
- Reference brown seaweeds (*Sargassum* and *Eisenia bicyclis* widely inhabit in the sea area around the FDNPS)

These plants and animals are widely distributed in the sea area around the FDNPS, so the radioactive material concentration in the seawater used for the assessment is the annual average concentration of 10 km × 10 km around the FDNPS, which matches 100-400 km² as recommended in I-23. of GSG -10 Annex I. In addition, in the assessment of plants and animals, the concentration near the seabed (bottom layer) is used because the impact of external exposure from radioactive materials migrated to the seabed sediment is greater than in the seawater and the selected standard flatfish live on the seabed.

7-2-5. Dose assessment

The dose is assessed by comparison with the derived consideration reference level (DCRL) shown in ICRP Publication 124 "Protection of the Environment under Different Exposure Situations" for each type of the reference plants and animals.

Table 7-2-1 Internal exposure conversion factor to marine plants and animals

(ICRP Pub.136 and others are shown in remarks)

| | Target nuclide | Internal exposure dose conversion factor ((mGy/day)/(Bq/kg)) | | | Remarks |
|----|----------------|---|---------|---------------|---|
| | | Flatfish | Crab | Brown seaweed | |
| 1 | H-3 | 7.9E-08 | 7.9E-08 | 7.9E-08 | |
| 2 | C-14 | 7.0E-07 | 7.0E-07 | 7.0E-07 | |
| 3 | Mn-54 | 1.1E-06 | 1.4E-06 | 9.4E-07 | |
| 4 | Fe-59 | 2.9E-06 | 3.4E-06 | 2.0E-06 | Calculated from BiotaDC |
| 5 | Co-58 | 1.6E-06 | 2.1E-06 | 1.5E-06 | |
| 6 | Co-60 | 3.8E-06 | 5.0E-06 | 3.6E-06 | |
| 7 | Ni-63 | 2.4E-07 | 2.4E-07 | 2.4E-07 | |
| 8 | Zn-65 | 7.7E-07 | 1.0E-06 | 7.0E-07 | |
| 9 | Rb-86 | 8.8E-06 | 9.1E-06 | 6.9E-06 | Calculated from BiotaDC |
| 10 | Sr-89 | 7.7E-06 | 7.9E-06 | 7.7E-06 | |
| 11 | Sr-90 | 1.4E-05 | 1.5E-05 | 1.4E-05 | |
| 12 | Y-90 | — | — | — | Contained in the parent nuclide Sr-90 |
| 13 | Y-91 | 8.0E-06 | 8.1E-06 | 6.4E-06 | Calculated from BiotaDC |
| 14 | Nb-95 | 1.5E-06 | 1.9E-06 | 1.4E-06 | |
| 15 | Tc-99 | 1.4E-06 | 1.4E-06 | 1.4E-06 | |
| 16 | Ru-103 | 2.1E-06 | 2.3E-06 | 2.0E-06 | |
| 17 | Ru-106 | 1.7E-05 | 1.9E-05 | 1.7E-05 | |
| 18 | Rh-103m | — | — | — | Contained in the parent nuclide Ru-103 |
| 19 | Rh-106 | — | — | — | Contained in the parent nuclide Ru-106 |
| 20 | Ag-110m | 4.3E-06 | 5.5E-06 | 4.1E-06 | Calculated from BiotaDC |
| 21 | Cd-113m | 2.5E-06 | 2.5E-06 | 2.4E-06 | Calculated from BiotaDC |
| 22 | Cd-115m | 8.0E-06 | 8.2E-06 | 6.4E-06 | Calculated from BiotaDC |
| 23 | Sn-119m | 1.2E-06 | 1.2E-06 | 1.1E-06 | Calculated from BiotaDC |
| 24 | Sn-123 | 7.0E-06 | 7.1E-06 | 5.8E-06 | Calculated from BiotaDC |
| 25 | Sn-126 | 1.7E-05 | 1.9E-05 | 1.7E-05 | The value of Ru-106 is used because no value is given to this nuclide in the source |
| 26 | Sb-124 | 7.0E-06 | 7.9E-06 | 6.7E-06 | |
| 27 | Sb-125 | 2.0E-06 | 2.2E-06 | 1.9E-06 | |
| 28 | Te-123m | 1.6E-06 | 1.7E-06 | 1.4E-06 | Calculated from BiotaDC |
| 29 | Te-125m | 1.7E-06 | 1.8E-06 | 1.6E-06 | Calculated from BiotaDC |
| 30 | Te-127 | 3.1E-06 | 3.1E-06 | 2.9E-06 | Calculated from BiotaDC |
| 31 | Te-127m | 4.2E-06 | 4.2E-06 | 4.0E-06 | Calculated from BiotaDC |

| | Target nuclide | Internal exposure dose conversion factor ((mGy/day)/(Bq/kg)) | | | Remarks |
|----|----------------|---|---------|---------------|---|
| | | Flatfish | Crab | Brown seaweed | |
| 32 | Te-129 | — | — | — | Contained in the parent nuclide Te-129m |
| 33 | Te-129m | 8.4E-06 | 8.6E-06 | 8.2E-06 | |
| 34 | I-129 | 1.0E-06 | 1.1E-06 | 1.0E-06 | |
| 35 | Cs-134 | 4.1E-06 | 4.8E-06 | 3.8E-06 | |
| 36 | Cs-135 | 1.2E-06 | 1.2E-06 | 1.2E-06 | |
| 37 | Cs-136 | 4.3E-06 | 5.3E-06 | 4.1E-06 | |
| 38 | Cs-137 | 4.1E-06 | 4.3E-06 | 4.1E-06 | |
| 39 | Ba-137m | — | — | — | Contained in the parent nuclide Cs-137 |
| 40 | Ba-140 | 1.4E-05 | 1.5E-05 | 1.4E-05 | |
| 41 | Ce-141 | 2.4E-06 | 2.6E-06 | 2.4E-06 | |
| 42 | Ce-144 | 1.6E-05 | 1.7E-05 | 1.6E-05 | |
| 43 | Pr-144 | — | — | — | Contained in the parent nuclide Ce-144 |
| 44 | Pr-144m | — | — | — | Contained in the parent nuclide Ce-144 |
| 45 | Pm-146 | 2.3E-06 | 2.6E-06 | 1.5E-06 | Calculated from BiotaDC |
| 46 | Pm-147 | 8.6E-07 | 8.6E-07 | 8.5E-07 | Calculated from BiotaDC |
| 47 | Pm-148 | 9.9E-06 | 1.1E-05 | 7.3E-06 | Calculated from BiotaDC |
| 48 | Pm-148m | 5.2E-06 | 6.1E-06 | 3.3E-06 | Calculated from BiotaDC |
| 49 | Sm-151 | 2.8E-07 | 2.8E-07 | 2.8E-07 | Calculated from BiotaDC |
| 50 | Eu-152 | 3.1E-06 | 3.6E-06 | 2.9E-06 | |
| 51 | Eu-154 | 5.0E-06 | 5.8E-06 | 5.0E-06 | |
| 52 | Eu-155 | 1.0E-06 | 1.0E-06 | 9.8E-07 | |
| 53 | Gd-153 | 8.5E-07 | 9.2E-07 | 7.0E-07 | Calculated from BiotaDC |
| 54 | Tb-160 | 4.8E-06 | 5.4E-06 | 3.7E-06 | Calculated from BiotaDC |
| 55 | Pu-238 | 7.7E-05 | 7.7E-05 | 7.7E-05 | |
| 56 | Pu-239 | 7.2E-05 | 7.2E-05 | 7.2E-05 | |
| 57 | Pu-240 | 7.2E-05 | 7.2E-05 | 7.2E-05 | |
| 58 | Pu-241 | 7.4E-08 | 7.4E-08 | 7.4E-08 | |
| 59 | Am-241 | 7.7E-05 | 7.7E-05 | 7.7E-05 | |
| 60 | Am-242m | 3.6E-06 | 3.6E-06 | 3.4E-06 | Calculated from BiotaDC |
| 61 | Am-243 | 7.9E-05 | 7.9E-05 | 7.8E-05 | Calculated from BiotaDC |
| 62 | Cm-242 | 8.6E-05 | 8.6E-05 | 8.6E-05 | |
| 63 | Cm-243 | 8.4E-05 | 8.4E-05 | 8.4E-05 | |

| | Target nuclide | Internal exposure dose conversion factor ((mGy/day)/(Bq/kg)) | | | Remarks |
|----|----------------|---|---------|---------------|---------|
| | | Flatfish | Crab | Brown seaweed | |
| 64 | Cm-244 | 8.2E-05 | 8.2E-05 | 8.2E-05 | |

Table 7-2-2 External exposure conversion factor to marine plants and animals

(ICRP Pub.136 and others are shown in remarks)

| | Target nuclide | External exposure dose conversion factor ((mGy/day)/(Bq/kg)) | | | Remarks |
|----|----------------|---|---------|---------------|--|
| | | Flatfish | Crab | Brown seaweed | |
| 1 | H-3 | 1.9E-14 | 2.4E-16 | 2.4E-16 | |
| 2 | C-14 | 4.3E-10 | 5.3E-10 | 5.3E-10 | |
| 3 | Mn-54 | 1.1E-05 | 1.0E-05 | 1.1E-05 | |
| 4 | Fe-59 | 1.5E-05 | 1.5E-05 | 1.6E-05 | Calculated from BiotaDC |
| 5 | Co-58 | 1.2E-05 | 1.2E-05 | 1.2E-05 | |
| 6 | Co-60 | 3.1E-05 | 3.1E-05 | 3.4E-05 | |
| 7 | Ni-63 | 2.6E-11 | 4.1E-11 | 4.1E-11 | |
| 8 | Zn-65 | 7.4E-06 | 7.2E-06 | 7.4E-06 | |
| 9 | Rb-86 | 1.7E-06 | 1.4E-06 | 3.7E-06 | Calculated from BiotaDC |
| 10 | Sr-89 | 3.6E-07 | 2.0E-07 | 4.1E-07 | |
| 11 | Sr-90 | 1.2E-06 | 5.5E-07 | 1.2E-06 | |
| 12 | Y-90 | — | — | — | Contained in the parent nuclide Sr-90 |
| 13 | Y-91 | 4.4E-07 | 2.5E-07 | 2.0E-06 | Calculated from BiotaDC |
| 14 | Nb-95 | 9.6E-06 | 9.4E-06 | 9.8E-06 | |
| 15 | Tc-99 | 3.1E-09 | 3.4E-09 | 3.6E-09 | |
| 16 | Ru-103 | 6.2E-06 | 6.0E-06 | 6.2E-06 | |
| 17 | Ru-106 | 5.3E-06 | 3.8E-06 | 5.3E-06 | |
| 18 | Rh-103m | — | — | — | Contained in the parent nuclide Ru-103 |
| 19 | Rh-106m | — | — | — | Contained in the parent nuclide Ru-106 |
| 20 | Ag-110m | 3.6E-05 | 3.4E-05 | 3.6E-05 | |
| 21 | Cd-113m | 1.7E-08 | 1.6E-08 | 1.4E-07 | Calculated from BiotaDC |
| 22 | Cd-115m | 8.2E-07 | 6.2E-07 | 2.4E-06 | Calculated from BiotaDC |
| 23 | Sn-119m | 1.0E-07 | 8.0E-08 | 1.7E-07 | Calculated from BiotaDC |
| 24 | Sn-123 | 3.7E-07 | 2.5E-07 | 1.6E-06 | Calculated from BiotaDC |

| | Target nuclide | External exposure dose conversion factor ((mGy/day)/(Bq/kg)) | | | Remarks |
|----|----------------|--|---------|---------------|--|
| | | Flatfish | Crab | Brown seaweed | |
| 25 | Sn-126 | 3.6E-05 | 3.4E-05 | 3.6E-05 | The value of Ag-110m is used because no value is given to this nuclide in the source |
| 26 | Sb-124 | 2.4E-05 | 2.3E-05 | 2.4E-05 | |
| 27 | Sb-125 | 5.5E-06 | 5.3E-06 | 5.5E-06 | |
| 28 | Te-123m | 1.8E-06 | 1.7E-06 | 2.0E-06 | Calculated from BiotaDC |
| 29 | Te-125m | 2.9E-07 | 2.4E-07 | 4.3E-07 | Calculated from BiotaDC |
| 30 | Te-127 | 8.9E-08 | 8.3E-08 | 2.9E-07 | Calculated from BiotaDC |
| 31 | Te-127m | 1.8E-07 | 1.6E-07 | 4.2E-07 | Calculated from BiotaDC |
| 32 | Te-129 | — | — | — | Contained in the parent nuclide Te-129m |
| 33 | Te-129m | 1.2E-06 | 1.1E-06 | 1.3E-06 | |
| 34 | I-129 | 2.2E-07 | 1.9E-07 | 2.4E-07 | |
| 35 | Cs-134 | 2.0E-05 | 1.9E-05 | 2.0E-05 | |
| 36 | Cs-135 | 2.2E-09 | 2.6E-09 | 2.6E-09 | |
| 37 | Cs-136 | 2.6E-05 | 2.6E-05 | 2.6E-05 | |
| 38 | Cs-137 | 7.2E-06 | 7.0E-06 | 7.2E-06 | |
| 39 | Ba-137m | — | — | — | Contained in the parent nuclide Cs-137 |
| 40 | Ba-140 | 3.1E-05 | 3.1E-05 | 3.4E-05 | |
| 41 | Ce-141 | 9.6E-07 | 9.1E-07 | 9.8E-07 | |
| 42 | Ce-144 | 2.6E-06 | 1.5E-06 | 2.6E-06 | |
| 43 | Pr-144 | — | — | — | Contained in the parent nuclide Ce-144 |
| 44 | Pr-144m | — | — | — | Contained in the parent nuclide Ce-144 |
| 45 | Pm-146 | 9.5E-06 | 9.1E-06 | 1.0E-05 | Calculated from BiotaDC |
| 46 | Pm-147 | 9.9E-10 | 1.1E-09 | 1.0E-08 | Calculated from BiotaDC |
| 47 | Pm-148 | 8.1E-06 | 7.5E-06 | 1.1E-05 | Calculated from BiotaDC |
| 48 | Pm-148m | 2.5E-05 | 2.4E-05 | 2.7E-05 | Calculated from BiotaDC |
| 49 | Sm-151 | 7.7E-11 | 8.4E-11 | 7.6E-10 | Calculated from BiotaDC |
| 50 | Eu-152 | 1.5E-05 | 1.4E-05 | 1.5E-05 | |
| 51 | Eu-154 | 1.6E-05 | 1.5E-05 | 1.6E-05 | |
| 52 | Eu-155 | 7.4E-07 | 7.0E-07 | 7.4E-07 | |
| 53 | Gd-153 | 1.2E-06 | 1.1E-06 | 1.4E-06 | Calculated from BiotaDC |
| 54 | Tb-160 | 1.4E-05 | 1.4E-05 | 1.5E-05 | Calculated from BiotaDC |

| | Target nuclide | External exposure dose conversion factor ((mGy/day)/(Bq/kg)) | | | Remarks |
|----|----------------|--|---------|---------------|-------------------------|
| | | Flatfish | Crab | Brown seaweed | |
| 55 | Pu-238 | 4.6E-09 | 3.8E-09 | 5.5E-09 | |
| 56 | Pu-239 | 2.6E-09 | 2.3E-09 | 3.1E-09 | |
| 57 | Pu-240 | 4.3E-09 | 3.6E-09 | 5.3E-09 | |
| 58 | Pu-241 | 1.9E-11 | 1.9E-11 | 2.0E-11 | |
| 59 | Am-241 | 2.9E-07 | 2.6E-07 | 2.9E-07 | |
| 60 | Am-242m | 2.4E-07 | 2.3E-07 | 4.2E-07 | Calculated from BiotaDC |
| 61 | Am-243 | 2.9E-06 | 2.8E-06 | 3.2E-06 | Calculated from BiotaDC |
| 62 | Cm-242 | 5.3E-09 | 4.3E-09 | 6.2E-09 | |
| 63 | Cm-243 | 1.6E-06 | 1.5E-06 | 1.6E-06 | |
| 64 | Cm-244 | 4.8E-09 | 3.8E-09 | 5.5E-09 | |

Table 7-2-3 Concentration ratio to marine plants and animals (ICRP Pub.114 and others, shown in remarks)

| | Target nuclide | Concentration ratio ((Bq/kg-f.w)/(Bq/L)) | | | Remarks |
|----|----------------|--|---------|---------------|---|
| | | Flatfish | Crab | Brown seaweed | |
| 1 | H-3 | 1.0E+00 | 1.0E+00 | 3.7E-01 | Excerpted from ICRP Pub.114 |
| 2 | C-14 | 1.2E+04 | 1.0E+04 | 8.0E+03 | Excerpted from ICRP Pub.114 |
| 3 | Mn-54 | 2.6E+03 | 4.5E+04 | 1.1E+04 | Excerpted from TRS-479 (fish and crab) Excerpted from ICRP Pub.114 (brown seaweed) |
| 4 | Fe-59 | 3.0E+04 | 5.0E+05 | 2.0E+04 | The concentration factor of TRS-422 is excerpted because it is not shown in ICRP Pub.114 or TRS-479 |
| 5 | Co-58 | 1.1E+04 | 5.5E+03 | 1.7E+03 | Excerpted from TRS-479 |
| 6 | Co-60 | 1.1E+04 | 5.5E+03 | 1.7E+03 | Excerpted from TRS-479 |
| 7 | Ni-63 | 2.7E+02 | 6.4E+03 | 2.0E+03 | Excerpted from TRS-479 |
| 8 | Zn-65 | 2.5E+04 | 3.0E+05 | 1.3E+04 | Excerpted from TRS-479 (fish) Excerpted from ICRP Pub.114 (crab and brown seaweed) |
| 9 | Rb-86 | 1.2E+02 | 6.3E+01 | 9.6E+01 | The value of congener Cs is used |
| 10 | Sr-89 | 4.4E+01 | 1.5E+02 | 4.3E+01 | Excerpted from TRS-479 |
| 11 | Sr-90 | 4.4E+01 | 1.5E+02 | 4.3E+01 | Excerpted from TRS-479 |
| 12 | Y-90 | - | - | - | Assessed with the parent nuclide Sr-90. |
| 13 | Y-91 | 2.0E+01 | 1.0E+03 | 1.0E+03 | The concentration factor of TRS-422 is excerpted because it is not shown in ICRP Pub.114 or TRS-479 |

| | Target nuclide | Concentration ratio ((Bq/kg-f.w)/(Bq/L)) | | | Remarks |
|----|----------------|--|---------|---------------|---|
| | | Flatfish | Crab | Brown seaweed | |
| 14 | Nb-95 | 3.0E+01 | 8.8E+02 | 4.9E+02 | Excerpted from ICRP Pub.114 (fish) Excerpted from TRS-479 (crab and brown seaweed) |
| 15 | Tc-99 | 8.0E+01 | 1.8E+04 | 5.3E+04 | Excerpted from ICRP Pub.114 (fish) Excerpted from TRS-479 (crab and brown seaweed) |
| 16 | Ru-103 | 2.9E+01 | 1.6E+03 | 1.2E+03 | Excerpted from TRS-479 |
| 17 | Ru-106 | 2.9E+01 | 1.6E+03 | 1.2E+03 | Excerpted from TRS-479 |
| 18 | Rh-103m | - | - | - | Assessed with the parent nuclide Ru-103 |
| 19 | Rh-106 | - | - | - | Assessed with the parent nuclide Ru-106 |
| 20 | Ag-110m | 1.1E+04 | 2.0E+05 | 3.9E+03 | Excerpted from TRS-479 (fish and brown seaweed) Excerpted from ICRP Pub.114 (crab) |
| 21 | Cd-113m | 2.9E+04 | 1.3E+05 | 1.6E+03 | Excerpted from TRS-479 (fish and crab) Excerpted from ICRP Pub.114 (brown seaweed) |
| 22 | Cd-115m | 2.9E+04 | 1.3E+05 | 1.6E+03 | Excerpted from TRS-479 (fish and crab) Excerpted from ICRP Pub.114 (brown seaweed) |
| 23 | Sn-119m | 5.0E+05 | 5.0E+05 | 2.0E+05 | The concentration factor of TRS-422 is excerpted because it is not shown in ICRP Pub.114 or TRS-479 |
| 24 | Sn-123 | 5.0E+05 | 5.0E+05 | 2.0E+05 | The concentration factor of TRS-422 is excerpted because it is not shown in ICRP Pub.114 or TRS-479 |
| 25 | Sn-126 | 5.0E+05 | 5.0E+05 | 2.0E+05 | The concentration factor of TRS-422 is excerpted because it is not shown in ICRP Pub.114 or TRS-479 |
| 26 | Sb-124 | 6.0E+02 | 4.7E+02 | 1.5E+03 | Excerpted from ICRP Pub.114 (fish and brown seaweed) Excerpted from TRS-479 (crab) |
| 27 | Sb-125 | 6.0E+02 | 4.7E+02 | 1.5E+03 | Excerpted from ICRP Pub.114 (fish and brown seaweed) Excerpted from TRS-479 (crab) |
| 28 | Te-123m | 1.0E+03 | 1.0E+03 | 1.0E+04 | Excerpted from ICRP Pub.114 |
| 29 | Te-125m | 1.0E+03 | 1.0E+03 | 1.0E+04 | Excerpted from ICRP Pub.114 |
| 30 | Te-127 | 1.0E+03 | 1.0E+03 | 1.0E+04 | Excerpted from ICRP Pub.114 |
| 31 | Te-127m | 1.0E+03 | 1.0E+03 | 1.0E+04 | Excerpted from ICRP Pub.114 |
| 32 | Te-129 | - | - | - | Assessed with the parent nuclide Te-129m |
| 33 | Te-129m | 1.0E+03 | 1.0E+03 | 1.0E+04 | Excerpted from ICRP Pub.114 |
| 34 | I-129 | 9.0E+00 | 8.8E+03 | 4.2E+03 | Excerpted from ICRP Pub.114 (fish) Excerpted from TRS-479 (crab and brown seaweed) |
| 35 | Cs-134 | 1.2E+02 | 6.3E+01 | 9.6E+01 | Excerpted from TRS-479 |
| 36 | Cs-135 | 1.2E+02 | 6.3E+01 | 9.6E+01 | Excerpted from TRS-479 |
| 37 | Cs-136 | 1.2E+02 | 6.3E+01 | 9.6E+01 | Excerpted from TRS-479 |
| 38 | Cs-137 | 1.2E+02 | 6.3E+01 | 9.6E+01 | Excerpted from TRS-479 |
| 39 | Ba-137m | - | - | - | Assessed with the parent nuclide Cs-137 |
| 40 | Ba-140 | 9.6E+00 | 8.0E+02 | 1.6E+03 | Excerpted from ICRP Pub.114 |
| 41 | Ce-141 | 3.9E+02 | 2.2E+03 | 2.1E+03 | Excerpted from TRS-479 |
| 42 | Ce-144 | 3.9E+02 | 2.2E+03 | 2.1E+03 | Excerpted from TRS-479 |

| | Target nuclide | Concentration ratio ((Bq/kg-f.w)/(Bq/L)) | | | Remarks |
|----|----------------|--|---------|---------------|--|
| | | Flatfish | Crab | Brown seaweed | |
| 43 | Pr-144 | - | - | - | Assessed with the parent nuclide Ce-144 |
| 44 | Pr-144m | - | - | - | Assessed with the parent nuclide Ce-144 |
| 45 | Pm-146 | 7.3E+02 | 2.4E+04 | 5.9E+03 | The value of congener Eu is used (fish and crab) The value of congener La is used (brown seaweed) |
| 46 | Pm-147 | 7.3E+02 | 2.4E+04 | 5.9E+03 | The value of congener Eu is used (fish and crab) The value of congener La is used (brown seaweed) |
| 47 | Pm-148 | 7.3E+02 | 2.4E+04 | 5.9E+03 | The value of congener Eu is used (fish and crab) The value of congener La is used (brown seaweed) |
| 48 | Pm-148m | 7.3E+02 | 2.4E+04 | 5.9E+03 | The value of congener Eu is used (fish and crab) The value of congener La is used (brown seaweed) |
| 49 | Sm-151 | 7.3E+02 | 2.4E+04 | 5.9E+03 | The value of congener Eu is used (fish and crab) The value of congener La is used (brown seaweed) |
| 50 | Eu-152 | 7.3E+02 | 2.4E+04 | 1.4E+03 | Excerpted from ICRP Pub.114 (fish and crab) Excerpted from TRS-479 (brown seaweed) |
| 51 | Eu-154 | 7.3E+02 | 2.4E+04 | 1.4E+03 | Excerpted from ICRP Pub.114 (fish and crab) Excerpted from TRS-479 (brown seaweed) |
| 52 | Eu-155 | 7.3E+02 | 2.4E+04 | 1.4E+03 | Excerpted from ICRP Pub.114 (fish and crab) Excerpted from TRS-479 (brown seaweed) |
| 53 | Gd-153 | 7.3E+02 | 2.4E+04 | 5.9E+03 | The value of congener Eu is used (fish and crab) The value of congener La is used (brown seaweed) |
| 54 | Tb-160 | 6.0E+01 | 4.0E+03 | 2.0E+03 | The concentration factor of TRS-422 is excerpted because it is not shown in ICRP Pub.114 or TRS-479 |
| 55 | Pu-238 | 2.5E+03 | 1.7E+03 | 4.1E+03 | Excerpted from TRS-479 |
| 56 | Pu-239 | 2.5E+03 | 1.7E+03 | 4.1E+03 | Excerpted from TRS-479 |
| 57 | Pu-240 | 2.5E+03 | 1.7E+03 | 4.1E+03 | Excerpted from TRS-479 |
| 58 | Pu-241 | 2.5E+03 | 1.7E+03 | 4.1E+03 | Excerpted from TRS-479 |
| 59 | Am-241 | 3.2E+02 | 9.9E+03 | 4.3E+02 | Excerpted from TRS-479 |
| 60 | Am-242m | 3.2E+02 | 9.9E+03 | 4.3E+02 | Excerpted from TRS-479 |
| 61 | Am-243 | 3.2E+02 | 9.9E+03 | 4.3E+02 | Excerpted from TRS-479 |
| 62 | Cm-242 | 1.9E+02 | 3.2E+04 | 1.2E+04 | Excerpted from ICRP Pub.114 (fish) Excerpted from TRS-479 (crab and brown seaweed) |
| 63 | Cm-243 | 1.9E+02 | 3.2E+04 | 1.2E+04 | Excerpted from ICRP Pub.114 (fish) Excerpted from TRS-479 (crab and brown seaweed) |
| 64 | Cm-244 | 1.9E+02 | 3.2E+04 | 1.2E+04 | Excerpted from ICRP Pub.114 (fish) Excerpted from TRS-479 (crab and brown seaweed) |

Table 7-2-4 Concentration distribution coefficient of the seawater and seabed sediment (TRS-422 and others are shown in remarks)

| | Target nuclide | Concentration distribution coefficient ((Bq/kg)/(Bq/L)) | Remarks |
|----|----------------|---|--|
| 1 | H-3 | 1.0E+00 | |
| 2 | C-14 | 1.0E+03 | |
| 3 | Mn-54 | 2.0E+06 | |
| 4 | Fe-59 | 3.0E+08 | |
| 5 | Co-58 | 3.0E+05 | |
| 6 | Co-60 | 3.0E+05 | |
| 7 | Ni-63 | 2.0E+04 | |
| 8 | Zn-65 | 7.0E+04 | |
| 9 | Rb-86 | 4.0E+03 | The value of congener Cs is used because no value is given to this nuclide in the source |
| 10 | Sr-89 | 8.0E+00 | |
| 11 | Sr-90 | 8.0E+00 | |
| 12 | Y-90 | - | Assessed with the parent nuclide Sr-90 |
| 13 | Y-91 | 9.0E+05 | |
| 14 | Nb-95 | 8.0E+05 | |
| 15 | Tc-99 | 1.0E+02 | |
| 16 | Ru-103 | 4.0E+04 | |
| 17 | Ru-106 | 4.0E+04 | |
| 18 | Rh-103m | - | Assessed with the parent nuclide Ru-103 |
| 19 | Rh-106 | - | Assessed with the parent nuclide Ru-106 |
| 20 | Ag-110m | 1.0E+04 | |
| 21 | Cd-113m | 3.0E+04 | |
| 22 | Cd-115m | 3.0E+04 | |
| 23 | Sn-119m | 4.0E+06 | |
| 24 | Sn-123 | 4.0E+06 | |
| 25 | Sn-126 | 4.0E+06 | |
| 26 | Sb-124 | 2.0E+03 | |
| 27 | Sb-125 | 2.0E+03 | |
| 28 | Te-123m | 1.0E+03 | |
| 29 | Te-125m | 1.0E+03 | |
| 30 | Te-127 | 1.0E+03 | |
| 31 | Te-127m | 1.0E+03 | |
| 32 | Te-129 | - | Assessed with the parent nuclide Te-129m |
| 33 | Te-129m | 1.0E+03 | |
| 34 | I-129 | 7.0E+01 | |
| 35 | Cs-134 | 4.0E+03 | |
| 36 | Cs-135 | 4.0E+03 | |
| 37 | Cs-136 | 4.0E+03 | |

| | Target nuclide | Concentration distribution coefficient ((Bq/kg)/(Bq/L)) | Remarks |
|----|----------------|---|---|
| 38 | Cs-137 | 4.0E+03 | |
| 39 | Ba-137m | - | Assessed with the parent nuclide Cs-137 |
| 40 | Ba-140 | 2.0E+03 | |
| 41 | Ce-141 | 3.0E+06 | |
| 42 | Ce-144 | 3.0E+06 | |
| 43 | Pr-144 | - | Assessed with the parent nuclide Ce-144 |
| 44 | Pr-144m | - | Assessed with the parent nuclide Ce-144 |
| 45 | Pm-146 | 2.0E+06 | |
| 46 | Pm-147 | 2.0E+06 | |
| 47 | Pm-148 | 2.0E+06 | |
| 48 | Pm-148m | 2.0E+06 | |
| 49 | Sm-151 | 3.0E+06 | |
| 50 | Eu-152 | 2.0E+06 | |
| 51 | Eu-154 | 2.0E+06 | |
| 52 | Eu-155 | 2.0E+06 | |
| 53 | Gd-153 | 2.0E+06 | |
| 54 | Tb-160 | 2.0E+06 | |
| 55 | Pu-238 | 1.0E+05 | |
| 56 | Pu-239 | 1.0E+05 | |
| 57 | Pu-240 | 1.0E+05 | |
| 58 | Pu-241 | 1.0E+05 | |
| 59 | Am-241 | 2.0E+06 | |
| 60 | Am-242m | 2.0E+06 | |
| 61 | Am-243 | 2.0E+06 | |
| 62 | Cm-242 | 2.0E+06 | |
| 63 | Cm-243 | 2.0E+06 | |
| 64 | Cm-244 | 2.0E+06 | |

7-3. Assessment result

7-3-1. Concentration in the seawater used for the assessment

As with the human protection assessment, the concentration in the seawater used for the exposure assessment of each nuclide was calculated by proportion calculation with the calculation result of advection and diffusion of tritium and the annual discharge amount of each nuclide. Here the concentration of the bottom layer is used because the impact of seabed sediment is considered in the exposure assessment.

Table 7-3-1 shows the concentration of tritium in the seawater in the bottom layer within 10 km × 10 km around the FDNPS (annual discharge amount) in the case of the annual discharge amount of 22 TBq (2.2E+13Bq) of tritium. The concentration for the assessment is the concentration based on the 2019 meteorological and oceanographic data as with the human exposure assessment.

Tables 7-3-2 to 4 show this result, and the concentration in the seawater used for the exposure assessment of each nuclide calculated from the source terms shown in Tables 6-1-1 to 3.

Table 7-3-1 Tritium concentration in the seawater in the case of the annual tritium discharge amount of 2.2E+13Bq

| Assessment point | Depth | Calculation result (Bq/L) | | | Concentration for assessment (Bq/L) |
|---|--------------|--|--|----------------|-------------------------------------|
| | | 2014 Meteorological and oceanographic data | 2019 Meteorological and oceanographic data | Difference (%) | |
| Average concentration within 10 km × 10 km around the FDNPS | Bottom layer | 5.0E-02 | 6.0E-02 | 19 | 6.0E-02 |

Table 7-3-2 Concentration in the seawater used for the assessment (Source term based on the composition of nuclides in the K4 tank group)

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| H-3 | 2.2E+13 | 6.0E-02 |
| C-14 | 1.7E+09 | 4.7E-06 |
| Mn-54 | 7.8E+05 | 2.1E-09 |
| Fe-59 | 2.0E+06 | 5.4E-09 |
| Co-58 | 9.3E+05 | 2.5E-09 |
| Co-60 | 5.1E+07 | 1.4E-07 |
| Ni-63 | 2.5E+08 | 6.9E-07 |
| Zn-65 | 1.7E+06 | 4.7E-09 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| Rb-86 | 2.2E+07 | 6.0E-08 |
| Sr-89 | 1.2E+07 | 3.2E-08 |
| Sr-90 | 2.5E+07 | 6.9E-08 |
| Y-90 | 2.5E+07 | 6.9E-08 |
| Y-91 | 2.5E+08 | 6.9E-07 |
| Nb-95 | 1.2E+06 | 3.2E-09 |
| Tc-99 | 8.1E+07 | 2.2E-07 |
| Ru-103 | 1.2E+06 | 3.2E-09 |
| Ru-106 | 1.9E+08 | 5.1E-07 |
| Rh-103m | 1.2E+06 | 3.2E-09 |
| Rh-106 | 1.9E+08 | 5.1E-07 |
| Ag-110m | 6.5E+05 | 1.8E-09 |
| Cd-113m | 2.1E+06 | 5.7E-09 |
| Cd-115m | 7.4E+07 | 2.0E-07 |
| Sn-119m | 2.0E+07 | 5.4E-08 |
| Sn-123 | 1.4E+08 | 3.8E-07 |
| Sn-126 | 3.1E+06 | 8.5E-09 |
| Sb-124 | 1.1E+06 | 3.0E-09 |
| Sb-125 | 3.8E+07 | 1.0E-07 |
| Te-123m | 1.1E+06 | 2.9E-09 |
| Te-125m | 3.8E+07 | 1.0E-07 |
| Te-127 | 3.7E+07 | 1.0E-07 |
| Te-127m | 3.7E+07 | 1.0E-07 |
| Te-129 | 9.4E+06 | 2.6E-08 |
| Te-129m | 3.7E+07 | 1.0E-07 |
| I-129 | 2.4E+08 | 6.6E-07 |
| Cs-134 | 5.2E+06 | 1.4E-08 |
| Cs-135 | 2.9E+02 | 7.9E-13 |
| Cs-136 | 3.5E+06 | 9.5E-09 |
| Cs-137 | 4.9E+07 | 1.3E-07 |
| Ba-137m | 4.9E+07 | 1.3E-07 |
| Ba-140 | 1.1E+07 | 3.0E-08 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km x 10 km) |
|----------------------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| Ce-141 | 2.9E+06 | 7.9E-09 |
| Ce-144 | 7.3E+06 | 2.0E-08 |
| Pr-144 | 7.3E+06 | 2.0E-08 |
| Pr-144m | 7.3E+06 | 2.0E-08 |
| Pm-146 | 1.1E+07 | 3.1E-08 |
| Pm-147 | 2.2E+07 | 6.0E-08 |
| Pm-148 | 5.8E+07 | 1.6E-07 |
| Pm-148m | 9.7E+05 | 2.7E-09 |
| Sm-151 | 1.0E+05 | 2.8E-10 |
| Eu-152 | 3.2E+06 | 8.8E-09 |
| Eu-154 | 1.4E+06 | 3.8E-09 |
| Eu-155 | 3.8E+06 | 1.0E-08 |
| Gd-153 | 3.7E+06 | 1.0E-08 |
| Tb-160 | 3.2E+06 | 8.8E-09 |
| Pu-238 | 7.3E+04 | 2.0E-10 |
| Pu-239 | 7.3E+04 | 2.0E-10 |
| Pu-240 | 7.3E+04 | 2.0E-10 |
| Pu-241 | 3.2E+06 | 8.8E-09 |
| Am-241 | 7.3E+04 | 2.0E-10 |
| Am-242m | 4.5E+03 | 1.2E-11 |
| Am-243 | 7.3E+04 | 2.0E-10 |
| Cm-242 | 7.3E+04 | 2.0E-10 |
| Cm-243 | 7.3E+04 | 2.0E-10 |
| Cm-244 | 7.3E+04 | 2.0E-10 |
| Target exposure assessment | | Environmental protection |

Table 7-3-3 Concentration in the seawater used for the assessment (Source term based on the composition of nuclides in the J1-C tank group)

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| H-3 | 2.2E+13 | 6.0E-02 |
| C-14 | 4.8E+08 | 1.3E-06 |
| Mn-54 | 1.0E+06 | 2.8E-09 |
| Fe-59 | 2.3E+06 | 6.4E-09 |
| Co-58 | 1.1E+06 | 3.0E-09 |
| Co-60 | 8.9E+06 | 2.4E-08 |
| Ni-63 | 2.3E+08 | 6.2E-07 |
| Zn-65 | 2.5E+06 | 6.9E-09 |
| Rb-86 | 1.3E+07 | 3.7E-08 |
| Sr-89 | 1.4E+06 | 4.0E-09 |
| Sr-90 | 9.7E+05 | 2.6E-09 |
| Y-90 | 9.7E+05 | 2.6E-09 |
| Y-91 | 4.6E+08 | 1.2E-06 |
| Nb-95 | 1.3E+06 | 3.7E-09 |
| Tc-99 | 3.2E+07 | 8.8E-08 |
| Ru-103 | 1.4E+06 | 3.9E-09 |
| Ru-106 | 3.8E+07 | 1.0E-07 |
| Rh-103m | 1.4E+06 | 3.9E-09 |
| Rh-106 | 3.8E+07 | 1.0E-07 |
| Ag-110m | 1.2E+06 | 3.1E-09 |
| Cd-113m | 2.3E+06 | 6.2E-09 |
| Cd-115m | 7.2E+07 | 2.0E-07 |
| Sn-119m | 1.1E+09 | 3.1E-06 |
| Sn-123 | 1.8E+08 | 4.8E-07 |
| Sn-126 | 7.8E+06 | 2.1E-08 |
| Sb-124 | 2.6E+06 | 7.1E-09 |
| Sb-125 | 6.2E+06 | 1.7E-08 |
| Te-123m | 2.5E+06 | 6.7E-09 |
| Te-125m | 6.2E+06 | 1.7E-08 |
| Te-127 | 1.3E+08 | 3.4E-07 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| Te-127m | 1.3E+08 | 3.6E-07 |
| Te-129 | 1.7E+07 | 4.5E-08 |
| Te-129m | 3.8E+07 | 1.0E-07 |
| I-129 | 3.2E+07 | 8.8E-08 |
| Cs-134 | 2.0E+06 | 5.6E-09 |
| Cs-135 | 3.2E+01 | 8.8E-14 |
| Cs-136 | 1.3E+06 | 3.4E-09 |
| Cs-137 | 5.1E+06 | 1.4E-08 |
| Ba-137m | 5.1E+06 | 1.4E-08 |
| Ba-140 | 5.4E+06 | 1.5E-08 |
| Ce-141 | 7.0E+06 | 1.9E-08 |
| Ce-144 | 1.5E+07 | 4.2E-08 |
| Pr-144 | 1.5E+07 | 4.2E-08 |
| Pr-144m | 1.5E+07 | 4.2E-08 |
| Pm-146 | 1.8E+06 | 4.9E-09 |
| Pm-147 | 2.1E+07 | 5.9E-08 |
| Pm-148 | 6.2E+06 | 1.7E-08 |
| Pm-148m | 1.3E+06 | 3.5E-09 |
| Sm-151 | 3.0E+05 | 8.0E-10 |
| Eu-152 | 7.5E+06 | 2.0E-08 |
| Eu-154 | 3.0E+06 | 8.0E-09 |
| Eu-155 | 9.1E+06 | 2.5E-08 |
| Gd-153 | 7.0E+06 | 1.9E-08 |
| Tb-160 | 3.8E+06 | 1.0E-08 |
| Pu-238 | 8.9E+05 | 2.4E-09 |
| Pu-239 | 8.9E+05 | 2.4E-09 |
| Pu-240 | 8.9E+05 | 2.4E-09 |
| Pu-241 | 3.2E+07 | 8.8E-08 |
| Am-241 | 8.9E+05 | 2.4E-09 |
| Am-242m | 1.6E+04 | 4.3E-11 |
| Am-243 | 8.9E+05 | 2.4E-09 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| Cm-242 | 8.9E+05 | 2.4E-09 |
| Cm-243 | 8.9E+05 | 2.4E-09 |
| Cm-244 | 8.9E+05 | 2.4E-09 |
| Target exposure assessment | | Environmental protection |

Table 7-3-4 Concentration in the seawater used for the assessment (Source term based on the composition of nuclides in the J1-G tank group)

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| H-3 | 2.2E+13 | 6.0E-02 |
| C-14 | 1.3E+09 | 3.6E-06 |
| Mn-54 | 3.1E+06 | 8.4E-09 |
| Fe-59 | 5.9E+06 | 1.6E-08 |
| Co-58 | 3.0E+06 | 8.2E-09 |
| Co-60 | 1.9E+07 | 5.1E-08 |
| Ni-63 | 7.2E+08 | 2.0E-06 |
| Zn-65 | 6.5E+06 | 1.8E-08 |
| Rb-86 | 3.8E+07 | 1.0E-07 |
| Sr-89 | 3.7E+06 | 1.0E-08 |
| Sr-90 | 2.6E+06 | 7.1E-09 |
| Y-90 | 2.6E+06 | 7.1E-09 |
| Y-91 | 9.8E+08 | 2.7E-06 |
| Nb-95 | 3.8E+06 | 1.0E-08 |
| Tc-99 | 1.1E+08 | 2.9E-07 |
| Ru-103 | 4.2E+06 | 1.1E-08 |
| Ru-106 | 3.9E+07 | 1.1E-07 |
| Rh-103m | 4.2E+06 | 1.1E-08 |
| Rh-106 | 3.9E+07 | 1.1E-07 |
| Ag-110m | 3.3E+06 | 8.9E-09 |
| Cd-113m | 7.0E+06 | 1.9E-08 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| Cd-115m | 1.9E+08 | 5.1E-07 |
| Sn-119m | 3.3E+09 | 8.9E-06 |
| Sn-123 | 5.1E+08 | 1.4E-06 |
| Sn-126 | 1.2E+07 | 3.3E-08 |
| Sb-124 | 6.8E+06 | 1.9E-08 |
| Sb-125 | 1.1E+07 | 3.1E-08 |
| Te-123m | 5.5E+06 | 1.5E-08 |
| Te-125m | 1.1E+07 | 3.1E-08 |
| Te-127 | 3.5E+08 | 9.6E-07 |
| Te-127m | 3.7E+08 | 1.0E-06 |
| Te-129 | 4.8E+07 | 1.3E-07 |
| Te-129m | 9.8E+07 | 2.7E-07 |
| I-129 | 2.7E+07 | 7.3E-08 |
| Cs-134 | 5.5E+06 | 1.5E-08 |
| Cs-135 | 1.7E+02 | 4.7E-13 |
| Cs-136 | 2.9E+06 | 8.0E-09 |
| Cs-137 | 2.7E+07 | 7.3E-08 |
| Ba-137m | 2.7E+07 | 7.3E-08 |
| Ba-140 | 1.4E+07 | 3.8E-08 |
| Ce-141 | 9.8E+06 | 2.7E-08 |
| Ce-144 | 4.5E+07 | 1.2E-07 |
| Pr-144 | 4.5E+07 | 1.2E-07 |
| Pr-144m | 4.5E+07 | 1.2E-07 |
| Pm-146 | 5.1E+06 | 1.4E-08 |
| Pm-147 | 5.9E+07 | 1.6E-07 |
| Pm-148 | 3.7E+07 | 1.0E-07 |
| Pm-148m | 3.3E+06 | 9.1E-09 |
| Sm-151 | 8.1E+05 | 2.2E-09 |
| Eu-152 | 1.5E+07 | 4.2E-08 |
| Eu-154 | 8.1E+06 | 2.2E-08 |
| Eu-155 | 1.5E+07 | 4.0E-08 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) |
|----------------------------|------------------------------|--|
| | | Average concentration of the bottom layer (Bq/L) |
| Gd-153 | 1.5E+07 | 4.2E-08 |
| Tb-160 | 1.1E+07 | 3.1E-08 |
| Pu-238 | 2.3E+06 | 6.2E-09 |
| Pu-239 | 2.3E+06 | 6.2E-09 |
| Pu-240 | 2.3E+06 | 6.2E-09 |
| Pu-241 | 8.1E+07 | 2.2E-07 |
| Am-241 | 2.3E+06 | 6.2E-09 |
| Am-242m | 4.2E+04 | 1.1E-10 |
| Am-243 | 2.3E+06 | 6.2E-09 |
| Cm-242 | 2.3E+06 | 6.2E-09 |
| Cm-243 | 2.3E+06 | 6.2E-09 |
| Cm-244 | 2.3E+06 | 6.2E-09 |
| Target exposure assessment | | Environmental protection |

7-3-2. Exposure assessment result

Table 7-3-5 shows the result of the exposure assessment of reference plants and animals. All results are low dose rates that are lower than 1/10,000 of the minimum limit value of the derived consideration reference level.

Table 7-3-5 Assessment result regarding environmental protection

| Assessed case | | Source term based on measured values | | |
|--|---------------|--------------------------------------|---------------------|----------------------|
| | | i. K4 tank group | ii. J1-C tank group | iii. J1-G tank group |
| Exposure (mGy/day) | Flatfish | 2E-05 | 2E-05 | 6E-05 |
| | Crab | 2E-05 | 2E-05 | 6E-05 |
| | Brown seaweed | 2E-05 | 2E-05 | 6E-05 |
| Derived consideration reference level (DCRL) [29] Flatfish: 1-10 mGy/day Crab: 10-100 mGy/day Brown seaweed: 1-10 mGy/day | | | | |

8. Discussion about the uncertainty of the assessment

This assessment was performed adding various data related to the disposal plan of ALPS treated water, assumptions of the exposure assessment, etc., to the assessment model including parameters created from obtained findings, etc. The assessment model including these parameters, the data, the set assumptions, etc., include uncertainty. So does the assessment result.

Generally, the uncertainty is roughly divided into (1) aleatory uncertainty (or variability) and (2) epistemic uncertainty. "Aleatory uncertainty (or variability)" is uncertainty caused by statistical distribution such as initial variation in data, and cannot be reduced even if data and knowledge to be obtained in the future are considered. "Epistemic uncertainty" is uncertainty due to lack of knowledge, though there is considered to be the one and only state.

The following shows the result of consideration of the degree of uncertainty referring to the result of simulation performed in each assessment process for each type, etc.

8-1. Uncertainty included in the selection of the source term

The following items are examples of uncertainty of the source term.

8-1-1. Uncertainty of the composition of nuclide (epistemic uncertainty)

The treated water to be purified in storage is planned to be subject to secondary treatment by ALPS, etc., and the composition of nuclides is unknown until measurement is performed after secondary treatment. Though it is guaranteed that the sum of the ratios to regulatory concentrations limits is less than 1, the composition of nuclides depends on various factors such as the composition and concentration of radioactive materials at the ALPS inlet at the time of treatment, the stage of the adsorbent in the ALPS adsorption vessel in the performance life period at the time of treatment, etc. The same applies to the contaminated water generated in the future.

Among the exposure assessment value by three source terms, there is about a five-fold difference between the source terms based on the K4 and J1-G tank groups. Since the difference in the tritium concentration is not large, this difference is mainly caused by the difference in the composition of nuclides, but the assessment is designed conservatively assuming that undetected nuclides including short-half-life radionuclides are included at their minimum limit values of detection and 70% or more of the uncertainty of the source term is due to the undetected nuclides as shown in Attachment IX "Contribution to the undetected nuclides in the source term based on the measured value," so the main cause of the uncertainty of the source term is considered to be the difference in the detection limit.

On the other hand, the sum of the ratios to regulatory concentrations limits of the composition of nuclides in the three tanks is about 0.3 and the sum of the ratios to regulatory concentrations limits of the composition of the nuclides of the J1-G tank group with the highest exposure assessment value is 0.22. The limit value in discharge control is the sum of the ratios to regulatory concentrations limits of less than 1, so if ALPS treated water in which the sum of the ratios to regulatory concentrations limits is close to 1, exposure may become 4 to 5 times larger.

If the tritium concentration in ALPS treated water is low, the discharge volume of water instead increases, so there is uncertainty due to the tritium concentration that exposure increases due to an increase in the discharge amount of nuclides other than tritium, but the discharge volume of water is limited to up to 500 m³/day and the annual discharge volume of water is 1.5E+08L (capacity factor: 80%), which is just 1.25 times larger than that of the K4 tank group (annual discharge volume of water: 1.2E+08L) and about 2 times larger than the J1-G tank group (annual discharge volume of water: 8.1E+07L).

8-1-2. Uncertainty of analysis (aleatory uncertainty)

The compositions of nuclides of the three tank groups used for the setting of the source term includes uncertainty of analysis. To verify the impact of the uncertainty of analysis on the exposure assessment value, we applied the expanded uncertainty calculated from the analysis result of the J1-C tank group to the measurement result of the J1-G tank group with a high exposure assessment value for the normal exposure assessment. Table 8-1 shows the composition of nuclides considering expanded uncertainty in the composition of nuclides of the J1-G tank group. Table 8-2 shows the concentration in the seawater used for the set source term and assessment. Table 8-3 shows the exposure assessment result.

The exposure assessment result of the source term considering the uncertainty of analysis is about 1.5 times larger than that not considering the uncertainty, so the uncertainty of the exposure assessment due to the uncertainty of the analysis is considered to be less than 2 times greater.

8-1-3. Summary of the uncertainty of the source term

As for the uncertainty of the source term, the difference due to the composition of nuclides of the tank group is about ± 5 -fold centering on the source term based on the J1-G group and the uncertainty of analysis is considered to be about ± 1.5 -fold.

Table 8-1 Composition of nuclides considering the uncertainty of detection for the composition of nuclides of the J1-G tank group

| Target nuclide | Regulatory concentration limit (Bq/L) | Composition of nuclides of the J1-G tank group (Bq/L) | Composition of nuclides of the J1-G tank group considering expanded uncertainty (Bq/L) | Ratio to regulatory concentration limit |
|----------------|---------------------------------------|---|--|---|
| H-3 | 6.0E+04 | 2.7E+05 | 2.7E+05 | - |
| C-14 | 2.0E+03 | 1.6E+01 | 2.0E+01 | 1.0E-02 |
| Mn-54 | 1.0E+03 | 3.8E-02 | 6.4E-02 | 6.4E-05 |
| Fe-59 | 4.0E+02 | 7.2E-02 | 1.2E-01 | 3.0E-04 |
| Co-58 | 1.0E+03 | 3.7E-02 | 6.2E-02 | 6.2E-05 |
| Co-60 | 2.0E+02 | 2.3E-01 | 2.7E-01 | 1.4E-03 |
| Ni-63 | 6.0E+03 | 8.8E+00 | 9.2E+00 | 1.5E-03 |
| Zn-65 | 2.0E+02 | 8.0E-02 | 1.3E-01 | 6.7E-04 |
| Rb-86 | 3.0E+02 | 4.7E-01 | 7.9E-01 | 2.6E-03 |
| Sr-89 | 3.0E+02 | 4.5E-02 | 5.3E-02 | 1.8E-04 |
| Sr-90 | 3.0E+01 | 3.2E-02 | 4.2E-02 | 1.4E-03 |
| Y-90 | 3.0E+02 | 3.2E-02 | 4.2E-02 | 1.4E-04 |
| Y-91 | 3.0E+02 | 1.2E+01 | 2.0E+01 | 6.6E-02 |
| Nb-95 | 1.0E+03 | 4.7E-02 | 7.9E-02 | 7.9E-05 |
| Tc-99 | 1.0E+03 | 1.3E+00 | 1.3E+00 | 1.3E-03 |
| Ru-103 | 1.0E+03 | 5.1E-02 | 8.6E-02 | 8.6E-05 |
| Ru-106 | 1.0E+02 | 4.8E-01 | 6.1E-01 | 6.1E-03 |
| Rh-103m | 2.0E+05 | 5.1E-02 | 8.6E-02 | 4.3E-07 |
| Rh-106 | 3.0E+05 | 4.8E-01 | 6.1E-01 | 2.0E-06 |
| Ag-110m | 3.0E+02 | 4.0E-02 | 6.7E-02 | 2.2E-04 |
| Cd-113m | 4.0E+01 | 8.6E-02 | 9.0E-02 | 2.2E-03 |
| Cd-115m | 3.0E+02 | 2.3E+00 | 4.5E+00 | 1.5E-02 |
| Sn-119m | 2.0E+03 | 4.0E+01 | 6.7E+01 | 3.4E-02 |
| Sn-123 | 4.0E+02 | 6.3E+00 | 1.1E+01 | 2.6E-02 |
| Sn-126 | 2.0E+02 | 1.5E-01 | 2.5E-01 | 1.3E-03 |
| Sb-124 | 3.0E+02 | 8.4E-02 | 1.4E-01 | 4.7E-04 |
| Sb-125 | 8.0E+02 | 1.4E-01 | 2.0E-01 | 2.5E-04 |
| Te-123m | 6.0E+02 | 6.7E-02 | 1.1E-01 | 1.9E-04 |
| Te-125m | 9.0E+02 | 1.4E-01 | 2.0E-01 | 2.2E-04 |
| Te-127 | 5.0E+03 | 4.3E+00 | 7.5E+00 | 1.5E-03 |

| Target nuclide | Regulatory concentration limit (Bq/L) | Composition of nuclides of the J1-G tank group (Bq/L) | Composition of nuclides of the J1-G tank group considering expanded uncertainty (Bq/L) | Ratio to regulatory concentration limit |
|----------------|---------------------------------------|---|--|---|
| Te-127m | 3.0E+02 | 4.5E+00 | 7.9E+00 | 2.6E-02 |
| Te-129 | 1.0E+04 | 5.9E-01 | 1.0E+00 | 1.0E-04 |
| Te-129m | 3.0E+02 | 1.2E+00 | 2.1E+00 | 7.1E-03 |
| I-129 | 9.0E+00 | 3.3E-01 | 3.8E-01 | 4.2E-02 |
| Cs-134 | 6.0E+01 | 6.7E-02 | 1.1E-01 | 1.9E-03 |
| Cs-135 | 6.0E+02 | 2.1E-06 | 2.6E-06 | 4.3E-09 |
| Cs-136 | 3.0E+02 | 3.6E-02 | 6.1E-02 | 2.0E-04 |
| Cs-137 | 9.0E+01 | 3.3E-01 | 4.0E-01 | 4.5E-03 |
| Ba-137m | 8.0E+05 | 3.3E-01 | 4.0E-01 | 5.0E-07 |
| Ba-140 | 3.0E+02 | 1.7E-01 | 2.9E-01 | 9.6E-04 |
| Ce-141 | 1.0E+03 | 1.2E-01 | 2.0E-01 | 2.0E-04 |
| Ce-144 | 2.0E+02 | 5.5E-01 | 9.4E-01 | 4.7E-03 |
| Pr-144 | 2.0E+04 | 5.5E-01 | 9.4E-01 | 4.7E-05 |
| Pr-144m | 4.0E+04 | 5.5E-01 | 9.4E-01 | 2.3E-05 |
| Pm-146 | 9.0E+02 | 6.3E-02 | 1.1E-01 | 1.2E-04 |
| Pm-147 | 3.0E+03 | 7.2E-01 | 1.2E+00 | 4.1E-04 |
| Pm-148 | 3.0E+02 | 4.5E-01 | 7.6E-01 | 2.5E-03 |
| Pm-148m | 5.0E+02 | 4.1E-02 | 6.9E-02 | 1.4E-04 |
| Sm-151 | 8.0E+03 | 1.0E-02 | 1.7E-02 | 2.1E-06 |
| Eu-152 | 6.0E+02 | 1.9E-01 | 3.2E-01 | 5.3E-04 |
| Eu-154 | 4.0E+02 | 1.0E-01 | 1.7E-01 | 4.3E-04 |
| Eu-155 | 3.0E+03 | 1.8E-01 | 3.0E-01 | 1.0E-04 |
| Gd-153 | 3.0E+03 | 1.9E-01 | 3.2E-01 | 1.1E-04 |
| Tb-160 | 5.0E+02 | 1.4E-01 | 2.4E-01 | 4.7E-04 |
| Pu-238 | 4.0E+00 | 2.8E-02 | 3.3E-02 | 8.4E-03 |
| Pu-239 | 4.0E+00 | 2.8E-02 | 3.3E-02 | 8.4E-03 |
| Pu-240 | 4.0E+00 | 2.8E-02 | 3.3E-02 | 8.4E-03 |
| Pu-241 | 2.0E+02 | 1.0E+00 | 1.2E+00 | 6.0E-03 |
| Am-241 | 5.0E+00 | 2.8E-02 | 3.3E-02 | 6.7E-03 |
| Am-242m | 5.0E+00 | 5.1E-04 | 6.1E-04 | 1.2E-04 |
| Am-243 | 5.0E+00 | 2.8E-02 | 3.3E-02 | 6.7E-03 |

| Target nuclide | Regulatory concentration limit (Bq/L) | Composition of nuclides of the J1-G tank group (Bq/L) | Composition of nuclides of the J1-G tank group considering expanded uncertainty (Bq/L) | Ratio to regulatory concentration limit |
|---|---------------------------------------|---|--|---|
| Cm-242 | 6.0E+01 | 2.8E-02 | 3.3E-02 | 5.6E-04 |
| Cm-243 | 6.0E+00 | 2.8E-02 | 3.3E-02 | 5.6E-03 |
| Cm-244 | 7.0E+00 | 2.8E-02 | 3.3E-02 | 4.8E-03 |
| Sum of the ratios to regulatory concentrations limits | | | | 3.2E-01 |

Table 8-2 Concentration in the seawater used for the assessment (Source term based on the composition of nuclides in the J1-G tank group reflecting the uncertainty of detection)

| Target nuclide | Source term (annual discharge amount) (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|--|--|---|--|
| | | Within 10 × 10 km Average of all layers | Within 10 × 10 km Average of the top layers | Beach assessment point Average of all layers |
| H-3 | 2.2E+13 | 5.6E-02 | 1.2E-01 | 9.0E-01 |
| C-14 | 6.1E+08 | 1.5E-06 | 3.3E-06 | 2.5E-05 |
| Mn-54 | 1.7E+06 | 4.4E-09 | 9.4E-09 | 7.0E-08 |
| Fe-59 | 3.9E+06 | 1.0E-08 | 2.1E-08 | 1.6E-07 |
| Co-58 | 1.9E+06 | 4.7E-09 | 1.0E-08 | 7.6E-08 |
| Co-60 | 1.0E+07 | 2.7E-08 | 5.7E-08 | 4.3E-07 |
| Ni-63 | 2.4E+08 | 6.1E-07 | 1.3E-06 | 9.7E-06 |
| Zn-65 | 4.2E+06 | 1.1E-08 | 2.3E-08 | 1.7E-07 |
| Rb-86 | 2.3E+07 | 5.7E-08 | 1.2E-07 | 9.2E-07 |
| Sr-89 | 1.7E+06 | 4.4E-09 | 9.3E-09 | 7.0E-08 |
| Sr-90 | 1.3E+06 | 3.2E-09 | 6.9E-09 | 5.2E-08 |
| Y-90 | 1.3E+06 | 3.2E-09 | 6.9E-09 | 5.2E-08 |
| Y-91 | 7.5E+08 | 1.9E-06 | 4.1E-06 | 3.1E-05 |
| Nb-95 | 2.3E+06 | 5.7E-09 | 1.2E-08 | 9.2E-08 |
| Tc-99 | 3.3E+07 | 8.3E-08 | 1.8E-07 | 1.3E-06 |
| Ru-103 | 2.4E+06 | 6.1E-09 | 1.3E-08 | 9.8E-08 |
| Ru-106 | 4.7E+07 | 1.2E-07 | 2.6E-07 | 1.9E-06 |
| Rh-103m | 2.4E+06 | 6.1E-09 | 1.3E-08 | 9.8E-08 |
| Rh-106 | 4.7E+07 | 1.2E-07 | 2.6E-07 | 1.9E-06 |
| Ag-110m | 1.9E+06 | 4.9E-09 | 1.1E-08 | 7.9E-08 |

| Target nuclide | Source term (annual discharge amount) (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|--|--|--|---|
| | | Within 10 × 10 km Average of all layers | Within 10 × 10 km Average of the top layers | Beach assessment point Average of all layers |
| Cd-113m | 2.4E+06 | 6.1E-09 | 1.3E-08 | 9.7E-08 |
| Cd-115m | 1.4E+08 | 3.6E-07 | 7.8E-07 | 5.8E-06 |
| Sn-119m | 1.9E+09 | 4.8E-06 | 1.0E-05 | 7.8E-05 |
| Sn-123 | 3.0E+08 | 7.6E-07 | 1.6E-06 | 1.2E-05 |
| Sn-126 | 1.3E+07 | 3.3E-08 | 7.2E-08 | 5.4E-07 |
| Sb-124 | 4.4E+06 | 1.1E-08 | 2.4E-08 | 1.8E-07 |
| Sb-125 | 8.9E+06 | 2.3E-08 | 4.8E-08 | 3.6E-07 |
| Te-123m | 4.2E+06 | 1.1E-08 | 2.3E-08 | 1.7E-07 |
| Te-125m | 8.9E+06 | 2.3E-08 | 4.8E-08 | 3.6E-07 |
| Te-127 | 2.2E+08 | 5.6E-07 | 1.2E-06 | 9.0E-06 |
| Te-127m | 2.3E+08 | 5.8E-07 | 1.3E-06 | 9.4E-06 |
| Te-129 | 6.7E+07 | 1.7E-07 | 3.7E-07 | 2.7E-06 |
| Te-129m | 6.7E+07 | 1.7E-07 | 3.7E-07 | 2.7E-06 |
| I-129 | 3.7E+07 | 9.4E-08 | 2.0E-07 | 1.5E-06 |
| Cs-134 | 3.4E+06 | 8.7E-09 | 1.9E-08 | 1.4E-07 |
| Cs-135 | 3.9E+01 | 1.0E-13 | 2.1E-13 | 1.6E-12 |
| Cs-136 | 2.1E+06 | 5.4E-09 | 1.2E-08 | 8.7E-08 |
| Cs-137 | 6.2E+06 | 1.6E-08 | 3.4E-08 | 2.5E-07 |
| Ba-137m | 6.2E+06 | 1.6E-08 | 3.4E-08 | 2.5E-07 |
| Ba-140 | 9.1E+06 | 2.3E-08 | 5.0E-08 | 3.7E-07 |
| Ce-141 | 1.2E+07 | 3.0E-08 | 6.4E-08 | 4.8E-07 |
| Ce-144 | 2.6E+07 | 6.6E-08 | 1.4E-07 | 1.1E-06 |
| Pr-144 | 2.6E+07 | 6.6E-08 | 1.4E-07 | 1.1E-06 |
| Pr-144m | 2.6E+07 | 6.6E-08 | 1.4E-07 | 1.1E-06 |
| Pm-146 | 3.0E+06 | 7.6E-09 | 1.6E-08 | 1.2E-07 |
| Pm-147 | 3.6E+07 | 9.3E-08 | 2.0E-07 | 1.5E-06 |
| Pm-148 | 1.0E+07 | 2.7E-08 | 5.7E-08 | 4.3E-07 |
| Pm-148m | 2.2E+06 | 5.5E-09 | 1.2E-08 | 8.9E-08 |
| Sm-151 | 5.0E+05 | 1.3E-09 | 2.7E-09 | 2.1E-08 |
| Eu-152 | 1.3E+07 | 3.2E-08 | 6.9E-08 | 5.2E-07 |
| Eu-154 | 5.0E+06 | 1.3E-08 | 2.7E-08 | 2.1E-07 |

| Target nuclide | Source term (annual discharge amount) (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------------------|--|--|--|---|
| | | Within 10 × 10 km Average of all layers | Within 10 × 10 km Average of the top layers | Beach assessment point Average of all layers |
| Eu-155 | 1.5E+07 | 3.9E-08 | 8.3E-08 | 6.3E-07 |
| Gd-153 | 1.2E+07 | 3.0E-08 | 6.4E-08 | 4.8E-07 |
| Tb-160 | 6.4E+06 | 1.6E-08 | 3.5E-08 | 2.6E-07 |
| Pu-238 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Pu-239 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Pu-240 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Pu-241 | 3.8E+07 | 9.8E-08 | 2.1E-07 | 1.6E-06 |
| Am-241 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Am-242m | 1.9E+04 | 4.8E-11 | 1.0E-10 | 7.7E-10 |
| Am-243 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Cm-242 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Cm-243 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Cm-244 | 1.1E+06 | 2.7E-09 | 5.8E-09 | 4.3E-08 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | During swimming From beach sand Ingestion of seawater Inhalation of seawater spray |

Table 8-3 Exposure assessment result based on the composition of nuclides in the J1-G tank group reflecting the uncertainty of detection (Assessment area: 10 km × 10 km)

| Assessed case | Source term | (1) Source term based on measured values | | | | | | (2) Source term considering the uncertainty of analysis (J1-G) | |
|------------------------------|----------------------|--|---------|---------------------|---------|----------------------|---------|--|---------|
| | | i. K4 tank group | | ii. J1-C tank group | | iii. J1-G tank group | | | |
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large | Average | Large |
| External exposure (mSv/year) | Sea surface | 6.5E-09 | | 1.7E-08 | | 4.7E-08 | | 8.0E-08 | |
| | Hull | 4.8E-09 | | 1.2E-08 | | 3.3E-08 | | 5.6E-08 | |
| | During swimming | 4.5E-09 | | 1.2E-08 | | 3.2E-08 | | 5.6E-08 | |
| | Beach sand | 7.8E-06 | | 2.1E-05 | | 5.6E-05 | | 9.7E-05 | |
| | Fishing net | 1.6E-06 | | 4.3E-06 | | 1.2E-05 | | 2.0E-05 | |
| Internal exposure (mSv/year) | Ingestion of water | 3.3E-07 | | 3.1E-07 | | 3.2E-07 | | 3.3E-07 | |
| | Inhalation of spray | 9.3E-08 | | 2.0E-07 | | 4.0E-07 | | 4.8E-07 | |
| | Ingestion of seafood | 1.5E-05 | 6.1E-05 | 2.8E-05 | 1.1E-04 | 7.9E-05 | 3.0E-04 | 1.3E-04 | 5.0E-04 |
| Total (mSv/year) | | 3E-05 | 7E-05 | 5E-05 | 1E-04 | 1E-04 | 4E-04 | 2E-04 | 6E-04 |

Table 8-4 Results of internal exposures assessment by age based on the composition of nuclides in the J1-G tank group reflecting the uncertainty of detection (Assessment area: 10 km × 10 km)

| Assessed case | Source term | (1) Source term based on measured values | | | | | | (2) Source term considering the uncertainty of analysis (J1-G) | |
|--|------------------------|--|---------|---------------------|---------|----------------------|---------|--|---------|
| | | i. K4 tank group | | ii. J1-C tank group | | iii. J1-G tank group | | | |
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large | Average | Large |
| Internal exposure from ingestion of water (mSv/year) | Adult | 3.3E-07 | | 3.1E-07 | | 3.2E-07 | | 3.2E-07 | |
| | Child under school age | 5.7E-07 | | 5.4E-07 | | 5.5E-07 | | 5.7E-07 | |
| | Infant | - | | - | | - | | - | |
| Internal exposure from inhalation of spray (mSv/year) | Adult | 9.3E-08 | | 2.0E-07 | | 4.0E-07 | | 4.7E-07 | |
| | Child under school age | 6.2E-08 | | 1.1E-07 | | 2.2E-07 | | 2.5E-07 | |
| | Infant | 4.0E-08 | | 6.5E-08 | | 1.2E-07 | | 1.3E-07 | |
| Internal exposure from ingestion of seafood (mSv/year) | Adult | 1.5E-05 | 6.1E-05 | 2.8E-05 | 1.1E-04 | 7.9E-05 | 3.0E-04 | 1.3E-04 | 5.0E-04 |
| | Child under school age | 2.4E-05 | 9.4E-05 | 5.1E-05 | 2.0E-04 | 1.5E-04 | 5.6E-04 | 2.4E-04 | 9.4E-04 |
| | Infant | 2.9E-05 | 1.1E-04 | 6.7E-05 | 2.5E-04 | 1.9E-04 | 7.1E-04 | 3.2E-04 | 1.2E-03 |

8-2. Uncertainty of modeling of diffusion and transfer in the environment

8-2-1. Uncertainty of meteorological and oceanographic data, etc. (aleatory uncertainty)

The diffusion simulation is considered to include uncertainty caused by variations such as the annual variations of meteorological and oceanographic data.

For this assessment, the meteorological and oceanographic data of 2014 to 2020 are used, but the biggest observed difference in the annual average concentration of 10 km × 10 km used for the assessment is up to about 20%. A document that simulated the diffusion of cesium using the same model to reproduce the monitoring results shows no difference in the shape of diffusion of each year and that the scale of uncertainty is not twice as great.

8-2-2. Uncertainty of the simulation model itself (epistemic uncertainty)

The diffusion simulation model does not reproduce all of the natural phenomena and scientific findings that the model is constructed based on is not complete. However, the model used this time has been verified by a reproduction calculation of the cesium concentration in the same sea area and the simulation result matches the measured value well. There could be a charge to verify this with another modeling to confirm the magnitude of uncertainty more accurately, but the uncertainty of the model itself is estimated to be not so great.

8-2-3. Uncertainty in the selection of migration pathways (epistemic uncertainty)

In the external exposure assessment, the external exposure from radioactive materials migrated to hulls, beach sand, and fishing nets are assessed. The factor of migration to hulls, beaches, and fishing nets are excerpted from domestic cases such as past guidelines, but not all data regarding the nuclides required for this assessment was obtained. The assessment was based on the data of limited nuclides.

Though there are few findings about these migration factors, the migration to sandy beaches can be assessed by the method of TECDOC-1759 (using the external exposure dose conversion factor of FGR15 issued by U.S. Environmental Protection Agency), so the exposure from sandy beaches was calculated and the result of this report was 20 to 200 or more times larger. However, it turned out that as the contribution to the overall exposure, the contribution of external exposure is smaller than internal exposure and the total exposure value does not differ so much from that of this report. Attachment XI "Conservativeness of the external exposure dose conversion factor" shows the details of the assessment result

using the external exposure dose conversion factor of FGR15 issued by U.S. Environmental Protection Agency.

8-2-4. Uncertainty in the concentration factor of seafood and the distribution coefficient of seabed sediment (epistemic uncertainty)

The concentration coefficient of fish, etc. used for internal exposure from ingestion of seafood shown in TRS-422 is calculated assuming that the concentration in the seawater and marine organisms are in the equilibrium state from the investigation results of the concentration in the seawater and fish, etc.

However, while the process of migration to organisms and seabed sediment takes much time, whereas movement of the seawater is fast, and it is uncertain whether they were in the equilibrium state at the time of the investigation. In addition, there are also great deal of variations depending on the type of fishes and seabed sediment, and survey locations, and TRS-422 indicates that insufficient reliable data are available to allow accurate assessments of ranges around a recommended value for most element–organism combinations. On the other hand, where a reliable database does exist for a given element and type of organism, in nearly every case the range of minimum and maximum CFs is one order of magnitude (or less) from the recommended value. Therefore, TRS-422 indicate that maximum and minimum CFs are one order of magnitude above and below the recommended value. This is same for the distribution coefficient of seabed sediment, where a range of values is required, maximum and minimum values could be assumed to be a factor of 10 higher and lower than the recommended value.

8-3. Uncertainty in the setting of exposure pathways

8-3-1. Uncertainty in the selection of exposure pathways (epistemic uncertainty)

The setting of exposure pathways may be insufficient. In TECDOC-1759, most of the pathways set as external exposure ones such as exposure from the sea surface and hulls in this assessment are not subject to the assessment, but pathways not set in this report such as ingestion of beach sediment, ingestion of seawater, and inhalation of seawater spray are picked up. As a result of a verification calculation of unselected pathways by the method of TECDOC-1759, pathways of which exposure assessment results exceeded the pathways selected in this report were found such as ingestion of seawater and inhalation of seawater spray, so they were added as pathways. However, the total value did not change because the impact of internal exposure from ingestion of seafood is great in the exposure assessment. For the result of the verification calculation., see Attachment VI “Transfer pathways and exposure pathways other than the assessment targets.” Please note that the difference from TECDOC-1759 is due to the inclusion of modeling of dispersion and transfer.

8-4. Uncertainty in the selection of the representative person

8-4-1. Uncertainty in the actual life of the representative person (aleatory uncertainty)

In this assessment, the life habit data of the critical group in the case of exposure simulation from domestic nuclear power plants is used. The latest data of the national health and nutrition survey is used for the ingestion of seafood, which has a slight annual variation of about 10 to 20%. However, considering this uncertainty, ingested fish assessed in this report is assumed to be consumed immediately after being caught in the area around the FDNPS without considering market dilution, decay of radioactive nuclides after catching, etc., so there is considered to be not uncertainty which may lead to underestimation.

8-4-2. Uncertainty in the selection of the representative pathway (epistemic uncertainty)

The area around the FDNPS is still in the middle of reconstruction: e.g. even now Difficult-to-Return Zones are set. It is still prohibited to live in Difficult-to-Return Zones. Even for the other zones, return of residents is very limited. Under such circumstances, it is very difficult to ascertain detailed life habits available for the setting of the representative person including the prediction of the future situation.

Therefore, in this assessment, the life habit data of the critical group used in the case of simulation of exposure from domestic nuclear power plants is used, but it includes uncertainty due to the difference from the actual life habits of residents in the surrounding area after reconstruction.

On the other hand, in this assessment, the reprocessing plant located in Aomori, which is also in Tohoku, applies the setting based on the social environment survey and the time of exposure from fishing nets is longer than that of this assessment, but it is less than two times longer. Moreover, the impact of external exposure is smaller than that of internal exposure from the ingestion of seafood, so there is no impact on the exposure assessment.

For the ingestion of seafood which affects the internal exposure result, nation-wide statistical data aggregated by age is used and about 10% different from the data of Tohoku. Fish and invertebrates (total of shellfish, cephalopods, and crustacea at reprocessing plant) of the reprocessing plant are 20 to 30% more and seaweeds of this report are 30% more, but the uncertainty of the food ingestion is unlikely to be two times greater and ingested fish assessed in this report is assumed to be consumed immediately after being caught in the area around the FDNPS without considering market dilution, decay of radioactive nuclides after catching, etc., so there is considered to be no uncertainty which may lead to underestimation.

8-4-3. Uncertainty depending on the range of the sea area to be assessed (epistemic uncertainty)

The further it is from the discharge outlet, the lower the concentration in the seawater becomes in the case of discharge of ALPS treated water, so there is uncertainty of variation of the concentration in the seawater used for the assessment depending on the scale of the range to be assessed.

To verify the impact due to the scale of the range to be assessed, we calculated the annual average concentration within 5 km × 5 km and 20 km × 10 km in addition to 10 km × 10 km and assessed exposure of human under normal conditions. The exposure assessment result of 20 km×10 km is about 20% lower than that of 10 km×10 km, but the difference was small. That of 5 km × 5 km was about 3 times higher than that of 10 km × 10 km. In reality, it is unlikely that fishing is performed only within 5 km×5 km around the FDNPS; and in this report, exposure is assessed assuming that only seafood caught in the assessed sea area but in reality, it is unlikely that only fish caught in the area around the FDNPS is ingested, so it is considered to be unnecessary to consider uncertainty about the range of the sea area. Attachment XII “Impact of the assessment range of concentrations in seawater used for the assessment of exposures” shows the result of the exposure assessment of 5 km × 5 km and 20 km × 10 km from the power station.

8-5. Summary about uncertainty

Table 8-5 summarizes these contents.

There is great uncertainty in the composition of nuclides in the source term and migration pathways such as the concentration factor of fish, but the exposure assessment result is sufficiently lower than the dose constraint and it is considered that the conservativeness of the assessment is not lost.

Table 8-5 Summary of uncertainty in this assessment

| Item | Details of uncertainty | Assessment of uncertainty |
|---|---|--|
| Selection of the source terms | The composition of nuclides of ALPS treated water is unknown until secondary treatment and measurement is completed, so it has epistemic uncertainty. | The exposure assessment result of the K4 tank group with a low detection limit in the source term based on the measured value is about 1/5 of the J1-G tank group with the highest one. On the other hand, the sum of ratios to regulatory concentration limit of the J1-G tank group is 0.22. If the sum of the ratios to regulatory concentration limit is 1 with the same nuclide ratio, exposure will be about 5 times greater. |
| | The measured value includes aleatory uncertainty based on uncertainty of analysis. | The impact of uncertainty of analysis seems to be less than double. |
| Modeling of diffusion and transfer in the environment | The meteorological and oceanographic data has annual variations and includes aleatory uncertainty. | We calculated the average concentration of 10 km × 10 km of 7 years and found a difference of about 20%. In the comparison with the measured value, the parts with high concentrations match well, so uncertainty is assumed to be less than two times greater in the calculation of the average calculation of 10 km × 10 km. |
| | The diffusion simulation model has epistemic uncertainty in the model itself. | |
| For the migration pathways | and the migration factor of external exposure, differences in elements are not considered, so the dose conversion factor of external exposure has epistemic uncertainty which does not cover all nuclides. | We calculated exposure from beaches from the method of TECDOC-1759 (using the external exposure dose conversion factor of FGR15) and it turned out that the result of the radiological impact assessment report was 20 to 200 or more times higher. Even so, the effect of external exposure on exposure is smaller than that of internal exposures, and the total exposure value does not differ so much from that of this report. |
| | The concentration factor of fish used for the internal exposure assessment from ingestion of seafood includes epistemic uncertainty due to insufficiency of data. | For the concentration factor, TRS-422 indicate that maximum and minimum CFs are one order of magnitude above and below the recommended value in the case of existence of reliable data for element–organism combination, and for the distribution coefficient, maximum and minimum values could be assumed to be a factor of 10 higher and lower than the recommended value. |
| Exposure pathways | There are epistemic uncertainties because the selected migration and exposure pathways do not cover all the pathways. | We calculated the unselected exposure pathways by the method of TECDOC-1759 and added pathways with higher exposure assessments than those of the selected pathways. However, the total value did not change because the impact of internal exposure from ingestion of seafood is great. |
| Selection of a representative person | The area around the FDNPS is undergoing reconstruction, so we used life habit data from domestic precedent cases. As a result, it includes epistemic uncertainty due to the difference in the actual life habits. The food ingestion is set from nationwide data and also includes epistemic uncertainty. | The external exposure time is shorter than that of the Rokkasho reprocessing plant, but it is smaller than internal exposure from ingestion of seafood and does not affect the exposure assessment result. For the ingestion of seafood which affects the internal exposure result, nation-wide statistical data aggregated by age is used and about 10% different from the data of Tohoku, but in the report, all ingested fish are assumed to have been caught in the area around the FDNPS in the assessment, so there is considered to be not uncertainty which may lead to underestimation. |
| | It includes epistemic uncertainty about the range of the appropriate area as the sea area to be assessed. | We assessed 5 km × 5 km, which is smaller, and 20 km × 10 km, which is larger, than 10 km × 10 km and it turned out that the exposure is about three times greater in the range of 5 km × 5 km and not much different in the range of 20 km × 20 km. Actually, it is unrealistic to perform fishing only within the range of 5 km × 5 km and the assessment in this report assumes that all ingested fish are caught in the area around the FDNPS, so it is considered to be unnecessary to consider uncertainty due to the setting of the assessed sea area. |

9. Monitoring to be performed in response to discharge of ALPS treated water into the sea

This section describes our analytical capabilities at the FDNPS as well as the plan of monitoring to be performed inside and outside the site in relation to the discharge of ALPS treated water of the FDNPS (as of the issuance of this revised report; to be revised as needed).

All of these enhance and expand the monitoring program which has been performed continuously since the accident at the FDNPS.

Through the monitoring activity in the site, we will ensure that ALPS treated water discharged into the environment is safe. Through the monitoring activity outside the site, we shall correctly ascertain the impact of discharge of ALPS treated water into the sea on the environment.

9-1. Analytical capability in the Fukushima Daiichi Nuclear Power Station

In the site of the FDNPS, the environment control building for environmental sample analysis and the Unit 5/6 analysis rooms (hot lab.) for analysis of samples with high activity concentration, which have been operated before the earthquake, are still in operation. In addition to these, we started the operation of the chemical analysis building for samples with low activity concentration for which measures to prevent contamination in the site and eliminate the impact of the environmental dose were performed in 2013. The analysis and measurement functions of the environment control building were terminated due to the contamination state of the facility and facility aging, and only the pretreatment function remains.

After the earthquake, initially we especially focused on handling of samples with high activity concentration in order to deal with the problem of contaminated water. However, in July 2013, when the chemical analysis building was completed and environmental samples were able to be analyzed, we started to develop human resources to analyze samples of which radioactive concentrations had been confirmed to be low such as the seawater. After that, as drainage of groundwater bypass water (hereinafter called "groundwater bypass") and treated water of the purification facilities such as the subdrain (hereinafter called "subdrain") to reduce the contaminated water generation, we have been expanding the training of workers for the Unit 5/6 analysis rooms and the chemical analysis building in parallel. For discharge of ALPS treated water into the sea, we will enhance and expand the analysis framework in terms of facilities and competence.

9-1-1. Analytical capability in terms of facilities

Since all analyses related to discharge of ALPS treated water into the sea are classified into analyses of samples with low activity concentration, it is planned to perform analyses and assessments using the facilities of the chemical analysis building. The layout arrangement, addition of analysis devices, etc., for the chemical analysis building shall be performed flexibly as needed. Table 9-1 shows the overview and functions of the analysis facilities in

the site of the FDNPS. Table 9-2 shows the overview of the analysis devices installed in the chemical analysis buildings.

Table 9-1 Overview and functions of the analysis facility

| Facility name | Function | Overview of the facility | Remarks |
|---|--|---|--|
| Environmental management building | Pretreatment (pretreatment of fish) | Analysis room + Measurement room: 480m ² Experimental table: 4 | <ul style="list-style-type: none"> ● Before the earthquake, we analyzed environmental samples but transferred the functions to the chemical analysis building and the Unit 5/6 analysis rooms after the earthquake ● The functions are limited to pretreatment |
| Units 5/6 analysis room | Analysis of samples with high activity concentration | Analysis room + Measurement room: 850m ² Experimental table: 23 Fume hood: 26 | <ul style="list-style-type: none"> ● Expanded the facility which had been operated since before the earthquake in 2016 |
| Chemical analysis building | Analysis of samples with low activity concentration | Analysis room + Measurement room: 1,000m ² Experimental table: 15 Fume hood: 35 | <ul style="list-style-type: none"> ● This facility was put into use in 2013. ● The analysis of ALPS treated water is planned to be performed here |
| Chemical analysis building (for expansion, planned) | Pretreatment operation and analysis of a sample of a low radioactive concentration | Analysis room + Measurement room: About 600 m ² [Facility proposal] Experimental table: 8 Fume hood: 21 Rotary evaporator: 5 Electrolytic condenser: 10 Lyophilizer: 6 H-3 -> He converter: 2 | <ul style="list-style-type: none"> ● The construction work is scheduled to be completed by the end of FY 2023. ● The number of analyzers, etc. may be changed in the future |

Table 9-2 Analyzers in the chemical analysis building (including those planned to be expanded in the future)

| Sample handled | Analyzer | Target nuclides to be measured | Number of units deployed |
|--|---|--|----------------------------------|
| Monitoring samples: seawater, etc. Drainage sample: Groundwater bypass and sub-drain ALPS outlet water: last stage etc. | Ge semiconductor detector | γ-ray emitting nuclides (e.g. Cs -134.137) | 12 |
| | Automatic α-measuring device | Total α | 2 |
| | Low back gas flow counter | Total β, Sr -90 | 5 |
| | β-nuclide analysis equipment | Sr-90 | 2 |
| | Low background liquid scintillation counter | Tritium, C -14 Cd-113 m, Ni-63 | 9 (Three more to be expanded) |
| | Inductively coupled plasma mass spectrometer (ICP-MS) | I-129, Tc-99 | 2 |
| | Noble gas mass spectrometer (He-MS) | Tritium | 2 (To be expanded) |
| High purity Ge semiconductor detector for low energy photons (LEPS) | Low-energy γ-ray emitting nuclide (including Sn-126) | 2 (To be expanded) | |

For the measuring instruments used for measurement, we verify the detection efficiency with the standard source and the standard solution as daily inspections at the start of work to maintain the device performance and measure samples. Table 9-3 shows the overview of

daily inspections of the measuring instruments installed in the FDNPS (verification of the detection efficiency).

Table 9-3 Verification of the detection efficiency in the daily inspection of measuring instruments

| Measuring instrument | Standard source | Confirmation method |
|--|-------------------------------------|---|
| Ge semiconductor detector | Co-57, Ba-133, Cs-137, Mn-54, Co-60 | Frequency: At the beginning of daily work Method: Obtain the detection efficiency for each nominal energy of the standard source and confirm that it is within the judgment value ($\pm 10\%$) Actions to be taken in case of deviation: The measured sample after the value judged last time is evaluated again, and the sample during the deviation period is measured if necessary |
| Automatic α-measuring device | Am-241 | |
| β-nuclide analysis equipment | Sr-90 Cs-137 | |
| Low background liquid scintillation counter | Tritium | |
| Inductively coupled plasma mass spectrometer (ICP-MS) | Li, Co, Y, Tl | Frequency: Each use Method: Measure the strength of each element. After checking the judged value or above, prepare a calibration curve before measurement. Strength of standard solution: Li: >1000 Co, Y: >200 Tl: >800 |

9-1-2. Analytical capability in terms of competence

The analysis work led by us shall be consigned to Tokyo Power Technology⁴³ (hereinafter called "TPT"). We shall formulate the plan for analysis and prepare resources suitable for the plan, supervise the work by TPT, judge the possibility of discharge based on the analysis result, manage and announce analysis data, etc.

Our employees who supervise analysis work shall have been certified to have skill levels sufficient for their roles through the on-site technique and skills certification system, and competence is secured in a planned manner by periodic competence assessments and effectiveness reviews.

On the other hand, TPT, which is the consignee of the analysis work, increases and secure competent analysts in order to maintain the capabilities to surely analyze the nuclides for which high skills are required (hereinafter called "difficult-to-measure nuclides") such as C-14. Moreover, to have objective confirmation of skills from the viewpoint of a third party, we shall participate in IAEA Proficiency Test Exercise⁴⁴ and continuously conduct crosschecking, etc., with analytical institutes inside Japan.

In the chemical analysis building, ISO/IEC-17025 certification⁴⁵ for Cs-134, Cs-137, and tritium has been acquired and maintained and it is planned to acquire certification for the Sr-

⁴³ We are a wholly owned subsidiary of Tokyo Electric Power Company Holdings, Inc. and have advantages in terms of design, construction, operation, and maintenance of electricity-related facilities including our company; environment investigation measurements and their assessments; investigations/analyses and measurements of substances, etc.; control of radioactive materials and radiation; decontamination in general; processing treatment/disposal of radioactive waste, etc.

⁴⁴ The IAEA prepares a sample with a known result for the test and provide it to each participating analysis institute. Then, each institute analyzes it and the IAEA compares the result with the components of the sample for the test to assess the accuracy of the analysis by each institute.

⁴⁵ Examining authority examine the ability of test places and correction organizations to authorize their capability.

90 analysis as well. In addition, the appropriateness of the data to be used for decision of discharge was confirmed by comparison with the analysis value of the third-party institute specified as the consignee by us. Table 9-4 shows the certification acquisition status by the certification institute for us (TPT) and each consignee analysis institute.


Table 9-4 Certification acquisition statuses of us (TPT) and consignee analysis institutes

| Organization | Certification | Acquisition status (17025) |
|--|-------------------------|---|
| TPT (Fukushima Daichi) | ISO/IEC17025 ISO9001 | (Chemical analysis building) Cs-134,Cs-137,H-3 |
| KAKEN Co.,Ltd. | ISO/IEC17025 | Cs-134,Cs-137 I-131 Sr-90 H-3 |
| Japan Chemical Analysis Center | ISO/IEC17025 ISO9001 | Gamma-emitting nuclide H-3 Radioactive strontium Plutonium |
| Tohoku Greening Environmental Conservation Co., Ltd. | ISO/IEC17025 ISO9001 | Cs-134,Cs-137 I-131 H-3 |

To ascertain the competence of each analyst, we increase those who can deal with analyses of difficult-measure nuclides by OJT and verify the competence with the Z score (within two times wider range as detected concentration \pm standard deviation), which is an ISO review method, by measurements using samples with known concentrations once a year for the nuclides subject to ISO/IEC-17025 authentication ⁴⁶ for all the personnel in charge of tritium and cesium (See Figure 9-1).

⁴⁶ "Analytical test of radionuclide (including Cs134/Cs137 and H-3) in public waters, wastewater, soil, ash and sludge"
(Certification institute: Perry Johnson Laboratory Accreditation Inc., Certificate: L20-355-R1)


(Bq/L)



Persons targeted for H-3 Skill Test: 13 analysts (A to M)
 Sample concentration: 10.2Bq/L
 Intermediate value of 10 times repeated measured of 3 samples by the sample creator
 Implementation period: October 9-29, 2020
 Implementation location: Chemical Analysis Building
 Judgment method: Z score (ISO inspection method)
 Judgment value: $|Z| \leq 2$

(Bq/L)

— : $|Z|=2$ concentration



Persons targeted for Cs-137 Skill Test: 25 analysts (A to Y)
 Sample concentration: 4.5Bq/L
 Intermediate value of 10 times repeated measured by the sample creator
 Implementation period: July 29 to August 6, 2020
 Implementation location: Chemical Analysis Building
 Judgment method: Z score (ISO inspection method)
 Judgment value: $|Z| \leq 2$

Figure 9-1 Example of competence check of analysts (result of FY 2020)

9-1-3. Our management and supervision

We request consignees to comply with the determined analysis procedures and secure the competence of analysts based on contracts, and receive and verify analysis procedures and competence control records.

Figure 9-2 shows the overview of the system that maintains the flow and quality of analysis, which means that the quality of the analysis process is kept constant and a mechanism to detect abnormalities of data is constructed.




Figure 9-2 Flow of analysis and overview of the system to maintain quality

In addition, the following activities are performed.

- Usage status of procedures and the implementation status of specifications are regularly checked in all analysis rooms (it is applied to all analytical work performed within the premises of the FDNPS)
- In order to ensure the quality of operation and work safety, it is stipulated as a requirement that work can be performed with the same procedure even when an analyst is replaced.
- Methods for checking procedures are standardized.
- The third-party organizations are required to submit work procedures in their specifications as well, and our company's involvement in the quality control of work processes will be enhanced.
- Guidance is given to contractors for identifying risks in the prior safety assessment before starting operation. TEPCO explains previous nonconformity cases and gives guidance to raise their awareness and ensure the thorough compliance with the rules

- Every month, TEPCO discusses with contractors on issues in analytical operation and the implementation status of the preventive measures for the recurrence of previous nonconformities to maintain performance
- Every month, TEPCO conducts on-site observations for analysis work with contractors to identify unsafe conditions to ensure safety at the site and maintain work quality
- Implementation status of analysis procedures established by contractors, is checked, and guidance is given for the identification and correction of the area to be improved in the work.

9-2. Monitoring within the premises of the Fukushima Daiichi Nuclear Power Station

The following three activities are to be performed at the site: (1) measurement and assessment of 64 nuclides by the measurement/confirmation facility of which results are used to judge the possibility of discharge and determine the dilution ratio (source monitoring), (2) monitoring with samples collected at the discharge vertical shaft (upper-stream storage) to confirm the dilution and mixing states of treated water with the seawater used for judgment of discharge immediately after the start of discharge, and (3) monitoring with samples collected from the seawater piping performed to confirm the dilution state every day during continuous discharge, all of which are led by us. This section describes the procedures, etc., used for maintaining the accuracy of monitoring as well.

Figure 9-3 shows monitoring to be performed within the premises of the FDNPS.




Figure 9-3 Monitoring within the premises of the FDNPS

9-2-1. Source monitoring

Source monitoring is monitoring of the source term (annual discharge amount (total amount) of each nuclide contained in the ALPS treated water, which is diluted and discharged into the sea). In this analysis, we collect samples after homogenization of ALPS treated water every time the measurement/confirmation facility is fully filled with ALPS treated water, and all nuclides to be measured in ALPS treated water (tritium, C-14, and 62 nuclides subject to removal by ALPS) are analyzed and assessed⁴⁷. From the analysis results, we verified that:

- The sum of the ratios to regulatory concentrations limits⁴⁸ of the concentrations of 63 nuclides excluding tritium falls below 1, which is the regulatory standard
- This is the basis for the determination of the flow rate of the ALPS treated amount to be diluted and discharged based on the measured tritium concentration to surely make the concentration after dilution less than 1,500Bq/L, which is the concentration specified in the fundamental policy of the government.

Therefore, the homogeneity of ALPS treated water stored in the measurement/confirmation facility is extremely important for securing the representativeness of collected samples. The measurement/confirmation facility where samples are collected consists of three tank groups each of which consists of 10 tanks with capacity of about 1,000 m³ connected by connecting piping so that they can be managed uniformly. For each tank group, the circulation/stirring facility is installed to stir and circulate the ALPS treated water stored in the tanks for homogenization. By operating the facility properly, we secure the representativeness of samples.

Samples are analyzed by TPT analysts in the chemical analysis building installed in the site of the FDNPS and planned to be expanded in the future (See Table 9-2). In addition, the mechanism for multiple parties to verify the analysis result has been established involving the analysis institute we designated as a third party; an analysis laboratory designated as a third party by the government; and the IAEA laboratories and the analysis laboratories of the member countries specified by the IAEA as a part of review of discharge of ALPS treated water. The framework of analysis led by the government and the IAEA is now being discussed by the government and the IAEA. The results are also planned to be announced.

⁴⁷ Some of the nuclides to be measured take time and actually took about two months for the measurement and assessment in the secondary treatment performance verification test (We are considering how to shorten the required time): Therefore, we plan to secure the storage capacity of about 10,000 m³ (amount generated in 2 months (150 m³/day)) as the capacity of the measurement/confirmation facility:

⁴⁸ See Reference A "Site boundary dose assessment of Fukushima Daiichi Nuclear Power Station and the regulatory concentration limit in the Japanese laws"

Table 9-5 shows the measurement and assessment method of each nuclides in the measurement/confirmation facility. Table 9-6 shows the minimum limit value and compliance method of each nuclide.

Table 9-5 Measurement and assessment methods of each nuclide

| No. | Nuclide | Radiation type | Measurement or assessment method |
|-----|---------|----------------|---|
| 1 | Mn-54 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 2 | Fe-59 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 3 | Co-58 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 4 | Co-60 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 5 | Ni-63 | β | Isolated by resin, mixed with a scintillator, and counted by a low back liquid scintillation counter. |
| 6 | Zn-65 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 7 | Rb-86 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 8 | Sr-89 | β | Isolated with resin, precipitated and recovered, mounted, and counted with the β nuclide analyzer in stainless steel dish |
| 9 | Sr-90 | β | Isolated with resin, precipitated and recovered, mounted, and counted with the β nuclide analyzer in stainless steel dish |
| 10 | Y-90 | β | [Evaluation value] Concentration assessment as radioactive equilibrium with Sr-90 |
| 11 | Y-91 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 12 | Nb-95 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 13 | Tc-99 | β | Samples are diluted with dilute nitric acid and counted with the inductively coupled plasma mass spectrometry (ICP-MS). |
| 14 | Ru-103 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 15 | Ru-106 | β | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 16 | Rh-103m | $\beta\gamma$ | [Evaluation value] Concentration assessment as radioactive equilibrium with Ru-103 |
| 17 | Rh-106 | γ | [Evaluation value] Concentration assessment as radioactive equilibrium with Ru-106 |
| 18 | Ag-110m | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 19 | Cd-113m | γ | Isolated by ion exchange, mixed with a scintillator, and counted by a low back liquid scintillation counter. |
| 20 | Cd-115m | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 21 | Sn-119m | γ | [Evaluation value] Assessed from the measured value of the radioactive concentration of Sn-123 and the calculated nuclide abundance ratio |
| 22 | Sn-123 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 23 | Sn-126 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |

| No. | Nuclide | Radiation type | Measurement or assessment method |
|-----|---------|----------------|---|
| 24 | Sb-124 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 25 | Sb-125 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 26 | Te-123m | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 27 | Te-125m | γ | [Evaluation value] Concentration assessment as radioactive equilibrium with Sb-125 |
| 28 | Te-127 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container, counted with a Ge semiconductor detector, and assessed using the half-life of the parent nuclide (Te-127m). |
| 29 | Te-127m | $\beta\gamma$ | [Evaluation value] Assessed from the measured value of the radioactive concentration of Te-127 and the calculated nuclide abundance ratio |
| 30 | Te-129 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container, counted with a Ge semiconductor detector, and assessed using the half-life of the parent nuclide (Te-129m). |
| 31 | Te-129m | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 32 | I-129 | $\beta\gamma$ | Samples were counted with the inductively coupled plasma mass spectrometry (ICP-MS) after adjusting to iodate ion by the addition of reagents. |
| 33 | Cs-134 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 34 | Cs-135 | β | [Evaluation value] Assessed from the measured value of the radioactive concentration of Cs-137 and the calculated nuclide abundance ratio |
| 35 | Cs-136 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 36 | Cs-137 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 37 | Ba-137m | γ | [Evaluation value] Concentration assessment as radioactive equilibrium with Cs-137 |
| 38 | Ba-140 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 39 | Ce-141 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 40 | Ce-144 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 41 | Pr-144 | $\beta\gamma$ | [Evaluation value] Concentration assessment as radiation equilibrium with Ce-144, using half-life of parent nuclide (Pr-144m) |
| 42 | Pr-144m | γ | [Evaluation value] Concentration assessment as radioactive equilibrium with Ce-144 |
| 43 | Pm-146 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 44 | Pm-147 | $\beta\gamma$ | [Assessed value] Assessed from the measured value of the radioactive concentration of congener Eu-154 and the calculated nuclide abundance ratio |
| 45 | Pm-148 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 46 | Pm-148m | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 47 | Sm-151 | $\beta\gamma$ | [Assessed value] Assessed from the measured value of the radioactive concentration of congener Eu-154 and the calculated nuclide abundance ratio |

| No. | Nuclide | Radiation type | Measurement or assessment method |
|-----|---------------|----------------|---|
| 48 | Eu-152 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 49 | Eu-154 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 50 | Eu-155 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 51 | Gd-153 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 52 | Tb-160 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 53 | Pu-238 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 54 | Pu-239 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 55 | Pu-240 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 56 | Pu-241 | β | [Evaluation value] Assessed from the total α discrete value and the isotopic ratio of Pu-238 |
| 57 | Am-241 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 58 | Am-242m | α | [Evaluation value] Assessed from the isotopic ratio of Am-241 |
| 59 | Am-243 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 60 | Cm-242 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 61 | Cm-243 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 62 | Cm-244 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| - | Tritium (FWT) | β | Isolated by distillation, mixed with a scintillator, and counted by a low back liquid scintillation counter. |
| - | C-14 | β | Converted to CO ₂ , collected and isolated on absorbent, mixed with a scintillator, and counted by a low back liquid scintillation counter. |

Table 9-6 Target detection limit and compliance method of each analyzed nuclide

| Nuclide | Analysis method | Target minimum limit of detection value ⁴⁹ | Applicable technique |
|-------------------------|---|---|--|
| γ-ray emitting nuclides | Samples are dispensed in a Marinelli container and measured with a Ge semiconductor detector. | 0.07Bq/L Set in Cs-137 ⁵⁰ | Series of Radioactivity Measuring Methods. No. 7 (Gamma ray spectrometry with germanium semiconductor detector) |
| Sr-89/90 | Sr was refined by Sr resin, precipitated and recovered as carbonate, and measured with a β-nuclide analysis equipment. | 0.04Bq/L Set in Sr-90 ⁵¹ | JAEA-Technology2009-051 (Simple and rapid analytical method for nuclides, contained in waste from research facilities, etc. (analytical guidelines)) |
| I-129 | Hypochlorous acid was added to the sample to adjust it to iodic acid ion, and then measured with an inductively coupled plasma mass analysis equipment. | 0.2Bq/L | Series of Radioactivity Measuring Methods. No. 32 (Method for rapid analysis of iodine 129 in environmental samples) |
| Tritium | After mixing the sample from which impurities have been removed by distillation with the scintillator, measurement is performed with a low back liquid scintillation counter. | 30Bq/L | Series of Radioactivity Measuring Methods. No. 9 (Tritium analysis method) |
| C-14 | The sample is heated by adding concentrated nitric acid and potassium persulfate, and the generated CO ₂ is collected in an absorbent, mixed with a scintillator, and measured by a low back liquid scintillation counter. | 10Bq/L | Series of Radioactivity Measuring Methods. No. 25 (Radiocarbon Analysis Method) JGC: Radiochemical Analysis of Radioactive Waste |
| Tc-99 | The sample is diluted with nitric acid and measured with an inductively coupled plasma mass spectrometer. | 2Bq/L | Radioactive waste management funding and research center: Research on upgrading and streamlining of radiochemical analytical technique |
| Total-α radioactivity | After α-nuclide is coprecipitated with iron hydroxide and iron is removed by extraction, it is evaporated to dryness and then baked to the stainless plate, and measured with an α automatic measuring device | 0.04Bq/L | Manual of standard procedures for analysis of radioactive effluents and gases from Tokai Works of Power Reactor and Nuclear Fuel Development Corporation |
| Cd-113m | Cd is refined and recovered by ion exchange, mixed with a scintillator, and measured by a low back liquid scintillation counter. | 0.2Bq/L | Analytical Chemistry, vol.63, No. 4. (Review of Analysis method with β-rays measurement method using low back liquid scintillation counter for ^{113m} Cd in stagnant water in FDNPS) |

⁴⁹Value for each nuclide set to confirm that the sum of the ratios to regulatory concentrations limits is less than 1

⁵⁰Other nuclides vary with baseline, interfering nuclides, background and gamma ray emission rate

⁵¹Sr-89 varies with Sr-90 concentration

| Nuclide | Analysis method | Target minimum limit of detection value ⁴⁹ | Applicable technique |
|---------|--|---|--|
| Ni-63 | Ni is refined and recovered by Ni resin, mixed with a scintillator, and measured by a low back liquid scintillation counter. | 20Bq/L | JAEA-Technology2009-051 (Simple and rapid analytical method for nuclides, contained in waste from research facilities, etc. (analytical guidelines)) |

9-2-2. Monitoring at the discharge vertical shaft (upper-stream storage)

ALPS treated water to be discharged into the sea is treated by ALPS until the sum of the ratios to regulatory concentrations limits of 63 nuclides excluding tritium fall below 1, in order to ensure the safety of ALPS treated water to be discharged into the environment.

On the other hand, to the extent of the available knowledge, ALPS treated water, etc., contains 0.15 to 2.16 million Bq/L of tritium, which exceeds the regulatory concentration limit (60,000 Bq/L), which is the upper limit on the discharge into the environment specified by laws. In addition, the Basic Policy of the government in April 2021 stipulates that the tritium concentration be less than 1,500 Bq/L as with the groundwater bypass and subdrain. In response to it, we decided to dilute ALPS treated water, etc., with a lot of seawater before discharge in order to meet the regulatory concentration limit and dispel concerns of consumers, etc., as much as possible for minimization of reputation damage.

Tritium is a nuclide that emits weak beta rays, which cannot be monitored continuously, unlike gamma rays from Cs-137. Therefore, the appropriateness of dilution is verified by collecting samples and measurement with the liquid scintillation counting device.

To start discharge into the sea, for the time being, we shall verify that appropriate dilution is performed by the dilution facility by the procedure shown in Figure 9-4 below and the tritium concentration is less than 1,500 Bq/L at the discharge vertical shaft (upper-stream storage) immediately before discharge into the environment, for each type of ALPS treated water (about 10,000 m³/tank group) of which sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium is less than 1 by the analysis and assessment by the measurement/confirmation facility (See 9-2-1).




Figure 9-4 Analysis and discharge procedure at the discharge vertical shaft (upper-stream storage)

9-2-3. Monitoring in seawater piping

After verification of the appropriateness of dilution described in 9-2-2. above, dilute the remaining ALPS treated water (about 10,000 m³/tank group), transfer it to the discharge vertical shaft (upper-stream storage), and discharge it continuously or intermittently. The capacity of the ALPS treated water transfer pump is 500 m³/day. Considering the capacity of each tank group of the measurement/confirmation facility (about 10,000 m³/tank group), it

takes about 20 days to discharge the whole of the remaining ALPS treated water measured even by continuous discharge.

Collect samples every day by the sampling facility installed in the seawater piping, analyze the tritium concentration, and, in principle, announce the result on the following day, in order to verify the appropriateness of dilution of tritium during this discharge period.

To verify whether appropriate dilution mixing is performed in the seawater piping, mass concentration of injected ALPS treated water in each section of piping was calculated by fluid analysis (seawater flow rate of 340,000 m³/day and ALPS treated water flow rate of 500 m³/day, the theoretical mass concentration of 0.14%). As a result of the assessment, it was verified that 100 or more times higher dilution effect than the target of this facility was obtained at 04: Down elbow outlet in Figure 9-5 in the downstream side from the ALPS treated water injection position.




Figure 9-5 Fluid analysis result regarding dilution mixing in the seawater piping

9-3. Monitoring outside of the premises of the Fukushima Daiichi Nuclear Power Station

After the accident at the FDNPS, the “Monitoring Coordination Meeting” was set up under the Nuclear Emergency Response Headquarters of the government and the “Comprehensive Radiation Monitoring Plan” was formulated in August 2011 for secure and planned implementation of find monitoring about the environment⁵². Based on this plan, we have been monitoring mainly Cs-134, Cs-137, and Sr-90 in the sea area for the purpose of ascertaining the states of diffusion and advection of radioactive materials discharged into the environment, etc., in cooperation with each monitoring executing body such as the related ministries, local governments, and us (hereinafter called “implementation entity”). The Comprehensive Radiation Monitoring Plan defines the division of roles of each implementation entity and each implementation entity has been fulfilling their roles according to the definition.

After the announcement of the Basic Policy on handling of the ALPS treated water in April 2021, each implementation entity has been considering enhancement and expansion of sea area monitoring (See 9-3-1 and 9-3-2). We recognize that in discharging ALPS treated water into the sea, it is important to enhance and expand sea area monitoring from the viewpoints of compliance with legal regulatory standards, etc., and actions based on international laws and practices, as well as prevention of reputation damage, dispelling of concerns of people inside and outside Japan, and deepening of understanding. Our consideration result was reflected in the Comprehensive Radiation Monitoring Plan at the Monitoring Coordination Meeting held on March 30, 2022. Figure 9-6 shows the position of monitoring by each implementation entity.




Figure 9-6 Position of sea area monitoring by each implementation entity

⁵² Monitoring Coordination Meeting of the Nuclear Emergency Response Headquarters (revised on March 30, 2022)
<https://radioactivity.nsr.go.jp/en/list/274/list-1.html>

The following shows the monitoring plan conducted and to be performed in the future by each implementation entity as of the end of March 2022.

9-3-1. Sea area monitoring around the Fukushima Daiichi Nuclear Power Station by TEPCO

In the past, we performed the following monitoring as a part of the total monitoring plan.

Table 9-7 Overview of our sea area monitoring based on the past total monitoring plan

| Target | Target nuclide | Measurement frequency (depending on the location and nuclide) |
|-----------------|---|---|
| Seawater | Cs-134/137, strontium, tritium, and plutonium | Every day or every six months |
| Seabed sediment | Cs-134/137, strontium, and plutonium | Every month or every six months |
| Fish, etc. | Cs-134/137 | Once a month |

Based on the Basic Policy of the government in April 2021, in the same month, we announced “TEPCO’s Action in response to Government’s Policy” including further enhancement and expansion of sea area monitoring in order to minimize reputation damage associated with discharge of ALPS treated water into the sea⁵³.

After that, we announced sea area monitoring (plan) in August 2021, as the executing body of discharge of ALPS treated water into the sea⁵⁴, and then assessed the state of diffusion of ALPS treated water by simulation in the radiological impact assessment in November 2021. We considered sea area monitoring for verification of the diffusion state and the migration state of radiological materials to fish and seaweeds in the sea area off the coast of Fukushima centering on the area adjacent to the FDNPS, in which the tritium concentration was assessed to change^{55, 56}.

To continuously get data for comparison with the diffusion state and migration state after discharge, it is planned to formulate the sea area monitoring plan setting the detection limit in addition to the consideration result announced in August 2021 and started the implementation of the plan in April 2022 before starting discharge. For this monitoring (sampling, radiation measurement, etc.), it is planned to ask agriculture, forestry and fisheries workers, related parties in local governments, etc. participate in and observe monitoring, and request an analysis by a third party organization specified by us and

⁵³ TEPCO Holdings’ Action in Response to the Government’s Policy on the Handling of ALPS Treated Water from the Fukushima Daiichi Nuclear Power Station
https://www.tepco.co.jp/en/hd/newsroom/press/archives/2021/20210416_01.html

⁵⁴ Status of Review Regarding the Handling of ALPS Treated Water
<https://www.tepco.co.jp/en/hd/newsroom/press/archives/2021/pdf/210825e0101.pdf>

⁵⁵ However, the change in the concentration is assessed to be 1 to 2Bq/L, which is as little as 1/10,000 to 1/5,000 of 10,000Bq/L, which is the WHO Guidelines for Drinking Water Quality.

⁵⁶ The sampling points are added from the diffusion simulation result in March 2020, and consequently the results showed this assessment requires no change. The frequency to ascertain usual values increased as well as enhance the verification of the state of migration to marine organisms

involvement of the IAEA as with source monitoring in order to secure objectivity and reliability of the monitoring result.

We plan to monitor not only the seawater but also fish and seaweeds to verify the state of migration of radioactive materials to marine plants and animals due to discharge.


We decided to enhance and expand sea area monitoring as follows. Figure 9-7 shows the details of enhancement and expansion of our sea area monitoring

- Increase in measurement points and targets
 - Considering that we are the executing body of discharge of ALPS treated water into the sea, we decided to perform monitoring focusing on the area around the discharge outlet and added a total of 13 tritium measurement points of the seawater and marine organisms (fish) in the area near the FDNPS and the coast of Fukushima (See red and orange boxes in Figure 9-7).
 - For seawater monitoring, we added three new monitoring points on the boundary of the “area where no fishing is conducted on a daily basis” considered in this assessment of radiation impact on human and environment (See the red texts in Figure 9-7).
 - For fish, we currently analyze cesium, which is representative⁵⁷ in the measurement of radiation impact, based on samples collected in 11 locations within 20 km off the coast of Fukushima (in one of which tritium analysis is still performed), and will analyze tritium in fish caught in a total of 11 locations including 10 new locations where currently tritium is not analyzed, in order to verify the impact of concentration of tritium (See orange boxes in the right figure in Figure 9-7). Tritium analysis is also performed for the seawater on the point.
 - We will collect and analyze seaweeds in two new locations outside the port as well as the location in the port where currently gamma nuclides are analyzed (See green boxes in Figure 9-7). We shall add tritium to the measured nuclides, verify whether it concentrates, etc., and add iodine, which is easy to concentrate in seaweeds, to the measured nuclides.
 - We will continue the current measurements of nuclides other than tritium and I-129, of which measurements are to be enhanced and expanded (Cs-134, Cs-137, Sr-90, Pu-238, and Pu-239+240)⁵⁸.

⁵⁷ This is because there are some nuclides which emit strong gamma rays.

⁵⁸ We shall perform monitoring of mainly tritium considering the migration and advection processes in the environment, but if any abnormality is found in the enhanced monitoring, we shall consider the necessity for additional monitoring of such nuclides and C-14.

- Increase in the frequency
 - As measurement points increase, the frequency is increased at points where tritium in the seawater has been measured (For measurement points, see blue boxes in Figure 9-7. For the frequency, see Table 9-9).
- The detection limit is set to match the target value set by the government
 - To verify the diffusion state of radioactive materials in the seawater and the state of marine organisms, the minimum limit values of detection of tritium and iodine 129 are reduced to be consistent with the target detection limit set by the government (For measurement points, see black boxes in Figure 9-7. For the detection limit, see Table 9-9)



<Legend>

[Current total monitoring plan]
 Nuclear Regulation Authority M-O
 Ministry of the Environment E-O
 Fisheries Agency (marine products) F-O
 Fukushima Prefecture T-O
 TEPCO T-O

[Enhancement plan of TEPCO]

- Points where the detection limit are to be revised (seawater)
- New sampling points (seawater)
- Points where frequencies are increased (seawater)
- Points where tritium is analyzed in addition to cesium (seawater and fish)
- Same points as before (seaweeds)
- New sampling points (seaweeds)



An area where no fishing is conducted on a daily basis 1.5 km east to west, 3.5 km north to south

*: Areas where common fishery rights are not established

Figure 9-7 Sampling point of sea area monitoring enhanced and expanded by us (Near the FDNPS/Coast within a 20 km radius)

Moreover, we decided to perform monitoring in 9 new points even in “Outside the area of 20 km off the coast of the FDNPS,” in which tritium has not been analyzed and the concentration is estimated not to exceed the background of seawater in our marine diffusion simulation.




Figure 9-8 Sampling point of sea area monitoring enhanced and expanded by us (Coast outside a 20 km radius)

Based on the above, the frequency and the number of sampling points of tritium analysis in sea area monitoring by us increases as shown in Table 9-8 below compared to the previous sea area monitoring.

Table 9-8 Frequency and the number of sampling points of tritium analysis in sea area monitoring near the FDNPS and in the coastal sea area by us

| Implementation entity | Tritium analysis | | | |
|---------------------------------------|-----------------------------------|-------------------|----------------|---------------|
| | Measurement frequency | Number of samples | | |
| | | Seawater | Fish | Seaweeds |
| Tokyo Electric Power Company Holdings | Once a week | 17 -> 20 | - | - |
| | Twice/month -> Once a week | 6 | - | - |
| | Once a month | 1 -> 20 | 1 -> 11 | - |
| | Three times/year | - | - | 0 -> 2 |

The detection limit is set as shown in the following table including the past analysis targets associated with enhancement and expansion of this sea area monitoring.

Table 9-9 Samples and nuclides to be measured, and detection limit (The parts in thick frames indicate the points to be enhanced and expanded)

| Target | Sampling site | Number of samples | Nuclides to be measured | Measurement frequency | Target detection limit |
|-----------------------------------|---|-------------------|---|---|--|
| Seawater (Surface layer) | Within the port | 10 | Cs-134/137 | Every day | 0.4 Bq/L |
| | | | Tritium | Once a week | 3 Bq/L |
| | Outside the port Within a 2 km radius | 2 | Cs-134/137 | Once a week | 0.003 Bq/L |
| | | | | Every day | 1 -> 0.4 Bq/L |
| | | | 5 -> 8 | Cs-134/137 | Once a week |
| | 7 -> 10 | H-3 | Once a week | 1 -> 0.4 Bq/L^{*1} | |
| | Coast Within a 20 km radius | 6 | Cs-134/137 | Once a week | 0.003 Bq/L |
| | | | Tritium | Twice/month -> Once a week^{*2} | 0.4 -> 0.1 Bq/L^{*3} |
| | Coast within a 20 km radius (fish catching point) | 1 | Tritium | Once a month | 0.1 Bq/L |
| | | | 0 -> 10 | Tritium | None -> Once a month |
| | Coast outside a 20 km radius | 9 | Cs-134/137 | Once a month | 0.003 Bq/L |
| | | | 0 -> 9 | Tritium | None -> Once a month |
| Fish | Coast Within a 20 km radius | 11 | Cs-134/137 | Once a month | 10 Bq/kg (raw) |
| | | | Sr-90 (Only the top five samples in terms of the Cs concentration) | Quarterly | 0.02 Bq/kg (raw) |
| | | 1 | Tritium (FWT) | Once a month | 0.1 Bq/L |
| | | | Tritium (OBT) | | 0.5 Bq/L |
| | | 0 -> 10 | Tritium (FWT)^{*4} | None -> Once a month | 0.1 Bq/L^{*6} |
| Tritium (OBT)^{*5} | 0.5 Bq/L | | | | |
| Seaweeds | Within the port | 1 | Cs-134/137 | Once a year -> Three times/year | 0.2 Bq/kg (raw) |
| | Outside the port Within a 2 km radius | 0 -> 2 | Cs-134/137 | None -> Three times/year | 0.2 Bq/kg (raw) |
| | | | I-129 | | 0.1 Bq/kg (raw) |
| | | | Tritium (FWT) | | 0.1 Bq/L |
| Tritium (OBT) | 0.5 Bq/L | | | | |

*1: Get the value of detection by the electrolytic concentration method (concentration method making use of the characteristic of tritium being hard to be decomposed by an electric current) as needed.

*2: The measurement with the detection limit set to 0.1Bq/L is performed once/month

*3: Performed at 0.4Bq/L for the time being depending on the state of the installation of the electrolytic condenser.

*4: Tritium which exists as water in tissues of organisms. It does not remain in organisms for a long time.

*5: Tritium which is connected to tissues in organisms. It remains in organisms longer than organization free water.

*6: The measurement is performed at 0.4Bq/L for the time being depending on the state of the installation of the electrolytic condenser.

For all of these measurements, analyses by not only us but also a third party organization specified by us are performed to secure objectivity and transparency.

For the announcement of measurement data, we will perform the following activities to deepen understanding from inside and outside Japan.

- Announce the results of the measurement and assessment correctly and timely in our web site as soon as they are prepared.
- Announce data in a manner easy for local and domestic consumers to understand. Moreover, describe the safety-related information regarding the announced measurement values.
- Prepare a report describing the monitoring result and the assessment, and plan to make it available in our web site, etc., every quarter.
- In the assessment, verify, for example, whether the result is within the marine diffusion simulation result, whether the result is equivalent to the concentration used for the radiological impact assessment, etc., and express them in an easy-to-understand manner.
- Also plan to report the result in opportunities where related parties in local governments, etc. and academics confirm and assess it.

9-3-2. Monitoring by the government and Fukushima prefecture

(1) Previous sea area monitoring performed by the government and Fukushima

This section covers sea area monitoring by implementation entities other than us in the Comprehensive Radiation Monitoring Plan, namely the government (mainly the Ministry of the Environment, the Nuclear Regulation Authority, and the Fisheries Agency), Fukushima prefecture, etc. based on disclosed information. The relevant Ministries and Agencies started monitoring immediately after the accident and has been announcing the result⁵⁹ in cooperation with Fukushima, research institutes, fisheries cooperatives, etc., and reviewing the contents, measurement points, etc., of monitoring and announcing the result⁶⁰. Table 9-10 shows the details of sea area monitoring by implementation entities other than us⁶¹. In the previous plan, sea area monitoring was performed for seawater, seabed sediment, and marine organisms in the following areas:

- (1) Sea area vicinity of FDNPS (within about 3 km from the middle between the Unit 2 and 3 exhaust stacks)
- (2) Coastal sea area (within about 30 km from the coastline from a part of Aomori and Iwate to Miyagi, Fukushima, and Ibaraki (including the estuary, excluding the vicinity sea area))
- (3) Offshore sea area (sea area within about 30 to 90 km from the coastline)
- (4) Ocean area (sea area within about 90 km to 300 km from the coastline)
- (5) Tokyo Bay (bay about 200 km away from FDNPS)

Table 9-10 Previous sea area monitoring by implementation entities other than us

a. Seawater

| Implementation entity | Measurement point | Measured nuclide | Measurement frequency (depending on the location and nuclide) |
|--|---|--|---|
| Government (mainly the Nuclear Regulation Authority and the Ministry of the Environment) | Vicinity sea area, coastal sea area, offshore sea area, ocean sea area, and Tokyo Bay | Cs-134/137, Sr-90, tritium | Every month to every year |
| Fukushima Prefecture | Vicinity sea area and coastal sea area | Cs-134/137, Sr-90, tritium, Pu-238/239+240 | Every month |
| (Reference) Tokyo Electric Power Company HD | Vicinity sea area and coastal sea area | Cs-134/137, Sr-90, tritium, Pu-238/239+240 | Every day or every six months |

⁵⁹ Radiation monitoring information
<https://radioactivity.nsr.go.jp/en/>

⁶⁰ Comprehensive Radiation Monitoring Plan
<https://radioactivity.nsr.go.jp/en/list/191/list-1.html>

⁶¹ Attachment of the total monitoring plan formulated at the monitoring adjustment meeting, which is chaired by the Minister of the Environment
https://radioactivity.nsr.go.jp/en/contents/16000/15098/24/274_20210401_s.pdf

b. Seabed sediment

| Implementation entity | Measurement point | Measured nuclide | Measurement frequency (depending on the location and nuclide) |
|--|--|-----------------------------------|---|
| Government (mainly the Nuclear Regulation Authority and the Ministry of the Environment) | Coastal sea area, offshore sea area, and Tokyo Bay | Cs-134/137 | Every month to every year |
| Fukushima Prefecture | Vicinity sea area and coastal sea area | Cs-134/137, Sr-90, Pu-238/239+240 | Every month to every six months |
| (Reference) Tokyo Electric Power Company HD | Vicinity sea area and coastal sea area | Cs-134/137, Sr-90, Pu-238/239+240 | Every month to every six months |

c. Marine organisms

| Implementation entity | Measurement point | Measured nuclide | Measurement frequency (depending on the location and nuclide) |
|---|---|------------------|---|
| Government (Fisheries Agency and Ministry of the Environment) | Coastal sea area, offshore sea area, and ocean area | Cs-134/137 | Every week to every three or four months |
| (Reference) Tokyo Electric Power Company HD | Coastal sea area | Cs-134/137 | Every month |

(2) Sea area monitoring enhanced and expanded by the government in response to discharge of ALPS treated water

In response to the Basic Policy of the government announced in April 2021, the future sea area monitoring was discussed at the Surveillance and Measurement Task Force of the sea area environment set up under the Monitoring Coordination Meeting, in which the relevant Ministries and Agencies such as the Nuclear Regulation Authority and the Ministry of Environment and the Sea Area Monitoring Expert Meeting on ALPS treated water set up under the Ministry of Environment. Then, the Comprehensive Radiation Monitoring Plan was revised at the Monitoring Coordination Meeting held in March 2022. They plan to enhance and expand the sea area monitoring before and after discharge of ALPS treated water such as setting of more sampling points within 10 km from the discharge outlet considering our discharge plan and the contents of this report⁶². The plan is as follows.

a. Seawater

- (1) Perform monitoring to ascertain the variation of the tritium concentration in the sea area before and after discharge.
 - There is considered to be almost no significant difference from the condition before discharge in a location about 10 km away from the discharge outlet

⁶² Material 1 of the monitoring coordination meeting (March 30, 2022) for enhancement and expansion of sea area monitoring by the government
<http://www.env.go.jp/water/shorisui/monitoring/014/mat01.pdf>

(The result of the diffusion simulation by TEPCO shows a possibility of a minor variation even in a location about 30 km away depending on the day)

- Set more sampling points within 10 km from the discharge outlet.
- To be on safeside, also perform monitoring at sampling points 30 km and 50 km away, offshore to the south of Miyagi, and offshore to the north of Ibaraki.
- Also perform monitoring at nearby swimming beaches.

(2) Basically, the measurement frequency of newly added points will be four times a year (considering seasonal variations). Immediately after discharge, the frequency of the measurement is increased including the bulletin figure with the detection limit raised.

(3) To be on safeside, measure the seven major nuclides (Cs-134, Cs-137, Co-60, Ru-106, Sb-125, Sr-90, and I-129) four times a year in some sampling points. In addition, perform it once a year for a wide range of related nuclides⁶³.

Table 9-11 shows the sea area monitoring plan for seawater of FY 2022.

Table 9-11 Sea area monitoring plan of the government for seawater enhanced and expanded

| Target nuclide | Sampling point | Sampling depth ^{*1} | Analysis frequency | Target detection limit | Analysis method |
|---|---|--|---|---|-----------------------------------|
| Tritium | Near the discharge outlet (about 300m from the discharge outlet) | Surface layer/Bottom layer | Four times a year | 0.1Bq/L ^{*3} | Electrolytic concentration method |
| | 1 km to 10 km from the discharge outlet | Surface layer/Bottom layer | Four times a year | 0.1Bq/L ^{*3} | Electrolytic concentration method |
| | About 30 km to 50 km from the discharge outlet, offshore to the south of Miyagi, and offshore to the north of Ibaraki | Surface layer/Bottom layer ^{*2} | Four times a year | 0.1Bq/L ^{*3} | Electrolytic concentration method |
| | Bathing beaches (Two points in each of the north and south are selected considering the opening conditions) | Surface layer | Twice a year (before and during the season) | 0.1Bq/L ^{*3} | Electrolytic concentration method |
| Seven major nuclides | Three points on the boundary with the area switch fishery rights (north, south, and east) | Surface layer/Bottom layer | Four times a year | Basically, follow the radioactivity measurement method series (Set the detection limit of Cs-134, Cs-137, and Sr-90 to 0.001Bq/L) | |
| Other related nuclides (basically 62 nuclides subject to removal by ALPS, and C-14) | Three points on the boundary with the area switch fishery rights (north, south, and east) | Surface layer/Bottom layer | Once a year | Basically, follow the radioactivity measurement method series (Set the detection limit of Cs-134, Cs-137, and Sr-90 to 0.001Bq/L) | |

*1: Surface layer: Sea surface to about 2 m, Bottom layer: About 2 m to 5 m or 10 m to 40 m from the seabed depending on the water depth

*2: Surface layer only for sampling points shown by blue stars and green circles outside the 50 km radius

*3: A detection limit of about 0.05Bq/L (specifically 0.02-0.07Bq/L) was obtained from the result of the measurement of seawater consigned by the Nuclear Regulation Authority based on this target detection limit.

⁶³ Basically C-14 and 62 nuclides subject to removal by ALPS.

b. Marine biota

- (1) Perform monitoring of tritium in marine biota (FWT and OBT) near the boundary with the area switch fishery right.
- (2) Also perform monitoring at the same points as (1) for C-14 in fish and I-129 in seaweeds.


Table 9-12 and Figures 9-9 and 9-10 show the sea area monitoring plan for marine biota of FY 2022.

Table 9-12 Sea area monitoring plan of the government for marine biota enhanced and expanded

| Target nuclide | Sampling point | Target organisms | Analysis frequency | Target detection limit | Analysis method |
|----------------|---|----------------------|--------------------|--------------------------------|--|
| Tritium*1 | Three points on the boundary with the area switch fishery rights (north, south, and east) | Fish (demersal fish) | Four times a year | FWT: 0.1Bq/L*2 OBT: 0.5Bq/L | FWT: Electrolytic concentration method OBT: Distillation method |
| I-129 | Three points on the boundary with the area switch fishery rights (north, south, and east) | Seaweeds | Four times a year | 0.1Bq/kg (raw) | ICP-MS |
| C-14 | Three points on the boundary with the area switch fishery rights (north, south, and east) | Fish (demersal fish) | Four times a year | 2Bq/kg (raw) | Follow the radiation measurement series (beta ray analysis) |

*1: Freeze-dry or burn aquatic organism samples to measure the concentration of tritium in water

*2: Aim to measure up to 0.05Bq/L, if possible



* Two additional sampling points of bathing beaches are to be set in the north and south sides, respectively

Figure 9-9 Sea area monitoring sampling point diagram of the government enhanced and expanded




Figure 9-10 Sea area monitoring sampling point diagram enhanced and expanded (wide area)

(3) Seawater monitoring enhanced and expanded by Fukushima prefecture in response to discharge of ALPS treated water

In response to discharge of ALPS treated water into the sea, Fukushima prefecture plans to monitor seawater in a wide observation area which consists a total of 9 locations, namely the existing 6 locations around the FDNPS and 1 additional location in each of the northern, eastern, and southern directions, as shown in Table 9-13 in the range where the concentration was assessed to be higher than the tritium concentration in the seawater in the surrounding sea water (0.1 to 1 Bq/L) considering the assessment of the advection and diffusion simulation in our report. Figure 9-11 shows the sampling points⁶⁴.

Table 9-13 Seawater monitoring in relation to ALPS treated water by Fukushima prefecture (FY 2-22)

| Sampling point | Sampling depth | Analysis frequency | Measurement item | Target detection limit | Analysis method |
|---|----------------|---|-----------------------------|--|--|
| Existing locations near the FDNPS (six locations) | Surface layer | 12 times a year | γ-nuclides | Approx. 0.001 to 0.002Bq/L (Cs-134/137) | Based on the Series of Radioactivity Measuring Methods |
| Additional locations (3 locations) | | Four times a year (Before discharge) 12 times a year (After discharge) | Tritium Total-β Sr-90 | Approx. 0.3 to 0.5Bq/L Approx. 0.01Bq/L Approx. 0.0005Bq/L | |
| | | | Pu-238/239+240 | Approx. 0.000003 to 0.00001Bq/L | |

Table 9-14 shows the monitoring to be performed by Fukushima as other seawater monitoring not related to discharge of ALPS treated water into the sea.

Table 9-14 Other seawater monitoring (FY 2022)

| Investigation type | Location | Number of points | Nuclides and frequency | | | | | |
|---|--------------------------------|--|----------------------------------|----------------------------|-----------------------|-----------------|--------|------------|
| | | | γ-ray emitting nuclides | Tritium | Total-β radioactivity | Sr-90 | Pu-238 | Pu-239+240 |
| Surveillance investigation around the nuclear power plant | Near the Fukushima Daiichi NPS | 9 points | Existing points | | | 12 times a year | | |
| | Near the Fukushima Daini NPS | 2 points | Four times a year | | | Once a year | | |
| | Comparison points | 1 point | Once a year | | | | | |
| Port/Sea surface fishing ground investigation | Important port | 3 points | 12 times a year (Cs-134, Cs-137) | - | - | - | - | - |
| | Fishing ports | 13 points | | - | - | - | - | - |
| | Shallow fishing ground | 7 points | | 12 times a year (6 points) | | | - | - |
| Bathing beach investigation | Bathing beach | 13 points | Twice a year (Cs-134, Cs-137) | Twice a year (7 points) | | | - | - |
| Public water area investigation | Sea area | 15 points (surface layer and bottom layer) | - | Twice a year | - | - | - | - |

⁶⁴ 35th Environmental Monitoring and Evaluation Sub-committee of the Safety Monitoring Council on Decommissioning of the Nuclear Power Station of Fukushima Prefecture Material 2-1, p.1 (Revised after discussion)
<http://www.pref.fukushima.lg.jp/uploaded/attachment/507135.pdf>

| Investigation type | Location | Number of points | Nuclides and frequency | | | | | |
|--|--|------------------|------------------------------------|-------------------|-----------------------|-------|--------|------------|
| | | | γ-ray emitting nuclides | Tritium | Total-β radioactivity | Sr-90 | Pu-238 | Pu-239+240 |
| Seawater monitoring associated with discharge of groundwater bypass water | Around the south discharge outlet at the Fukushima Daiichi | 1 point | Four times a year (Cs-134, Cs-137) | Four times a year | - | - | - | - |
| Seawater monitoring associated with discharge of treated water of the subdrain and groundwater drain | Around the north discharge outlet at the Fukushima Daiichi | 1 point | Four times a year (Cs-134, Cs-137) | Four times a year | - | - | - | - |




Figure9-11 Investigation points of seawater monitoring for ALPS treated water by Fukushima Prefecture

(4) Cooperation with the IAEA for sea area monitoring by the government and IAEA marine monitoring

Since 2014, the government has been conducting the IAEA Marine Monitoring with the aim of obtaining objective evaluation from the IAEA on the appropriateness of monitoring implementation methods and analytical capabilities of Japan's laboratories participating in sea area monitoring conducted by the government.

In the IAEA Marine Monitoring, samples of seawater, sediment off the coast of the FDNPS, and marine biota unloaded in Fukushima Prefecture which had been collected off the coast of the FDNPS were collected in the presence of the IAEA and occasionally from third-country laboratories. The samples were divided into analytical laboratories and analyzed individually, and an interlaboratory comparison (ILC) was conducted to compare the results. ILC Report (2017-2020)⁶⁵ published in August 2021 states that “Japan's sample collection procedures follow the appropriate methodological standards required to obtain representative samples” and “The results obtained demonstrate a continued high level of accuracy and competence on the part of the Japanese laboratories involved in the analyses of radionuclides in marine samples for the Sea Area Monitoring Plan.” IAEA marine monitoring will be continued in the future.

⁶⁵ IAEA, Preliminary Report 2021 Interlaboratory Comparisons 2017–2020: Determination of Radionuclides in Seawater, Sediment and Fish
<https://www.iaea.org/sites/default/files/21/07/preliminary-report-2021-interlaboratory-comparison-2017-2020-determination-of-radionuclides-in-seawater-sediment-and-fish.pdf>

9-4. Actions to be taken in case of abnormalities

Verify that it is within the assumed range, by comparison with the marine diffusion simulation result, the concentration used for the radiological impact assessment, etc., for the sea area monitoring described in 9-3. If it exceeds the variation range of usual values, verify the results of other implementation entities of monitoring for the investigation of the cause. If any greatly exceeding the variation range of usual values is observed, stop discharge into the sea, measure the corresponding points again, tentatively expand the range and frequency, and verify that there is no abnormality in the surrounding sea area.

Therefore, we will accumulate the analysis results of sea area monitoring from April 2022 to ascertain them as usual values before discharge into the sea.

9-5. Summary of monitoring

As mentioned above, while the government, Fukushima prefecture and we are proceeding with sea area monitoring, sea area monitoring is enhanced and expanded before and after discharge of ALPS treated water. If any abnormal value is detected in enhanced and expanded sea area monitoring or any abnormal value is detected in monitoring, we will make sure to stop discharge until it is verified that discharge can be performed safely.

10. Summary

For planned discharge of ALPS treated water into the sea in the FDNPS, the exposure assessment on human and environment is performed based on the current information (design stage).

The result of a calculation setting multiple source terms and multiple food ingestions assuming that 0.05mSv/year is equivalent to the dose constraint with the optimization based on the Basic Policy of the government in April 2021, shows the annual exposure amount of the set representative person $3\text{E-}05$ to $4\text{E-}04\text{mSv/year}$, which is much smaller than 1mSv/year, which is the dose limit to public shown in the ICRP recommendation, as well as 0.05mSv/year deemed by the Nuclear Regulation Authority to be equivalent to the dose constraint.

The result of a calculation setting multiple source terms for the impact on the environment as with the assessment for the human shows that the value for the reference plants and animals set based on the ICRP recommendation is $2\text{E-}05$ to $6\text{E-}05\text{mGy/day}$, which is much lower than 1 to 10mGy/day for flatfish and brown seaweeds and 10 to 100mGy/day for crabs, which as the derived consideration reference levels (DCRL) shown in the ICRP recommendation for the reference plants and animals.

Chapter 8 shows the uncertainty of this assessment result.

We will optimize the risks associated with disposal further as needed by the progress of design and implementation of the plan including rigorous selection of measurement target nuclides, using the knowledge obtained through reviews by experts of the IAEA, cross-checking with third parties, etc., and appropriately reflecting the opinions from various fields. Accordingly, we plan to revise the assessment of this report as needed.

References

- [1] International Atomic Energy Agency, IAEA Safety Standards Series No.GSG-9 "Regulatory Control of Radioactive Discharges to the Environment", 2018.
- [2] International Atomic Energy Agency, IAEA Safety Standards Series No.GSG-10 "Prospective Radiological Environmental Impact Assessment for Facilities and Activities", IAEA, 2018.
- [3] International Commission on Radiological Protection, 1990 Recommendations of the International Commission on Radiological Protection, ICRP Publication 60, 1990.
- [4] D.Tsumune, T.Tsubono, K.Misumi, Y.Tateda, Y.Toyoda, Y.Onda, and M.Aoyama, "Impacts of direct release and river discharge on oceanic ¹³⁷Cs derived from the Fukushima Dai-ichi Nuclear Power Plant accident", 2020.
- [5] Nuclear Safety Commission, Dose Assessment to the General Public in the Safety Review of Commercial Light Water Reactor Facilities, 1989.
- [6] Ministry of Health, Labour and Welfare, National Health and Nutrition Survey in Japan in 2019, 2020.
- [7] Ministerial Meeting on Decommissioning and Contaminated Water Measures, Mid- to Long-Term Roadmap towards Decommissioning of the Fukushima Daiichi Nuclear Power Station, 2019.
- [8] Tritiated Water Taskforce, Tritiated Water Taskforce Report, 2016.
- [9] Sub-committee on the Handling of ALPS Treated Water, Sub-committee on the Handling of ALPS Treated Water Report, 2020.
- [10] Ministerial Meeting on Decommissioning, Contaminated Water and Treated Water Measures, Basic Policy on handling of ALPS treated water at the Tokyo Electric Power Company Holdings' Fukushima Daiichi Nuclear Power Station, 2021.
- [11] Tokyo Electric Power Company Holdings, Inc., TEPCO Holdings' Action in Response to the Government's Policy on the Handling of ALPS Treated Water from the Fukushima Daiichi Nuclear Power Station, 2021.
- [12] Nuclear Regulation Authority, Concept and Assessment Guidelines for Verifications in the Radiological Impact Assessment, 2022.
- [13] International Atomic Energy Agency, General Safety Requirements Part 3, No. GSR Part 3, "Radiation Protection and Safety of Radiation Sources: International Basic Safety Standards", International Atomic Energy Agency, 2014.
- [14] L'Institut de Radioprotection et de Sûreté Nucléaire, Tritium and the environment, 2012.
- [15] Tokyo Electric Power Company Holdings, Inc., Results from secondary treatment performance confirmation tests on water treated with multi-nuclide removal equipment (final report), 2020.
- [16] International Commission on Radiological Protection, ICRP Publication 107, "Nuclear Decay Data for Dosimetric Calculations", 2008.
- [17] Tokyo Electric Power Company Holdings, Inc., TEPCO draft study responding to the Subcommittee Report on Handling ALPS Treated Water, 2020.
- [18] Atushi Hashimoto, Hiromaru Hiraguchi, Yasushi Toyoda, Ko Nakaya, Prediction of regional climate change over Japan due to global warming (part 1) Evaluation of Numerical Weather Forecasting and Analysis System (NuWFAS) applied to a long-term climate simulation, 2010.
- [19] W. C. Skamarock, J. B. Klemp, J. Dudhia, D. O. Gill, D. M. Barker, M. Duda, H. Huang, W. Wang and J. G. Powers, A description of the advanced research WRF version 3, NCAR Tech. Note NCAR/TN-475+STR, 113pp, 2008.

- [20] Y.Miyazawa, R.Zhang, X.Guo, H.Tamura, D.Ambe, J.-S.Lee, A.Okuno, H.Yoshinari, T.Setou, and K.Komatsu, Water mass variability in the western North Pacific detected in a 15-year eddy resolving ocean reanalysis, 2009.
- [21] Central Research Institute of Electric Power Industry, The environmental impact assessment technology investigation of decommissioning of reactor for power generation, attachment "the Handbook for Determining Environmental Impacts of Decommissioning Work (3rd edition)", 2006 consigned investigation of the Ministry of Economy, Trade and Industry, 2007.
- [22] Japan Nuclear Fuel Service, Application for the Designation of Reprocessing Business of Rokkasho Plant, 1989.
- [23] International Atomic Energy Agency, Determining the Suitability of Materials for Disposal at Sea under the London Convention 1972 and London Protocol 1996: A Radiological Assessment Procedure, 2015.
- [24] Decision by the Atomic Energy Commission, Guidelines for the Assessment of Dose Target Values Around Light Water Reactor Facilities, 1976.
- [25] International Atomic Energy Agency, Technical Reports Series No.422 "Sediment Distribution Coefficients and Concentration Factors for Biota in the Marine Environment", 2004.
- [26] Stanley E. Thompson, C. Ann Burton, Dorothy J. Quinn, Yook C. Ng, CONCENTRATION FACTORS OF CHEMICAL ELEMENTS IN EDIBLE AQUATIC ORGANISM, LAWRENCE LIVERMORE LABORATORY, 1972.
- [27] International Commission on Radiological Protection, ICRP Publication 101a, "Assessing Dose of the Representative Person for the Purpose of the Radiation Protection of the Public", 2006.
- [28] International Commission on Radiological Protection, ICRP Publication 124, "Protection of the Environment under Different Exposure Situations", 2013.
- [29] International Commission on Radiological Protection, ICRP Publication 136, "Dose Coefficients for Non-human Biota Environmentally Exposed to Radiation, 2017.
- [30] International Commission on Radiological Protection, "BiotaDC v.1.5.1," 2017. [Online]. Available: <http://biotadc.icrp.org/>.
- [31] International Commission on Radiological Protection, ICRP Publication 114, "Environmental Protection: Transfer Parameters for Reference Animals and Plants", 2019.
- [32] Environment Agency, 4th fundamental investigation for natural environment preservation - Environmental investigation report of marine organisms (Tideland, seaweed bed, and coral reef investigation), 1994.
- [33] Agency for Cultural Affairs, Emergency investigation of natural monuments, Vegetation map/Major plant and animal map, Fukushima, 1971.
- [34] Nuclear Regulation Authority, Pronouncement which set the dose limit based on the regulations such as the Regulations on Business of Smelting of Nuclear Source Materials or Nuclear Fuel Materials, 2015.

Terms

| Term | Description |
|---|---|
| Advanced liquid processing system (ALPS) | Water treatment facility which can purify 62 types of radioactive materials other than tritium contained in contaminated water up to a level which meets the standard set by laws. (Multi-Nuclide Removal Facility) |
| ALPS treated water | Water purified by ALPS, etc. so that the radioactive materials other than tritium surely fall below the regulatory standards for safety. (The sum of the ratios to regulatory concentrations limits of nuclides excluding tritium is less than 1) |
| Treated water to be purified | Water which is purified by ALPS, etc., but does not meet the regulatory standard for safety (The sum of the ratios to regulatory concentrations limits of nuclides excluding tritium is less than 1) |
| ALPS treated water, etc. | Generic term for ALPS treated water and treated water to be purified |
| Strontium treated water | Contaminated water with most of the cesium and strontium removed. |
| Secondary treatment | Purifying treated water to be purified in which radioactive materials other than tritium are not purified until the sum of the ratios to regulatory concentrations limits is less than 1 by ALPS, etc. |
| Groundwater bypass | Measure to reduce the amount of groundwater approaching the reactor building, etc., by pumping groundwater flowing from the mountain side to the sea side from a well far away from the reactor building, etc., and discharging it to the sea after verification that the discharge standard is met. |
| Subdrain | Measure to perform purification by pumping with the subdrain (well near the building) and discharge the sea after verification that the discharge standard is met, in order to reduce the amount of contaminated water increased by inflow of groundwater into the reactor building, etc. |
| Regulatory concentration limit | Standard of discharge of radioactive waste into the sea set in "Pronouncement which set the dose limit based on the regulations such as the Regulations on Business of Smelting of Nuclear Source Materials or Nuclear Fuel Materials." If the corresponding radioactive waste contains radioactive materials, the sum of the ratios to regulatory concentrations limits has to be less than 1. |
| Target discharge control value | Target control value set for each nuclide to be discharge in order to control the amount of radioactive materials discharged by the nuclear power plant per year. For the FDNPS, the target discharge control value of tritium before the accident is set to 22 TBq (2.2E+13Bq). |
| Operation and management value | Concentration limit value set by us for dose reduction for eight nuclides whose impacts on exposure are considered to be great at the time of disposal of ALPS treated water. If any concentration over this is detected, stop discharge and transfer the water to the storage tank. |
| WHO Guidelines for Drinking Water Quality | Guidelines for drinking water quality set by the World Health Organization for securing of the safety of drinking water. These guidelines show water quality which do not cause any problem when a person keep drinking the water from the viewpoints of radioactive materials, microorganisms, chemical substances, etc. As radioactive material concentrations, 10Bq/L and 10,000Bq/L are shown for Cs-137 and tritium, respectively. |
| International Commission on Radiological Protection (ICRP) recommendation | Document that shows the Basic Policy (concept) of radiation protection recommended by ICRP and the basic numerical standards. |

| Term | Description |
|--|--|
| International Atomic Energy Agency (IAEA) safety standard document | Document issued by the IAEA which shows the standards for protection of safety such as human health, lives, and assets in using radiation and radioactive materials as activities for securing nuclear safety. It consists of the safety principles, the safety requirements, the safety guidelines, etc., and shows the policy, the standards, etc., to follow. The IAEA safety standard document is prepared reflecting the comments of all IAEA member countries. |
| Representative person | Virtual person set as the target of exposure in the exposure assessment of public for consideration of radiation protection. Consider environments, life habits, etc., in which the exposure amounts increase, etc. |
| Potential exposure | Exposure caused by possible events in operation or events or possible events sequences including accidents of radiation sources or failures and operation mistakes of equipment. It was considered for the future. It is used for consideration of radiation protection. |
| An area where no fishing is conducted on a daily basis | Area where members of fisheries cooperatives jointly use a certain water area and rights to perform fishing (common fishery rights) are not established. Areas where common fishery rights are not established. |
| Area sea model | Numerical analysis model of tidal currents developed in Rutgers University in the U.S. |
| Submersion model | External exposure dose calculation model assuming the state that people are surrounded by radioactive materials (submersion). |
| Concentration factor | Expedient factor indicating the relationship between the radioactive nuclide concentration in marine organisms (per wet weight) in marine organisms (in principle, edible parts) and the radioactive nuclide concentration in the seawater in the environment where such organisms live, which is used for the assessment model for migration to organisms. |
| Dose conversion factor for the effective dose | Conversion factor to assess the human exposure amount from radiation from radioactive materials. |
| Effective dose factor | Conversion factor to assess the human internal exposure dose from the inhalation amount and ingestion of radioactive nuclides. |
| Environmental protection | Protecting organisms other than human from adverse effects of ionizing radiation. |
| Reference plants and animals | Specific types of animals and plants assumed in order to associate radiation exposure from the environment with the dose and impact. |
| Dose conversion coefficients for plants and animals | Conversion factor for simplified calculations of internal and external exposure doses to organism by radioactive nuclides in the environment. |
| Derived consideration reference level (DCRL) | Range of the dose rate with a range of one order of magnitude set for each species advocated by ICRP. Dose rate level at which the impact has to be considered if is exceeded. (Derived consideration reference level) |
| Concentration ratio | Migration factor from an empirical calculation of the ratio of the (overall) radioactive nuclide concentration in aquatic organisms to the underwater concentration in the environment to be used for radiation exposure to plants and animals from the environment. |
| Distribution coefficient | Ratio of radioactive materials at which the concentration in the seawater (Bq/L) and the concentration in the seabed sediment (Bq/kg) are in the equilibrium state. It is used for the assessment of migration of radioactive materials from the seawater to seabed sediment. |

Preparation member

For preparation of this report, in-house personnel with knowledge on the radiological impact assessment were appointed and external experts were invited as members in three fields, which are especially important for the radiological impact assessment: human radiation protection, environmental protection, and marine dispersion calculation.

- Sponsor

Junichi Matsumoto (Tokyo Electric Power Company Holdings, Inc.)

- Assessment member

Team leader: Tomomi Okamura (Tokyo Electric Power Company Holdings, Inc.)

Team members: Hideo Kiyooka (Tokyo Electric Power Company Holdings, Inc.)

Yuta Ichiba (Tokyo Electric Power Company Holdings, Inc.)

Ryota Taguchi (Tokyo Electric Power Company Holdings, Inc.)

Itsumasa Urabe (Professor Emeritus, Fukuyama University,
Environmental impact assessment)

Yutaka Tateda (Guest Research Fellow, Sustainable System
Research Laboratory, Central Research Institute of
Electric Power Industry, marine animals and plants
exposure assessment)

Takatoshi Hattori (Associate Vice President, Sustainable System
Research Laboratory, Central Research Institute of
Electric Power Industry, human exposure assessment)

Yukio Masumoto (Professor, The University of Tokyo, dispersion
calculation)

Daisuke Tsumune (Senior Research Scientist, Sustainable System
Research Laboratory, Central Research Institute of
Electric Power Industry, dispersion calculation)

- Observer

Tadafumi Koyama (Distinguished Research Scientist, Central Research
Institute of Electric Power Industry)

- Secretariat

Gaku Sato (Tokyo Electric Power Company Holdings, Inc.)

Katsuhisa Matsuzaki (Tokyo Electric Power Company Holdings, Inc.)

End

Attachment I Rationale behind the selection of nuclides subject to removal by ALPS

I-1. Selection of nuclides subject to removal

It is assumed that the water to be treated in the advanced liquid processing system (fresh water, RO concentrated salt water, and treatment device outlet water) contains radioactive materials derived from the fuel in the Units 1 to 3 reactors (hereinafter called "FP nuclide") and radioactive materials derived from corrosion products contained in the water retained during plant operation (hereinafter called "CP nuclide"). In order to reduce the risk of radiation exposure to the surrounding public area in the event of leakage of the water to be treated into the environment, it is necessary to estimate the nuclides present at high concentrations so that they can be removed by the advanced liquid processing system among FP nuclides and CP nuclides contained in the water to be treated.

Therefore, in estimating the concentration of radioactive materials contained in the water to be treated, for FP nuclides, nuclides assumed to exist at significant concentrations were selected based on the assessment results of the core inventory; for nuclides for which measurement of radioactive materials was carried out in March 2011, the concentration in the stagnant water was estimated from the measurement results; and for nuclides for which measurement was not carried out, the concentration in the stagnant water was estimated from the assessment results of the core inventory.

The concentration of CP nuclides in the stagnant water was estimated using the measurement results of CP nuclides in the water retained in the reactor and the concentrated waste liquid tank during plant operation, because nuclides contained in the water retained in the reactor during plant operation were transferred to the stagnant water, and it is considered that nuclides contained in the water retained in the concentrated waste liquid tank were mixed when the stagnant water was transferred to the high-temperature incinerator building. The operation of the advanced liquid processing system was assumed to be started 1 year (365 days) after reactor shutdown for both FP and CP nuclides, so the concentration in the stagnant water was estimated by decay correction 365 days after reactor shutdown considering the half-life. Comparing the estimated concentration obtained by decay correction at 365 days after reactor shutdown and nuclides over 1/100 of the regulatory concentration limit were selected as nuclides subject to removal by the advanced liquid processing system assuming that they exist at significant concentrations in the stagnant water. The sum of the ratio of the estimated concentration to the regulatory concentration limit of nuclides which are excluded because they are below 1/100 of the regulatory concentration limit is about 0.05 at maximum. Therefore the concentration of the excluded nuclides is considered to be sufficiently low.

I-2. Selection method and selection result of nuclides subject to removal

(1) Selection method and selection result of nuclides subject to removal from FP nuclides
Nuclides subject to removal from FP nuclides were selected according to the flow of Figure I-1. As a result, 56 nuclides were selected as nuclides subject to removal.

(2) Selection method and selection result of nuclides subject to removal from CP nuclides
Nuclides subject to removal from CP nuclides were selected according to the flow of Figure I-2. As a result, 6 nuclides were selected as nuclides subject to removal.

(3) Summary of the selection result of nuclides subject to removal

A total of 62 nuclides were selected: 56 nuclides selected from FP nuclides and 6 nuclides selected from CP nuclides (See Table I-1).




Figure I-1: Flow to select the nuclides subject to removal in FP nuclides

Step 1
 For nuclides to be measured in the radioactivity measurement of the water retained in Units 1 to 3 reactor building before the earthquake (January 2009 to February 2011) and listed in the pronouncement appendix*1, dilute the maximum measured value to 1/100, perform decay correction considering the half-life, and calculate the estimated concentration 365 after reactor shutdown.

Note) Ni-59, Ni-63, and Nb-94 of which concentrations can be estimated based on the theoretical calculation method and scaling factor method for homogeneous/uniform vitrified waste are estimated from the concentration of Co-60, which is a key nuclide, using the values converted from the theoretical calculation method and the scaling factor.

Step 2
 For nuclides to be measured in the radioactivity measurement of the water retained in the concentrated waste liquid tank before the earthquake (May 2010 to February 2011) and listed in the pronouncement appendix*1, dilute the maximum measured value to 1/100, perform decay correction considering the half-life, and calculate the estimated concentration 365 after reactor shutdown.

Note) Ni-59, Ni-63, and Nb-94 of which concentrations can be estimated based on the theoretical calculation method and scaling factor method for homogeneous/uniform vitrified waste are estimated from the concentration of Co-60, which is a key nuclide, using the values converted from the theoretical calculation method and the scaling factor.

*1 Pronouncement that sets the dose limit based on the regulations such as the Regulations on Business of Smelting of Nuclear Source Materials or Nuclear Fuel Materials (Column 6 of Appendix Table 1)

Step 3
 Whether the total value of the concentration of each nuclide calculated in steps 1 and 2 exceeds 1/100 of the regulatory concentration limit*2

*2 Underwater concentration limit out of the monitoring area in the pronouncement that sets the dose limit based on the regulations such as the Regulations on Business of Smelting of Nuclear Source Materials or Nuclear Fuel Materials (Column 6 of Appendix Table 1)

Nuclides subject to removal

Eliminated from the removal targets

Figure I-2 Flow to select the nuclides subject to removal in CP nuclides

Table I-1 List of the nuclides subject to removal

| No. | Nuclide | Physical half-life | Radiation type | No | Nuclide | Physical half-life | Radiation type |
|-----|---------|--------------------|----------------|----|---------|--------------------|----------------|
| 1 | Mn-54 | 310d | γ | 32 | I-129 | 1.6E+07y | $\beta\gamma$ |
| 2 | Fe-59 | 44 d | γ | 33 | Cs-134 | 2.1y | $\beta\gamma$ |
| 3 | Co-58 | 71d | γ | 34 | Cs-135 | 2.3E+06y | β |
| 4 | Co-60 | 5.3y | $\beta\gamma$ | 35 | Cs-136 | 13d | $\beta\gamma$ |
| 5 | Ni-63 | 100y | β | 36 | Cs-137 | 30y | $\beta\gamma$ |
| 6 | Zn-65 | 240d | $\beta\gamma$ | 37 | Ba-137m | 2.6m | γ |
| 7 | Rb-86 | 19d | $\beta\gamma$ | 38 | Ba-140 | 13d | $\beta\gamma$ |
| 8 | Sr-89 | 51d | β | 39 | Ce-141 | 33d | $\beta\gamma$ |
| 9 | Sr-90 | 29y | β | 40 | Ce-144 | 280d | $\beta\gamma$ |
| 10 | Y-90 | 64h | β | 41 | Pr-144 | 17m | $\beta\gamma$ |
| 11 | Y-91 | 59d | $\beta\gamma$ | 42 | Pr-144m | 7.2m | γ |
| 12 | Nb-95 | 35d | $\beta\gamma$ | 43 | Pm-146 | 5.5y | $\beta\gamma$ |
| 13 | Tc-99 | 2.1E+05y | β | 44 | Pm-147 | 2.6y | $\beta\gamma$ |
| 14 | Ru-103 | 39d | $\beta\gamma$ | 45 | Pm-148 | 5.4d | $\beta\gamma$ |
| 15 | Ru-106 | 370d | β | 46 | Pm-148m | 41d | γ |
| 16 | Rh-103m | 56m | $\beta\gamma$ | 47 | Sm-151 | 90y | $\beta\gamma$ |
| 17 | Rh-106 | 30s | γ | 48 | Eu-152 | 14y | $\beta\gamma$ |
| 18 | Ag-110m | 250d | $\beta\gamma$ | 49 | Eu-154 | 8.6y | $\beta\gamma$ |
| 19 | Cd-113m | 14 y | γ | 50 | Eu-155 | 4.8y | $\beta\gamma$ |
| 20 | Cd-115m | 45d | $\beta\gamma$ | 51 | Gd-153 | 240d | γ |
| 21 | Sn-119m | 290d | γ | 52 | Tb-160 | 72d | $\beta\gamma$ |
| 22 | Sn-123 | 130d | $\beta\gamma$ | 53 | Pu-238 | 88y | α |
| 23 | Sn-126 | 2.3E+05y | $\beta\gamma$ | 54 | Pu-239 | 2.4E+04y | α |
| 24 | Sb-124 | 60d | $\beta\gamma$ | 55 | Pu-240 | 6.6E+03y | α |
| 25 | Sb-125 | 2.8y | $\beta\gamma$ | 56 | Pu-241 | 14y | β |
| 26 | Te-123m | 120d | γ | 57 | Am-241 | 430y | α |
| 27 | Te-125m | 57d | γ | 58 | Am-242m | 140y | α |
| 28 | Te-127 | 9.4h | $\beta\gamma$ | 59 | Am-243 | 7.4E+03y | α |
| 29 | Te-127m | 110d | $\beta\gamma$ | 60 | Cm-242 | 160d | α |
| 30 | Te-129 | 70m | $\beta\gamma$ | 61 | Cm-243 | 29y | α |
| 31 | Te-129m | 34d | $\beta\gamma$ | 62 | Cm-244 | 18y | α |

Attachment II Properties of ALPS treated water, etc.


At the FDNPS, the sequence of events of the station since the accident has led to various analyses. Various analyses also have been conducted on the treatment of contaminated water, which is very complicated.

This section describes the overview of contaminated water treatment and the analysis result of the properties of ALPS treated water.

II-1. Overview of the occurrence of contaminated water (stagnant water in the building) and the system of the contaminated water treatment facility

In the FDNPS, the residual fuel debris in the building is cooled with water, and mixing of the cooling water and the groundwater or rainwater entering the building causes contaminated water. The daily average amount of contaminated water was reduced to about 140m³ in the result of FY2020 thanks to the reduction of water entering the reactor building by countermeasures such as land side impermeable wall (frozen soil wall) and sub-drains.

To reduce the risks caused by radioactive materials contained in contaminated water, at first cesium and strontium were removed preferentially, which accounts for most of the radioactive materials contained in contaminated water, using cesium adsorption devices such as Kurion and SARRY. After that, water desalinated with desalination devices is recirculated for cooling the burst slug in the core, and the residual concentrated water is treated with the advanced liquid processing system (hereinafter called "ALPS") as "strontium treated water (water before treated by ALPS)" to remove the 62 nuclides subject to removal, which accounts for most of the nuclides, other than tritium, and then stored in tanks installed on high ground.



* ALPS treated water, etc., which is purified with the advanced liquid processing system, etc., until the radioactive materials other than tritium surely fall below the regulatory limit of safety is defined as "ALPS treated water," and the other water as "treated water to be purified"

Figure II-1 Overall outline figure of contaminated water treatment

II-2. Overview of the system of ALPS

ALPS is designed to be able to remove up to less than the regulatory concentration limit without dilution of the 62 nuclides¹ estimated to be contained in the above-mentioned strontium treated water at such high concentrations that they should be removed except tritium, which ALPS cannot remove, by treatment using physical and chemical properties such as coprecipitation with chemicals, adsorption by active carbon and physical materials, and filtration with a physical filter; this capability has already been demonstrated through the actual operation (For details of the performance, see II-3. "Performance of ALPS").

In the FDNPS, three types of ALPS are installed: existing ALPS, additional ALPS, and high-performance ALPS. Since all of them have similar removal performance (DF: decontamination factor), current treatment is performed mainly in the existing and additional ALPS considering ease of adjustments of the treatment amount. Table II-1 shows the overview of ALPS.

Table II-1 Overview of the facility of ALPS

| Name | Put into service | Capacity | Characteristics |
|------------------------------|------------------|--|---|
| Existing ALPS | 2013.3 | 250m ³ /day/series × 3 series (Total: 750m ³ /day) | After putting into service, added adsorption vessels and changed the adsorption material to improve the performance |
| Additional ALPS | 2014.9 | 250m ³ /day/series × 3 series (Total: 750m ³ /day) | Deleted iron coprecipitation by pretreatment with the existing ALPS and performed addition of adsorption vessels, change of the adsorption material, etc. |
| High-performance ALPS | 2014.10 | 500m ³ /day/series × 1 series (Total: 500m ³ /day) | Unlike the existing and additional ones, this has no coprecipitation process |

Table II-2 shows the overview of the nuclide removal system of ALPS.

Table II-2 Overview of the nuclide Removal system with ALPS

| Removal system | Main nuclides subject to removal | Role |
|---|---|--|
| Pretreatment facilities | Iron coprecipitation treatment (Existing ALPS only) | α nuclides, Co-60, and Mn-54 Decomposition of the complexes that inhibit adsorption, and removal of heavy metal and α nuclides, etc., by iron coprecipitation |
| | Carbonate coprecipitation treatment (excluding the high-performance ALPS) | Adsorption inhibition ions (Mg, Ca, etc.) Sr-89/90 Remove the inhibition ions of Sr adsorption and improve the Sr removal performance by adsorption |
| Advanced liquid processing system (Adsorption) | Active carbon | Colloidal nuclides (I-129, Co-60, etc.) Remove the nuclides that have various ionic and colloidal forms with multiple types of adsorption materials |
| | Sr adsorbent | Sr-89/90 |
| | Cs adsorbent | Cs-134/137 |

¹ For details of the selection process and the selected nuclides, see Attachment I "Rationale behind the selection of nuclides subject to removal by ALPS."

| | | | |
|---------|----------------|-----------------------------------|--|
| vessel) | I,Sb adsorbent | I-129 (IO ³⁻), Sb-125 | |
| | I adsorbent | I-129(I ⁻) | |
| | Ru adsorbent | Ru-106 | |

ALPS is operated efficiently by backing up the subsequent adsorption vessels in the case of break-through of the first vessel and changing the order of the adsorption vessels by merry-go-round operation of some of the adsorption vessels. Figure II-2 shows an example of an adsorption vessel composition² and Figure III-3 the details of the merry-go-round operation of some of the adsorption vessels.




Figure II-2 Example of an adsorption vessel composition (example as of September 2018)




Figure II-3 Image of replacement and operation of the adsorption material (merry-go-round operation) (for a composition of three adsorption vessels)

² The composition of the adsorption vessels has been reassessed as needed according to the properties of water to be treated, etc.

II-3. Performance of ALPS

In ALPS, the concentrations of radioactive materials, mainly 7 nuclides (Cs-134, Cs-137, Co-60, Sb-125, Ru-106, Sr-90, I-129) which are nuclides to removal by ALPS and significantly detected nuclides through the process of treatment, at the facility inlet and outlet are measured ((1) and (7) in the figure) to verify the removal performance of radioactive materials, as well as in the middle of the treatment process to verify the break-through trend of the adsorption vessels ((2) to (6) in the figure)³. Details of this measurement are shown in Figure II-4.




Figure II-4 Measurement performed in ALPS

After the start of the operation of ALPS, about 70% of the treated water contains radioactive properties over the sum of the ratios to regulatory concentrations limits of 1 due to various circumstances (see II-7, "Reason for generation of treated water to be purified"), but ALPS has been working properly except special circumstances.

Figure II-5-1 to 13 show the trend regarding the measurement results of the inlet and outlet of

³ The measurement items and measurement frequency have been reassessed as needed according to the properties of water to be treated, etc.

ALPS for the seven major nuclides, etc. Especially after 2019, in which the above-mentioned special circumstances disappeared, ALPS has been operated stably and each nuclide has been removed stably and appropriately.




Figure II-5-1 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Cs-137)
 (*1 ND indicates less than the detection limit.)






Figure II-5-2 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Cs-134)
 (*1 ND indicates less than the detection limit.)






Figure II-5-3 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Sr-90)
 (*1 ND indicates less than the detection limit.)




Figure II-5-4 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Co-60)
 (*1 ND indicates less than the detection limit.)






Figure II-5-5 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Sb-125)
 (*1 ND indicates less than the detection limit.)






Figure II-5-6 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Ru-106)
 (*1 ND indicates less than the detection limit.)






Figure II-5-7 Radioactive concentration in the inlet and outlet of each advanced liquid processing system I-129
 (*1 ND indicates less than the detection limit.)






Figure II-5-8 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Total beta nuclide)
 (*1 ND indicates less than the detection limit.)






Figure II-5-9 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Mn-54)
 (*1 ND indicates less than the detection limit.)






Figure II-5-10 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Sr-89)
 (*1 ND indicates less than the detection limit.)




Figure II-5-11 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Tc-99)
 (*1 ND indicates less than the detection limit.)




Figure II-5-12 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (C-14)
 (*1 ND indicates less than the detection limit.)






Figure II-5-13 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Rh-106)
 (*1 ND indicates less than the detection limit.)






Figure II-5-14 Radioactive concentration in the inlet and outlet of each advanced liquid processing system (Total alpha nuclide)
 (*1 ND indicates less than the detection limit.)

II-4. Secondary treatment performance of ALPS for treated water to be purified

II-4-1 Background of the secondary performance test

As of now, approx. 70% of the water stored in the FDNPS is water of which sum of the ratios to regulatory concentrations limits is assessed to be 1 or more (so-called “treated water to be purified”) due to the various reasons shown in II-7. As described in the section about the discharge method in the main text, the secondary treatment of this treated water to be purified is surely performed before discharge to verify that sum of the ratios to regulatory concentrations limits other than tritium before dilution is less than 1.

ALPS is designed to be able to treat strontium treated water with a high radioactive material concentration, etc., and its capability to remove radioactive materials has been proven in actual operation, but there was an opinion that the secondary treatment of ALPS was very important and it should be proven immediately with measured values that radioactive materials other than tritium can be removed by secondary treatment up to the sum of the ratios to regulatory concentration limits of less than 1⁴.

In response to this opinion, we decided to perform the secondary treatment test of treated water to be purified of a high concentration (sum of the ratios to regulatory concentrations limits of 100 or more) in ALPS, and started the secondary treatment performance test using the additional ALPS in September 2020 and completed it by December of the same year.

II-4-2 Overview of the secondary performance test

In this secondary treatment performance test, two tank groups (J1-C tank group as the high concentration side (sum of the ratios to regulatory concentrations limits: approx. 2,400) and J1-G tank group as the low concentration side (sum of the ratios to regulatory concentrations limits: approx. 390)) were selected from the tank groups of the sum of the ratios to regulatory concentrations limits of 100 or higher, and 1,000m³ was treated from each of the tanks. For the piping used for the transfer, water replacement operation already included in the system was performed before the test.

Afterward, the treated water was sampled and the concentrations of the 62 nuclides subject to removal by ALPS, C-14, and tritium were measured to verify that the sum of the ratios to regulatory concentrations limits of the 63 nuclides except tritium became less than 1 by secondary treatment, and the procedure and process of the nuclide analysis were performed.

II-4-3 Result of the secondary performance test

Table II-3 and 4 show the results. It was verified that the sum of the ratios to regulatory concentrations limits of any treated water to be purified became less than 1 by secondary treatment.

⁴ Minutes of the 17th Subcommittee on Handling of the ALPS treated water p.11

Table II-3 Secondary treatment performance test result by ALPS (J1-C tank group)

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁵ | | After secondary treatment ⁶ | | Remarks |
|-------------------------------|--|---|--|---|--|--|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| H-3 (About 12 years) | 6.0E+04 | 8.51E+05 | 1.4E+01 | 8.22E+05 | 1.4E+01 | Dilute to less than 1,500Bq/L before discharge |
| C-14 (About 5700 years) | 2.0E+03 | 1.53E+01 | 7.6E-03 | 1.76E+01 | 8.8E-03 | |
| Mn-54 (About 310 days) | 1.0E+03 | < 3.62E-01 | 3.6E-04 | < 3.83E-02 | 3.8E-05 | |
| Fe-59 (About 44 days) | 4.0E+02 | < 6.41E-01 | 1.6E-03 | < 8.66E-02 | 2.2E-04 | |
| Co-58 (About 71 days) | 1.0E+03 | < 3.44E-01 | 3.4E-04 | < 4.11E-02 | 4.1E-05 | |
| Co-60 (About 5.3 years) | 2.0E+02 | 3.63E+01 | 1.8E-01 | 3.33E-01 | 1.7E-03 | |
| Ni-63 (About 100 days) | 6.0E+03 | 5.19E+01 | 8.6E-03 | < 8.45E+00 | 1.4E-03 | |
| Zn-65 (About 240 days) | 2.0E+02 | < 7.19E-01 | 3.6E-03 | < 9.41E-02 | 4.7E-04 | |
| Rb-86 (About 19 days) | 3.0E+02 | < 4.11E+00 | 1.4E-02 | < 4.97E-01 | 1.7E-03 | |
| Sr-89 (About 51 days) | 3.0E+02 | < 6.72E+03 | 2.2E+01 | < 5.37E-02 | 1.8E-04 | |

⁵ Composite (mixing/stirring) was performed for the samples collected between September 19 and 21, 2020, and then analysis was performed.

⁶ Samples were collected on September 27, 2020, and then analysis was performed.

⁷ If the result falls below the lower limit of detection, describe the lower limit of detection following "<."

⁸ If the analysis result is less than the lower limit of detection, the lower limit of detection is used for the calculation.

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁵ | | After secondary treatment ⁶ | | Remarks |
|---|--|---|--|---|--|---|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| Sr-90 (About 29 years) | 3.0E+01 | 6.46E+04 | 2.2E+03 | 3.57E-02 | 1.2E-03 | |
| Y-90 (About 64 hours) | 3.0E+02 | 6.46E+04 | 2.2E+02 | 3.57E-02 | 1.2E-04 | Radioactive equilibrium with Sr-90 |
| Y-91 (About 59 days) | 3.0E+02 | < 8.45E+01 | 2.8E-01 | < 1.65E+01 | 5.5E-02 | |
| Nb-95 (About 35 days) | 1.0E+03 | < 3.50E-01 | 3.5E-04 | < 4.96E-02 | 5.0E-05 | |
| Tc-99 (About 210 thousand years) | 1.0E+03 | 1.74E+01 | 1.7E-02 | < 1.23E+00 | 1.2E-03 | |
| Ru-103 (About 39 days) | 1.0E+03 | < 7.21E-01 | 7.2E-04 | < 5.27E-02 | 5.3E-05 | |
| Ru-106 (About 370 days) | 1.0E+02 | < 5.00E+00 | 5.0E-02 | < 1.43E+00 | 1.4E-02 | |
| Rh-103m (About 56 minutes) | 2.0E+05 | < 7.21E-01 | 3.6E-06 | < 5.27E-02 | 2.6E-07 | Radioactive equilibrium with Ru-103 |
| Rh-106 (About 30 seconds) | 3.0E+05 | < 5.00E+00 | 1.7E-05 | < 1.43E+00 | 4.8E-06 | Radioactive equilibrium with Ru-106 |
| Ag-110m (About 250 days) | 3.0E+02 | < 5.41E-01 | 1.8E-03 | < 4.26E-02 | 1.4E-04 | |
| Cd-113m (About 14 years) | 4.0E+01 | < 2.05E+01 | 5.1E-01 | < 8.52E-02 | 2.1E-03 | |
| Cd-115m (45 days) | 3.0E+02 | < 2.26E+01 | 7.5E-02 | < 2.70E+00 | 9.0E-03 | |
| Sn-119m (About 290 days) | 2.0E+03 | < 3.90E+02 | 1.9E-01 | < 4.24E+01 | 2.1E-02 | Assessed from the radioactive concentration of Sn-123 |
| Sn-123 (About 130 days) | 4.0E+02 | < 6.06E+01 | 1.5E-01 | < 6.59E+00 | 1.6E-02 | |
| Sn-126 (About 230 thousand years) | 2.0E+02 | < 2.88E+00 | 1.4E-02 | < 2.92E-01 | 1.5E-03 | |
| Sb-124 (About 60 days) | 3.0E+02 | < 2.79E-01 | 9.3E-04 | < 9.67E-02 | 3.2E-04 | |
| Sb-125 (About 2.8 years) | 8.0E+02 | 8.30E+01 | 1.0E-01 | 2.26E-01 | 2.8E-04 | |
| Te-123m (About 120 days) | 6.0E+02 | < 8.32E-01 | 1.4E-03 | < 9.19E-02 | 1.5E-04 | |

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁵ | | After secondary treatment ⁶ | | Remarks |
|--|--|---|--|---|--|---|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| Te-125m (About 57 days) | 9.0E+02 | 8.30E+01 | 9.2E-02 | 2.26E-01 | 2.5E-04 | Radioactive equilibrium with Sb-125 |
| Te-127 (About 9.4 hours) | 5.0E+03 | < 7.25E+01 | 1.5E-02 | < 4.69E+00 | 9.4E-04 | |
| Te-127m (About 110 days) | 3.0E+02 | < 7.53E+01 | 2.5E-01 | < 4.87E+00 | 1.6E-02 | Assessed from the radioactive concentration of Te-127 |
| Te-129 (About 70 minutes) | 1.0E+04 | < 1.27E+01 | 1.3E-03 | < 6.15E-01 | 6.1E-05 | |
| Te-129m (About 34 days) | 3.0E+02 | < 1.31E+01 | 4.4E-02 | < 1.37E+00 | 4.6E-03 | |
| I-129 (About 16 million years) | 9.0E+00 | 2.99E+01 | 3.3E+00 | 1.16E+00 | 1.3E-01 | |
| Cs-134 (About 2.1 years) | 6.0E+01 | < 2.93E+01 | 4.9E-01 | < 7.60E-02 | 1.3E-03 | |
| Cs-135 (About 2.3 million years) | 6.0E+02 | 3.81E-03 | 6.4E-06 | < 1.18E-06 | 2.0E-09 | Assessed from the radioactive concentration of Cs-137 |
| Cs-136 (About 13 days) | 3.0E+02 | < 3.77E-01 | 1.3E-03 | < 4.68E-02 | 1.6E-04 | |
| Cs-137 (About 30 years) | 9.0E+01 | < 5.99E+02 | 6.7E+00 | < 1.85E-01 | 2.1E-03 | |
| Ba-137m (About 2.6 minutes) | 8.0E+05 | 5.99E+02 | 7.5E-04 | < 1.85E-01 | 2.3E-07 | Radioactive equilibrium with Cs-137 |
| Ba-140 (About 13 days) | 3.0E+02 | < 2.40E+00 | 8.0E-03 | < 2.02E-01 | 6.7E-04 | |
| Ce-141 (About 33 days) | 1.0E+03 | < 1.51E+00 | 1.5E-03 | < 2.62E-01 | 2.6E-04 | |
| Ce-144 (About 280 days) | 2.0E+02 | < 6.84E+00 | 3.4E-02 | < 5.69E-01 | 2.8E-03 | |
| Pr-144 (About 17 minutes) | 2.0E+04 | < 6.84E+00 | 3.4E-04 | < 5.69E-01 | 2.8E-05 | Radioactive equilibrium with Ce-144 |
| Pr-144m (About 7.2 minutes) | 4.0E+04 | < 6.84E+00 | 1.7E-04 | < 5.69E-01 | 1.4E-05 | Radioactive equilibrium with Ce-144 |
| Pm-146 (About 5.5 years) | 9.0E+02 | < 1.23E+00 | 1.4E-03 | < 6.66E-02 | 7.4E-05 | |
| Pm-147 (About 2.6 years) | 3.0E+03 | < 4.08E+00 | 1.4E-03 | < 8.04E-01 | 2.7E-04 | Assessed from the radioactive concentration of Eu-154 |

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁵ | | After secondary treatment ⁶ | | Remarks |
|---|--|---|--|---|--|---|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| Pm-148 (About 5.4 days) | 3.0E+02 | < 6.49E-01 | 2.2E-03 | < 2.33E-01 | 7.8E-04 | |
| Pm-148m (About 41 days) | 5.0E+02 | < 6.34E-01 | 1.3E-03 | < 4.84E-02 | 9.7E-05 | |
| Sm-151 (About 90 years) | 8.0E+03 | < 5.77E-02 | 7.2E-06 | < 1.14E-02 | 1.4E-06 | Assessed from the radioactive concentration of Eu-154 |
| Eu-152 (About 14 years) | 6.0E+02 | < 2.70E+00 | 4.5E-03 | < 2.84E-01 | 4.7E-04 | |
| Eu-154 (About 8.6 years) | 4.0E+02 | < 5.77E-01 | 1.4E-03 | < 1.14E-01 | 2.8E-04 | |
| Eu-155 (About 4.8 years) | 3.0E+03 | < 3.43E+00 | 1.1E-03 | < 3.36E-01 | 1.1E-04 | |
| Gd-153 (About 240 days) | 3.0E+03 | < 3.17E+00 | 1.1E-03 | < 2.64E-01 | 8.8E-05 | |
| Tb-160 (About 72 days) | 5.0E+02 | < 1.66E+00 | 3.3E-03 | < 1.43E-01 | 2.9E-04 | |
| Pu-238 (About 88 years) | 4.0E+00 | < 5.70E-01 | 1.4E-01 | < 3.25E-02 | 8.1E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-239 (About 24000 years) | 4.0E+00 | < 5.70E-01 | 1.4E-01 | < 3.25E-02 | 8.1E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-240 (About 6600 years) | 4.0E+00 | < 5.70E-01 | 1.4E-01 | < 3.25E-02 | 8.1E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-241 (About 14 years) | 2.0E+02 | < 2.07E+01 | 1.0E-01 | < 1.18E+00 | 5.9E-03 | Assessed from the radioactive concentration of Pu-238 |
| Am-241 (About 430 years) | 5.0E+00 | < 5.70E-01 | 1.1E-01 | < 3.25E-02 | 6.5E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Am-242m (About 140 years) | 5.0E+00 | < 1.03E-02 | 2.1E-03 | < 5.87E-04 | 1.2E-04 | Assessed from the radioactive concentration of Am-241 |
| Am-243 (About 7400 years) | 5.0E+00 | < 5.70E-01 | 1.1E-01 | < 3.25E-02 | 6.5E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-242 (About 160 days) | 6.0E+01 | < 5.70E-01 | 9.5E-03 | < 3.25E-02 | 5.4E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-243 (About 29 years) | 6.0E+00 | < 5.70E-01 | 9.5E-02 | < 3.25E-02 | 5.4E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-244 (About 18 years) | 7.0E+00 | < 5.70E-01 | 8.1E-02 | < 3.25E-02 | 4.6E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Sum of the ratios to regulatory concentrations limits of nuclides other than tritium | | - | 2.4E+03 | - | 3.5E-01 | |

Table II-4 Secondary treatment performance test result by ALPS (J1-G tank group)

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁹ | | After secondary treatment ¹⁰ | | Remarks |
|--|--|---|--|---|--|--|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| H-3 (About 12 years) | 6.0E+04 | 2.73E+05 | 4.6E+00 | 2.72E+05 | 4.5E+00 | Dilute to less than 1,500Bq/L before discharge |
| C-14 (About 5700 years) | 2.0E+03 | 1.26E+01 | 6.3E-03 | 1.56E+01 | 7.8E-03 | |
| Mn-54 (About 310 days) | 1.0E+03 | < 2.02E-01 | 2.0E-04 | < 3.79E-02 | 3.8E-05 | |
| Fe-59 (About 44 days) | 4.0E+02 | < 3.51E-01 | 8.8E-04 | < 7.17E-02 | 1.8E-04 | |
| Co-58 (About 71 days) | 1.0E+03 | < 2.11E-01 | 2.1E-04 | < 3.74E-02 | 3.7E-05 | |
| Co-60 (About 5.3 years) | 2.0E+02 | 1.31E+01 | 6.5E-02 | 2.33E-01 | 1.2E-03 | |
| Ni-63 (About 100 days) | 6.0E+03 | < 1.84E+01 | 3.1E-03 | < 8.84E+00 | 1.5E-03 | |
| Zn-65 (About 240 days) | 2.0E+02 | < 4.35E-01 | 2.2E-03 | < 7.97E-02 | 4.0E-04 | |
| Rb-86 (About 19 days) | 3.0E+02 | < 2.56E+00 | 8.5E-03 | < 4.67E-01 | 1.6E-03 | |
| Sr-89 (About 51 days) | 3.0E+02 | < 7.87E+02 | 2.6E+00 | < 4.52E-02 | 1.5E-04 | |
| Sr-90 (About 29 years) | 3.0E+01 | 1.04E+04 | 3.5E+02 | < 3.18E-02 | 1.1E-03 | |
| Y-90 (About 64 hours) | 3.0E+02 | 1.04E+04 | 3.5E+01 | < 3.18E-02 | 1.1E-04 | Radioactive equilibrium with Sr-90 |
| Y-91 (About 59 days) | 3.0E+02 | < 4.82E+01 | 1.6E-01 | < 1.18E+01 | 3.9E-02 | |
| Nb-95 (About 35 days) | 1.0E+03 | < 2.56E-01 | 2.6E-04 | < 4.70E-02 | 4.7E-05 | |
| Tc-99 (About 210 thousand years) | 1.0E+03 | 1.20E+00 | 1.2E-03 | < 1.29E+00 | 1.3E-03 | |
| Ru-103 (About 39 days) | 1.0E+03 | < 3.39E-01 | 3.4E-04 | < 5.06E-02 | 5.1E-05 | |

⁹ Composite (mixing/stirring) was performed for the samples collected between October 5 and 7, 2020, and then analysis was performed.

¹⁰ Samples were collected on October 13, 2020, and then analysis was performed.

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁹ | | After secondary treatment ¹⁰ | | Remarks |
|---|--|---|--|---|--|---|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| Ru-106 (About 370 days) | 1.0E+02 | < 2.27E+00 | 2.3E-02 | 4.83E-01 | 4.8E-03 | |
| Rh-103m (About 56 minutes) | 2.0E+05 | < 3.39E-01 | 1.7E-06 | < 5.06E-02 | 2.5E-07 | Radioactive equilibrium with Ru-103 |
| Rh-106 (About 30 seconds) | 3.0E+05 | < 2.27E+00 | 7.6E-06 | 4.83E-01 | 1.6E-06 | Radioactive equilibrium with Ru-106 |
| Ag-110m (About 250 days) | 3.0E+02 | < 2.92E-01 | 9.7E-04 | < 4.00E-02 | 1.3E-04 | |
| Cd-113m (About 14 years) | 4.0E+01 | < 2.04E+01 | 5.1E-01 | < 8.55E-02 | 2.1E-03 | |
| Cd-115m (45 days) | 3.0E+02 | < 1.16E+01 | 3.9E-02 | < 2.29E+00 | 7.6E-03 | |
| Sn-119m (About 290 days) | 2.0E+03 | < 2.13E+02 | 1.1E-01 | < 4.03E+01 | 2.0E-02 | Assessed from the radioactive concentration of Sn-123 |
| Sn-123 (About 130 days) | 4.0E+02 | < 3.31E+01 | 8.3E-02 | < 6.26E+00 | 1.6E-02 | |
| Sn-126 (About 230 thousand years) | 2.0E+02 | < 1.16E+00 | 5.8E-03 | < 1.47E-01 | 7.3E-04 | |
| Sb-124 (About 60 days) | 3.0E+02 | < 2.20E-01 | 7.3E-04 | < 8.42E-02 | 2.8E-04 | |
| Sb-125 (About 2.8 years) | 8.0E+02 | 3.23E+01 | 4.0E-02 | 1.37E-01 | 1.7E-04 | |
| Te-123m (About 120 days) | 6.0E+02 | < 3.83E-01 | 6.4E-04 | < 6.67E-02 | 1.1E-04 | |
| Te-125m (About 57 days) | 9.0E+02 | 3.23E+01 | 3.6E-02 | 1.37E-01 | 1.5E-04 | Radioactive equilibrium with Sb-125 |
| Te-127 (About 9.4 hours) | 5.0E+03 | < 3.53E+01 | 7.1E-03 | < 4.33E+00 | 8.7E-04 | |
| Te-127m (About 110 days) | 3.0E+02 | < 3.67E+01 | 1.2E-01 | < 4.50E+00 | 1.5E-02 | Assessed from the radioactive concentration of Te-127 |
| Te-129 (About 70 minutes) | 1.0E+04 | < 4.71E+00 | 4.7E-04 | < 5.94E-01 | 5.9E-05 | |
| Te-129m (About 34 days) | 3.0E+02 | < 6.61E+00 | 2.2E-02 | < 1.21E+00 | 4.0E-03 | |
| I-129 (About 16 million years) | 9.0E+00 | 2.79E+00 | 3.1E-01 | 3.28E-01 | 3.6E-02 | |
| Cs-134 (About 2.1 years) | 6.0E+01 | 5.94E+00 | 9.9E-02 | < 6.65E-02 | 1.1E-03 | |

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁹ | | After secondary treatment ¹⁰ | | Remarks |
|--|--|---|--|---|--|---|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| Cs-135 (About 2.3 million years) | 6.0E+02 | 7.51E-04 | 1.3E-06 | 2.10E-06 | 3.5E-09 | Assessed from the radioactive concentration of Cs-137 |
| Cs-136 (About 13 days) | 3.0E+02 | < 1.96E-01 | 6.5E-04 | < 3.63E-02 | 1.2E-04 | |
| Cs-137 (About 30 years) | 9.0E+01 | 1.18E+02 | 1.3E+00 | 3.29E-01 | 3.7E-03 | |
| Ba-137m (About 2.6 minutes) | 8.0E+05 | 1.18E+02 | 1.5E-04 | 3.29E-01 | 4.1E-07 | Radioactive equilibrium with Cs-137 |
| Ba-140 (About 13 days) | 3.0E+02 | < 1.22E+00 | 4.1E-03 | < 1.73E-01 | 5.8E-04 | |
| Ce-141 (About 33 days) | 1.0E+03 | < 9.39E-01 | 9.4E-04 | < 1.19E-01 | 1.2E-04 | |
| Ce-144 (About 280 days) | 2.0E+02 | < 3.02E+00 | 1.5E-02 | < 5.53E-01 | 2.8E-03 | |
| Pr-144 (About 17 minutes) | 2.0E+04 | < 3.02E+00 | 1.5E-04 | < 5.53E-01 | 2.8E-05 | Radioactive equilibrium with Ce-144 |
| Pr-144m (About 7.2 minutes) | 4.0E+04 | < 3.02E+00 | 7.6E-05 | < 5.53E-01 | 1.4E-05 | Radioactive equilibrium with Ce-144 |
| Pm-146 (About 5.5 years) | 9.0E+02 | < 5.26E-01 | 5.8E-04 | < 6.30E-02 | 7.0E-05 | |
| Pm-147 (About 2.6 years) | 3.0E+03 | < 2.53E+00 | 8.4E-04 | < 7.20E-01 | 2.4E-04 | Assessed from the radioactive concentration of Eu-154 |
| Pm-148 (About 5.4 days) | 3.0E+02 | < 5.19E-01 | 1.7E-03 | < 4.52E-01 | 1.5E-03 | |
| Pm-148m (About 41 days) | 5.0E+02 | < 2.76E-01 | 5.5E-04 | < 4.09E-02 | 8.2E-05 | |
| Sm-151 (About 90 years) | 8.0E+03 | < 3.57E-02 | 4.5E-06 | < 1.02E-02 | 1.3E-06 | Assessed from the radioactive concentration of Eu-154 |
| Eu-152 (About 14 years) | 6.0E+02 | < 1.21E+00 | 2.0E-03 | < 1.90E-01 | 3.2E-04 | |
| Eu-154 (About 8.6 years) | 4.0E+02 | < 3.57E-01 | 8.9E-04 | < 1.02E-01 | 2.5E-04 | |
| Eu-155 (About 4.8 years) | 3.0E+03 | < 1.38E+00 | 4.6E-04 | < 1.75E-01 | 5.8E-05 | |
| Gd-153 (About 240 days) | 3.0E+03 | < 1.21E+00 | 4.0E-04 | < 1.85E-01 | 6.2E-05 | |
| Tb-160 (About 72 days) | 5.0E+02 | < 6.88E-01 | 1.4E-03 | < 1.35E-01 | 2.7E-04 | |

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Before secondary treatment ⁹ | | After secondary treatment ¹⁰ | | Remarks |
|--|--|---|--|---|--|--|
| | | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | Analysis result ⁷ [Bq/L] | Ratio to regulatory limit ⁸ | |
| Pu-238 (About 88 years) | 4.0E+00 | < 3.19E-02 | 8.0E-03 | < 2.80E-02 | 7.0E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-239 (About 24000 years) | 4.0E+00 | < 3.19E-02 | 8.0E-03 | < 2.80E-02 | 7.0E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-240 (About 6600 years) | 4.0E+00 | < 3.19E-02 | 8.0E-03 | < 2.80E-02 | 7.0E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-241 (About 14 years) | 2.0E+02 | < 1.16E+00 | 5.8E-03 | < 1.02E+00 | 5.1E-03 | Assessed from the radioactive concentration of Pu-238 |
| Am-241 (About 430 years) | 5.0E+00 | < 3.19E-02 | 6.4E-03 | < 2.80E-02 | 5.6E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Am-242m (About 140 years) | 5.0E+00 | < 5.77E-04 | 1.2E-04 | < 5.05E-04 | 1.0E-04 | Assessed from the radioactive concentration of Am-241 |
| Am-243 (About 7400 years) | 5.0E+00 | < 3.19E-02 | 6.4E-03 | < 2.80E-02 | 5.6E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-242 (About 160 days) | 6.0E+01 | < 3.19E-02 | 5.3E-04 | < 2.80E-02 | 4.7E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-243 (About 29 years) | 6.0E+00 | < 3.19E-02 | 5.3E-03 | < 2.80E-02 | 4.7E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-244 (About 18 years) | 7.0E+00 | < 3.19E-02 | 4.6E-03 | < 2.80E-02 | 4.0E-03 | Assessed as included in the measurement value of the total α radioactivity |
| Sum of the ratios to regulatory concentrations limits of nuclides other than tritium | | - | 3.9E+02 | - | 2.2E-01 | |

II-5. Analysis of the radioactive materials in the stored ALPS treated water, etc.

As shown in II-3. "Performance of ALPS", in measured point (7) of the ALPS outlet, mainly the seven nuclides detected significantly in the process of treatment among those subject to removal by ALPS (Cs-134, Cs-137, Co-60, Sb-125, Ru-106, Sr-90, and I-129) were measured. The result is shown on our web site.

Our web site:

<https://www.tepco.co.jp/decommission/progress/watertreatment/images/exit.pdf> (ja)

https://www.tepco.co.jp/en/decommission/progress/watertreatment/images/exit_en.pdf (en)

The judgment of whether stored water is regarded as “ALPS treated water” and “treated water to be purified” shall be performed according to the following procedure based on this measurement result.

In other words, when the transfer destination tank group (8 to 10 tanks connected at the time of water reception) becomes full, water of which ratios to regulatory concentrations limits of 63 nuclides other than tritium were estimated to be less than 1 using the following formula is judged as ALPS treated water and the other water as treated water to be purified, based on the measurement result of the sample (water) collected in the ALPS outlet (measured point (7)) during reception of water in the corresponding tanks group from ALPS.

$$C_{All} = C_{M7} + C_{C-14} + C_{55} < 1$$

where

- C_{All} : Sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium
- C_{M7} : Sum of the ratios to regulatory concentrations limits calculated from the measurement results of the seven major nuclides
- C_{C-14} : Ratio to the regulatory concentrations limit of C-14 (conservatively set to the ratio to the regulatory concentrations limit of 0.11 calculated from the maximum concentration (215Bq/L) measured in the past)
- C_{55} : Estimated value of the sum of the ratios to regulatory concentrations limits of the 55 nuclides not included in the 7 nuclides among the 62 nuclides (The estimated value based on the past measurement results is set to 0.3)

Based on the result of the measurement, nuclides deemed to be less than the detection limit (ND) are assumed to be included at the concentration of the lower limit of detection and the lower limit of detection is used for the assessment of the above formula. The following table shows examples of measurement results and values in the calculation of the sum of the ratios to regulatory concentration limits.

Table II-5 Relationship between the analysis results of the seven major nuclides and the sum of the ratios to regulatory concentration limits of the seven major nuclides

| Nuclide | Cs-137 | Cs-134 | Co-60 | Sb-125 | Ru-106 | Sr-90 | I-129 |
|---|--|----------------|----------|----------------|---------------|----------------|----------|
| Measured concentration | ND (<1.26E-01) | ND (<1.66E-01) | 2.35E-01 | ND (<4.57E-01) | ND (<1.15E00) | ND (<3.90E-01) | 2.02E-01 |
| Calculated concentration | 1.26E-01 | 1.66E-01 | 2.35E-01 | 4.57E-01 | 1.15E+00 | 3.90E-01 | 2.02E-01 |
| Regulatory concentration limit | 9.00E+01 | 6.00E+01 | 2.00E+02 | 8.00E+02 | 1.00E+02 | 3.00E+01 | 9.00E+00 |
| Ratio to regulatory concentration limit | 1.40E-03 | 2.76E-03 | 1.18E-03 | 5.71E-04 | 1.15E-02 | 1.30E-02 | 2.24E-02 |
| Sum of the regulatory ratios of the 7 nuclides (C_{M7}) | 0.05 (5.28E-02) | | | | | | |
| Sum of the regulatory ratios of the 63 nuclides (C_{All}) | 0.05 (= C_{M7}) + 0.11 (= C_{C-14}) + 0.3 (= C_{55}) = 0.46 | | | | | | |

Figure II-5 shows the concentration distribution of the seven major nuclides arranged from the

analysis result of the tank group of which sum of the ratios to regulatory concentrations limits other than tritium is estimated to be less than 1.

- Measured value of the radioactive concentration of each tank group (excluding reused tanks) (as of March 31, 2021)
- Secondary treatment test water
https://www.tepco.co.jp/decommission/information/newsrelease/reference/pdf/2020/2h/rf_20201224_1.pdf




Figure II-5 Concentration distribution of the seven major nuclides in the analysis result of ALPS treated water (as of the end of March 2021)

- * The analysis results in which sum of the ratios to regulatory concentrations limits of the 7 major nuclides is less than 0.59 (for 80 tanks) (excluding secondary treatment test water)
- * The vertical axis indicates the number of tanks (counted as the lower detection limit if not detected)
- * Values are measured values at the times and no half-life correction is considered.

Figure II-6 shows the analysis result concentration distribution created by extracting the analysis results of the analyzed tanks for tritium and C-14, which are not subject to removal by ALPS.




Figure II-6 Concentration distribution of tritium and C-14 in the analysis result of ALPS treated water, etc. (as of the end of March 2021)

- * The analysis results of the tank group (189 tanks for tritium and 81 tanks for C-14) are plotted (excluding secondary treatment test water)
- * The vertical axis indicates the number of tanks (counted as the lower detection limit if not detected)
- * Values are measured values at the times and no half-life correction is considered.

As a result of the above-mentioned estimation, approx. 70% of the water currently stored in the tanks is judged to be “treated water to be purified,” which does not satisfy the above formula: in other words, the sum of the ratios to regulatory concentrations limits of 63 nuclides (C_{All}) is greater than 1. “Treated water to be purified” is discharged only after secondary treatment is conducted immediately before future discharge into the sea, and after it is confirmed that the regulatory concentration limit is less than 1 with the facility for measurement and confirmation. In addition, this sample is not representative because each tank group does not have a necessary stirring device to guarantee the homogeneity. Therefore, for the actual judgment of whether the discharge is possible, the correct regulatory concentration limit obtained from the result of the measurement and assessment in the facility for measurement and confirmation is used.

All data of the past measurement and estimation results of the above-mentioned method are published on our web site. Our treatment water portal shows the measurement results of each tank group. The latest data is available in the following links.

Our web site (Japanese only):

https://www.tepco.co.jp/decommission/data/daily_analysis/tank/index-j.html

Treated water portal:

<https://www.tepco.co.jp/decommission/progress/watertreatment/> (ja)

https://www.tepco.co.jp/en/decommission/progress/watertreatment/images/tankarea_en.pdf (en)

For the K4 tank group of which sum of the ratios to regulatory concentrations limits becomes less than 1 after treated by ALPS once, the 64 nuclides included in the collected sample are measured and assessed according to the measurement and assessment method shown in Table II-6 (however, the representativeness of the sample is not secured). The K4 tank group is the receiving tank group in the operation considering the sum of the ratios to regulatory concentrations limits of less than 1 in ALPS in FY 2016. For analysis, samples were collected from 8 out of 35 tanks, the water samples were mixed (composite sample), and 62 nuclides were analyzed. For C-14, the average value of the results of analyses of five tanks after verification of the presence is shown. Table II-7 shows the results.

Table II-6 Measurement and assessment methods of each nuclide

| No. | Nuclide | Radiation type | Measurement or assessment method |
|-----|---------|----------------|---|
| 1 | Mn-54 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 2 | Fe-59 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 3 | Co-58 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 4 | Co-60 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 5 | Ni-63 | β | Isolated by resin, mixed with a scintillator, and counted by a low back liquid scintillation counter. |
| 6 | Zn-65 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 7 | Rb-86 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 8 | Sr-89 | β | Isolated with resin, precipitated and recovered, mounted, and counted with the β nuclide analyzer in stainless steel dish |
| 9 | Sr-90 | β | Isolated with resin, precipitated and recovered, mounted, and counted with the β nuclide analyzer in stainless steel dish |
| 10 | Y-90 | β | Concentration assessment as Sr -90 and radioactive equilibrium |
| 11 | Y-91 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 12 | Nb-95 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 13 | Tc-99 | β | Samples are diluted with dilute nitric acid and counted with the inductively coupled plasma mass spectrometry (ICP-MS). |
| 14 | Ru-103 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 15 | Ru-106 | β | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 16 | Rh-103m | $\beta\gamma$ | Concentration assessment as radioactive equilibrium with Ru-103 |
| 17 | Rh-106 | γ | Concentration assessment as radioactive equilibrium with Ru-106 |
| 18 | Ag-110m | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 19 | Cd-113m | γ | Isolated by ion exchange, mixed with a scintillator, and counted by a low back liquid scintillation counter. |
| 20 | Cd-115m | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 21 | Sn-119m | γ | Assessed from the measured value of the radioactive concentration of Sn-123 and the calculated nuclide abundance ratio |
| 22 | Sn-123 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 23 | Sn-126 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and |

| No. | Nuclide | Radiation type | Measurement or assessment method |
|-----|---------|----------------|---|
| | | | counted with a Ge semiconductor detector. |
| 24 | Sb-124 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 25 | Sb-125 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 26 | Te-123m | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 27 | Te-125m | γ | Concentration assessment as radioactive equilibrium with Sb-125 |
| 28 | Te-127 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container, counted with a Ge semiconductor detector, and assessed using the half-life of the parent nuclide (Te-127m). |
| 29 | Te-127m | $\beta\gamma$ | Assessed from the measured value of the radioactive concentration of Te-127 and the calculated nuclide abundance ratio |
| 30 | Te-129 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container, counted with a Ge semiconductor detector, and assessed using the half-life of the parent nuclide (Te-129m). |
| 31 | Te-129m | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 32 | I-129 | $\beta\gamma$ | Samples were counted with the inductively coupled plasma mass spectrometry (ICP-MS) after adjusting to iodate ion by the addition of reagents. |
| 33 | Cs-134 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 34 | Cs-135 | β | Assessed from the measured value of the radioactive concentration of Cs-137 and the calculated nuclide abundance ratio |
| 35 | Cs-136 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 36 | Cs-137 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 37 | Ba-137m | γ | Concentration assessment as radioactive equilibrium with Cs-137 |
| 38 | Ba-140 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 39 | Ce-141 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 40 | Ce-144 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 41 | Pr-144 | $\beta\gamma$ | Concentration assessment as radioactive equilibrium with Ce-144, using half-life of parent nuclide (Pr-144m) |
| 42 | Pr-144m | γ | Concentration assessment as radioactive equilibrium with Ce-144 |
| 43 | Pm-146 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 44 | Pm-147 | $\beta\gamma$ | Assessed from the measured value of the radioactive concentration of Eu-154 and the calculated nuclide abundance ratio |
| 45 | Pm-148 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 46 | Pm-148m | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 47 | Sm-151 | $\beta\gamma$ | Assessed from the measured value of the radioactive concentration of Eu-154 and the calculated nuclide abundance ratio |
| 48 | Eu-152 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 49 | Eu-154 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 50 | Eu-155 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |

| No. | Nuclide | Radiation type | Measurement or assessment method |
|-----|----------|----------------|---|
| 51 | Gd-153 | γ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 52 | Tb-160 | $\beta\gamma$ | Homogenized samples are collected in a Marinelli container and counted with a Ge semiconductor detector. |
| 53 | Pu-238 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 54 | Pu-239 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 55 | Pu-240 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 56 | Pu-241 | β | Assessed from the total α discrete value and the isotopic ratio of Pu-238 |
| 57 | Am-241 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 58 | Am-242m | α | Assessed from the isotopic ratio of Am-241 |
| 59 | Am-243 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 60 | Cm-242 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 61 | Cm-243 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| 62 | Cm-244 | α | After iron is removed by iron coprecipitation, the sample is evaporated to dryness in a stainless steel dish and the total α measured value counted with the ZnS α automatic measuring device is used as it is without proportionate division with other nuclides |
| - | H-3(FWT) | β | Isolated by distillation, mixed with a scintillator, and counted by a low back liquid scintillation counter. |
| - | C-14 | β | Converted to CO ₂ , collected and isolated on absorbent, mixed with a scintillator, and counted by a low back liquid scintillation counter. |

Table II-7 Analysis result of the K4 tank group

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Analysis result [Bq/L] | Ratio to regulatory limit | Remarks |
|---|--|---------------------------|------------------------------|--|
| H-3 (About 12 years) | 6.0E+04 | 1.9E+05 | 3.2E+00 | Dilute to less than 1,500Bq/L before discharge |
| C-14 (About 5700 years) | 2.0E+03 | 1.5E+01 | 7.5E-03 | |
| Mn-54 (About 310 days) | 1.0E+03 | < 6.7E-03 | 6.7E-06 | |
| Fe-59 (About 44 days) | 4.0E+02 | < 1.7E-02 | 4.3E-05 | |
| Co-58 (About 71 days) | 1.0E+03 | < 8.0E-03 | 8.0E-06 | |
| Co-60 (About 5.3 years) | 2.0E+02 | 4.4E-01 | 2.2E-03 | |
| Ni-63 (About 100 days) | 6.0E+03 | 2.2E+00 | 3.7E-04 | |
| Zn-65 (About 240 days) | 2.0E+02 | < 1.5E-02 | 7.5E-05 | |
| Rb-86 (About 19 days) | 3.0E+02 | < 1.9E-01 | 6.3E-04 | |
| Sr-89 (About 51 days) | 3.0E+02 | < 1.0E-01 | 3.3E-04 | |
| Sr-90 (About 29 years) | 3.0E+01 | 2.2E-01 | 7.3E-03 | |
| Y-90 (About 64 hours) | 3.0E+02 | 2.2E-01 | 7.3E-04 | Radioactive equilibrium with Sr- 90 |
| Y-91 (About 59 days) | 3.0E+02 | < 2.2E+00 | 7.3E-03 | |
| Nb-95 (About 35 days) | 1.0E+03 | < 1.0E-02 | 1.0E-05 | |
| Tc-99 (About 210 thousand years) | 1.0E+03 | 7.0E-01 | 7.0E-04 | |
| Ru-103 (About 39 days) | 1.0E+03 | < 1.0E-02 | 1.0E-05 | |
| Ru-106 (About 370 days) | 1.0E+02 | 1.6E+00 | 1.6E-02 | |
| Rh-103m (About 56 minutes) | 2.0E+05 | < 1.0E-02 | 5.0E-08 | Radioactive equilibrium with Ru- 103 |
| Rh-106 (About 30 seconds) | 3.0E+05 | 1.6E+00 | 5.3E-06 | Radioactive equilibrium with Ru- 106 |
| Ag-110m (About 250 days) | 3.0E+02 | < 5.6E-03 | 1.9E-05 | |
| Cd-113m (About 14 years) | 4.0E+01 | < 1.8E-02 | 4.5E-04 | |
| Cd-115m (45 days) | 3.0E+02 | < 6.4E-01 | 2.1E-03 | |
| Sn-119m (About 290 days) | 2.0E+03 | < 1.7E-01 | 8.5E-05 | Assessed from the radioactive concentration of Sn-123 |
| Sn-123 (About 130 days) | 4.0E+02 | < 1.2E+00 | 3.0E-03 | |
| Sn-126 (About 230 thousand years) | 2.0E+02 | < 2.7E-02 | 1.4E-04 | |

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Analysis result [Bq/L] | Ratio to regulatory limit | Remarks |
|-------------------------------------|--|---------------------------|------------------------------|---|
| Sb-124 (About 60 days) | 3.0E+02 | < 9.5E-03 | 3.2E-05 | |
| Sb-125 (About 2.8 years) | 8.0E+02 | 3.3E-01 | 4.1E-04 | |
| Te-123m (About 120 days) | 6.0E+02 | < 9.2E-03 | 1.5E-05 | |
| Te-125m (About 57 days) | 9.0E+02 | 3.3E-01 | 3.7E-04 | Radioactive equilibrium with Sb-125 |
| Te-127 (About 9.4 hours) | 5.0E+03 | < 3.2E-01 | 6.4E-05 | |
| Te-127m (About 110 days) | 3.0E+02 | < 3.2E-01 | 1.1E-03 | Assessed from the radioactive concentration of Te-127 |
| Te-129 (About 70 minutes) | 1.0E+04 | < 8.1E-02 | 8.1E-06 | |
| Te-129m (About 34 days) | 3.0E+02 | < 3.2E-01 | 1.1E-03 | |
| I-129 (About 16 million years) | 9.0E+00 | 2.1E+00 | 2.3E-01 | |
| Cs-134 (About 2.1 years) | 6.0E+01 | 4.5E-02 | 7.5E-04 | |
| Cs-135 (About 2.3 million years) | 6.0E+02 | 2.5E-06 | 4.2E-09 | Assessed from the radioactive concentration of Cs-137 |
| Cs-136 (About 13 days) | 3.0E+02 | < 3.0E-02 | 1.0E-04 | |
| Cs-137 (About 30 years) | 9.0E+01 | 4.2E-01 | 4.7E-03 | |
| Ba-137m (About 2.6 minutes) | 8.0E+05 | 4.2E-01 | 5.3E-07 | Radioactive equilibrium with Cs-137 |
| Ba-140 (About 13 days) | 3.0E+02 | < 9.5E-02 | 3.2E-04 | |
| Ce-141 (About 33 days) | 1.0E+03 | < 2.5E-02 | 2.5E-05 | |
| Ce-144 (About 280 days) | 2.0E+02 | < 6.3E-02 | 3.2E-04 | |
| Pr-144 (About 17 minutes) | 2.0E+04 | < 6.3E-02 | 3.2E-06 | Radioactive equilibrium with Ce-144 |
| Pr-144m (About 7.2 minutes) | 4.0E+04 | < 6.3E-02 | 1.6E-06 | Radioactive equilibrium with Ce-144 |
| Pm-146 (About 5.5 years) | 9.0E+02 | < 9.8E-02 | 1.1E-04 | |
| Pm-147 (About 2.6 years) | 3.0E+03 | < 1.9E-01 | 6.3E-05 | Assessed from the radioactive concentration of Eu-154 |
| Pm-148 (About 5.4 days) | 3.0E+02 | < 5.0E-01 | 1.7E-03 | |
| Pm-148m (About 41 days) | 5.0E+02 | < 8.4E-03 | 1.7E-05 | |
| Sm-151 (About 90 years) | 8.0E+03 | < 9.0E-04 | 1.1E-07 | Assessed from the radioactive concentration of Eu-154 |

| Nuclide (Half-life) | Regulatory concentration limit [Bq/L] | Analysis result [Bq/L] | Ratio to regulatory limit | Remarks |
|---|--|---------------------------|------------------------------|---|
| Eu-152 (About 14 years) | 6.0E+02 | < 2.8E-02 | 4.7E-05 | |
| Eu-154 (About 8.6 years) | 4.0E+02 | < 1.2E-02 | 3.0E-05 | |
| Eu-155 (About 4.8 years) | 3.0E+03 | < 3.3E-02 | 1.1E-05 | |
| Gd-153 (About 240 days) | 3.0E+03 | < 3.2E-02 | 1.1E-05 | |
| Tb-160 (About 72 days) | 5.0E+02 | < 2.8E-02 | 5.6E-05 | |
| Pu-238 (About 88 years) | 4.0E+00 | < 6.3E-04 | 1.6E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-239 (About 24000 years) | 4.0E+00 | < 6.3E-04 | 1.6E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-240 (About 6600 years) | 4.0E+00 | < 6.3E-04 | 1.6E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Pu-241 (About 14 years) | 2.0E+02 | < 2.8E-02 | 1.4E-04 | Assessed from the radioactive concentration of Pu-238 |
| Am-241 (About 430 years) | 5.0E+00 | < 6.3E-04 | 1.3E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Am-242m (About 140 years) | 5.0E+00 | < 3.9E-05 | 7.8E-06 | Assessed from the radioactive concentration of Am-241 |
| Am-243 (About 7400 years) | 5.0E+00 | < 6.3E-04 | 1.3E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-242 (About 160 days) | 6.0E+01 | < 6.3E-04 | 1.1E-05 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-243 (About 29 years) | 6.0E+00 | < 6.3E-04 | 1.1E-04 | Assessed as included in the measurement value of the total α radioactivity |
| Cm-244 (About 18 years) | 7.0E+00 | < 6.3E-04 | 9.0E-05 | Assessed as included in the measurement value of the total α radioactivity |
| Sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium | | | 2.9E-01 | |

* For C-14, the average value of the measurement results of five tanks is shown; for H-3, that of seven tanks; and for the other nuclides, the analysis result of the composite sample

II-6. Water quality other than radioactive materials

As mentioned above, ALPS is equipped with coprecipitation, adsorption, and physical filters, etc., all of which are used to remove the 62 nuclides subject to removal regardless of their chemical forms. Judging from the past analysis results, not only radioactive materials but also materials that may affect the water quality are removed when passing through the filters.

Table II-8 shows the tank group from which samples were collected and the timing of receiving water stored in the tanks¹¹. Table II-9-1 and 2 show the results of the 46 measurement items based on our “general wastewater treatment management guideline.” It was verified that all of them met the standards set by the laws and ordinances in Japan. It should be noted that since no facility to secure the representativeness of samples is installed in the tank group, in this analysis, one tank is randomly selected from the tank group and samples collected from the middle layer of the tank are analyzed without stirring or circulation, so the representativeness is not necessarily secured.

Table II-8 Tank group of which chemical substances were analyzed based on the general wastewater standard, and timing of receiving water

| Area | Groups | Time of receiving ALPS treated water, etc. |
|------|--------|--|
| G3 | A | FY 2013 |
| J4 | B | FY 2014 |
| H1 | E | FY 2015 |
| K3 | A | FY 2016 |
| K4 | A | FY 2016 |
| H2 | C | FY 2017 |
| G1S | A | FY 2018 |

Table II-9-1 Results of analyses of chemical substances, etc., in tanks containing ALPS treated water, etc. (Part 1)

| Item | Guideline or permissible limit | Unit | Area and tank group | | | |
|-------------------------------|--|------|---------------------|-----|-----|-----|
| | | | G3 | J4 | H1 | K3 |
| | | | A | B | E | A |
| Hydrogen ion | 5.0 < / < 9.0 | pH | 8.8 | 8.3 | 7.8 | 8.3 |
| Mass of suspended solids (SS) | Permissible limit 200 (Daily average 150) | mg/L | <1 | <1 | <1 | <1 |
| Chemical oxygen demand (COD) | Permissible limit 160 (Daily average 120) | mg/L | 2.4 | 2.8 | 3.9 | 3.9 |

¹¹ December 28, 2018, “Analysis of chemical substance in tanks containing ALPS treated water etc.”
https://www.meti.go.jp/earthquake/nuclear/osensuitaisaku/committee/takakusyu/pdf/012_04_01.pdf

| Item | Guideline or permissible limit | Unit | Area and tank group | | | |
|---------------------------------|--|------------|---------------------|---------|---------|---------|
| | | | G3 | J4 | H1 | K3 |
| | | | A | B | E | A |
| Boron (mg/L) | Permissible limit 230 (Sea area) | mg/L | 3.5 | 4.4 | 2.3 | 0.9 |
| Soluble iron | Permissible limit 10 | mg/L | <1 | <1 | <1 | <1 |
| Copper | Permissible limit 3 | mg/L | <0.1 | <0.1 | <0.1 | <0.1 |
| Nickel | Permissible limit 2 | mg/L | <0.1 | <0.1 | <0.1 | <0.1 |
| Chromium | Permissible limit 2 | mg/L | <0.1 | <0.1 | <0.1 | <0.1 |
| Zinc | Permissible limit 2 | mg/L | <0.1 | <0.1 | <0.1 | <0.1 |
| Biochemical oxygen demand (BOD) | Permissible limit 160 (Daily average 120) | mg/L | <1 | <1 | <1 | <1 |
| Coliform count | Permissible limit Daily average 3000 | Pieces/cm3 | 0 | 0 | 0 | 0 |
| Cadmium | Permissible limit 0.03 | mg/L | <0.01 | <0.01 | <0.01 | <0.01 |
| Cyan | Permissible limit 1 | mg/L | <0.05 | <0.05 | <0.05 | <0.05 |
| Organic phosphorus | Permissible limit 1 | mg/L | <0.1 | <0.1 | <0.1 | <0.1 |
| Lead | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 | <0.01 |
| Hexavalent chromium | Permissible limit 0.5 | mg/L | <0.05 | <0.05 | <0.05 | <0.05 |
| Arsenic | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 | <0.01 |
| Mercury | Permissible limit 0.005 | mg/L | <0.0005 | <0.0005 | <0.0005 | <0.0005 |
| Alkyl mercury | It should not be detected | mg/L | <0.0005 | <0.0005 | <0.0005 | <0.0005 |
| Polychlorinated biphenyls | Permissible limit 0.003 | mg/L | <0.0005 | <0.0005 | <0.0005 | <0.0005 |
| Trichloroethylene | Permissible limit 0.1 | mg/L | <0.03 | <0.03 | <0.03 | <0.03 |
| Tetrachloroethylene | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 | <0.01 |
| Dichloromethane | Permissible limit 0.2 | mg/L | <0.02 | <0.02 | <0.02 | <0.02 |
| Carbon tetrachloride | Permissible limit 0.02 | mg/L | <0.002 | <0.002 | <0.002 | <0.002 |
| 1,2-dichloroethane | Permissible limit 0.04 | mg/L | <0.004 | <0.004 | <0.004 | <0.004 |
| 1,1-dichloroethane | Permissible limit 1 | mg/L | <0.1 | <0.1 | <0.1 | <0.1 |
| Cis-1, 2-dichloroethylene | Permissible limit 0.4 | mg/L | <0.04 | <0.04 | <0.04 | <0.04 |
| 1,1,1-trichloroethane | Permissible limit 3 | mg/L | <0.3 | <0.3 | <0.3 | <0.3 |
| 1,1,2-trichloroethane | Permissible limit 0.06 | mg/L | <0.006 | <0.006 | <0.006 | <0.006 |
| 1,3-dichloropropene | Permissible limit 0.02 | mg/L | <0.002 | <0.002 | <0.002 | <0.002 |
| Thiuram | Permissible limit 0.06 | mg/L | <0.006 | <0.006 | <0.006 | <0.006 |
| Simazine | Permissible limit 0.03 | mg/L | <0.003 | <0.003 | <0.003 | <0.003 |
| Thiobencarb | Permissible limit 0.2 | mg/L | <0.02 | <0.02 | <0.02 | <0.02 |
| Benzene | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 | <0.01 |

| Item | Guideline or permissible limit | Unit | Area and tank group | | | |
|---|--|------|---------------------|--------|--------|--------|
| | | | G3 | J4 | H1 | K3 |
| | | | A | B | E | A |
| Selenium | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 | <0.01 |
| Fenitrothion | Permissible limit 0.03 | mg/L | <0.003 | <0.003 | <0.003 | <0.003 |
| Phenols | Permissible limit 5 | mg/L | <0.1 | <0.1 | <0.1 | <0.1 |
| Fluorine | Permissible element 15 (Sea area) | mg/L | <0.5 | <0.5 | <0.5 | <0.5 |
| Soluble manganese | Permissible limit 10 | mg/L | <1 | <1 | <1 | <1 |
| Ammonia, ammonium compounds | Permissible limit 100 | mg/L | <1 | <1 | <1 | <1 |
| Nitrous acid compound and nitrous acid compound | | mg/L | 2 | 2 | <1 | 11 |
| 1,4-dioxane | Permissible limit 0.5 | mg/L | <0.05 | <0.05 | <0.05 | <0.05 |
| n-Hexane Extract (Mineral oil) | Permissible limit 5 | mg/L | <0.5 | <0.5 | <0.5 | <0.5 |
| n-Hexane Extract (Animal and vegetable oil) | Permissible limit 30 | mg/L | <1 | <1 | <1 | <1 |
| Nitrogen | Permissible limit 120 (Daily average 60) | mg/L | 2 | 2.3 | 0.7 | 11.1 |
| Phosphate | Permissible limit 16 (Daily average 8) | mg/L | <0.05 | <0.05 | <0.05 | <0.05 |

Table II-9-2 Results of analyses of chemical substances, etc. in tanks containing ALPS treated water, etc. (Part 2)

| Item | Guideline or permissible limit | Unit | Area and tank group | | |
|-------------------------------|---|------|---------------------|------|------|
| | | | K4 | H2 | G1S |
| | | | A | C | A |
| Hydrogen ion | 5.0 < / < 9.0 | pH | 8.3 | 8.5 | 8.3 |
| Mass of suspended solids (SS) | Permissible limit 200 (Daily average 150) | mg/L | <1 | <1 | <1 |
| Chemical oxygen demand (COD) | Permissible limit 160 (Daily average 120) | mg/L | 0.9 | 1.8 | 1.5 |
| Boron (mg/L) | Permissible limit 230 (Sea area) | mg/L | 0.4 | 1.1 | 1.1 |
| Soluble iron | Permissible limit 10 | mg/L | <1 | <1 | <1 |
| Copper | Permissible limit 3 | mg/L | <0.1 | <0.1 | <0.1 |
| Nickel | Permissible limit 2 | mg/L | <0.1 | <0.1 | <0.1 |
| Chromium | Permissible limit 2 | mg/L | <0.1 | <0.1 | <0.1 |

| Item | Guideline or permissible limit | Unit | Area and tank group | | |
|---------------------------------|---|------------|---------------------|---------|---------|
| | | | K4 | H2 | G1S |
| | | | A | C | A |
| Zinc | Permissible limit 2 | mg/L | <0.1 | <0.1 | <0.1 |
| Biochemical oxygen demand (BOD) | Permissible limit 160 (Daily average 120) | mg/L | 2 | <1 | <1 |
| Coliform count | Permissible limit Daily average 3000 | Pieces/cm3 | 0 | 0 | 0 |
| Cadmium | Permissible limit 0.03 | mg/L | <0.01 | <0.01 | <0.01 |
| Cyan | Permissible limit 1 | mg/L | <0.05 | <0.05 | <0.05 |
| Organic phosphorus | Permissible limit 1 | mg/L | <0.1 | <0.1 | <0.1 |
| Lead | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 |
| Hexavalent chromium | Permissible limit 0.5 | mg/L | <0.05 | <0.05 | <0.05 |
| Arsenic | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 |
| Mercury | Permissible limit 0.005 | mg/L | <0.0005 | <0.0005 | <0.0005 |
| Alkyl mercury | It should not be detected | mg/L | <0.0005 | <0.0005 | <0.0005 |
| Polychlorinated biphenyls | Permissible limit 0.003 | mg/L | <0.0005 | <0.0005 | <0.0005 |
| Trichloroethylene | Permissible limit 0.1 | mg/L | <0.03 | <0.03 | <0.03 |
| Tetrachloroethylene | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 |
| Dichloromethane | Permissible limit 0.2 | mg/L | <0.02 | <0.02 | <0.02 |
| Carbon tetrachloride | Permissible limit 0.02 | mg/L | <0.002 | <0.002 | <0.002 |
| 1,2-dichloroethane | Permissible limit 0.04 | mg/L | <0.004 | <0.004 | <0.004 |
| 1,1-dichloroethane | Permissible limit 1 | mg/L | <0.1 | <0.1 | <0.1 |
| Cis-1, 2-dichloroethylene | Permissible limit 0.4 | mg/L | <0.04 | <0.04 | <0.04 |
| 1,1,1-trichloroethane | Permissible limit 3 | mg/L | <0.3 | <0.3 | <0.3 |
| 1,1,2-trichloroethane | Permissible limit 0.06 | mg/L | <0.006 | <0.006 | <0.006 |
| 1,3-dichloropropene | Permissible limit 0.02 | mg/L | <0.002 | <0.002 | <0.002 |
| Thiuram | Permissible limit 0.06 | mg/L | <0.006 | <0.006 | <0.006 |
| Simazine | Permissible limit 0.03 | mg/L | <0.003 | <0.003 | <0.003 |
| Thiobencarb | Permissible limit 0.2 | mg/L | <0.02 | <0.02 | <0.02 |
| Benzene | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 |
| Selenium | Permissible limit 0.1 | mg/L | <0.01 | <0.01 | <0.01 |
| Fenitrothion | Permissible limit 0.03 | mg/L | <0.003 | <0.003 | <0.003 |
| Phenols | Permissible limit 5 | mg/L | <0.1 | <0.1 | <0.1 |
| Fluorine | Permissible element 15 (Sea area) | mg/L | <0.5 | <0.5 | <0.5 |
| Soluble manganese | Permissible limit 10 | mg/L | <1 | <1 | <1 |

| Item | Guideline or permissible limit | Unit | Area and tank group | | |
|---|--|------|---------------------|-------|-------|
| | | | K4 | H2 | G1S |
| | | | A | C | A |
| Ammonia, ammonium compounds | Permissible limit 100 | mg/L | <1 | <1 | <1 |
| Nitrous acid compound and nitrous acid compound | | mg/L | 25 | 7 | 10 |
| 1,4-dioxane | Permissible limit 0.5 | mg/L | <0.05 | <0.05 | <0.05 |
| n-Hexane Extract (Mineral oil) | Permissible limit 5 | mg/L | <0.5 | <0.5 | <0.5 |
| n-Hexane Extract (Animal and vegetable oil) | Permissible limit 30 | mg/L | <1 | <1 | <1 |
| Nitrogen | Permissible limit 120 (Daily average 60) | mg/L | 24.6 | 7.5 | 10 |
| Phosphate | Permissible limit 16 (Daily average 8) | mg/L | <0.05 | <0.05 | <0.05 |

II-7. Reason for generation of treated water to be purified

ALPS can remove the 62 nuclides subject to removal from contaminated water and make the sum of the ratios to regulatory concentrations limits less than 1 by performing treatment once, but as a result of estimation by the above-mentioned method, “treated water to be purified” of which contained radioactive material concentration is equivalent to or higher than the sum of the ratios to regulatory concentrations limits of 1 and which is to be subject to secondary treatment accounts for 70% of all water stored in the tank (about 67% as of February 2022). The following shows the reason depending on the timing of each treatment.

a. FY 2013 to 2015

Highly contaminated water with only cesium removed was stored in tanks at the site prior to the start of the operation of ALPS. Due to the direct radiation and skyshine rays from the highly contaminated water, the radiation dose at the boundary of the site was very large and assessed to be 9.76mSv/year at the site boundary, which greatly exceeded the standard set by the government, “The effective dose at the site boundary is less than 1mSv/year.”

In response to this situation, we continued the operation while accepting the outlet concentration of each adsorption vessel slightly exceeding the replacement standard and treated highly contaminated water raising the operating rate, aiming at early achievement of the effective dose of 1mSv/year at the site boundary.

As a result, the effective dose of 1mSv/year at the site boundary was achieved at the end of FY 2015, but naturally, treated water to be purified of which radioactive material concentration is equivalent to or higher than the sum of the ratios to regulatory concentrations limits of 1 was stored in the tanks.

It was immediately after the start of the operation of ALPS, so excessive concentrations also occurred due to facility trouble. Treated water to be purified of which sum of the ratios to regulatory concentrations limits exceeds 10 thousand was caused by the facility trouble, but the cause of the facility trouble has been removed and the event has not reoccurred.

b. FY 2016

In this period, the treatment capacity exceeded the speed of tank construction due to the advancement of treatment of highly concentrated water up to the preceding fiscal year, so tanks for storage of treated water were lacking, but treatment was performed to make the sum of the ratios to regulatory concentrations limits less than 1 by accelerating construction of tanks for storage of treated water and making use of the performance of ALPS.

Like this, the original performance of ALPS was used more appropriately than before, which reduced the frequency of treated water to be treated of which sum of the ratios to regulatory concentrations limits is 1 or more.

c. FY 2017 to 2018

Immediately after the accident, we hastened to collect tanks from all over Japan and used them for storage of contaminated water, etc. However, among these flange tanks, leak events occurred one after another, and the storage of strontium treated water (water from which most of the cesium and strontium has been removed before the treatment by ALPS) became an issue during this period.

Therefore, we decided to perform early treatment of the stored strontium treated water (water before treatment by ALPS) by ALPS to solve the issue of storage in flange tanks aiming at completion by the end of FY 2018, and raised the operating ratio while accepting slightly excessive concentrations at the outlet of each adsorption vessel again.

As a result, the treatment of all strontium treated water in the flange tanks was completed in November 2018, but compared to FY2016, the frequency of exceeding the regulatory concentration limit was higher.

All ALPS treated water, etc., stored in flange tanks have been transferred to weld tanks by March 2019.

Attachment III Impact of the organically bound tritium in the exposure assessment of tritium

ALPS treated water contains a lot of tritium water (HTO). If ingested, tritium water is converted to free water tritium (FWT), which behaves as normal water (H_2O) keeping the form of tritium water to organically bound tritium (OBT), a part of which is ingested into the tissue. OBT remains in the body longer and has greater exposure effects than FWT, so ICRP sets its effective dose factor of ingestion of OBT separately from tritium water. FWT is a name representing behavior in the body, but it is the same as tritium water, so it is written as HTO in this document.

III-1. Disposition of tritium

According to the model of ICRP Publication 56[III-1], about 3% of tritiated water (HTO) taken into the body changes into OBT and remains in the body longer than HTO. The half-life of HTO in the body is about 10 days, while that of OBT is about 40 days. (Figure III-1)

On the other hand, when tritium is taken into the body as OBT, 50% is assumed to be immediately converted to HTO in the blood. With the half-life mentioned above, each of OBT and HTO is eventually excreted from the blood as HTO. (Figure III-2)

Based on such a pharmacokinetic model in the body, ICRP Publication 72 [III-2] sets the effective dose factors for tritium as follows.

- Tritiated water (HTO) 1.8E-11 Sv/Bq
- Organically bound tritium (OBT) 4.2E-11 Sv/Bq




Figure III-1 ICRP model for ingestion of tritiated water (HTO)

(Source: Annex C [III-3] of UNSCEAR2016)




Figure III-2 ICRP model for ingestion of OBT

(Source: Annex C of UNSCEAR2016)

The ICRP Publication 134 [III-4] provides a new pharmacokinetic model that incorporates OBT with a biological half-life of about 40 days and OBT with a biological half-life of about 1 year, which remains in the body for a more extended period. (Figures III-3 and III-4)

The effective dose factors based on this model are higher than those presented in ICRP Publication 72, as shown below. Even so, calculating exposures using those factors does not significantly affect the exposure assessment results.

- Tritiated water (HTO) 1.9E-11 Sv/Bq
- Organically bound tritium (OBT) 5.1E-11 Sv/Bq

The model predicts that about 6% of total tritium in the body will be OBT if HTO is ingested continuously.




Figure III-3 New ICRP model for ingestion of HTO

(Source: Annex C of UNSCEAR2016)

Figure III-4 New ICRP model for ingestion of OBT

(Source: Annex C of UNSCEAR2016)

III-2. Impact of ingestion of OBT on the exposure assessment

ALPS is equipped with coprecipitation, adsorption, and physical filters, etc., which are used to eliminate the 62 nuclides subject to removal regardless of their chemical forms. None of the past analysis results shows the inclusion of a lot of organic matters (See Attachment II “Water quality of ALPS treated water, etc.”). Therefore, all tritium contained in ALPS treated water was assumed to be HTO in the assessment of internal exposure by drinking and ingestion of seawater spray without considering OBT.

On the other hand, a part of HTO is converted to OBT in animals and vegetables in the environment, so a part of the tritium ingested as seafood is considered to be OBT. However, since no concentration in the environment that changes the isotopic ratio between tritium and hydrogen is seen, and water accounts for about 70 to 90% of seafood, it is considered that OBT does not change the tritium concentration in seafood significantly.

The effective dose factor $DC_{\text{correction}}$ can be represented by the following formula where the effective dose factor of ingestion of HTO is DC_{FWT} , that of ingestion of OBT is DC_{OBT} , and the ratio of OBT to the ingested tritium is X%.

$$DC_{\text{correction}} = (1-X/100) \cdot DC_{\text{FWT}} + X/100 \cdot DC_{\text{OBT}} \quad (\text{III-1})$$

Table III-1 shows the effective dose factor corrected by the formula (III-1).

In this report, the calculation was made with the percentage of OBT as 10% in the assessment of internal exposure from ingestion of seafood.

Table III-1 Effective dose factor corrected by the percentage of OBT in tritium ingested from seafood

| Percentage of OBT of seafood (%) | Effective dose factor (mSv/Bq) | | | Remarks |
|----------------------------------|--------------------------------|---------------------------|---------|-------------------------|
| | Adult | Children under school age | Infants | |
| 0 | 1.8E-08 | 3.1E-08 | 6.4E-08 | |
| 10 | 2.0E-08 | 3.5E-08 | 7.0E-08 | Used for the assessment |
| 20 | 2.3E-08 | 3.9E-08 | 7.5E-08 | |
| 100 | 4.2E-08 | 7.3E-08 | 1.2E-07 | |

III-3. OBt of marine plants and animals

For the isotopic ratio between HTO and OBt in the environment, the result of monitoring performed around the La Hague reprocessing plant in France is shown (Figure III-5) [III-5]. The isotopic ratio is the same in any species including fish and seaweed, so no trend of concentration has been observed.




Figure III-5 Investigation result of the OBt and HTO concentrations in marine plants and animals performed in the sea area around the La Hague reprocessing plant

In our monitoring of fish continued since 2014 around the Fukushima Daiichi Nuclear Power Station, OBt has never been observed in the 83 samples measured so far.

References

- [III-1] ICRP Publication 56 "Age-dependent Doses to Members of the Public from Intake of Radionuclides - Part1",1989
- [III-2] ICRP Publication 72 " Age-dependent Doses to the Members of the Public from Intake of Radionuclides - Part 5 Compilation of Ingestion and Inhalation Coefficients",1995
- [III-3] UNSCEAR 2016 Report "SOURCES, EFFECTS AND RISKS OF IONIZING RADIATION UNSCEAR 2016 Report ANNEX C BIOLOGICAL EFFECTS OF SELECTED INTERNAL EMITTERS - TRITIUM",2017
- [III-4] ICRP Publication 134 "Occupational Intakes of Radionuclides: Part 2",2016
- [III-5] Bruno Fiévet, Julien Pommier, Claire Voiseux, Pascal Bailly du Bois, Philippe Laguionie, Catherine Cossonnet, and Luc Solier "Transfer of Tritium Released into the Marine Environment by French Nuclear Facilities Bordering the English Channel",2013

Attachment IV Analysis on the period of discharge of ALPS treated water

At the FDNPS, it is planned to secure the site necessary for decommissioning based on the “Mid- and Long-term Roadmap toward Decommissioning of the Fukushima Daiichi Nuclear Power Station of Tokyo Electric Power Company Holdings, Inc.” and the “Reduction Target Map of Mid-term Risks of TEPCO Fukushima Daiichi NPS” by installing facilities for dilution and discharge of ALPS treated water and related facilities to discharge ALPS treated water stored in the tanks.

The following shows that the site necessary for decommissioning can be secured by discharging ALPS treated water and reducing the tanks according to the plan, using the ALPS treated water discharge simulation.

IV-1. Prerequisites for ALPS treated water discharge simulation

The following describes the simulation period, the specifications of the dilution and discharge facilities, and the conditions regarding the ALPS treated water to be discharged as the prerequisites of ALPS treated water discharge simulation.

The unit of the simulation period shall be one year from FY 2021¹; discharge is to be started in FY 2023 and discharge is to be completed in FY 2051².

As the specifications of the dilution and discharge facilities, the flow rate of ALPS treated water is assumed to be up to 500m³/day and the annual operating rate 80% (292 days of discharge). The seawater flow rate is assumed to be 170 to 510 thousand m³/day with 1 to 3 seawater pumps assumed to be in operation.

As conditions regarding ALPS treated water to be discharged, the upper limit of the annual discharge amount of tritium is assumed to be 22 TBq. The tank capacity in each fiscal year shall be a constraint condition because the purpose of discharge of ALPS treated water into the sea is to secure the site necessary for decommissioning. In addition, tritium is a radioactive material of which half-life is about 12 years, so the annual reduction amount is assumed to be about 5.5%. It is planned to discharge a small amount in the early stage of discharge so the annual discharge amount of tritium of FY 2023 is set to half of that of FY 2024.

In addition, the ALPS treated water to be discharged in the future includes “(A) ALPS treated water to be generated daily” and “(B) ALPS treated water, etc., stored in the tanks.” As the discharge order of the water, it is assumed that about 30 thousand m³ of “ALPS treated water stored in the tank” in the K4 tanks used as facilities for measurement and confirmation will be discharged and then “ALPS treated water to be generated daily” and “ALPS treated water

¹ The business year in Japan starts on April 1st and ends on March 31st of the following year.

² In the Mid- and Long-term Roadmap, the goal is set to the completion of decommissioning 30 to 40 years after December 2011, in which the discharge of radioactive materials was managed and the radiation dose was greatly inhibited.

stored in the tank” will be discharged in ascending order of the tritium concentration. Discharge of “ALPS treated water to be generated daily” is to be continued as long as it is generated until the total amount of tritium in the building becomes 0. In doing so, the generation amount of contaminated water is assumed to decrease 10m³/day every year step by step so that the daily generation amount of “ALPS treated water to be generated daily” will become 100m³/day after 2025.

Table IV-1 Prerequisites for ALPS treated water discharge simulation

| | |
|--|---|
| Annual release of tritium (Less than 22 TBq/year) | Set the total amount of discharge so that discharge into the sea will be completed in FY 2051 to the extent that it will not affect the site utilization plan |
| Simulation assessment start date | April 1, 2021 (simulation by year) |
| Discharge start date | April 1, 2023 |
| ALPS treated water flow rate | Up to 500 m ³ /day |
| Seawater flow rate for dilution | 170 thousand m ³ /day (1 seawater pump) to 510 thousand m ³ /day (3 seawater pumps) |
| ALPS treated water discharge order | About 30 thousand m ³ of water in the K4 tank used as facilities for measurement and confirmation will be discharged in ascending order of the tritium concentration After that, the water in the other tanks and the newly generated ALPS treated water will also be discharged in ascending order of the tritium concentration |
| Tritium decay | The half-life is considered to be about 12 years (decrease by about 5.5% in 1 year) and decay is considered for newly generation one as well |
| ALPS treated water generation amount | The generation amount of contaminated water is assumed to decrease 10m ³ /day every year step by step so that it will become 100m ³ /day after FY 2025 |
| Number of days of discharge | 292 days (Operating rate: 80%) |

“ALPS treated water to be generated daily” will be generated in the future and is highly uncertain, so the assessment was performed in two cases: cases with the largest and smallest total amounts of tritium, respectively. In the case with the largest total amount of tritium, it is assumed that the concentration of newly generated tritium is the largest value, 448 thousand Bq/L, between January and June 2021 and the total amount of tritium in the building is about 1150 TBq assuming that the whole of 3400 TBq remain in the building or tanks at the time of the accident. In the case with the smallest total amount of tritium, it is assumed that the concentration of newly generated tritium is the smallest value, 215 thousand Bq/L, between January and June 2021 and the total amount of tritium in the building estimated from the stagnant water storage amount and concentration in the building is about 81 TBq.

Table IV-2 Assessment case of ALPS treated water discharge simulation

| Case | Case with the largest total amount of tritium | Case with the smallest total amount of tritium |
|--|---|--|
| Concentration of newly generated tritium | 448 thousand Bq/L (January 5, 2021, Largest in 2021) | 215 thousand Bq/L (June 1, 2021, Smallest in 2021) |
| Total amount of tritium in the building (As of April 1, 2021) | About 1150 TBq (At the time of the accident, the whole of 3400 TBq remained in the building and tanks) | About 81 TBq (Estimated from the stagnant water storage amount and concentration in the building) |

Based on these prerequisites, we assessed the minimum value of the annual tritium discharge amount of every year, the water storage amount of ALPS treated water, etc., the average flow rate of ALPS treated water, and the average tritium concentration before and after seawater dilution.

IV-2. ALPS treated water discharge simulation result

For each case, we changed the annual total tritium charge amount not to affect the site usage plan and assessed the total discharge amount, with which discharge into the sea will be assessed in FY 2051. As a result, it was verified that the maximum and minimum annual tritium discharge amounts of the case with the largest and smallest total tritium amount are up to 22 and 16 TBq, respectively, and discharge will be completed by FY 2051 with the annual amount below 22 TBq in both cases.

The annual tritium discharge amount of each fiscal year was 11 TBq/year in FY 2023, 22 TBq/year between FY 2024 and FY 2029, 18 TBq/year between FY 2030 and FY 2032, and 16 TBq/year in and after FY 2033 in the case with the largest total tritium amount. On the other hand, it was 8 TBq/year in FY 2023, 16 TBq/year between FY 2024 and FY 2028, and 11 TBq/year in and after FY 2029 in the case with the smallest total tritium amount.




Figure IV-1 Case with the largest total amount of tritium




Figure IV-2 Case with the smallest total amount of tritium

Attachment V Impacts of intake and discharge of diluted water on outside
 For discharge of ALPS treated water, the concentration of tritium, which is difficult to remove, is diluted with seawater 100 or more times until it becomes less than 1,500Bq/L, which is much lower than that specified in laws and regulations, before discharge. The seawater for diluting the ALPS treated water is planned to be taken from the unit 5 intake. However, regarding the seawater concentration within the port, the concentration of radioactive materials is slightly higher than that of the seawater in the surrounding sea area. Considering this point, as well as the impact of the seabed soil within the port, the seawater will be drawn from the north side of the unit 5/6 discharge outlet in the plan.

V-1. State of the concentration in seawater in the port

The current state of Cs-137 concentration in the port is shown in Figure V-1. The concentration near the water intake of units 1 to 4 is high, and it becomes lower as measurement points are away from the water intake of units 1 to 4 toward the port outlet or units 5/6.

Note:

1. Within the port, daily sampling results were used. For the north-south discharge outlet and port outlet, weekly detailed analysis results were used.
2. Non-detection data were calculated at lower limits of detection. The lower limits of detection are < 0.001 Bq/L for the north-south discharge outlet and the port outlet, < 0.4 Bq/L for the east-west and north-south within the port, and < 0.7 Bq/L for others.
3. The calculation period for FY2021 is 9 months, from April 1, 2021, to December 31, 2021.




Figure V-1 State of the Cs-137 concentration in the port

V-2. Assumed impacts of intake and discharge of seawater for dilution on outside and countermeasures

As shown in V-1., the radioactive material concentration in seawater in the port tends to be high near units 1 - 4 intake. Seawater for dilution is planned to be taken from near the unit 5 intake and seawater with high concentration may be drawn from the unit 1 - 4 intake open-channel to the unit 5/6 side.

As a countermeasure in the installation of intake facilities, a unit 5/6 intake open-channel will be separated with a partition weir (riprap sloping weir + sheet) for prevention of inflow of seawater from the units 1 - 4 side, and instead a part of the north breakwater permeation prevention work will be remodeled so that the seawater for dilution is taken in from outside the port. (Figure V-2)

As a result, the concentration of radioactive materials in seawater in the unit 5/6 intake open-channel may decrease. In contrast, the concentration around the unloading wharf, where diffusion to the unit 5/6 intake channel will be restricted, may slightly increase, but the impact of intake and discharge of seawater for dilution on outside is considered to be inhibited.




Figure V-2 Intake and discharge plan and state of the Cs-137 concentration in the port

V-3. Assessment of the impacts of intake and discharge of seawater for dilution on outside
 To verify the effect of the countermeasure, external effects were compared and assessed in cases where seawater inside the port (area on the side of units 1 to 4) is taken in and where seawater outside the port (north side of the unit 5/6 discharge outlet) is taken in.
 The assessment was performed by adding the movement amount of the radioactive materials that move to outside the port with seawater for dilution to the source term in the human exposure assessment of discharge of ALPS treated water.

(1) Setting of the movement amount of the radioactive materials added to the source term
 Concentrations of seawater for dilution used for comparison and assessment are set based on the monitoring results (for about 3 years from FY 2019). The water taken from the outside of the port was on the north of the unit 5/6 discharge outlet, and the water taken within the port was north side within the port. (Figure V-3)

The target nuclides are Cs-137, Sr-90, and tritium whose presence in the seawater in the port was verified and which are subject to monitoring (For Cs-137 and Sr-90, the progeny nuclides, Ba-137 and Y-90, are assumed to be contained at the same concentration in the equilibrium state).

The minimum detection limits differ between the port and outside the port (it is higher within the port). Based on this, there is a possibility that the Cs-137 and tritium on the north side within the port are overestimated, but it is clear that the concentrations on the north side of the unit 5/6 discharge outlet are lower.

Note:

1. Regarding the concentration of Cs-137 for the north side of the unit 5/6 discharge outlet, weekly detailed analysis results were used, and for the north side within the port daily analysis results were used.
2. Regarding the concentration of Sr-90, for the north side of the unit 5/6 discharge outlet monthly analysis results were used, and for the north side within the port weekly analysis results were used.
3. For the H-3 concentrations, the weekly analysis results are used for both cases.
4. The calculation period for FY2021 is 9 months, from April 1, 2021, to December 31, 2021.




Figure V-3 Radioactive material concentration of seawater for dilution used for comparison and assessment

The movement amount $M(i)$ of nuclide i , which is a radioactive material included in seawater for dilution (if three seawater pumps for dilution are in operation) and moving to outside the port, was calculated from the concentration in seawater for diluted water, $C_D(i)$, set above by the following equation:

$$M(i) \text{ [Bq/year]} = C_D(i) \text{ [Bq/L]} \times 510,000 \text{ [m}^3\text{/day]} \times 1000 \text{ [L/m}^3\text{]} \times 365 \text{ [day/year]} \times 0.8 \text{ (availability rate)}$$

Two types of source terms were used for the assessment: “measured values of the K4 tank group” and “measured values of the J1-G tank group” used for radiological impact assessment. The amount of added radioactivity transferred is shown in Table V-1.

Table V-1 Annual amount of radioactivity transferred by nuclide of seawater for dilution

| Nuclide | Water intake outside the port (North side of the unit 5/6 discharge outlet) | | Water intake inside the port (North side within the port) | |
|---------|--|------------------------------------|--|------------------------------------|
| | Concentration for assessment (Bq/L) | Volume to be transferred (Bq/year) | Concentration for assessment (Bq/L) | Volume to be transferred (Bq/year) |
| Cs-137 | 2.4E-01 | 3.6E+10 | 4.6E-01 | 6.9E+10 |
| Sr-90 | 1.3E-02 | 1.9E+09 | 4.3E-02 | 6.4E+09 |
| H-3 | 1.1E+00 | 1.6E+11 | 2.1E+00 | 3.1E+11 |

(2) Study results

The results of the exposure assessment are shown in Tables V-2 and V-3. Water intake outside the port has fewer impacts on the external exposures.

However, the results in both assessments are more minor compared with the dose limit of 1 mSv/year and the target dose for domestic nuclear power plant of 0.05 mSv/year, which is corresponding to the dose constraint. Even if seawater inside the port is taken in for dilution, the impact of radiation exposure is more minor.

**Table V-2 Comparison of the exposure assessment results of representative persons
(Large amount of ingestion of seafood)**

| Assessed case | | Source term of the K4 tank group based on measured values | | | Source term of the J1-G tank group based on measured values | | | Remarks | |
|------------------------------|----------------------|---|---|---|---|---|---|-------------------|--|
| | | Exposure assessment under normal conditions | Water intake outside the port (North side of the unit 5/6 discharge outlet) | Water intake inside the port (North side within the port) | Exposure assessment under normal conditions | Water intake outside the port (North side of the unit 5/6 discharge outlet) | Water intake inside the port (North side within the port) | | |
| External exposure (mSv/year) | Sea surface | 6.5E-09 | 7.4E-08 | 1.4E-07 | 4.7E-08 | 1.1E-07 | 1.8E-07 | Value of an adult | |
| | Hull | 4.8E-09 | 5.8E-08 | 1.1E-07 | 3.3E-08 | 8.7E-08 | 1.4E-07 | | |
| | During swimming | 4.5E-09 | 5.1E-08 | 9.4E-08 | 3.2E-08 | 7.9E-08 | 1.2E-07 | | |
| | Beach sand | 7.8E-06 | 9.4E-05 | 1.7E-04 | 5.6E-05 | 1.4E-04 | 2.2E-04 | | |
| Fishing net | 1.6E-06 | 1.7E-05 | 3.1E-05 | 1.2E-05 | 2.7E-05 | 4.1E-05 | | | |
| Internal exposure (mSv/year) | Ingestion of water | 3.3E-07 | 7.3E-07 | 1.2E-06 | 3.2E-07 | 7.2E-07 | 1.2E-06 | | |
| | Inhalation of spray | 9.3E-08 | 4.1E-07 | 7.8E-07 | 4.0E-07 | 7.2E-07 | 1.1E-06 | | |
| | Ingestion of seafood | 6.1E-05 | 7.3E-05 | 8.4E-05 | 3.0E-04 | 3.1E-04 | 3.2E-04 | | |
| Total | | 7E-05 | 2E-04 | 3E-04 | 4E-04 | 5E-04 | 6E-04 | | |

**Table V-3 Results of internal exposures assessment by age
(Large amount of ingestion of seafood)**

| Assessed case | | Source term of the K4 tank group based on measured values | | | Source term of the J1-G tank group based on measured values | | | Remarks |
|--|-------------------------|---|---|---|---|---|---|---------|
| | | Exposure assessment under normal conditions | Water intake outside the port (North side of the unit 5/6 discharge outlet) | Water intake inside the port (North side within the port) | Exposure assessment under normal conditions | Water intake outside the port (North side of the unit 5/6 discharge outlet) | Water intake inside the port (North side within the port) | |
| Internal exposure from ingestion of water (mSv/year) | Adult | 3.3E-07 | 7.3E-07 | 1.2E-06 | 3.2E-07 | 7.2E-07 | 1.2E-06 | |
| | Child under school year | 5.7E-07 | 9.2E-07 | 1.4E-06 | 5.5E-07 | 9.0E-07 | 1.3E-06 | |
| | Infant | — | — | — | — | — | — | |
| Internal exposure from inhalation of spray (mSv/year) | Adult | 9.3E-08 | 4.1E-07 | 7.8E-07 | 4.0E-07 | 7.2E-07 | 1.1E-06 | |
| | Child under school year | 6.2E-08 | 2.8E-07 | 5.4E-07 | 2.2E-07 | 4.4E-07 | 6.9E-07 | |
| | Infant | 4.0E-08 | 1.5E-07 | 2.9E-07 | 1.2E-07 | 2.3E-07 | 3.6E-07 | |
| Internal exposure from ingestion of seafood (mSv/year) | Adult | 6.1E-05 | 7.3E-05 | 8.4E-05 | 3.0E-04 | 3.1E-04 | 3.2E-04 | |
| | Child under school year | 9.4E-05 | 9.9E-05 | 1.1E-04 | 5.6E-04 | 5.6E-04 | 5.7E-04 | |
| | Infant | 1.1E-04 | 1.1E-04 | 1.2E-04 | 7.1E-04 | 7.1E-04 | 7.2E-04 | |

Attachment VI Transfer pathways and exposure pathways other than the assessment targets

The Radiological Impact Assessment Report Regarding the Discharge of ALPS Treated Water into the Sea (design stage) (November 2021, hereinafter called “the original report”) refers to “Dose Assessment to the General Public in the Safety Review of Commercial Light Water Reactor Facilities” approved by the former Nuclear Safety Commission, which had been formulating the domestic safety guidelines, (hereinafter called “Dose Assessment of Light Water Reactor”) and the Application for the Designation of Reprocessing Business of Rokkasho Plant, (hereinafter called “Rokkasho Application”) which is a precedent case, in the selection of the migration and exposure pathways, as well as using IAEA GSG-10 as a reference. In “Dose Assessment of Light Water Reactor,” case studies of potentially important exposure pathways are performed as the examination of the basic concept of the dose assessment to the public in the safety review of reactor facilities for power generation, and the following pathways are simulated as the dose assessment with the radioactive materials in liquid waste.

- (1) External exposure during work at sea
- (2) External exposure during swimming
- (3) External exposure during work at a beach
- (4) External exposure during fishing operation
- (5) Internal exposure from ingestion of seafood

As a result of the simulation, internal exposure from ingestion of seafood is considered to be the most important form of exposure from intake of liquid waste.

On the other hand, the following exposure pathways were assessed and reviewed in the Rokkasho Application.

- (1) External exposure from sea surface
- (2) External exposure from hulls
- (3) External exposure during underwater work
- (4) External exposure from fishing nets
- (5) Internal exposure from ingestion of seafood

External exposure during work at a beach was not selected because there is no beach in the vicinity. In the original report, migration and exposure pathways were first selected based on these documents.

On the other hand, IAEA GSG-10 shows pathways to be considered for transfer and exposure pathways. These transfer pathways and exposure pathways were examined again from the viewpoint of the comprehensiveness of the pathways, and after the simulation of the exposure dose, the additional pathways were examined from the viewpoint of the scale and comprehensiveness of exposure.

Specifically, the transfer and exposure pathways described in the IAEA-TECDOC-1759 [VI-1] (radiological assessment procedures for determining the suitability of materials for sea dumping) were assessed using the assessment method shown in this document and

compared with the exposure assessment results in the original report, and studied on needs of immigration and addition of exposure pathway.

VI-1. Comparative assessment by the method of TECDOC -1759

VI-1-1. Source term

Since nuclides with large exposure impacts differ depending on the exposure assessment method and pathway, the source term based on the measured values including all the 64 nuclides was used.

VI-1-2. Modeling of diffusion and transfer in the environment

The following migration pathways were selected in accordance with the pathways shown by IAEA in GSG-10.

(1) Direct radiation

The radioactive materials handled in the disposal of ALPS treated water is limited to ALPS treated water or diluted ALPS treated water. ALPS treated water is water purified in advance until the sum of the ratios to regulatory concentrations limits of the radioactive materials other than tritium becomes less than 1. Therefore, it was not selected as a migration pathway in the original report considering that there is almost no impact of exposure from ALPS treated water and the direct radiation from the facility.

Not selected in this assessment either.

(2) Diffusion in air, and deposition from the atmosphere onto the ground surface and subsequent resuspension

Since ALPS treated water is diluted with seawater and discharged into the sea as liquid and further diluted in the sea before migration to air, it was not selected as a migration pathway in the original report considering that there is almost no impact of exposure from the radioactive materials diffused into the air.

Not selected in this assessment either.

(3) Advection and diffusion in seawater

Since ALPS treated water is discharged into the sea as liquid, advection and diffusion in seawater were selected in the original report.

Selected in this assessment as well.

(4) Migration from seawater to hulls

Radioactive materials diffused in seawater may migrate to the hulls of ships continuously operating in the surrounding sea area, so it was selected as a migration pathway in the original report.

In TECDOC-1759, no example of a pathway or calculation method is exemplified, so it is not subject to simulation in this assessment.

(5) Migration from seawater to coastal sediment

Since radioactive materials advected and diffused in seawater may migrate to coastal sediment, it was selected as a migration pathway in the original report. In TECDOC-1759, examples of a pathway and a calculation method are also exemplified, so it was also selected in this assessment.

(6) Migration from seawater to suspended particles and seabed sediment

Radioactive materials advected and diffused in seawater are partly adsorbed by suspended particles and seabed sediment, and the concentration in seawater decreases due to the migration. On the other hand, radioactive materials accumulate in seabed sediment, and the concentration in seawater and the concentration in seabed sediment will reach equilibrium in the long term. In the original report, it was not conservatively considered in the stage of advection or diffusion and it was considered that the equilibrium state was achieved with the distribution factor with seabed sediment in the exposure assessment of marine plants and animals.

In TECDOC-1759, an example of a calculation method was exemplified with a model of discharged radioactive materials migrating from seawater to suspended particles and seabed sediment, so it was also selected in this assessment.

(7) Migration from seawater to fishing nets

Radioactive materials advected and diffused in seawater may migrate to fishing nets used in seawater. Since it was assessed in the domestic precedent case, it was selected in the original report.

In TECDOC-1759, no example of a pathway or calculation method is shown, so it was not selected in this assessment.

(8) Migration from seawater to the atmosphere

Since ALPS treated water was diluted with seawater as liquid before being discharged into the sea and diluted in the sea before migration to air, it was not

selected as a migration pathway in the report considering that there is almost no impact of exposure from the radioactive materials diffused from seawater to air. In TECDOC-1759, examples of a pathway of migration as spray from seawater and a calculation method are exemplified, so it was selected as a pathway.

(9) Migration from coastal sediment to air

Since only a small amount of coastal sediment migrates to the air, and it remains on the seashore for only a short time, so the exposure impact was negligible and it was not selected as a migration pathway in the original report.

In TECDOC-1759, examples of a pathway and a calculation method are exemplified, so it was selected as a pathway.

(10) Migration from seawater to seafood

Migration (concentration) from seawater to seafood is widely known and has been assessed in domestic precedent cases including light water reactors, so it was selected in the original report.

In TECDOC-1759, examples of a pathway and a calculation method are exemplified, so it was also selected as a pathway.

Though the diffusion simulation uses the same calculation result as that of the report, in TECDOC-1759, the dissolved concentration $C_{DW}(j)$ is calculated considering the suspended particle concentration and migration to seabed sediment from the equilibrium concentration $C_{BOX}(j)$ of nuclide j calculated from the annual discharge amount of the nuclides discharged into the calculation area and the amount of seawater which passes through the calculation area by the following equation:

$$C_{DW}(j) = \frac{C_{BOX}(j)}{1 + K_d(j) \left(S + \frac{L_B \rho_B}{D} \right)} \quad (VI-1)$$

where

- $K_d(j)$ is the sediment partition factor of radionuclide j (m^3/kg)
- S is the suspended sediment concentration (kg/m^3), $3E-03 kg/m^3$ is used
- L_B is the thickness of the sediment boundary layer (m), $1E-02 m$ is used
- ρ_B is the density of the sediment boundary layer (kg/m^3), $1500 kg/m^3$ is used
- D is the water depth of the model (m), A water depth of 12 m, the depth of the discharge point, is used

The mass density $C_p(j)$ (Bq/kg) of the suspended particles was obtained by the following equation:

$$C_P(j) = K_d(j) C_{DW}(j) \quad (VI-2)$$

The total concentration in seawater $C_w(j)$ of dissolved and suspended particles was obtained by the following equation:

$$C_w(j) = (1 + K_d(j)S) C_{DW}(j) \quad (VI-3)$$

VI-1-3. Identification of exposure pathways

The following exposure pathways were simulated from the pathways and calculation methods shown in TECDOC-1759.

- External exposure from beach sand
- Internal exposure from accidental ingestion of coastal sediment
- Internal exposure from accidental ingestion of seawater
- Internal exposure from accidental inhalation of dispersed coastal sediment
- Internal exposure from inhalation of seawater spray
- Internal exposure from ingestion of seafood
- Exposure due to skin contamination

The calculation method is as follows:

(1) External exposure from beach sand

The external exposure from nuclide migrated to beaches $E_{\text{ext,shore,public}}(\text{Sv})$ is calculated by the following equation:

$$E_{\text{ext,shore,public}} = t_{\text{public}} \sum_j C_s(j) DC_{\text{gr}}(j) \quad (VI-4)$$

$$C_s(j) = \frac{C_P(j) \rho_s d_s}{10} \quad (VI-5)$$

where

- t_{public} is the time spent at the beach (h)
- $DC_{\text{gr}}(j)$ is the dose conversion factor for ground contamination of radionuclide j ((Sv/h)/(Bq/m²)); Dose conversion factors for ground surface contamination specified in the latest FGR 15[VI-2] prepared by the United States Environmental Protection Agency were used (See in Table VI -1).
- $C_s(j)$ is the surface contamination density of radionuclide j in the shore sediments (in Bq/m²)
- ρ_s is the density of coastal sediment (kg/m³), 1.5 E + 03 kg/m³ is used

d_s is the effective thickness of coastal sediment (m), 0.1 m is used
 The activity concentration radionuclide j in suspended particles $C_p(j)$ (Bq/kg-dry weight) is calculated by equation (VI-2).

(2) Internal exposure from accidental ingestion of coastal sediment

The internal exposure from accidental ingestion of coastal sediment $E_{ing, shore, public}$ (Sv) is calculated by the following equation:

$$E_{ing, shore, public} = t_{public} H_{shore} \sum_j \frac{C_s(j)}{\rho_s L_B} DC_{ing}(j) \quad (VI-6)$$

where

- t_{public} is the time spent at the beach (h)
- H_{shore} is the hourly ingestion rate of beach sediment (kg/h), 5.0E-06kg/h, the recommended value of TECDOC-1759, is used
- $C_s(j)$ is the surface contamination density of radionuclide j in the shore sediments (Bq/m²)
- ρ_s is the density of coastal sediment (kg/m³), 1.5 E + 03 kg/m³ is used
- d_s is the effective thickness of coastal sediment (m), 0.1 m is used
- $DC_{ing}(j)$ is the effective dose (Sv/Bq) [VI-3] per unit intake by ingestion of radionuclide j (See Table VI -2).

(3) Internal exposure from ingestion of seawater

The internal exposure from accidental drinking of seawater during swimming on the seashore $E_{drink, public}$ (Sv) is calculated by the following equation:

$$E_{drink, public} = t_{public} H_{swim} \sum_j C_w(j) DC_{ing}(j) \quad (VI-7)$$

where

- t_{public} is the time spent while swimming (h)
- H_{swim} is the intake rate of seawater during swimming (L/h); conservatively, 0.2L/h is used.
- $C_w(j)$ is the concentration of nuclide j in the seawater calculated by equation (VI-3) (Bq/m³);
- $DC_{ing}(j)$ is the effective dose (Sv/Bq) [VI-3] per unit intake by ingestion of radionuclide j (See Table VI -2).

(4) Internal exposure from accidental inhalation of dispersed coastal sediment

The internal exposure from inhalation of dispersed coastal sediment on the shore

$E_{inh,shore,public}$ (Sv) is calculated by the following equation:

$$E_{inh,shore,public} = t_{public} R_{inh,public} DL_{shore} \sum_j C_p(j) DC_{inh}(j) \quad (VI-8)$$

where

t_{public} is the time spent at the beach (h)

$R_{inh, public}$ is the inhalation rate of a member of the public in m^3/h , the recommended value of TECDOC-1759 ($0.92m^3/h$ for adults) is used

DL_{shore} is the load factor (kg/m^3) for dust from coastal sediment, $2.5E-09 kg/m^3$, the recommended value of TECDOC-1759, is used

$DC_{inh}(j)$ is the effective dose (Sv/Bq) per unit intake by inhalation of radionuclide j (See in Table VI -3).

The concentration of radionuclides in sediment $C_p(j)$ (Bq/kg) can be calculated by equation (VI-2).

(5) Internal exposure from inhalation of seawater spray

The internal exposure from seawater spray caused by wave, etc., on the shore

$E_{inh,spray,public}$ (Sv) is calculated by the following equation:

$$E_{inh,spray,public} = t_{public} R_{inh,public} \frac{C_{spray}}{\rho_w} \sum_j C_w(j) DC_{inh}(j) \quad (VI-9)$$

where

t_{public} is the time spent at the beach (h)

$R_{inh, public}$ is the inhalation rate of a member of the public (m^3/h), the recommended value ($0.92 m^3/h$ for adults) is used

C_{spray} is the concentration of seawater spray in the air (kg/m^3), $1.0E-02kg/m^3$, the recommended value of TECDOC-1759, is used

ρ_w is the density of seawater (kg/m^3), $1E+03 kg/m^3$ is used

$C_w(j)$ is the concentration of radionuclide j in the seawater (Bq/m^3)

$DC_{inh}(j)$ is the effective dose per unit intake by inhalation (Sv/Bq) (See Table VI -3).

(6) Internal exposure from ingestion of seafood

The internal exposure from ingestion of seafood $E_{\text{ing,food,public}}$ (Sv) is calculated by the following equation:

$$E_{\text{ing,food,public}} = \sum_k H_B(k) \sum_j C_{EB}(j,k) DC_{\text{ing}}(j) \quad (\text{VI-10})$$

where

$H_B(k)$ is the annual ingestion of seafood k (kg)

$DC_{\text{ing}}(j)$ is the effective dose per unit intake by ingestion of radionuclide j (Sv/Bq)
(See Table VI -2).

$C_{EB}(j,k)$ is the concentration of nuclide j in the edible part of seafood k and
calculated by the following equation:

$$C_{EB}(j,k) = CF(j,k) C_{DW}(j) \quad (\text{VI-11})$$

where

$CF(j,k)$ is the concentration factor for nuclide j of seafood k ((Bq/kg)/(Bq/L)).

$C_{DW}(j)$ is the dissolved concentration of radionuclide j in the seawater (Bq/m³) and
is calculated by equation (VI-1).

(7) Exposure of the skin from sea seabed sediment settled on the skin

Exposure from sea seabed sediment that is adhered to fishing nets during fishing operation and settled on the skin was simulated and the skin effective dose E_{skin} (Sv) is calculated by the following equation:

$$E_{\text{skin}} = 0.01 t_{\text{public}} \sum_j S_d DC_{\text{skin}}(j) / 8760 \quad (\text{VI-12})$$

where

0.01 is the skin tissue loading factor.

t_{public} is the duration of exposure (h).

$DC_{skin}(j)$ is the dose conversion factor for the skin ((Sv/y)/(Bq/cm²)) specified in IAEA SRS44[VI-4] (beta and gamma-ray emitting nuclides) (See Table VI - 4).

8760 is the unit conversion factor (h/y)

S_d is the surface contamination density (Bq/cm²) calculated by the following equation:

$$S_d = K_d(j) C_{DW}(j) \rho_d \quad (VI-13)$$

where

$K_d(j)$ is the distribution factor of the nuclide j between seawater and sea seabed sediment ((Bq/kg)/(Bq/L))

$C_{DW}(j)$ is the concentration of nuclide j in seawater (Bq/L)

ρ is the density of sea seabed sediment (kg/cm³), 1.5 E-03 kg/cm³ is used.

d is the thickness of the sea seabed sediment settled on the skin (cm), 0.01 cm is used.

VI-1-4. Setting of the representative person subject to the exposure assessment

The features of representative persons subject to the exposure assessment were the same as 6-1-2.(4).

- Engage in fishing 120 days (2,880 hours) a year, of which 80 days (1,920 hours) are spent near fishing nets.
- Stay at the beach 500 hours a year and swim for 96 hours.
- The ingestion of seafood is the intake of persons who consume a large amount of seafood. (Table VI-5)

Table VI-1 Dose conversion factor for the effective dose from radiation from beach sand (Source: U.S. EPA FGR15)

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ²)) | Remarks |
|---------|---|-----------------------|
| H-3 | 6.7E-22 | |
| C-14 | 6.1E-19 | |
| Mn-54 | 5.3E-16 | |
| Fe-59 | 7.3E-16 | |
| Co-58 | 6.2E-16 | |
| Co-60 | 1.5E-15 | |
| Ni-63 | 8.0E-20 | |
| Zn-65 | 3.6E-16 | |
| Rb-86 | 1.6E-16 | |
| Sr-89 | 8.9E-17 | |
| Sr-90 | 6.5E-18 | |
| Y-90 | 1.5E-16 | |
| Y-91 | 9.4E-17 | |
| Nb-95 | 4.9E-16 | |
| Tc-99 | 2.0E-18 | |
| Ru-103 | 3.2E-16 | |
| Ru-106 | 1.7E-20 | |
| Rh-103m | 4.3E-20 | |
| Rh-106 | 3.4E-16 | |
| Ag-110m | 1.7E-15 | |
| Cd-113m | 6.3E-18 | |
| Cd-115m | 1.1E-16 | |
| Sn-119m | 9.6E-19 | |
| Sn-123 | 8.1E-17 | |
| Sn-126 | 1.1E-15 | Sb-126m is considered |
| Sb-124 | 1.2E-15 | |
| Sb-125 | 2.7E-16 | |
| Te-123m | 7.7E-17 | |
| Te-125m | 4.1E-18 | |
| Te-127 | 1.5E-17 | |
| Te-127m | 1.7E-18 | Te-127 is considered |
| Te-129 | 1.1E-16 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ²)) | Remarks |
|---------|---|----------------------|
| Te-129m | 5.1E-17 | Te-129 is considered |
| I-129 | 4.4E-18 | |
| Cs-134 | 1.0E-15 | |
| Cs-135 | 1.6E-18 | |
| Cs-136 | 1.3E-15 | |
| Cs-137 | 7.9E-18 | |
| Ba-137m | 3.9E-16 | |
| Ba-140 | 1.6E-15 | La-140 is considered |
| Ce-141 | 4.5E-17 | |
| Ce-144 | 1.1E-17 | |
| Pr-144 | 2.0E-16 | |
| Pr-144m | 3.5E-18 | |
| Pm-146 | 4.8E-16 | |
| Pm-147 | 9.4E-19 | |
| Pm-148 | 4.6E-16 | |
| Pm-148m | 1.3E-15 | |
| Sm-151 | 1.1E-19 | |
| Eu-152 | 7.2E-16 | |
| Eu-154 | 7.9E-16 | |
| Eu-155 | 3.1E-17 | |
| Gd-153 | 4.3E-17 | |
| Tb-160 | 7.1E-16 | |
| Pu-238 | 2.1E-20 | |
| Pu-239 | 4.2E-20 | |
| Pu-240 | 2.2E-20 | |
| Pu-241 | 1.7E-21 | |
| Am-241 | 9.9E-18 | |
| Am-242m | 1.4E-17 | Am-242 is considered |
| Am-243 | 1.3E-16 | Np-239 is considered |
| Cm-242 | 2.6E-20 | |
| Cm-243 | 7.1E-17 | |
| Cm-244 | 3.1E-20 | |

Table VI-2 Committed effective dose per unit intake for ingestion (Source: IAEA GSR-Part3)

| Target Nuclide | Effective dose factor (Sv/Bq) | | | Remarks |
|-----------------------|-------------------------------|------------------------|---------|--|
| | Adult | Child under school age | Infant | |
| H-3 (HTO) | 1.8E-11 | 3.1E-11 | 6.4E-11 | Used for the assessment of ingestion of water |
| H-3 (considering OBT) | 2.0E-11 | 3.5E-11 | 7.0E-11 | Used for the assessment of ingestion of seafood assuming that 10% of tritium to be ingested is OBT |
| C-14 | 5.8E-10 | 9.9E-10 | 1.4E-09 | |
| Mn-54 | 7.1E-10 | 1.9E-09 | 5.4E-09 | |
| Fe-59 | 1.8E-09 | 7.5E-09 | 3.9E-08 | |
| Co-58 | 7.4E-10 | 2.6E-09 | 7.3E-09 | |
| Co-60 | 3.4E-09 | 1.7E-08 | 5.4E-08 | |
| Ni-63 | 1.5E-10 | 4.6E-10 | 1.6E-09 | |
| Zn-65 | 3.9E-09 | 9.7E-09 | 3.6E-08 | |
| Rb-86 | 2.8E-09 | 9.9E-09 | 3.1E-08 | |
| Sr-89 | 2.6E-09 | 8.9E-09 | 3.6E-08 | |
| Sr-90 | 2.8E-08 | 4.7E-08 | 2.3E-07 | Including the impact of the progeny nuclide |
| Y-90 | 2.7E-09 | 1.0E-08 | 3.1E-08 | |
| Y-91 | 2.4E-09 | 8.8E-09 | 2.8E-08 | |
| Nb-95 | 5.8E-10 | 1.8E-09 | 4.6E-09 | |
| Tc-99 | 6.4E-10 | 2.3E-09 | 1.0E-08 | |
| Ru-103 | 7.3E-10 | 2.4E-09 | 7.1E-09 | Including the impact of the progeny nuclide |
| Ru-106 | 7.0E-09 | 2.5E-08 | 8.4E-08 | Including the impact of the progeny nuclide |
| Rh-103m | 3.8E-12 | 1.3E-11 | 4.7E-11 | |
| Rh-106 | – | – | – | Independent intake is not considered because the half-life is short enough (about 30 seconds). |
| Ag-110m | 2.8E-09 | 7.8E-09 | 2.4E-08 | |
| Cd-113m | 2.3E-08 | 3.9E-08 | 1.2E-07 | |
| Cd-115m | 3.3E-09 | 9.7E-09 | 4.1E-08 | |
| Sn-119m | 3.4E-10 | 1.3E-09 | 4.1E-09 | |
| Sn-123 | 2.1E-09 | 7.8E-09 | 2.5E-08 | |
| Sn-126 | 4.7E-09 | 1.6E-08 | 5.0E-08 | |
| Sb-124 | 2.5E-09 | 8.4E-09 | 2.5E-08 | |
| Sb-125 | 1.1E-09 | 3.4E-09 | 1.1E-08 | |
| Te-123m | 1.4E-09 | 4.9E-09 | 1.9E-08 | |
| Te-125m | 8.7E-10 | 3.3E-09 | 1.3E-08 | |
| Te-127 | 1.7E-10 | 6.2E-10 | 1.5E-09 | |

| Target Nuclide | Effective dose factor (Sv/Bq) | | | Remarks |
|----------------|-------------------------------|------------------------|---------|---|
| | Adult | Child under school age | Infant | |
| Te-127m | 2.3E-09 | 9.5E-09 | 4.1E-08 | |
| Te-129 | 6.3E-11 | 2.1E-10 | 7.5E-10 | |
| Te-129m | 3.0E-09 | 1.2E-08 | 4.4E-08 | Including the impact of the progeny nuclide |
| I-129 | 1.1E-07 | 1.7E-07 | 1.8E-07 | |
| Cs-134 | 1.9E-08 | 1.3E-08 | 2.6E-08 | |
| Cs-135 | 2.0E-09 | 1.7E-09 | 4.1E-09 | |
| Cs-136 | 3.0E-09 | 6.1E-09 | 1.5E-08 | |
| Cs-137 | 1.3E-08 | 9.6E-09 | 2.1E-08 | Including the impact of the progeny nuclide |
| Ba-137m | – | – | – | Independent intake is not considered because the half-life is short enough (about 2.6 minutes). |
| Ba-140 | 2.6E-09 | 9.2E-09 | 3.2E-08 | |
| Ce-141 | 7.1E-10 | 2.6E-09 | 8.1E-09 | |
| Ce-144 | 5.2E-09 | 1.9E-08 | 6.6E-08 | Including the impact of the progeny nuclide |
| Pr-144 | 5.0E-11 | 1.7E-10 | 6.4E-10 | |
| Pr-144m | – | – | – | Independent intake is not considered because the half-life is short enough (about 7.2 minutes). |
| Pm-146 | 9.0E-10 | 2.8E-09 | 1.0E-08 | |
| Pm-147 | 2.6E-10 | 9.6E-10 | 3.6E-09 | |
| Pm-148 | 2.7E-09 | 9.7E-09 | 3.0E-08 | |
| Pm-148m | 1.7E-09 | 5.5E-09 | 1.5E-08 | |
| Sm-151 | 9.8E-11 | 3.3E-10 | 1.5E-09 | |
| Eu-152 | 1.4E-09 | 4.1E-09 | 1.6E-08 | |
| Eu-154 | 2.0E-09 | 6.5E-09 | 2.5E-08 | |
| Eu-155 | 3.2E-10 | 1.1E-09 | 4.3E-09 | |
| Gd-153 | 2.7E-10 | 9.4E-10 | 2.9E-09 | |
| Tb-160 | 1.6E-09 | 5.4E-09 | 1.6E-08 | |
| Pu-238 | 2.3E-07 | 3.1E-07 | 4.0E-06 | |
| Pu-239 | 2.5E-07 | 3.3E-07 | 4.2E-06 | |
| Pu-240 | 2.5E-07 | 3.3E-07 | 4.2E-06 | |
| Pu-241 | 4.8E-09 | 5.5E-09 | 5.6E-08 | |
| Am-241 | 2.0E-07 | 2.7E-07 | 3.7E-06 | |
| Am-242m | 1.9E-07 | 2.3E-07 | 3.1E-06 | |
| Am-243 | 2.0E-07 | 2.7E-07 | 3.6E-06 | |
| Cm-242 | 1.2E-08 | 3.9E-08 | 5.9E-07 | |
| Cm-243 | 1.5E-07 | 2.2E-07 | 3.2E-06 | |
| Cm-244 | 1.2E-07 | 1.9E-07 | 2.9E-06 | |

Table VI-3 Committed effective dose per unit intake from inhalation (Source: IAEA GSR-Part3)

| Target Nuclide | Effective dose factor (Sv/Bq) | | | Remarks |
|----------------|-------------------------------|------------------------|---------|--|
| | Adult | Child under school age | Infant | |
| H-3 | 1.8E-11 | 3.1E-11 | 6.4E-11 | The conversion factor of tritium vapor is used |
| C-14 | 5.8E-09 | 1.1E-08 | 1.9E-08 | |
| Mn-54 | 1.5E-09 | 3.8E-09 | 7.5E-09 | |
| Fe-59 | 4.0E-09 | 8.1E-09 | 2.1E-08 | |
| Co-58 | 2.1E-09 | 4.5E-09 | 9.0E-09 | |
| Co-60 | 3.1E-08 | 5.9E-08 | 9.2E-08 | |
| Ni-63 | 1.3E-09 | 2.7E-09 | 4.8E-09 | |
| Zn-65 | 2.2E-09 | 5.7E-09 | 1.5E-08 | |
| Rb-86 | 9.3E-10 | 3.4E-09 | 1.2E-08 | |
| Sr-89 | 7.9E-09 | 1.7E-08 | 3.9E-08 | |
| Sr-90 | 1.6E-07 | 2.7E-07 | 4.2E-07 | Including the impact of the progeny nuclide |
| Y-90 | 1.5E-09 | 4.2E-09 | 1.3E-08 | |
| Y-91 | 8.9E-09 | 1.9E-08 | 4.3E-08 | |
| Nb-95 | 1.8E-09 | 3.6E-09 | 7.7E-09 | |
| Tc-99 | 1.3E-08 | 2.4E-08 | 4.1E-08 | |
| Ru-103 | 3.0E-09 | 6.0E-09 | 1.3E-08 | Including the impact of the progeny nuclide |
| Ru-106 | 6.6E-08 | 1.4E-07 | 2.6E-07 | Including the impact of the progeny nuclide |
| Rh-103m | 2.7E-12 | 6.7E-12 | 2.0E-11 | |
| Rh-106 | – | – | – | Independent intake is not considered because the half-life is short enough (about 30 seconds). |
| Ag-110m | 1.2E-08 | 2.6E-08 | 4.6E-08 | |
| Cd-113m | 1.1E-07 | 1.8E-07 | 3.0E-07 | |
| Cd-115m | 7.7E-09 | 1.7E-08 | 4.6E-08 | |
| Sn-119m | 2.2E-09 | 4.7E-09 | 1.0E-08 | |
| Sn-123 | 8.1E-09 | 1.8E-08 | 4.0E-08 | |
| Sn-126 | 2.8E-08 | 6.2E-07 | 1.2E-07 | |
| Sb-124 | 8.6E-09 | 1.8E-08 | 3.9E-08 | |
| Sb-125 | 1.2E-08 | 2.4E-08 | 4.2E-08 | |
| Te-123m | 5.1E-09 | 9.8E-09 | 2.0E-08 | |
| Te-125m | 4.2E-09 | 7.8E-09 | 1.7E-08 | |
| Te-127 | 1.4E-10 | 3.9E-10 | 1.2E-09 | |
| Te-127m | 9.8E-09 | 2.0E-08 | 4.1E-08 | |
| Te-129 | 3.9E-11 | 1.0E-10 | 3.5E-10 | |

| Target Nuclide | Effective dose factor (Sv/Bq) | | | Remarks |
|----------------|-------------------------------|------------------------|---------|---|
| | Adult | Child under school age | Infant | |
| Te-129m | 7.9E-09 | 1.7E-08 | 3.8E-08 | Including the impact of the progeny nuclide |
| I-129 | 3.6E-08 | 6.1E-08 | 7.2E-08 | |
| Cs-134 | 2.0E-08 | 4.1E-08 | 7.0E-08 | |
| Cs-135 | 8.6E-09 | 1.6E-08 | 2.7E-08 | |
| Cs-136 | 2.8E-09 | 6.0E-09 | 1.5E-08 | |
| Cs-137 | 3.9E-08 | 7.0E-08 | 1.1E-07 | Including the impact of the progeny nuclide |
| Ba-137m | – | – | – | Independent intake is not considered because the half-life is short enough (about 2.6 minutes). |
| Ba-140 | 5.8E-09 | 1.2E-08 | 2.9E-08 | |
| Ce-141 | 3.8E-09 | 7.1E-09 | 1.6E-08 | |
| Ce-144 | 5.3E-08 | 1.4E-07 | 3.6E-07 | Including the impact of the progeny nuclide |
| Pr-144 | 1.8E-11 | 5.2E-11 | 1.9E-10 | |
| Pr-144m | – | – | – | Independent intake is not considered because the half-life is short enough (about 7.2 minutes). |
| Pm-146 | 2.1E-08 | 3.9E-08 | 6.4E-08 | |
| Pm-147 | 5.0E-09 | 1.1E-08 | 2.1E-08 | |
| Pm-148 | 2.2E-09 | 5.5E-09 | 1.5E-08 | |
| Pm-148m | 5.7E-09 | 1.2E-08 | 2.5E-08 | |
| Sm-151 | 4.0E-09 | 6.7E-09 | 1.1E-08 | |
| Eu-152 | 4.2E-08 | 7.0E-08 | 1.1E-07 | |
| Eu-154 | 5.3E-08 | 9.7E-08 | 1.6E-07 | |
| Eu-155 | 6.9E-09 | 1.4E-08 | 2.6E-08 | |
| Gd-153 | 2.1E-09 | 6.5E-09 | 1.5E-08 | |
| Tb-160 | 7.0E-09 | 1.5E-08 | 3.2E-08 | |
| Pu-238 | 1.1E-04 | 1.4E-04 | 2.0E-04 | |
| Pu-239 | 1.2E-04 | 1.5E-04 | 2.1E-04 | |
| Pu-240 | 1.2E-04 | 1.5E-04 | 2.1E-04 | |
| Pu-241 | 2.3E-06 | 2.6E-06 | 2.8E-06 | |
| Am-241 | 9.6E-05 | 1.2E-04 | 1.8E-04 | |
| Am-242m | 9.2E-05 | 1.1E-04 | 1.6E-04 | |
| Am-243 | 9.6E-05 | 1.2E-04 | 1.8E-04 | |
| Cm-242 | 5.9E-06 | 1.2E-05 | 2.7E-05 | |
| Cm-243 | 6.9E-05 | 9.5E-05 | 1.6E-04 | |
| Cm-244 | 5.7E-05 | 8.3E-05 | 1.5E-04 | |

Table VI-4 Skin equivalent dose conversion factors (β and γ emitting nuclides)

| Nuclide | Skin equivalent dose conversion factors ((Sv/year)/(Bq/cm ²)) | Remarks |
|---------|---|---------|
| H-3 | 0.0E+00 | |
| C-14 | 7.9E-03 | |
| Mn-54 | 5.3E-04 | |
| Fe-59 | 1.8E-02 | |
| Co-58 | 4.2E-03 | |
| Co-60 | 1.7E-02 | |
| Ni-63 | 1.6E-04 | |
| Zn-65 | 7.7E-04 | |
| Rb-86 | 2.3E-02 | |
| Sr-89 | 2.3E-02 | |
| Sr-90 | 4.5E-02 | |
| Y-90 | 2.4E-02 | |
| Y-91 | 2.3E-02 | |
| Nb-95 | 6.4E-03 | |
| Tc-99 | 1.4E-02 | |
| Ru-103 | 1.1E-02 | |
| Ru-106 | 2.5E-02 | |
| Rh-103m | 1.4E-05 | |
| Rh-106 | 0.0E+00 | |
| Ag-110m | 8.5E-03 | |
| Cd-113m | 2.0E-02 | |
| Cd-115m | 2.3E-02 | |
| Sn-119m | 0.0E+00 | |
| Sn-123 | 0.0E+00 | |
| Sn-126 | 1.6E-02 | |
| Sb-124 | 2.2E-02 | |
| Sb-125 | 1.8E-02 | |
| Te-123m | 2.0E-02 | |
| Te-125m | 2.6E-02 | |
| Te-127 | 2.1E-02 | |
| Te-127m | 3.7E-02 | |

| Nuclide | Skin equivalent dose conversion factors ((Sv/year)/(Bq/cm ²)) | Remarks |
|---------|--|---------|
| Te-129 | 2.3E-02 | |
| Te-129m | 3.7E-02 | |
| I-129 | 5.8E-03 | |
| Cs-134 | 1.7E-02 | |
| Cs-135 | 9.6E-03 | |
| Cs-136 | 2.1E-02 | |
| Cs-137 | 2.2E-02 | |
| Ba-137m | 0.0E+00 | |
| Ba-140 | 5.3E-02 | |
| Ce-141 | 2.5E-02 | |
| Ce-144 | 3.9E-02 | |
| Pr-144 | 0.0E+00 | |
| Pr-144m | 0.0E+00 | |
| Pm-146 | 0.0E+00 | |
| Pm-147 | 1.1E-02 | |
| Pm-148 | 0.0E+00 | |
| Pm-148m | 0.0E+00 | |
| Sm-151 | 2.5E-04 | |
| Eu-152 | 1.5E-02 | |
| Eu-154 | 3.1E-02 | |
| Eu-155 | 7.6E-03 | |
| Gd-153 | 3.6E-03 | |
| Tb-160 | 3.1E-02 | |
| Pu-238 | 9.5E-04 | |
| Pu-239 | 1.3E-05 | |
| Pu-240 | 9.1E-07 | |
| Pu-241 | 1.4E-08 | |
| Am-241 | 6.3E-04 | |
| Am-242m | 1.7E-02 | |
| Am-243 | 3.7E-02 | |
| Cm-242 | 2.1E-05 | |
| Cm-243 | 1.7E-02 | |

| Nuclide | Skin equivalent dose conversion factors ((Sv/year)/(Bq/cm ²)) | Remarks |
|---------|--|---------|
| Cm-244 | 1.9E-05 | |

Table VI-5 Intake of persons who consume a large amount of seafood (g/day)

| | Fish | Invertebrate | Seaweeds |
|-----------------------|------|--------------|----------|
| Adult | 190 | 62 | 52 |
| Children under school | 97 | 31 | 26 |
| Infants | 39 | 12 | 10 |

VI-2. Exposure assessment result

The source terms of the following three cases were assessed by the assessment method of TECDOC-1759 and compared with the results in the original report.

- i. K4 tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.29)
- ii. J1-C tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.35)
- iii. J1-G tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.22)

The results of the comparison are shown in Table VI-6(1) to (3).

Regardless of the source term, none of the assessment results exceeded the exposure from the ingestion of seafood, fishing nets, and beach sand in the original report. However, because the exposure from ingestion of seawater and inhalation of seawater spray are larger than the exposure from sea surface, etc. described in the original report, it was decided to select them as additional pathways for this report as well.

Table VI-6(1) Comparison of the exposure assessment results by the source term of the K4 tank group

| Assessed case | | Original report | TECDOC-1759 | Remarks |
|--------------------------------------|--|--------------------|--------------------|--|
| External exposure (mSv/year) | Exposure from sea surface | 6.5E-09 | Not to be assessed | |
| | Exposure from hulls | 4.8E-09 | Not to be assessed | |
| | Exposure during swimming | 4.5E-09 | Not to be assessed | |
| | Exposure from beach sand | 7.8E-06 | 4.0E-07 | In the assessment of the original report, conservative dose conversion factors were used for external exposures, and therefore the results are considered to be conservative. |
| | Exposure from fishing nets | 1.6E-06 | Not to be assessed | |
| Internal exposure (mSv/year) (Adult) | Ingestion of coastal sediment | Not to be assessed | 7.8E-10 | |
| | Ingestion of seawater | Not to be assessed | 3.3E-07 | Since the tritium in the ALPS treated water before dilution, of which concentration exceed the regulatory concentration limit, has higher concentration than the other nuclides after discharge into the sea as well, the exposure through accidentally ingestion of seawater is mainly caused by tritium. |
| | Inhalation of dispersed coastal sediment | Not to be assessed | 5.1E-12 | |
| | Inhalation of seawater spray | Not to be assessed | 7.7E-08 | |
| | Ingestion of seafood | 6.1E-05 | 1.6E-05 | In the assessment of the original report, the concentration in seafood was assessed using conservative concentrations in seawater rather than taking into account adhesion to suspended particles and sea seabed sediment. Therefore, the assessment result is considered to be conservative. |
| Exposure of the skin (mSv/year) | When seabed sediment settles on the skin | Not to be assessed | 1.5E-09 | |
| Total (mSv/year) | | 7E-05 | 2E-05 | |

Table VI-6(2) Comparison of the exposure assessment results by the source term of the J1-C tank group

| Assessed case | | Original report | TECDOC-1759 | Remarks |
|--------------------------------------|--|--------------------|--------------------|--|
| External exposure (mSv/year) | Exposure from sea surface | 1.7E-08 | Not to be assessed | |
| | Exposure from hulls | 1.2E-08 | Not to be assessed | |
| | Exposure during swimming | 1.2E-08 | Not to be assessed | |
| | Exposure from beach sand | 2.1E-05 | 2.1E-07 | In the assessment of the original report, conservative dose conversion factors were used for external exposures, and therefore the results are considered to be conservative. |
| | Exposure from fishing nets | 4.3E-06 | Not to be assessed | |
| Internal exposure (mSv/year) (Adult) | Ingestion of coastal sediment | Not to be assessed | 6.6E-10 | |
| | Ingestion of seawater | Not to be assessed | 3.1E-07 | Since the tritium in the ALPS treated water before dilution, of which concentration exceed the regulatory concentration limit, has higher concentration than the other nuclides after discharge into the sea as well, the exposure through accidentally ingestion of seawater is mainly caused by tritium. |
| | Inhalation of dispersed coastal sediment | Not to be assessed | 4.2E-11 | |
| | Inhalation of seawater spray | Not to be assessed | 7.5E-08 | |
| | Ingestion of seafood | 1.1E-04 | 2.9E-06 | In the assessment of the original report, the concentration in seafood was assessed using conservative concentrations in seawater rather than taking into account adhesion to suspended particles and sea seabed sediment. Therefore, the assessment result is considered to be conservative. |
| Exposure of the skin (mSv/year) | When seabed sediment settles on the skin | Not to be assessed | 2.2E-09 | |
| Total (mSv/year) | | 1E-04 | 3E-06 | |

Table VI-6(3) Comparison of the exposure assessment results by the source term of the J1-G tank group

| Assessed case | | Original report | TECDOC-1759 | Remarks |
|--------------------------------------|--|--------------------|--------------------|--|
| External exposure (mSv/year) | Exposure from sea surface | 4.7E-08 | Not to be assessed | |
| | Exposure from hulls | 3.3E-08 | Not to be assessed | |
| | Exposure during Swimming | 3.2E-08 | Not to be assessed | |
| | Exposure from beach sand | 5.6E-05 | 2.1E-07 | In the assessment of the original report, conservative dose conversion factors were used for external exposures, and therefore the results are considered to be conservative. |
| | Exposure from fishing nets | 1.2E-05 | Not to be assessed | |
| Internal exposure (mSv/year) (Adult) | Ingestion of coastal sediment | Not to be assessed | 6.6E-10 | |
| | Ingestion of seawater | Not to be assessed | 3.1E-07 | Since the tritium in the ALPS treated water before dilution, of which concentration exceed the regulatory concentration limit, has higher concentration than the other nuclides after discharge into the sea as well, the exposure through accidently ingestion of seawater is mainly caused by tritium. |
| | Inhalation of dispersed coastal sediment | Not to be assessed | 4.2E-11 | |
| | Inhalation of seawater spray | 4.0E-07 | 7.5E-08 | |
| | Ingestion of seafood | Not to be assessed | 4.6E-06 | In the assessment of the original report, the concentration in seafood was assessed using conservative concentrations in seawater rather than taking into account adhesion to suspended particles and sea seabed sediment. Therefore, the assessment result is considered to be conservative. |
| Exposure of the skin (mSv/year) | When seabed sediment settles on the skin | Not to be assessed | 5.2E-09 | |
| Total (mSv/year) | | 4E-04 | 5E-06 | |

References

- [VI-1] IAEA, TECDOC-1759" Determining the Suitability of Materials for Disposal at Sea under the London Convention 1972 and London Protocol 1996: A Radiological Assessment Procedure",2015
- [VI-2] EPA, FEDERAL GUIDANCE REPORT NO.15 "EXTERNAL EXPOSURE TO RADIONUCLIDES IN AIR, WATER AND SOIL",2019
- [VI-3] IAEA, General Safety Requirements Part 3" Radiation Protection and Safety of Radiation Sources: International Basic Safety Standards",2014
- [VI-4] IAEA, Safety Report Series No. 44" Derivation of Activity Concentration Values for Exclusion, Exemption and Clearance",2005

Attachment VII Validity of the diffusion simulation

In the chapter 6-1-2.(2) “Modeling of diffusion and transfer after discharge”, the simulation model used to calculate the advection and diffusion of tritium is the model for the reproduction calculation of the diffusion of cesium leaked into the sea area due to the Accident at the Fukushima Daiichi Nuclear Power Station.

The following describes the validity of the diffusion simulation from various viewpoints.

VII-1. Reproducibility of the flow rate

As described in the chapter 6-1-2.(2) “Modeling of diffusion and transfer after discharge”, this simulation used actual meteorological and oceanographic data for the reproduction calculation of cesium leaked from the Fukushima Daiichi Nuclear Power Station, and confirmed the reproducibility by comparing it with actual sea area monitoring data.

Figure VII-1 shows a comparison of the north and south components of the flow rate measured with the acoustic doppler current profiler (ADCP; 600 kHz, RDI) in the locations about 5 km to the south of the Fukushima Daiichi nuclear power station and about 2.8 km offshore (37°22.6' N, 141°3.7'E) and the flow rate reproduced by simulation between October 8 and December 10, 2014 and between April 22 and June 25, 2015 [VII-1]. The match rate between the simulation and measured value is high no matter whether the river flow rate is considered.




Figure VII-1 Comparison between the flow rate measured near the Fukushima Daiichi Nuclear Power Station and the reproduction calculation by simulation

VII-2. Reproducibility of the cesium concentration

Figure VII-2 shows the result of comparison between the annual average value of the cesium 137 concentration [VII-2] of surface seawater obtained by coastal seawater monitoring in Fukushima by TEPCO and the annual average concentration distribution of the surface reproduced by simulation between 2013 and 2016. "O" shows the monitoring points, the colors show the measured Cs-137 concentrations, and the contour figure shows the calculation result of simulation. Similarly, Figure VII-3 shows a comparison with the annual average value of the cesium 137 concentration [VII-2] of surface seawater obtained by seawater monitoring in the offshore sea area by the Secretariat of the Nuclear Regulation Authority. The high concentration in the coastal area around the power station and the general concentration trend are reproduced well.

Moreover, Figure VII-4 shows the data in the scatter diagram. The measured values are almost similar to the simulated ones in the upper right region, where the concentration is high (blue dashed line).

On the other hand, in the lower-left region where the concentration is low (red dashed line), the measured values tend to be higher than the simulated results. Measured values are higher in the low concentration region probably because the simulation results do not adequately reflect some sources, such as the supply of cesium from rivers and inflow of cesium due to recirculation by currents in the North Pacific Ocean. Thus, this does not raise issues regarding the reproducibility of simulation results in this assessment conducted to evaluate the impact of the discharge of the ALPS treated water.




Figure VII-2 Comparison between the measured value and simulation of the Cs-137 concentration in the coastal area around the Fukushima Daiichi Nuclear Power Station




Figure VII-3 Comparison between the measured value and simulation of the Cs-137 concentration offshore in the sea area around the Fukushima Daiichi Nuclear Power Station




Figure VII-4 Comparison between the measured value and simulation of the Cs-137 concentration in the sea area around the Fukushima Daiichi Nuclear Power Station (Blue and red mainly show coast and offshore, respectively.)

VII-3. Concentration distribution around the discharge outlet

The tritium simulation model used in 6-1-2.(2) “Modeling of diffusion and transfer after discharge” is a model to simulate migration and diffusion in vast areas and did not simulate the physical flow around the discharge outlet. Therefore, despite the upward discharge of water, the concentration near the seabed around the discharge outlet is higher than in the surrounding areas. Still, the result is that the concentration just above the discharge outlet does not show an increase much.

On the other hand, during the actual discharge, it will entrain surrounding seawater, facilitating the mixing and dilution. In addition, since the ALPS treated water to be discharged has already been diluted more than 100 times with seawater, the salinity and specific gravity of the water will be almost the same as those of the surrounding seawater. Therefore, although there is a slight difference in the concentration distribution around the discharge outlet, the diffusion in areas away from the outlet will not be expected to differ significantly to the simulated results.

Attachment VIII “Difference in the diffusion area by discharge location” of the report compares the simulated tritium diffusion when the discharge point is 1 km off the coast with the result when a discharge point is a unit 5/6 discharge outlet.

Although the concentration distribution around the discharge outlet is different, as shown in Figures VII-5 and VII-6, there is no notable difference in the diffusion in the surrounding sea area.




Figure VII-5 Comparison of the distribution of annual mean tritium concentration in the sea between different discharge locations (sea surface)




Figure VII-6 Comparison of the distribution of annual mean tritium concentration in the sea between different discharge locations (cross-sectional view)

In addition, even when the upward flow is not considered, the mean concentration in the 10 km × 10 km area calculated in the simulation is higher in the upper layer than the concentration around the discharge outlet, because as shown in Figures VII-7 to 10, the water depth in the surrounding sea gradually becomes deeper, and the concentration on the bottom offshore is much lower than in the surface layer.




Figure VII-7 Cross-sectional view of the seabed up to about 10 km offshore




Figure VII-8 Cross-sectional view of distribution of annual mean tritium concentration up to 10 km offshore




Figure VII-9 Distribution of annual mean tritium concentration on the sea surface up to 3 km offshore




Figure VII-10 Distribution of annual mean tritium concentration on the sea bottom up to 3 km offshore

VII-4. Calculation period

As shown in 6-1-3, a simulation calculation of 7 years was performed in order to verify the fluctuation caused by the fluctuation in annual meteorological and oceanographic data. The result shows that the fluctuation in the annual average concentration of all layers within the range of 10 km × 10 km was small. Figure VII-11 shows the change in the daily average concentration in the same calculation. The concentration fluctuates significantly and no accumulation trend was observed in each calculation period (one year). No significant difference is expected to occur between the result of the calculations performed each year and the result of calculations performed for multiple consecutive years. Therefore, the result of the calculations for each year will be used because there is considered to be no problem in evaluating the impact over a long period of discharge with the assessment based on the result of one-year's calculations.




Figure VII-11 Calculation result of the daily average concentration within the range of 10 km x 10 km of each year

VII-5. Validity of the calculation area

The calculation area of the simulation used in the report is approximately 490 km north-south and 270 km east-west. Table VII-1 shows the maximum value and position of the area boundary from the annual average concentration calculated from meteorological and oceanographic data for the years 2014 to 2020. Table VII-2 shows the annual maximum value, position, and date of occurrence of the area boundary based on the daily average concentration. The annual average concentration distribution diagram of tritium concentration of the entire area (result shown diagrammatically down to the lower limit of 1E-05Bq/L) is shown in Figure VII-12.

The maximum value of the annual average concentration range on the boundary of the calculation area is from 1.1E-04 to 2.6E-04Bq/L and maximum daily average concentration range is from 5.3E-03 to 1.4E-02Bq/L, all in the east side, but compared to the tritium concentration in sea water in sea area around Japan (about 1.0E-1Bq/L) [VII-3], which is sufficiently low.

In addition, the exposure assessment result calculated from the annual average concentration of 10 km × 10 km area around the power station is much lower than the dose limit for the general public of 1mSv/year, as well as the dose constraint of 0.05mSv/year, and it is not necessary to assess the impact of radioactivity outside of the calculation area.


Table VII-1 Maximum value and position of the annual average concentration on the model boundary (north, south, and east) of each year

| Year | Concentration (Bq/L) | Coordinate | | |
|------|----------------------|---|---|---|
| | | East - West (0: West boundary, 460: East boundary) | North - South (0: South boundary, 658: North boundary) | Depth (0: Bottom layer, 29: Top layer) |
| 2014 | 1.1E-04 | 460 (East boundary) | 80 | 23 |
| 2015 | 2.6E-04 | 460 (East boundary) | 145 | 29 |
| 2016 | 1.4E-04 | 460 (East boundary) | 318 | 25 |
| 2017 | 2.4E-04 | 460 (East boundary) | 224 | 23 |
| 2018 | 1.9E-04 | 460 (East boundary) | 150 | 29 |
| 2019 | 1.6E-04 | 460 (East boundary) | 181 | 28 |
| 2020 | 1.9E-04 | 460 (East boundary) | 232 | 28 |


Table VII-2 Maximum value, position, and date occurred of the daily average concentration on the model boundary (north, south, and east) of each year

| Date occurred | Concentration (Bq/L) | Coordinate | | |
|---------------|----------------------|---|---|---|
| | | East - West (0: West boundary, 460: East boundary) | North - South (0: South boundary, 658: North boundary) | Depth (0: Bottom layer, 29: Top layer) |
| 2014/9/21 | 6.7E-03 | 460 (East boundary) | 198 | 19 |
| 2015/8/2 | 7.2E-03 | 460 (East boundary) | 158 | 25 |
| 2016/8/6 | 1.4E-02 | 460 (East boundary) | 341 | 28 |
| 2017/7/28 | 6.5E-03 | 460 (East boundary) | 252 | 29 |
| 2018/8/15 | 5.3E-03 | 460 (East boundary) | 215 | 21 |
| 2019/8/1 | 1.0E-02 | 460 (East boundary) | 177 | 27 |
| 2020/5/30 | 1.1E-02 | 460 (East boundary) | 234 | 28 |


2014




2015




2016




2017



2018



2019



2020




Figure VII-12 Annual average concentration distribution diagram of the tritium concentration (result shown diagrammatically up to 1E-05Bq/L as the lowest limit)


References

- [VII-1] D.Tsumune, T.Tsubono, K.Misumi, Y.Tateda, Y.Toyoda, Y.Onda, and M.Aoyama, "Impacts of direct release and river discharge on oceanic ^{137}Cs derived from the Fukushima Dai-ichi Nuclear Power Plant accident", 2020
- [VII-2] <https://radioactivity.nsr.go.jp/ja/list/428/list-1.html>
- [VII-3] Marine Ecology Research Institute "FY2020 Commissioned Project Survey Report such as Disaster Prevention Measures, etc. for Nuclear Facilities (Investigation of radioactivity and comprehensive assessment in marine environment)" March 2021

Attachment VIII Difference in the diffusion area by discharge location

In the consideration of the discharge method of ALPS treated water, initially a plan of discharging from the unit 5/6 discharge outlet was considered as with the normal operation of units 5 and 6. Figure VIII-1 shows the water discharge position under consideration in this plan and the position of the unit 5/6 discharge outlet.

Figures VIII-2 to 4 show a comparison of diffusion simulation results among different discharge positions. Though no significant difference is observed in the concentration range of 0.1Bq/L, the concentration around the power station is lower in discharge from 1 km offshore.




Source: This map was created by Tokyo Electric Power Company Holdings, Inc. based on a map published by the Geographical Survey Institute (Electronic Map Web)


<https://maps.gsi.go.jp/#13/37.422730/141.044970/&base=std&ls=std&disp=1&vs=c1j0h0k0l0u0t0z0r0s0m0f1>

*Area where common fishery rights are not set.

Figure VIII-1 Discharge position and position of the unit 5/6 discharge outlet in the current plan



(Discharge from an outlet 1 km off the coast) (Discharge from unit 5/6 discharge outlet)
Figure VIII-2 Comparison of the distribution of annual mean concentration of the sea surface between different discharge locations (wide area)



(Discharge from an outlet 1 km off the coast) (Discharge from unit 5/6 discharge outlet)
Figure VIII-3 Comparison of the distribution of annual mean concentration of the sea surface between different discharge locations (enlarged diagram)





Figure VIII-4 Comparison of the distribution of annual mean concentration between different discharge locations (cross-sectional view)

Attachment IX Contribution to the undetected nuclides in the source term based on the measured value

The 64 nuclides subject to this assessment include many undetected nuclides which have never been detected in the past analysis assessments. As shown in 6-1-2.(1) “Source term (annual discharge amount of each nuclide)” annual discharge amount is conservatively assumed to include nuclides below the detection limit in the source term based on actual measurement. However, it is estimated that the actual concentrations of many of the nuclides which have never been detected are much lower than the detection limit considering their half-lives, etc.

In order to verify conservativeness in the result of the exposure assessment, the exposure assessment result of each nuclide is aggregated separating detected nuclides from undetected nuclides

Tables IX-1 to 4 show the result.

In both cases, it is considered that the contribution from undetected nuclides is significant, and the assessment result contains high conservativeness.

Table IX-1 Contributions of detected and undetected nuclides (human exposure)

| Assessed case | Source term | Source term based on measured values | | | | | |
|--|----------------------|--------------------------------------|---------|---------------------|---------|----------------------|---------|
| | | i. K4 tank group | | ii. J1-C tank group | | iii. J1-G tank group | |
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| Exposure* (mSv/year) | Detected nuclide | 5.7E-06 | 2.0E-05 | 1.4E-06 | 4.0E-06 | 2.1E-06 | 6.4E-06 |
| | Undetected nuclide | 1.9E-05 | 5.1E-05 | 5.2E-05 | 1.3E-04 | 1.5E-04 | 3.6E-04 |
| | Total | 2.5E-05 | 7.1E-05 | 5.4E-05 | 1.3E-04 | 1.5E-04 | 3.7E-04 |
| Percentage of undetected nuclides in total | | 77% | 71% | 97% | 97% | 99% | 98% |

* Exposure is the total of external exposure and internal exposure

Table IX-2 Contributions of detected and undetected nuclides (environmental protection and K4 tank group)

| Assessed case | | K4 tank group | | |
|--|--------------------|---------------|---------|---------------|
| | | Flatfish | Crab | Brown seaweed |
| Exposure (mGy/day) | Detected nuclide | 7.5E-07 | 7.6E-07 | 8.3E-07 |
| | Undetected nuclide | 1.7E-05 | 1.7E-05 | 1.8E-05 |
| | Total | 1.7E-05 | 1.7E-05 | 1.9E-05 |
| Percentage of undetected nuclides in total | | 96% | 96% | 96% |

Table IX-3 Contributions of detected and undetected nuclides (environmental protection and J1-C tank group)

| Assessed case | | J1-C tank group | | |
|--|--------------------|-----------------|---------|---------------|
| | | Flatfish | Crab | Brown seaweed |
| Exposure (mGy/day) | Detected nuclide | 1.4E-07 | 1.4E-07 | 1.5E-07 |
| | Undetected nuclide | 2.2E-05 | 2.2E-05 | 2.3E-05 |
| | Total | 2.2E-05 | 2.2E-05 | 2.3E-05 |
| Percentage of undetected nuclides in total | | 99% | 99% | 99% |

Table IX-4 Contributions of detected and undetected nuclides (environmental protection and J1-G tank group)

| Assessed case | | J1-G tank group | | |
|--|--------------------|-----------------|---------|---------------|
| | | Flatfish | Crab | Brown seaweed |
| Exposure (mGy/day) | Detected nuclide | 2.9E-07 | 2.8E-07 | 3.0E-07 |
| | Undetected nuclide | 5.6E-05 | 5.5E-05 | 5.8E-05 |
| | Total | 5.6E-05 | 5.5E-05 | 5.9E-05 |
| Percentage of undetected nuclides in total | | 99% | 99% | 99% |

Attachment X Breakdown of the exposure assessment result by nuclide

X-1. Internal exposures assessment of human

For the following exposure assessments shown in 6-1. "Exposure assessment under normal conditions", Tables X-1-1 to 4, X-2-1 to 4, and X-3-1 to 4 show the internal exposure assessment result of each nuclide.

Source term based on measured values of 64 nuclides

- i. K4 tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.29)
- ii. J1-C tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.35)
- iii. J1-G tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.22)

Table X-1-1 Internal exposure assessment result from ingestion of seawater (Source term based on measured values (K4 tank group))

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|---------|
| | Adult | Children under school age | Infants | |
| H-3 | 3.0E-07 | 5.2E-07 | Exempted | |
| I-129 | 2.1E-08 | 3.2E-08 | Exempted | |
| Ru-106 | 1.0E-09 | 3.6E-09 | Exempted | |
| C-14 | 7.7E-10 | 1.3E-09 | Exempted | |
| Sr-90 | 5.5E-10 | 9.2E-10 | Exempted | |
| Cs-137 | 4.9E-10 | 3.6E-10 | Exempted | |
| Y-91 | 4.7E-10 | 1.7E-09 | Exempted | |
| Sn-123 | 2.2E-10 | 8.3E-10 | Exempted | |
| Cd-115m | 1.9E-10 | 5.5E-10 | Exempted | |
| Co-60 | 1.3E-10 | 6.7E-10 | Exempted | |
| Pm-148 | 1.2E-10 | 4.3E-10 | Exempted | |
| Te-129m | 8.5E-11 | 3.4E-10 | Exempted | |
| Cs-134 | 7.6E-11 | 5.2E-11 | Exempted | |
| Te-127m | 6.5E-11 | 2.7E-10 | Exempted | |
| Y-90 | 5.3E-11 | 2.0E-10 | Exempted | |
| Rb-86 | 4.7E-11 | 1.7E-10 | Exempted | |
| Tc-99 | 4.0E-11 | 1.4E-10 | Exempted | |
| Cd-113m | 3.7E-11 | 6.2E-11 | Exempted | |
| Sb-125 | 3.2E-11 | 1.0E-10 | Exempted | |
| Ni-63 | 2.9E-11 | 9.0E-11 | Exempted | |
| Ce-144 | 2.9E-11 | 1.1E-10 | Exempted | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|---------|
| | Adult | Children under school age | Infants | |
| Te-125m | 2.6E-11 | 9.7E-11 | Exempted | |
| Sr-89 | 2.3E-11 | 7.9E-11 | Exempted | |
| Ba-140 | 2.2E-11 | 7.8E-11 | Exempted | |
| Pu-239 | 1.4E-11 | 1.8E-11 | Exempted | |
| Pu-240 | 1.4E-11 | 1.8E-11 | Exempted | |
| Pu-238 | 1.3E-11 | 1.7E-11 | Exempted | |
| Pu-241 | 1.2E-11 | 1.4E-11 | Exempted | |
| Sn-126 | 1.1E-11 | 3.8E-11 | Exempted | |
| Am-241 | 1.1E-11 | 1.5E-11 | Exempted | |
| Am-243 | 1.1E-11 | 1.5E-11 | Exempted | |
| Cm-243 | 8.4E-12 | 1.2E-11 | Exempted | |
| Cs-136 | 8.0E-12 | 1.6E-11 | Exempted | |
| Pm-146 | 7.8E-12 | 2.4E-11 | Exempted | |
| Cm-244 | 6.7E-12 | 1.1E-11 | Exempted | |
| Zn-65 | 5.2E-12 | 1.3E-11 | Exempted | |
| Sn-119m | 5.1E-12 | 2.0E-11 | Exempted | |
| Te-127 | 4.8E-12 | 1.8E-11 | Exempted | |
| Pm-147 | 4.4E-12 | 1.6E-11 | Exempted | |
| Tb-160 | 4.0E-12 | 1.3E-11 | Exempted | |
| Eu-152 | 3.5E-12 | 1.0E-11 | Exempted | |
| Fe-59 | 2.7E-12 | 1.1E-11 | Exempted | |
| Eu-154 | 2.1E-12 | 6.9E-12 | Exempted | |
| Sb-124 | 2.1E-12 | 7.1E-12 | Exempted | |
| Te-129 | 1.8E-12 | 6.0E-12 | Exempted | |
| Ce-141 | 1.6E-12 | 5.8E-12 | Exempted | |
| Ag-110m | 1.4E-12 | 3.9E-12 | Exempted | |
| Pm-148m | 1.3E-12 | 4.1E-12 | Exempted | |
| Te-123m | 1.1E-12 | 4.0E-12 | Exempted | |
| Eu-155 | 9.4E-13 | 3.2E-12 | Exempted | |
| Gd-153 | 7.7E-13 | 2.7E-12 | Exempted | |
| Cm-242 | 6.7E-13 | 2.2E-12 | Exempted | |
| Am-242m | 6.6E-13 | 8.0E-13 | Exempted | |
| Ru-103 | 6.5E-13 | 2.1E-12 | Exempted | |
| Co-58 | 5.3E-13 | 1.8E-12 | Exempted | |
| Nb-95 | 5.2E-13 | 1.6E-12 | Exempted | |
| Mn-54 | 4.2E-13 | 1.1E-12 | Exempted | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Pr-144 | 2.8E-13 | 9.5E-13 | Exempted | |
| Sm-151 | 7.8E-15 | 2.6E-14 | Exempted | |
| Rh-103m | 3.4E-15 | 1.2E-14 | Exempted | |
| Cs-135 | 4.4E-16 | 3.8E-16 | Exempted | |
| Rh-106 | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Total | 3.3E-07 | 5.7E-07 | Exempted | |

Table X-1-2 Assessment result of internal exposure from inhalation of seawater spray (Source term based on measured values (K4 tank group))

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| H-3 | 7.3E-08 | 5.0E-08 | 3.4E-08 | |
| Ru-106 | 2.3E-09 | 1.9E-09 | 1.1E-09 | |
| C-14 | 1.9E-09 | 1.4E-09 | 7.9E-10 | |
| I-129 | 1.6E-09 | 1.1E-09 | 4.2E-10 | |
| Pu-239 | 1.6E-09 | 7.9E-10 | 3.6E-10 | |
| Pu-240 | 1.6E-09 | 7.9E-10 | 3.6E-10 | |
| Pu-238 | 1.5E-09 | 7.4E-10 | 3.5E-10 | |
| Pu-241 | 1.4E-09 | 6.1E-10 | 2.2E-10 | |
| Am-241 | 1.3E-09 | 6.4E-10 | 3.1E-10 | |
| Am-243 | 1.3E-09 | 6.4E-10 | 3.1E-10 | |
| Cm-243 | 9.3E-10 | 5.0E-10 | 2.8E-10 | |
| Cm-244 | 7.7E-10 | 4.4E-10 | 2.6E-10 | |
| Sr-90 | 7.5E-10 | 5.0E-10 | 2.5E-10 | |
| Y-91 | 4.2E-10 | 3.5E-10 | 2.6E-10 | |
| Cs-137 | 3.5E-10 | 2.5E-10 | 1.3E-10 | |
| Co-60 | 2.9E-10 | 2.2E-10 | 1.1E-10 | |
| Sn-123 | 2.1E-10 | 1.8E-10 | 1.3E-10 | |
| Tc-99 | 1.9E-10 | 1.4E-10 | 7.9E-11 | |
| Cd-115m | 1.1E-10 | 9.1E-11 | 8.1E-11 | |
| Sb-125 | 8.5E-11 | 6.7E-11 | 3.8E-11 | |
| Cm-242 | 8.0E-11 | 6.4E-11 | 4.7E-11 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Am-242m | 7.7E-11 | 3.6E-11 | 1.7E-11 | |
| Ce-144 | 7.2E-11 | 7.4E-11 | 6.3E-11 | |
| Te-127m | 6.7E-11 | 5.4E-11 | 3.6E-11 | |
| Ni-63 | 6.1E-11 | 5.0E-11 | 2.9E-11 | |
| Te-129m | 5.4E-11 | 4.6E-11 | 3.4E-11 | |
| Pm-146 | 4.4E-11 | 3.2E-11 | 1.7E-11 | |
| Cd-113m | 4.2E-11 | 2.7E-11 | 1.5E-11 | |
| Te-125m | 3.0E-11 | 2.2E-11 | 1.5E-11 | |
| Eu-152 | 2.5E-11 | 1.6E-11 | 8.5E-12 | |
| Pm-148 | 2.4E-11 | 2.3E-11 | 2.1E-11 | |
| Pm-147 | 2.0E-11 | 1.8E-11 | 1.1E-11 | |
| Cs-134 | 1.9E-11 | 1.6E-11 | 8.7E-12 | |
| Sr-89 | 1.7E-11 | 1.4E-11 | 1.1E-11 | |
| Sn-126 | 1.6E-11 | 1.4E-10 | 8.9E-12 | |
| Eu-154 | 1.4E-11 | 9.8E-12 | 5.3E-12 | |
| Ba-140 | 1.2E-11 | 9.6E-12 | 7.6E-12 | |
| Sn-119m | 8.0E-12 | 6.7E-12 | 4.7E-12 | |
| Y-90 | 7.1E-12 | 7.8E-12 | 7.9E-12 | |
| Eu-155 | 4.9E-12 | 3.9E-12 | 2.4E-12 | |
| Tb-160 | 4.2E-12 | 3.5E-12 | 2.5E-12 | |
| Rb-86 | 3.8E-12 | 5.4E-12 | 6.3E-12 | |
| Ce-141 | 2.0E-12 | 1.5E-12 | 1.1E-12 | |
| Cs-136 | 1.8E-12 | 1.5E-12 | 1.2E-12 | |
| Sb-124 | 1.8E-12 | 1.4E-12 | 1.0E-12 | |
| Fe-59 | 1.5E-12 | 1.2E-12 | 9.8E-13 | |
| Ag-110m | 1.4E-12 | 1.2E-12 | 7.1E-13 | |
| Gd-153 | 1.4E-12 | 1.7E-12 | 1.3E-12 | |
| Pm-148m | 1.0E-12 | 8.5E-13 | 5.8E-13 | |
| Te-123m | 1.0E-12 | 7.6E-13 | 5.1E-13 | |
| Te-127 | 9.6E-13 | 1.0E-12 | 1.1E-12 | |
| Zn-65 | 7.1E-13 | 7.2E-13 | 6.2E-13 | |
| Ru-103 | 6.4E-13 | 5.0E-13 | 3.6E-13 | |
| Nb-95 | 3.9E-13 | 3.0E-13 | 2.1E-13 | |
| Co-58 | 3.6E-13 | 3.0E-13 | 2.0E-13 | |
| Te-129 | 2.7E-13 | 2.7E-13 | 3.1E-13 | |
| Mn-54 | 2.2E-13 | 2.1E-13 | 1.4E-13 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Sm-151 | 7.7E-14 | 5.1E-14 | 2.7E-14 | |
| Pr-144 | 2.4E-14 | 2.8E-14 | 3.3E-14 | |
| Rh-103m | 5.8E-16 | 5.6E-16 | 5.5E-16 | |
| Cs-135 | 4.6E-16 | 3.4E-16 | 1.9E-16 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 9.3E-08 | 6.2E-08 | 4.0E-08 | |

Table X-1-3 Assessment result of internal exposure from ingestion of seafood (Source term based on measured values (K4 tank group), Average ingestion)

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Sn-123 | 9.8E-06 | 1.8E-05 | 2.4E-05 | |
| I-129 | 2.7E-06 | 2.0E-06 | 8.6E-07 | |
| C-14 | 1.4E-06 | 1.2E-06 | 6.8E-07 | |
| Sn-126 | 4.9E-07 | 8.4E-07 | 1.1E-06 | |
| Cd-115m | 3.0E-07 | 4.4E-07 | 7.4E-07 | |
| Sn-119m | 2.3E-07 | 4.3E-07 | 5.6E-07 | |
| Cd-113m | 5.8E-08 | 5.0E-08 | 6.1E-08 | |
| Co-60 | 4.9E-08 | 1.2E-07 | 1.6E-07 | |
| H-3 | 3.3E-08 | 2.8E-08 | 2.3E-08 | |
| Ru-106 | 3.3E-08 | 5.7E-08 | 7.6E-08 | |
| Fe-59 | 2.3E-08 | 4.8E-08 | 1.0E-07 | |
| Te-129m | 1.8E-08 | 3.6E-08 | 5.3E-08 | |
| Pm-148 | 1.7E-08 | 3.1E-08 | 3.9E-08 | |
| Tc-99 | 1.6E-08 | 2.8E-08 | 4.9E-08 | |
| Te-127m | 1.4E-08 | 2.8E-08 | 4.9E-08 | |
| Y-91 | 1.3E-08 | 2.3E-08 | 2.9E-08 | |
| Zn-65 | 5.5E-09 | 7.0E-09 | 1.0E-08 | |
| Te-125m | 5.5E-09 | 1.0E-08 | 1.6E-08 | |
| Cs-137 | 4.1E-09 | 1.5E-09 | 1.4E-09 | |
| Ni-63 | 3.6E-09 | 5.4E-09 | 7.6E-09 | |
| Ce-144 | 2.7E-09 | 4.9E-09 | 6.8E-09 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Ag-110m | 2.1E-09 | 2.9E-09 | 3.6E-09 | |
| Sb-125 | 1.5E-09 | 2.3E-09 | 3.1E-09 | |
| Y-90 | 1.4E-09 | 2.6E-09 | 3.2E-09 | |
| Am-241 | 1.4E-09 | 9.2E-10 | 5.0E-09 | |
| Am-243 | 1.4E-09 | 9.2E-10 | 4.9E-09 | |
| Pu-239 | 1.4E-09 | 8.8E-10 | 4.4E-09 | |
| Pu-240 | 1.4E-09 | 8.8E-10 | 4.4E-09 | |
| Pu-238 | 1.2E-09 | 8.3E-10 | 4.2E-09 | |
| Pu-241 | 1.2E-09 | 6.5E-10 | 2.6E-09 | |
| Pm-146 | 1.1E-09 | 1.8E-09 | 2.5E-09 | |
| Te-127 | 1.0E-09 | 1.9E-09 | 1.8E-09 | |
| Cm-243 | 7.2E-10 | 5.1E-10 | 3.0E-09 | |
| Pm-147 | 6.4E-10 | 1.2E-09 | 1.8E-09 | |
| Cs-134 | 6.4E-10 | 2.2E-10 | 1.8E-10 | |
| Cm-244 | 5.8E-10 | 4.4E-10 | 2.7E-09 | |
| Eu-152 | 5.1E-10 | 7.4E-10 | 1.2E-09 | |
| Te-129 | 3.9E-10 | 6.3E-10 | 9.0E-10 | |
| Mn-54 | 3.2E-10 | 4.3E-10 | 4.8E-10 | |
| Eu-154 | 3.1E-10 | 5.1E-10 | 7.7E-10 | |
| Tb-160 | 2.7E-10 | 4.5E-10 | 5.3E-10 | |
| Sr-90 | 2.5E-10 | 2.1E-10 | 4.2E-10 | |
| Te-123m | 2.5E-10 | 4.2E-10 | 6.6E-10 | |
| Co-58 | 2.0E-10 | 3.4E-10 | 3.8E-10 | |
| Pm-148m | 1.8E-10 | 3.0E-10 | 3.2E-10 | |
| Ce-141 | 1.5E-10 | 2.7E-10 | 3.3E-10 | |
| Eu-155 | 1.4E-10 | 2.4E-10 | 3.6E-10 | |
| Gd-153 | 1.1E-10 | 2.0E-10 | 2.4E-10 | |
| Sb-124 | 9.7E-11 | 1.6E-10 | 2.0E-10 | |
| Am-242m | 8.3E-11 | 4.9E-11 | 2.6E-10 | |
| Cs-136 | 6.7E-11 | 6.8E-11 | 6.9E-11 | |
| Cm-242 | 5.8E-11 | 9.1E-11 | 5.5E-10 | |
| Rb-86 | 5.0E-11 | 8.9E-11 | 1.1E-10 | |
| Ba-140 | 3.9E-11 | 6.7E-11 | 9.4E-11 | |
| Nb-95 | 2.8E-11 | 4.2E-11 | 4.3E-11 | |
| Pr-144 | 2.3E-11 | 3.7E-11 | 5.6E-11 | |
| Ru-103 | 2.1E-11 | 3.4E-11 | 4.0E-11 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Sr-89 | 1.1E-11 | 1.8E-11 | 3.0E-11 | |
| Sm-151 | 1.1E-12 | 1.9E-12 | 3.5E-12 | |
| Rh-103m | 1.7E-13 | 2.9E-13 | 4.2E-13 | |
| Cs-135 | 3.7E-15 | 1.6E-15 | 1.6E-15 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 1.5E-05 | 2.4E-05 | 2.9E-05 | |

Table X-1-4 Assessment result of internal exposure from ingestion of seafood (Source term based on measured values (K4 tank group), More ingestion)

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Sn-123 | 3.7E-05 | 7.0E-05 | 8.9E-05 | |
| I-129 | 1.3E-05 | 1.0E-05 | 4.1E-06 | |
| C-14 | 5.2E-06 | 4.5E-06 | 2.5E-06 | |
| Sn-126 | 1.9E-06 | 3.2E-06 | 4.0E-06 | |
| Cd-115m | 1.6E-06 | 2.3E-06 | 3.8E-06 | |
| Sn-119m | 8.5E-07 | 1.6E-06 | 2.1E-06 | |
| Cd-113m | 3.1E-07 | 2.6E-07 | 3.1E-07 | |
| Co-60 | 2.7E-07 | 6.8E-07 | 8.4E-07 | |
| Ru-106 | 1.6E-07 | 2.9E-07 | 3.8E-07 | |
| H-3 | 1.3E-07 | 1.1E-07 | 8.7E-08 | |
| Fe-59 | 1.2E-07 | 2.6E-07 | 5.3E-07 | |
| Pm-148 | 9.4E-08 | 1.7E-07 | 2.0E-07 | |
| Te-129m | 8.0E-08 | 1.6E-07 | 2.3E-07 | |
| Tc-99 | 7.7E-08 | 1.4E-07 | 2.3E-07 | |
| Y-91 | 6.7E-08 | 1.2E-07 | 1.5E-07 | |
| Te-127m | 6.1E-08 | 1.3E-07 | 2.1E-07 | |
| Zn-65 | 3.3E-08 | 4.1E-08 | 5.9E-08 | |
| Te-125m | 2.4E-08 | 4.5E-08 | 7.0E-08 | |
| Cs-137 | 1.5E-08 | 5.6E-09 | 4.9E-09 | |
| Ni-63 | 1.5E-08 | 2.3E-08 | 3.1E-08 | |
| Ce-144 | 1.4E-08 | 2.5E-08 | 3.4E-08 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Ag-110m | 9.9E-09 | 1.4E-08 | 1.7E-08 | |
| Y-90 | 7.5E-09 | 1.4E-08 | 1.7E-08 | |
| Pu-239 | 7.0E-09 | 4.6E-09 | 2.3E-08 | |
| Pu-240 | 7.0E-09 | 4.6E-09 | 2.3E-08 | |
| Am-241 | 6.7E-09 | 4.6E-09 | 2.4E-08 | |
| Am-243 | 6.7E-09 | 4.6E-09 | 2.3E-08 | |
| Pu-238 | 6.4E-09 | 4.3E-09 | 2.2E-08 | |
| Pm-146 | 6.1E-09 | 9.6E-09 | 1.3E-08 | |
| Pu-241 | 6.0E-09 | 3.4E-09 | 1.3E-08 | |
| Sb-125 | 5.2E-09 | 8.2E-09 | 1.1E-08 | |
| Te-127 | 4.5E-09 | 8.3E-09 | 7.8E-09 | |
| Cm-243 | 3.5E-09 | 2.5E-09 | 1.4E-08 | |
| Pm-147 | 3.4E-09 | 6.4E-09 | 9.2E-09 | |
| Cm-244 | 2.8E-09 | 2.2E-09 | 1.3E-08 | |
| Eu-152 | 2.7E-09 | 4.0E-09 | 6.1E-09 | |
| Cs-134 | 2.3E-09 | 8.1E-10 | 6.4E-10 | |
| Mn-54 | 1.8E-09 | 2.5E-09 | 2.7E-09 | |
| Te-129 | 1.7E-09 | 2.8E-09 | 3.9E-09 | |
| Eu-154 | 1.7E-09 | 2.7E-09 | 4.1E-09 | |
| Tb-160 | 1.5E-09 | 2.5E-09 | 2.8E-09 | |
| Sr-90 | 1.1E-09 | 9.6E-10 | 1.8E-09 | |
| Co-58 | 1.1E-09 | 1.9E-09 | 2.1E-09 | |
| Te-123m | 1.1E-09 | 1.9E-09 | 2.8E-09 | |
| Pm-148m | 9.9E-10 | 1.6E-09 | 1.7E-09 | |
| Ce-141 | 7.5E-10 | 1.4E-09 | 1.7E-09 | |
| Eu-155 | 7.4E-10 | 1.3E-09 | 1.9E-09 | |
| Gd-153 | 6.0E-10 | 1.0E-09 | 1.3E-09 | |
| Am-242m | 4.0E-10 | 2.4E-10 | 1.2E-09 | |
| Sb-124 | 3.4E-10 | 5.8E-10 | 6.9E-10 | |
| Cm-242 | 2.8E-10 | 4.5E-10 | 2.6E-09 | |
| Cs-136 | 2.5E-10 | 2.5E-10 | 2.5E-10 | |
| Rb-86 | 2.1E-10 | 3.7E-10 | 4.6E-10 | |
| Ba-140 | 1.6E-10 | 2.9E-10 | 4.0E-10 | |
| Nb-95 | 1.4E-10 | 2.2E-10 | 2.1E-10 | |
| Pr-144 | 1.1E-10 | 1.9E-10 | 2.7E-10 | |
| Ru-103 | 1.1E-10 | 1.7E-10 | 2.0E-10 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Sr-89 | 4.8E-11 | 8.2E-11 | 1.3E-10 | |
| Sm-151 | 6.1E-12 | 1.0E-11 | 1.8E-11 | |
| Rh-103m | 9.4E-13 | 1.6E-12 | 2.2E-12 | |
| Cs-135 | 1.4E-14 | 5.9E-15 | 5.6E-15 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 6.1E-05 | 9.4E-05 | 1.1E-04 | |

**Table X-2-1 Internal exposure assessment result from ingestion of seawater
(Source term based on measured values (J1-C tank group))**

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|---------|
| | Adult | Children under school age | Infants | |
| H-3 | 3.0E-07 | 5.2E-07 | Exempted | |
| I-129 | 2.7E-09 | 4.2E-09 | Exempted | |
| Y-91 | 8.4E-10 | 3.1E-09 | Exempted | |
| Sn-119m | 2.9E-10 | 1.1E-09 | Exempted | |
| Sn-123 | 2.9E-10 | 1.1E-09 | Exempted | |
| Te-127m | 2.3E-10 | 9.6E-10 | Exempted | |
| C-14 | 2.2E-10 | 3.7E-10 | Exempted | |
| Ru-106 | 2.0E-10 | 7.2E-10 | Exempted | |
| Cd-115m | 1.8E-10 | 5.4E-10 | Exempted | |
| Pu-239 | 1.7E-10 | 2.2E-10 | Exempted | |
| Pu-240 | 1.7E-10 | 2.2E-10 | Exempted | |
| Pu-238 | 1.6E-10 | 2.1E-10 | Exempted | |
| Am-241 | 1.4E-10 | 1.8E-10 | Exempted | |
| Am-243 | 1.4E-10 | 1.8E-10 | Exempted | |
| Pu-241 | 1.2E-10 | 1.4E-10 | Exempted | |
| Cm-243 | 1.0E-10 | 1.5E-10 | Exempted | |
| Te-129m | 8.7E-11 | 3.5E-10 | Exempted | |
| Cm-244 | 8.2E-11 | 1.3E-10 | Exempted | |
| Ce-144 | 6.1E-11 | 2.2E-10 | Exempted | |
| Cs-137 | 5.1E-11 | 3.8E-11 | Exempted | |
| Cd-113m | 4.0E-11 | 6.8E-11 | Exempted | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|---------|
| | Adult | Children under school age | Infants | |
| Cs-134 | 3.0E-11 | 2.0E-11 | Exempted | |
| Rb-86 | 2.9E-11 | 1.0E-10 | Exempted | |
| Sn-126 | 2.8E-11 | 9.6E-11 | Exempted | |
| Ni-63 | 2.6E-11 | 8.1E-11 | Exempted | |
| Co-60 | 2.3E-11 | 1.2E-10 | Exempted | |
| Sr-90 | 2.1E-11 | 3.5E-11 | Exempted | |
| Te-127 | 1.6E-11 | 6.0E-11 | Exempted | |
| Tc-99 | 1.6E-11 | 5.7E-11 | Exempted | |
| Pm-148 | 1.3E-11 | 4.6E-11 | Exempted | |
| Ba-140 | 1.1E-11 | 3.8E-11 | Exempted | |
| Cm-242 | 8.2E-12 | 2.7E-11 | Exempted | |
| Eu-152 | 8.1E-12 | 2.4E-11 | Exempted | |
| Zn-65 | 7.6E-12 | 1.9E-11 | Exempted | |
| Sb-125 | 5.2E-12 | 1.6E-11 | Exempted | |
| Sb-124 | 5.0E-12 | 1.7E-11 | Exempted | |
| Tb-160 | 4.6E-12 | 1.6E-11 | Exempted | |
| Eu-154 | 4.5E-12 | 1.5E-11 | Exempted | |
| Pm-147 | 4.3E-12 | 1.6E-11 | Exempted | |
| Te-125m | 4.1E-12 | 1.6E-11 | Exempted | |
| Ce-141 | 3.8E-12 | 1.4E-11 | Exempted | |
| Fe-59 | 3.2E-12 | 1.3E-11 | Exempted | |
| Cs-136 | 2.9E-12 | 5.9E-12 | Exempted | |
| Sr-89 | 2.9E-12 | 9.9E-12 | Exempted | |
| Te-123m | 2.7E-12 | 9.3E-12 | Exempted | |
| Ag-110m | 2.5E-12 | 6.9E-12 | Exempted | |
| Am-242m | 2.3E-12 | 2.8E-12 | Exempted | |
| Eu-155 | 2.2E-12 | 7.7E-12 | Exempted | |
| Y-90 | 2.0E-12 | 7.4E-12 | Exempted | |
| Te-129 | 1.8E-12 | 6.1E-12 | Exempted | |
| Pm-148m | 1.7E-12 | 5.4E-12 | Exempted | |
| Gd-153 | 1.4E-12 | 5.0E-12 | Exempted | |
| Pm-146 | 1.2E-12 | 3.9E-12 | Exempted | |
| Ru-103 | 8.0E-13 | 2.6E-12 | Exempted | |
| Co-58 | 6.3E-13 | 2.2E-12 | Exempted | |
| Nb-95 | 6.0E-13 | 1.9E-12 | Exempted | |
| Pr-144 | 5.9E-13 | 2.0E-12 | Exempted | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Mn-54 | 5.6E-13 | 1.5E-12 | Exempted | |
| Sm-151 | 2.2E-14 | 7.5E-14 | Exempted | |
| Rh-103m | 4.1E-15 | 1.4E-14 | Exempted | |
| Cs-135 | 4.9E-17 | 4.2E-17 | Exempted | |
| Rh-106 | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Total | 3.1E-07 | 5.4E-07 | Exempted | |

Table X-2-2 Assessment result of internal exposure from inhalation of seawater spray (Source term based on measured values (J1-C tank group))

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| H-3 | 7.3E-08 | 5.0E-08 | 3.4E-08 | |
| Pu-239 | 2.0E-08 | 9.6E-09 | 4.4E-09 | |
| Pu-240 | 2.0E-08 | 9.6E-09 | 4.4E-09 | |
| Pu-238 | 1.8E-08 | 9.0E-09 | 4.2E-09 | |
| Am-241 | 1.6E-08 | 7.7E-09 | 3.8E-09 | |
| Am-243 | 1.6E-08 | 7.7E-09 | 3.8E-09 | |
| Pu-241 | 1.4E-08 | 6.1E-09 | 2.1E-09 | |
| Cm-243 | 1.1E-08 | 6.1E-09 | 3.4E-09 | |
| Cm-244 | 9.3E-09 | 5.3E-09 | 3.2E-09 | |
| Cm-242 | 9.7E-10 | 7.7E-10 | 5.7E-10 | |
| Y-91 | 7.5E-10 | 6.3E-10 | 4.7E-10 | |
| C-14 | 5.2E-10 | 3.9E-10 | 2.2E-10 | |
| Ru-106 | 4.6E-10 | 3.8E-10 | 2.3E-10 | |
| Sn-119m | 4.6E-10 | 3.8E-10 | 2.7E-10 | |
| Am-242m | 2.7E-10 | 1.3E-10 | 6.0E-11 | |
| Sn-123 | 2.7E-10 | 2.3E-10 | 1.7E-10 | |
| Te-127m | 2.4E-10 | 1.9E-10 | 1.3E-10 | |
| I-129 | 2.1E-10 | 1.4E-10 | 5.5E-11 | |
| Ce-144 | 1.5E-10 | 1.6E-10 | 1.3E-10 | |
| Cd-115m | 1.0E-10 | 8.9E-11 | 7.9E-11 | |
| Tc-99 | 7.7E-11 | 5.6E-11 | 3.1E-11 | |
| Eu-152 | 5.8E-11 | 3.8E-11 | 2.0E-11 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Te-129m | 5.5E-11 | 4.6E-11 | 3.4E-11 | |
| Ni-63 | 5.5E-11 | 4.5E-11 | 2.6E-11 | |
| Co-60 | 5.1E-11 | 3.8E-11 | 1.9E-11 | |
| Cd-113m | 4.6E-11 | 3.0E-11 | 1.6E-11 | |
| Sn-126 | 4.0E-11 | 3.5E-10 | 2.2E-11 | |
| Cs-137 | 3.7E-11 | 2.6E-11 | 1.3E-11 | |
| Eu-154 | 2.9E-11 | 2.1E-11 | 1.1E-11 | |
| Sr-90 | 2.9E-11 | 1.9E-11 | 9.7E-12 | |
| Pm-147 | 2.0E-11 | 1.7E-11 | 1.1E-11 | |
| Sb-125 | 1.4E-11 | 1.1E-11 | 6.2E-12 | |
| Eu-155 | 1.2E-11 | 9.3E-12 | 5.6E-12 | |
| Cs-134 | 7.5E-12 | 6.1E-12 | 3.4E-12 | |
| Pm-146 | 7.0E-12 | 5.1E-12 | 2.7E-12 | |
| Ba-140 | 5.8E-12 | 4.7E-12 | 3.7E-12 | |
| Ce-141 | 4.9E-12 | 3.6E-12 | 2.7E-12 | |
| Tb-160 | 4.9E-12 | 4.1E-12 | 2.9E-12 | |
| Te-125m | 4.8E-12 | 3.5E-12 | 2.5E-12 | |
| Sb-124 | 4.1E-12 | 3.4E-12 | 2.4E-12 | |
| Te-127 | 3.3E-12 | 3.6E-12 | 3.6E-12 | |
| Gd-153 | 2.7E-12 | 3.3E-12 | 2.5E-12 | |
| Ag-110m | 2.6E-12 | 2.2E-12 | 1.3E-12 | |
| Pm-148 | 2.5E-12 | 2.5E-12 | 2.2E-12 | |
| Te-123m | 2.3E-12 | 1.8E-12 | 1.2E-12 | |
| Rb-86 | 2.3E-12 | 3.3E-12 | 3.8E-12 | |
| Sr-89 | 2.1E-12 | 1.8E-12 | 1.3E-12 | |
| Fe-59 | 1.7E-12 | 1.4E-12 | 1.2E-12 | |
| Pm-148m | 1.4E-12 | 1.1E-12 | 7.7E-13 | |
| Zn-65 | 1.0E-12 | 1.0E-12 | 9.0E-13 | |
| Ru-103 | 7.9E-13 | 6.2E-13 | 4.4E-13 | |
| Cs-136 | 6.5E-13 | 5.5E-13 | 4.5E-13 | |
| Nb-95 | 4.5E-13 | 3.5E-13 | 2.5E-13 | |
| Co-58 | 4.3E-13 | 3.6E-13 | 2.4E-13 | |
| Mn-54 | 2.8E-13 | 2.8E-13 | 1.8E-13 | |
| Te-129 | 2.7E-13 | 2.7E-13 | 3.1E-13 | |
| Y-90 | 2.7E-13 | 2.9E-13 | 3.0E-13 | |
| Sm-151 | 2.2E-13 | 1.4E-13 | 7.7E-14 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Pr-144 | 5.1E-14 | 5.8E-14 | 6.9E-14 | |
| Rh-103m | 7.1E-16 | 6.9E-16 | 6.8E-16 | |
| Cs-135 | 5.1E-17 | 3.7E-17 | 2.1E-17 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 2.0E-07 | 1.1E-07 | 6.5E-08 | |

Table X-2-3 Assessment result of internal exposure from ingestion of seafood (Source term based on measured values (J1-C tank group), Average ingestion)

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Sn-119m | 1.3E-05 | 2.5E-05 | 3.2E-05 | |
| Sn-123 | 1.3E-05 | 2.3E-05 | 3.1E-05 | |
| Sn-126 | 1.2E-06 | 2.1E-06 | 2.7E-06 | |
| C-14 | 3.8E-07 | 3.3E-07 | 1.9E-07 | |
| I-129 | 3.6E-07 | 2.7E-07 | 1.1E-07 | |
| Cd-115m | 2.9E-07 | 4.3E-07 | 7.2E-07 | |
| Cd-113m | 6.4E-08 | 5.4E-08 | 6.7E-08 | |
| Te-127m | 5.0E-08 | 1.0E-07 | 1.8E-07 | |
| H-3 | 3.3E-08 | 2.8E-08 | 2.3E-08 | |
| Fe-59 | 2.7E-08 | 5.7E-08 | 1.2E-07 | |
| Y-91 | 2.3E-08 | 4.1E-08 | 5.1E-08 | |
| Te-129m | 1.9E-08 | 3.6E-08 | 5.4E-08 | |
| Am-241 | 1.7E-08 | 1.1E-08 | 6.1E-08 | |
| Am-243 | 1.7E-08 | 1.1E-08 | 5.9E-08 | |
| Pu-239 | 1.6E-08 | 1.1E-08 | 5.4E-08 | |
| Pu-240 | 1.6E-08 | 1.1E-08 | 5.4E-08 | |
| Pu-238 | 1.5E-08 | 1.0E-08 | 5.1E-08 | |
| Pu-241 | 1.1E-08 | 6.5E-09 | 2.6E-08 | |
| Cm-243 | 8.7E-09 | 6.2E-09 | 3.6E-08 | |
| Co-60 | 8.6E-09 | 2.2E-08 | 2.7E-08 | |
| Zn-65 | 8.0E-09 | 1.0E-08 | 1.5E-08 | |
| Cm-244 | 7.0E-09 | 5.4E-09 | 3.3E-08 | |
| Ru-106 | 6.6E-09 | 1.2E-08 | 1.5E-08 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Tc-99 | 6.5E-09 | 1.1E-08 | 1.9E-08 | |
| Ce-144 | 5.8E-09 | 1.0E-08 | 1.4E-08 | |
| Ag-110m | 3.7E-09 | 5.2E-09 | 6.4E-09 | |
| Te-127 | 3.5E-09 | 6.3E-09 | 6.2E-09 | |
| Ni-63 | 3.2E-09 | 4.9E-09 | 6.8E-09 | |
| Pm-148 | 1.9E-09 | 3.4E-09 | 4.1E-09 | |
| Eu-152 | 1.2E-09 | 1.7E-09 | 2.7E-09 | |
| Te-125m | 8.9E-10 | 1.6E-09 | 2.6E-09 | |
| Cm-242 | 7.0E-10 | 1.1E-09 | 6.6E-09 | |
| Eu-154 | 6.6E-10 | 1.1E-09 | 1.6E-09 | |
| Pm-147 | 6.2E-10 | 1.2E-09 | 1.7E-09 | |
| Te-123m | 5.7E-10 | 9.8E-10 | 1.5E-09 | |
| Cs-137 | 4.3E-10 | 1.6E-10 | 1.4E-10 | |
| Mn-54 | 4.2E-10 | 5.7E-10 | 6.4E-10 | |
| Te-129 | 3.9E-10 | 6.4E-10 | 9.2E-10 | |
| Ce-141 | 3.6E-10 | 6.4E-10 | 7.9E-10 | |
| Eu-155 | 3.3E-10 | 5.6E-10 | 8.7E-10 | |
| Tb-160 | 3.1E-10 | 5.2E-10 | 6.1E-10 | |
| Am-242m | 2.9E-10 | 1.7E-10 | 9.1E-10 | |
| Cs-134 | 2.5E-10 | 8.5E-11 | 7.0E-11 | |
| Pm-148m | 2.4E-10 | 4.0E-10 | 4.3E-10 | |
| Sb-125 | 2.4E-10 | 3.7E-10 | 4.9E-10 | |
| Co-58 | 2.3E-10 | 4.1E-10 | 4.6E-10 | |
| Sb-124 | 2.3E-10 | 3.9E-10 | 4.7E-10 | |
| Gd-153 | 2.1E-10 | 3.7E-10 | 4.5E-10 | |
| Pm-146 | 1.8E-10 | 2.8E-10 | 4.0E-10 | |
| Y-90 | 5.4E-11 | 9.9E-11 | 1.2E-10 | |
| Pr-144 | 4.7E-11 | 7.8E-11 | 1.2E-10 | |
| Nb-95 | 3.2E-11 | 4.9E-11 | 5.0E-11 | |
| Rb-86 | 3.1E-11 | 5.4E-11 | 6.9E-11 | |
| Ru-103 | 2.6E-11 | 4.2E-11 | 4.9E-11 | |
| Cs-136 | 2.4E-11 | 2.5E-11 | 2.5E-11 | |
| Ba-140 | 1.9E-11 | 3.3E-11 | 4.6E-11 | |
| Sr-90 | 9.6E-12 | 8.1E-12 | 1.6E-11 | |
| Sm-151 | 3.2E-12 | 5.5E-12 | 9.8E-12 | |
| Sr-89 | 1.3E-12 | 2.3E-12 | 3.7E-12 | |
| Rh-103m | 2.1E-13 | 3.6E-13 | 5.2E-13 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Cs-135 | 4.2E-16 | 1.8E-16 | 1.7E-16 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 2.8E-05 | 5.1E-05 | 6.7E-05 | |

**Table X-2-4 Assessment result of internal exposure from ingestion of seafood
(Source term based on measured values (J1-C tank group), More ingestion)**

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Sn-119m | 4.9E-05 | 9.4E-05 | 1.2E-04 | |
| Sn-123 | 4.7E-05 | 8.9E-05 | 1.1E-04 | |
| Sn-126 | 4.6E-06 | 8.0E-06 | 9.9E-06 | |
| I-129 | 1.7E-06 | 1.3E-06 | 5.4E-07 | |
| Cd-115m | 1.5E-06 | 2.3E-06 | 3.7E-06 | |
| C-14 | 1.4E-06 | 1.3E-06 | 7.0E-07 | |
| Cd-113m | 3.4E-07 | 2.9E-07 | 3.4E-07 | |
| Te-127m | 2.2E-07 | 4.5E-07 | 7.6E-07 | |
| Fe-59 | 1.5E-07 | 3.1E-07 | 6.2E-07 | |
| H-3 | 1.3E-07 | 1.1E-07 | 8.7E-08 | |
| Y-91 | 1.2E-07 | 2.2E-07 | 2.7E-07 | |
| Pu-239 | 8.5E-08 | 5.6E-08 | 2.8E-07 | |
| Pu-240 | 8.5E-08 | 5.6E-08 | 2.8E-07 | |
| Am-241 | 8.2E-08 | 5.5E-08 | 2.9E-07 | |
| Am-243 | 8.2E-08 | 5.5E-08 | 2.8E-07 | |
| Te-129m | 8.1E-08 | 1.6E-07 | 2.3E-07 | |
| Pu-238 | 7.8E-08 | 5.3E-08 | 2.6E-07 | |
| Pu-241 | 5.9E-08 | 3.4E-08 | 1.3E-07 | |
| Zn-65 | 4.8E-08 | 6.0E-08 | 8.6E-08 | |
| Co-60 | 4.7E-08 | 1.2E-07 | 1.5E-07 | |
| Cm-243 | 4.2E-08 | 3.1E-08 | 1.7E-07 | |
| Cm-244 | 3.4E-08 | 2.7E-08 | 1.6E-07 | |
| Ru-106 | 3.3E-08 | 5.9E-08 | 7.6E-08 | |
| Tc-99 | 3.1E-08 | 5.5E-08 | 9.2E-08 | |
| Ce-144 | 2.9E-08 | 5.3E-08 | 7.1E-08 | |
| Ag-110m | 1.8E-08 | 2.5E-08 | 3.0E-08 | |
| Te-127 | 1.5E-08 | 2.8E-08 | 2.7E-08 | |
| Ni-63 | 1.3E-08 | 2.1E-08 | 2.8E-08 | |
| Pm-148 | 1.0E-08 | 1.8E-08 | 2.2E-08 | |
| Eu-152 | 6.3E-09 | 9.3E-09 | 1.4E-08 | |
| Te-125m | 3.9E-09 | 7.3E-09 | 1.1E-08 | |
| Eu-154 | 3.5E-09 | 5.8E-09 | 8.6E-09 | |
| Cm-242 | 3.4E-09 | 5.5E-09 | 3.2E-08 | |
| Pm-147 | 3.4E-09 | 6.2E-09 | 9.0E-09 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Te-123m | 2.5E-09 | 4.4E-09 | 6.6E-09 | |
| Mn-54 | 2.4E-09 | 3.2E-09 | 3.6E-09 | |
| Ce-141 | 1.8E-09 | 3.3E-09 | 4.0E-09 | |
| Eu-155 | 1.8E-09 | 3.0E-09 | 4.6E-09 | |
| Te-129 | 1.7E-09 | 2.8E-09 | 4.0E-09 | |
| Tb-160 | 1.7E-09 | 2.8E-09 | 3.3E-09 | |
| Cs-137 | 1.6E-09 | 5.8E-10 | 5.1E-10 | |
| Am-242m | 1.4E-09 | 8.4E-10 | 4.4E-09 | |
| Pm-148m | 1.3E-09 | 2.1E-09 | 2.3E-09 | |
| Co-58 | 1.3E-09 | 2.2E-09 | 2.4E-09 | |
| Gd-153 | 1.1E-09 | 2.0E-09 | 2.4E-09 | |
| Pm-146 | 9.7E-10 | 1.5E-09 | 2.1E-09 | |
| Cs-134 | 9.1E-10 | 3.2E-10 | 2.5E-10 | |
| Sb-125 | 8.4E-10 | 1.3E-09 | 1.7E-09 | |
| Sb-124 | 8.1E-10 | 1.4E-09 | 1.6E-09 | |
| Y-90 | 2.9E-10 | 5.3E-10 | 6.3E-10 | |
| Pr-144 | 2.3E-10 | 3.9E-10 | 5.7E-10 | |
| Nb-95 | 1.6E-10 | 2.5E-10 | 2.5E-10 | |
| Ru-103 | 1.3E-10 | 2.1E-10 | 2.4E-10 | |
| Rb-86 | 1.3E-10 | 2.3E-10 | 2.8E-10 | |
| Cs-136 | 8.9E-11 | 9.2E-11 | 9.0E-11 | |
| Ba-140 | 8.0E-11 | 1.4E-10 | 1.9E-10 | |
| Sr-90 | 4.3E-11 | 3.6E-11 | 7.0E-11 | |
| Sm-151 | 1.7E-11 | 2.9E-11 | 5.2E-11 | |
| Sr-89 | 6.0E-12 | 1.0E-11 | 1.6E-11 | |
| Rh-103m | 1.2E-12 | 2.0E-12 | 2.8E-12 | |
| Cs-135 | 1.5E-15 | 6.5E-16 | 6.3E-16 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 1.1E-04 | 2.0E-04 | 2.5E-04 | |

**Table X-3-1 Internal exposure assessment result from ingestion of seawater
(Source term based on measured values (J1-C tank group))**

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|---------|
| | Adult | Children under school age | Infants | |
| H-3 | 3.0E-07 | 5.2E-07 | Exempted | |
| I-129 | 2.3E-09 | 3.5E-09 | Exempted | |
| Y-91 | 1.8E-09 | 6.6E-09 | Exempted | |
| Sn-119m | 8.5E-10 | 3.3E-09 | Exempted | |
| Sn-123 | 8.3E-10 | 3.1E-09 | Exempted | |
| Te-127m | 6.5E-10 | 2.7E-09 | Exempted | |
| C-14 | 5.8E-10 | 9.9E-10 | Exempted | |
| Cd-115m | 4.7E-10 | 1.4E-09 | Exempted | |
| Pu-239 | 4.4E-10 | 5.8E-10 | Exempted | |
| Pu-240 | 4.4E-10 | 5.8E-10 | Exempted | |
| Pu-238 | 4.0E-10 | 5.4E-10 | Exempted | |
| Am-241 | 3.5E-10 | 4.7E-10 | Exempted | |
| Am-243 | 3.5E-10 | 4.7E-10 | Exempted | |
| Pu-241 | 3.0E-10 | 3.4E-10 | Exempted | |
| Cs-137 | 2.7E-10 | 2.0E-10 | Exempted | |
| Cm-243 | 2.6E-10 | 3.9E-10 | Exempted | |
| Te-129m | 2.3E-10 | 9.0E-10 | Exempted | |
| Cm-244 | 2.1E-10 | 3.3E-10 | Exempted | |
| Ru-106 | 2.1E-10 | 7.5E-10 | Exempted | |
| Ce-144 | 1.8E-10 | 6.5E-10 | Exempted | |
| Cd-113m | 1.2E-10 | 2.1E-10 | Exempted | |
| Ni-63 | 8.3E-11 | 2.5E-10 | Exempted | |
| Rb-86 | 8.2E-11 | 2.9E-10 | Exempted | |
| Cs-134 | 8.0E-11 | 5.5E-11 | Exempted | |
| Pm-148 | 7.6E-11 | 2.7E-10 | Exempted | |
| Sr-90 | 5.6E-11 | 9.4E-11 | Exempted | |
| Tc-99 | 5.2E-11 | 1.9E-10 | Exempted | |
| Co-60 | 4.9E-11 | 2.4E-10 | Exempted | |
| Te-127 | 4.6E-11 | 1.7E-10 | Exempted | |
| Sn-126 | 4.4E-11 | 1.5E-10 | Exempted | |
| Ba-140 | 2.8E-11 | 9.8E-11 | Exempted | |
| Cm-242 | 2.1E-11 | 6.8E-11 | Exempted | |
| Zn-65 | 2.0E-11 | 4.9E-11 | Exempted | |
| Eu-152 | 1.7E-11 | 4.9E-11 | Exempted | |
| Tb-160 | 1.4E-11 | 4.7E-11 | Exempted | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|----------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Sb-124 | 1.3E-11 | 4.4E-11 | Exempted | |
| Eu-154 | 1.3E-11 | 4.1E-11 | Exempted | |
| Pm-147 | 1.2E-11 | 4.3E-11 | Exempted | |
| Sb-125 | 9.6E-12 | 3.0E-11 | Exempted | |
| Fe-59 | 8.1E-12 | 3.4E-11 | Exempted | |
| Te-125m | 7.6E-12 | 2.9E-11 | Exempted | |
| Sr-89 | 7.3E-12 | 2.5E-11 | Exempted | |
| Ag-110m | 7.0E-12 | 2.0E-11 | Exempted | |
| Cs-136 | 6.8E-12 | 1.4E-11 | Exempted | |
| Am-242m | 6.1E-12 | 7.3E-12 | Exempted | |
| Te-123m | 5.9E-12 | 2.1E-11 | Exempted | |
| Y-90 | 5.4E-12 | 2.0E-11 | Exempted | |
| Ce-141 | 5.3E-12 | 2.0E-11 | Exempted | |
| Te-129 | 4.7E-12 | 1.6E-11 | Exempted | |
| Pm-148m | 4.4E-12 | 1.4E-11 | Exempted | |
| Eu-155 | 3.6E-12 | 1.2E-11 | Exempted | |
| Pm-146 | 3.5E-12 | 1.1E-11 | Exempted | |
| Gd-153 | 3.2E-12 | 1.1E-11 | Exempted | |
| Ru-103 | 2.3E-12 | 7.7E-12 | Exempted | |
| Pr-144 | 1.7E-12 | 5.9E-12 | Exempted | |
| Co-58 | 1.7E-12 | 6.0E-12 | Exempted | |
| Nb-95 | 1.7E-12 | 5.3E-12 | Exempted | |
| Mn-54 | 1.7E-12 | 4.5E-12 | Exempted | |
| Sm-151 | 6.1E-14 | 2.1E-13 | Exempted | |
| Rh-103m | 1.2E-14 | 4.1E-14 | Exempted | |
| Cs-135 | 2.6E-16 | 2.2E-16 | Exempted | |
| Rh-106 | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | Exempted | Assessed with the parent nuclide |
| Total | 3.2E-07 | 5.5E-07 | Exempted | |

**Table X-3-2 Assessment result of internal exposure from inhalation of seawater spray
(Source term based on measured values (J1-G tank group))**

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| H-3 | 7.3E-08 | 5.0E-08 | 3.4E-08 | |
| Pu-239 | 5.1E-08 | 2.5E-08 | 1.1E-08 | |
| Pu-240 | 5.1E-08 | 2.5E-08 | 1.1E-08 | |
| Pu-238 | 4.6E-08 | 2.3E-08 | 1.1E-08 | |
| Am-241 | 4.1E-08 | 2.0E-08 | 9.8E-09 | |
| Am-243 | 4.1E-08 | 2.0E-08 | 9.8E-09 | |
| Pu-241 | 3.5E-08 | 1.5E-08 | 5.4E-09 | |
| Cm-243 | 2.9E-08 | 1.6E-08 | 8.7E-09 | |
| Cm-244 | 2.4E-08 | 1.4E-08 | 8.1E-09 | |
| Cm-242 | 2.5E-09 | 2.0E-09 | 1.5E-09 | |
| Y-91 | 1.6E-09 | 1.3E-09 | 1.0E-09 | |
| C-14 | 1.4E-09 | 1.0E-09 | 5.9E-10 | |
| Sn-119m | 1.3E-09 | 1.1E-09 | 7.8E-10 | |
| Sn-123 | 7.7E-10 | 6.7E-10 | 4.9E-10 | |
| Am-242m | 7.1E-10 | 3.3E-10 | 1.6E-10 | |
| Te-127m | 6.6E-10 | 5.3E-10 | 3.6E-10 | |
| Ru-106 | 4.8E-10 | 4.0E-10 | 2.4E-10 | |
| Ce-144 | 4.4E-10 | 4.6E-10 | 3.8E-10 | |
| Cd-115m | 2.7E-10 | 2.3E-10 | 2.1E-10 | |
| Tc-99 | 2.5E-10 | 1.8E-10 | 1.0E-10 | |
| Cs-137 | 1.9E-10 | 1.4E-10 | 7.0E-11 | |
| I-129 | 1.8E-10 | 1.2E-10 | 4.6E-11 | |
| Ni-63 | 1.7E-10 | 1.4E-10 | 8.2E-11 | |
| Te-129m | 1.4E-10 | 1.2E-10 | 8.8E-11 | |
| Cd-113m | 1.4E-10 | 9.2E-11 | 5.0E-11 | |
| Eu-152 | 1.2E-10 | 7.9E-11 | 4.1E-11 | |
| Co-60 | 1.1E-10 | 8.0E-11 | 4.1E-11 | |
| Eu-154 | 8.0E-11 | 5.7E-11 | 3.1E-11 | |
| Sr-90 | 7.7E-11 | 5.1E-11 | 2.6E-11 | |
| Sn-126 | 6.3E-11 | 5.5E-10 | 3.5E-11 | |
| Pm-147 | 5.4E-11 | 4.7E-11 | 2.9E-11 | |
| Sb-125 | 2.5E-11 | 2.0E-11 | 1.1E-11 | |
| Cs-134 | 2.0E-11 | 1.6E-11 | 9.1E-12 | |
| Pm-146 | 2.0E-11 | 1.5E-11 | 7.8E-12 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Eu-155 | 1.9E-11 | 1.5E-11 | 9.1E-12 | |
| Pm-148 | 1.5E-11 | 1.5E-11 | 1.3E-11 | |
| Ba-140 | 1.5E-11 | 1.2E-11 | 9.6E-12 | |
| Tb-160 | 1.5E-11 | 1.2E-11 | 8.7E-12 | |
| Sb-124 | 1.1E-11 | 8.9E-12 | 6.4E-12 | |
| Te-127 | 9.1E-12 | 9.9E-12 | 1.0E-11 | |
| Te-125m | 8.9E-12 | 6.5E-12 | 4.6E-12 | |
| Ag-110m | 7.2E-12 | 6.2E-12 | 3.6E-12 | |
| Ce-141 | 6.9E-12 | 5.0E-12 | 3.7E-12 | |
| Rb-86 | 6.6E-12 | 9.5E-12 | 1.1E-11 | |
| Gd-153 | 6.0E-12 | 7.3E-12 | 5.5E-12 | |
| Sr-89 | 5.4E-12 | 4.5E-12 | 3.4E-12 | |
| Te-123m | 5.2E-12 | 3.9E-12 | 2.6E-12 | |
| Fe-59 | 4.3E-12 | 3.4E-12 | 2.9E-12 | |
| Pm-148m | 3.5E-12 | 2.9E-12 | 2.0E-12 | |
| Zn-65 | 2.7E-12 | 2.7E-12 | 2.3E-12 | |
| Ru-103 | 2.3E-12 | 1.8E-12 | 1.3E-12 | |
| Cs-136 | 1.5E-12 | 1.3E-12 | 1.0E-12 | |
| Nb-95 | 1.3E-12 | 1.0E-12 | 7.0E-13 | |
| Co-58 | 1.2E-12 | 9.8E-13 | 6.5E-13 | |
| Mn-54 | 8.6E-13 | 8.5E-13 | 5.5E-13 | |
| Y-90 | 7.2E-13 | 8.0E-13 | 8.1E-13 | |
| Te-129 | 7.1E-13 | 7.1E-13 | 8.1E-13 | |
| Sm-151 | 6.0E-13 | 4.0E-13 | 2.1E-13 | |
| Pr-144 | 1.5E-13 | 1.7E-13 | 2.0E-13 | |
| Rh-103m | 2.1E-15 | 2.0E-15 | 2.0E-15 | |
| Cs-135 | 2.7E-16 | 2.0E-16 | 1.1E-16 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 4.0E-07 | 2.2E-07 | 1.2E-07 | |

**Table X-3-3 Assessment result of internal exposure from ingestion of seafood
(Source term based on measured values (J1-G tank group), Average ingestion)**

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Sn-119m | 3.7E-05 | 7.1E-05 | 9.2E-05 | |
| Sn-123 | 3.6E-05 | 6.7E-05 | 8.8E-05 | |
| Sn-126 | 1.9E-06 | 3.3E-06 | 4.2E-06 | |
| C-14 | 1.0E-06 | 8.8E-07 | 5.1E-07 | |
| Cd-115m | 7.5E-07 | 1.1E-06 | 1.9E-06 | |
| I-129 | 3.0E-07 | 2.3E-07 | 9.5E-08 | |
| Cd-113m | 2.0E-07 | 1.7E-07 | 2.0E-07 | |
| Te-127m | 1.4E-07 | 2.8E-07 | 4.9E-07 | |
| Fe-59 | 6.8E-08 | 1.4E-07 | 3.0E-07 | |
| Te-129m | 4.9E-08 | 9.5E-08 | 1.4E-07 | |
| Y-91 | 4.8E-08 | 8.8E-08 | 1.1E-07 | |
| Am-241 | 4.4E-08 | 2.9E-08 | 1.6E-07 | |
| Am-243 | 4.4E-08 | 2.9E-08 | 1.5E-07 | |
| Pu-239 | 4.2E-08 | 2.8E-08 | 1.4E-07 | |
| Pu-240 | 4.2E-08 | 2.8E-08 | 1.4E-07 | |
| Pu-238 | 3.9E-08 | 2.6E-08 | 1.3E-07 | |
| H-3 | 3.3E-08 | 2.8E-08 | 2.3E-08 | |
| Pu-241 | 2.9E-08 | 1.6E-08 | 6.6E-08 | |
| Cm-243 | 2.3E-08 | 1.6E-08 | 9.3E-08 | |
| Tc-99 | 2.1E-08 | 3.7E-08 | 6.4E-08 | |
| Zn-65 | 2.1E-08 | 2.6E-08 | 3.8E-08 | |
| Co-60 | 1.8E-08 | 4.6E-08 | 5.7E-08 | |
| Cm-244 | 1.8E-08 | 1.4E-08 | 8.4E-08 | |
| Ce-144 | 1.7E-08 | 3.0E-08 | 4.1E-08 | |
| Pm-148 | 1.1E-08 | 2.0E-08 | 2.4E-08 | |
| Ag-110m | 1.0E-08 | 1.5E-08 | 1.8E-08 | |
| Ni-63 | 1.0E-08 | 1.5E-08 | 2.2E-08 | |
| Te-127 | 9.9E-09 | 1.8E-08 | 1.7E-08 | |
| Ru-106 | 6.9E-09 | 1.2E-08 | 1.6E-08 | |
| Eu-152 | 2.4E-09 | 3.6E-09 | 5.5E-09 | |
| Cs-137 | 2.3E-09 | 8.3E-10 | 7.5E-10 | |
| Eu-154 | 1.8E-09 | 3.0E-09 | 4.5E-09 | |
| Cm-242 | 1.8E-09 | 2.9E-09 | 1.7E-08 | |
| Pm-147 | 1.7E-09 | 3.2E-09 | 4.7E-09 | |
| Te-125m | 1.6E-09 | 3.0E-09 | 4.8E-09 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Mn-54 | 1.3E-09 | 1.7E-09 | 1.9E-09 | |
| Te-123m | 1.3E-09 | 2.2E-09 | 3.4E-09 | |
| Te-129 | 1.0E-09 | 1.7E-09 | 2.4E-09 | |
| Tb-160 | 9.4E-10 | 1.6E-09 | 1.9E-09 | |
| Am-242m | 7.6E-10 | 4.5E-10 | 2.4E-09 | |
| Cs-134 | 6.7E-10 | 2.3E-10 | 1.9E-10 | |
| Co-58 | 6.4E-10 | 1.1E-09 | 1.2E-09 | |
| Pm-148m | 6.4E-10 | 1.0E-09 | 1.1E-09 | |
| Sb-124 | 6.0E-10 | 1.0E-09 | 1.2E-09 | |
| Eu-155 | 5.3E-10 | 9.0E-10 | 1.4E-09 | |
| Pm-146 | 5.2E-10 | 8.1E-10 | 1.1E-09 | |
| Ce-141 | 5.0E-10 | 9.0E-10 | 1.1E-09 | |
| Gd-153 | 4.7E-10 | 8.2E-10 | 1.0E-09 | |
| Sb-125 | 4.4E-10 | 6.9E-10 | 9.1E-10 | |
| Y-90 | 1.4E-10 | 2.7E-10 | 3.3E-10 | |
| Pr-144 | 1.4E-10 | 2.3E-10 | 3.4E-10 | |
| Nb-95 | 9.2E-11 | 1.4E-10 | 1.4E-10 | |
| Rb-86 | 8.8E-11 | 1.5E-10 | 2.0E-10 | |
| Ru-103 | 7.6E-11 | 1.2E-10 | 1.4E-10 | |
| Cs-136 | 5.7E-11 | 5.8E-11 | 5.8E-11 | |
| Ba-140 | 4.9E-11 | 8.4E-11 | 1.2E-10 | |
| Sr-90 | 2.6E-11 | 2.2E-11 | 4.3E-11 | |
| Sm-151 | 8.9E-12 | 1.5E-11 | 2.7E-11 | |
| Sr-89 | 3.4E-12 | 5.8E-12 | 9.4E-12 | |
| Rh-103m | 6.2E-13 | 1.1E-12 | 1.5E-12 | |
| Cs-135 | 2.2E-15 | 9.4E-16 | 9.3E-16 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 7.9E-05 | 1.5E-04 | 1.9E-04 | |

**Table X-3-4 Assessment result of internal exposure from ingestion of seafood
(Source term based on measured values (J1-C tank group), More ingestion)**

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|---------|
| | Adult | Children under school age | Infants | |
| Sn-119m | 1.4E-04 | 2.7E-04 | 3.4E-04 | |
| Sn-123 | 1.4E-04 | 2.6E-04 | 3.3E-04 | |
| Sn-126 | 7.3E-06 | 1.3E-05 | 1.6E-05 | |
| Cd-115m | 4.0E-06 | 5.9E-06 | 9.7E-06 | |
| C-14 | 3.9E-06 | 3.4E-06 | 1.9E-06 | |
| I-129 | 1.4E-06 | 1.1E-06 | 4.5E-07 | |
| Cd-113m | 1.0E-06 | 8.8E-07 | 1.1E-06 | |
| Te-127m | 6.0E-07 | 1.3E-06 | 2.1E-06 | |
| Fe-59 | 3.7E-07 | 7.7E-07 | 1.6E-06 | |
| Y-91 | 2.6E-07 | 4.7E-07 | 5.8E-07 | |
| Pu-239 | 2.2E-07 | 1.4E-07 | 7.1E-07 | |
| Pu-240 | 2.2E-07 | 1.4E-07 | 7.1E-07 | |
| Am-241 | 2.1E-07 | 1.4E-07 | 7.5E-07 | |
| Am-243 | 2.1E-07 | 1.4E-07 | 7.3E-07 | |
| Te-129m | 2.1E-07 | 4.2E-07 | 6.0E-07 | |
| Pu-238 | 2.0E-07 | 1.4E-07 | 6.8E-07 | |
| Pu-241 | 1.5E-07 | 8.6E-08 | 3.4E-07 | |
| H-3 | 1.3E-07 | 1.1E-07 | 8.7E-08 | |
| Zn-65 | 1.2E-07 | 1.5E-07 | 2.2E-07 | |
| Cm-243 | 1.1E-07 | 8.0E-08 | 4.5E-07 | |
| Tc-99 | 1.0E-07 | 1.8E-07 | 3.0E-07 | |
| Co-60 | 1.0E-07 | 2.5E-07 | 3.1E-07 | |
| Cm-244 | 8.7E-08 | 6.9E-08 | 4.1E-07 | |
| Ce-144 | 8.5E-08 | 1.6E-07 | 2.1E-07 | |
| Pm-148 | 6.0E-08 | 1.1E-07 | 1.3E-07 | |
| Ag-110m | 5.0E-08 | 7.0E-08 | 8.4E-08 | |
| Te-127 | 4.3E-08 | 7.8E-08 | 7.4E-08 | |
| Ni-63 | 4.2E-08 | 6.5E-08 | 8.8E-08 | |
| Ru-106 | 3.4E-08 | 6.1E-08 | 8.0E-08 | |
| Eu-152 | 1.3E-08 | 1.9E-08 | 2.9E-08 | |
| Eu-154 | 9.8E-09 | 1.6E-08 | 2.4E-08 | |
| Pm-147 | 9.2E-09 | 1.7E-08 | 2.5E-08 | |
| Cm-242 | 8.7E-09 | 1.4E-08 | 8.2E-08 | |
| Cs-137 | 8.2E-09 | 3.1E-09 | 2.7E-09 | |

| Nuclide | Exposure assessment result (mSv/year) | | | Remarks |
|---------|---------------------------------------|---------------------------|---------|----------------------------------|
| | Adult | Children under school age | Infants | |
| Mn-54 | 7.4E-09 | 9.9E-09 | 1.1E-08 | |
| Te-125m | 7.1E-09 | 1.4E-08 | 2.1E-08 | |
| Te-123m | 5.5E-09 | 9.6E-09 | 1.5E-08 | |
| Tb-160 | 5.1E-09 | 8.6E-09 | 9.9E-09 | |
| Te-129 | 4.4E-09 | 7.4E-09 | 1.0E-08 | |
| Am-242m | 3.6E-09 | 2.2E-09 | 1.1E-08 | |
| Co-58 | 3.5E-09 | 6.1E-09 | 6.7E-09 | |
| Pm-148m | 3.4E-09 | 5.5E-09 | 5.9E-09 | |
| Eu-155 | 2.8E-09 | 4.9E-09 | 7.4E-09 | |
| Pm-146 | 2.8E-09 | 4.3E-09 | 6.0E-09 | |
| Ce-141 | 2.5E-09 | 4.6E-09 | 5.6E-09 | |
| Gd-153 | 2.5E-09 | 4.4E-09 | 5.2E-09 | |
| Cs-134 | 2.4E-09 | 8.5E-10 | 6.8E-10 | |
| Sb-124 | 2.1E-09 | 3.6E-09 | 4.3E-09 | |
| Sb-125 | 1.6E-09 | 2.5E-09 | 3.2E-09 | |
| Y-90 | 7.7E-10 | 1.4E-09 | 1.7E-09 | |
| Pr-144 | 6.8E-10 | 1.2E-09 | 1.7E-09 | |
| Nb-95 | 4.6E-10 | 7.2E-10 | 7.1E-10 | |
| Ru-103 | 3.8E-10 | 6.3E-10 | 7.1E-10 | |
| Rb-86 | 3.6E-10 | 6.5E-10 | 8.0E-10 | |
| Cs-136 | 2.1E-10 | 2.1E-10 | 2.1E-10 | |
| Ba-140 | 2.1E-10 | 3.7E-10 | 5.0E-10 | |
| Sr-90 | 1.2E-10 | 9.8E-11 | 1.9E-10 | |
| Sm-151 | 4.8E-11 | 8.1E-11 | 1.4E-10 | |
| Sr-89 | 1.5E-11 | 2.6E-11 | 4.1E-11 | |
| Rh-103m | 3.4E-12 | 5.8E-12 | 8.1E-12 | |
| Cs-135 | 8.1E-15 | 3.5E-15 | 3.3E-15 | |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 3.0E-04 | 5.6E-04 | 7.1E-04 | |

X-2. Assessment result regarding environmental protection

For the following exposure assessments shown in chapter 7. "Assessment regarding environmental protection", Tables X-4 to 6 show the assessment result of each nuclide.

Source term based on measured values of 64 nuclides

- i. K4 tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.29)
- ii. J1-C tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.35)
- iii. J1-G tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.22)

Table X-4 Assessment result of environmental protection (Source term based on measured values (K4 tank group))

| Nuclide | Exposure assessment result (mGy/day) | | | Remarks |
|---------|--------------------------------------|---------|---------------|---------|
| | Flatfish | Crab | Brown seaweed | |
| Fe-59 | 1.2E-05 | 1.2E-05 | 1.3E-05 | |
| Sn-123 | 1.6E-06 | 1.5E-06 | 1.7E-06 | |
| Pm-148 | 1.3E-06 | 1.2E-06 | 1.7E-06 | |
| Sn-126 | 6.9E-07 | 6.6E-07 | 6.4E-07 | |
| Co-60 | 6.5E-07 | 6.5E-07 | 7.1E-07 | |
| Pm-146 | 2.9E-07 | 2.8E-07 | 3.1E-07 | |
| Y-91 | 1.4E-07 | 8.4E-08 | 6.3E-07 | |
| Eu-152 | 1.3E-07 | 1.2E-07 | 1.3E-07 | |
| Tb-160 | 1.2E-07 | 1.2E-07 | 1.3E-07 | |
| Ce-144 | 7.8E-08 | 4.6E-08 | 7.8E-08 | |
| Pm-148m | 6.6E-08 | 6.4E-08 | 7.2E-08 | |
| Eu-154 | 6.1E-08 | 5.7E-08 | 6.1E-08 | |
| Ru-106 | 5.4E-08 | 5.4E-08 | 6.4E-08 | |
| Cd-115m | 4.9E-08 | 2.2E-07 | 9.3E-09 | |
| Sn-119m | 4.3E-08 | 4.1E-08 | 3.0E-08 | |
| C-14 | 4.0E-08 | 3.3E-08 | 2.7E-08 | |
| Mn-54 | 2.3E-08 | 2.1E-08 | 2.3E-08 | |
| Gd-153 | 1.2E-08 | 1.1E-08 | 1.4E-08 | |
| Nb-95 | 1.2E-08 | 1.2E-08 | 1.2E-08 | |
| Ce-141 | 1.1E-08 | 1.1E-08 | 1.2E-08 | |
| Eu-155 | 7.7E-09 | 7.5E-09 | 7.7E-09 | |
| H-3 | 4.7E-09 | 4.7E-09 | 1.8E-09 | |
| Co-58 | 4.6E-09 | 4.6E-09 | 4.6E-09 | |
| Cs-137 | 2.0E-09 | 1.9E-09 | 2.0E-09 | |
| Zn-65 | 1.3E-09 | 2.6E-09 | 1.3E-09 | |

| Nuclide | Exposure assessment result (mGy/day) | | | Remarks |
|---------|--------------------------------------|---------|---------------|----------------------------------|
| | Flatfish | Crab | Brown seaweed | |
| Ba-140 | 9.3E-10 | 1.3E-09 | 1.7E-09 | |
| Te-129m | 9.1E-10 | 9.2E-10 | 8.4E-09 | |
| Sb-125 | 7.0E-10 | 6.6E-10 | 8.7E-10 | |
| Am-243 | 5.8E-10 | 7.1E-10 | 6.4E-10 | |
| Cs-134 | 5.8E-10 | 5.4E-10 | 5.7E-10 | |
| Cs-136 | 5.0E-10 | 5.0E-10 | 5.0E-10 | |
| Te-127m | 4.3E-10 | 4.3E-10 | 4.1E-09 | |
| Cd-113m | 4.1E-10 | 1.8E-09 | 3.4E-11 | |
| Ag-110m | 4.0E-10 | 2.2E-09 | 3.5E-10 | |
| Ru-103 | 3.9E-10 | 3.9E-10 | 4.0E-10 | |
| Cm-243 | 3.2E-10 | 8.3E-10 | 5.2E-10 | |
| Te-127 | 3.2E-10 | 3.2E-10 | 2.9E-09 | |
| Rb-86 | 2.7E-10 | 2.0E-10 | 4.8E-10 | |
| Te-125m | 1.9E-10 | 2.0E-10 | 1.7E-09 | |
| Pm-147 | 9.7E-11 | 1.3E-09 | 9.0E-10 | |
| Sb-124 | 8.5E-11 | 8.0E-11 | 1.0E-10 | |
| Am-241 | 6.3E-11 | 2.0E-10 | 6.4E-11 | |
| Ni-63 | 4.5E-11 | 1.1E-09 | 3.3E-10 | |
| Sr-90 | 4.3E-11 | 1.6E-10 | 4.2E-11 | |
| Pu-238 | 3.8E-11 | 2.6E-11 | 6.3E-11 | |
| Pu-240 | 3.6E-11 | 2.4E-11 | 5.9E-11 | |
| Pu-239 | 3.6E-11 | 2.4E-11 | 5.9E-11 | |
| Tc-99 | 2.5E-11 | 5.6E-09 | 1.6E-08 | |
| I-129 | 1.1E-11 | 6.4E-09 | 2.8E-09 | |
| Sr-89 | 1.1E-11 | 3.7E-11 | 1.1E-11 | |
| Te-123m | 7.3E-12 | 7.4E-12 | 4.4E-11 | |
| Cm-242 | 4.3E-12 | 5.5E-10 | 2.1E-10 | |
| Cm-244 | 4.1E-12 | 5.2E-10 | 2.0E-10 | |
| Am-242m | 3.0E-12 | 3.3E-12 | 5.2E-12 | |
| Pu-241 | 1.6E-12 | 1.1E-12 | 2.7E-12 | |
| Sm-151 | 9.1E-14 | 1.9E-12 | 7.9E-13 | |
| Cs-135 | 1.2E-16 | 6.4E-17 | 9.5E-17 | |
| Y-90 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Rh-103m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Te-129 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |

| Nuclide | Exposure assessment result (mGy/day) | | | Remarks |
|---------|--------------------------------------|---------|---------------|----------------------------------|
| | Flatfish | Crab | Brown seaweed | |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 1.7E-05 | 1.7E-05 | 1.9E-05 | |

Table X-5 Assessment result of environmental protection (Source term based on measured values (J1-C tank group))

| Nuclide | Exposure assessment result (mGy/day) | | | Remarks |
|---------|--------------------------------------|---------|---------------|---------|
| | Flatfish | Crab | Brown seaweed | |
| Fe-59 | 1.4E-05 | 1.4E-05 | 1.5E-05 | |
| Sn-119m | 2.5E-06 | 2.3E-06 | 1.7E-06 | |
| Sn-123 | 2.0E-06 | 2.0E-06 | 2.1E-06 | |
| Sn-126 | 1.7E-06 | 1.6E-06 | 1.6E-06 | |
| Eu-152 | 3.1E-07 | 2.9E-07 | 3.1E-07 | |
| Y-91 | 2.5E-07 | 1.5E-07 | 1.1E-06 | |
| Ce-144 | 1.6E-07 | 9.5E-08 | 1.6E-07 | |
| Tb-160 | 1.4E-07 | 1.4E-07 | 1.5E-07 | |
| Pm-148 | 1.4E-07 | 1.3E-07 | 1.9E-07 | |
| Eu-154 | 1.3E-07 | 1.2E-07 | 1.3E-07 | |
| Co-60 | 1.1E-07 | 1.1E-07 | 1.2E-07 | |
| Pm-148m | 8.8E-08 | 8.5E-08 | 9.5E-08 | |
| Cd-115m | 4.8E-08 | 2.1E-07 | 9.1E-09 | |
| Pm-146 | 4.7E-08 | 4.5E-08 | 4.9E-08 | |
| Mn-54 | 3.1E-08 | 2.8E-08 | 3.1E-08 | |
| Ce-141 | 2.7E-08 | 2.6E-08 | 2.8E-08 | |
| Gd-153 | 2.3E-08 | 2.1E-08 | 2.7E-08 | |
| Eu-155 | 1.8E-08 | 1.8E-08 | 1.8E-08 | |
| Nb-95 | 1.4E-08 | 1.4E-08 | 1.4E-08 | |
| C-14 | 1.1E-08 | 9.2E-09 | 7.4E-09 | |
| Ru-106 | 1.1E-08 | 1.1E-08 | 1.3E-08 | |
| Am-243 | 7.1E-09 | 8.6E-09 | 7.8E-09 | |
| Co-58 | 5.5E-09 | 5.4E-09 | 5.4E-09 | |
| H-3 | 4.7E-09 | 4.7E-09 | 1.8E-09 | |
| Cm-243 | 3.9E-09 | 1.0E-08 | 6.3E-09 | |
| Zn-65 | 1.9E-09 | 3.8E-09 | 1.8E-09 | |
| Te-127m | 1.5E-09 | 1.5E-09 | 1.4E-08 | |
| Te-127 | 1.1E-09 | 1.1E-09 | 1.0E-08 | |
| Te-129m | 9.2E-10 | 9.4E-10 | 8.5E-09 | |
| Am-241 | 7.6E-10 | 2.5E-09 | 7.8E-10 | |

| Nuclide | Exposure assessment result (mGy/day) | | | Remarks |
|---------|--------------------------------------|---------|---------------|----------------------------------|
| | Flatfish | Crab | Brown seaweed | |
| Ag-110m | 7.2E-10 | 4.0E-09 | 6.2E-10 | |
| Ru-103 | 4.8E-10 | 4.8E-10 | 4.9E-10 | |
| Pu-238 | 4.7E-10 | 3.2E-10 | 7.6E-10 | |
| Ba-140 | 4.6E-10 | 6.3E-10 | 8.5E-10 | |
| Cd-113m | 4.5E-10 | 2.0E-09 | 3.7E-11 | |
| Pu-240 | 4.4E-10 | 3.0E-10 | 7.1E-10 | |
| Pu-239 | 4.3E-10 | 3.0E-10 | 7.1E-10 | |
| Cs-134 | 2.3E-10 | 2.1E-10 | 2.2E-10 | |
| Cs-137 | 2.1E-10 | 2.0E-10 | 2.1E-10 | |
| Sb-124 | 2.0E-10 | 1.9E-10 | 2.4E-10 | |
| Cs-136 | 1.8E-10 | 1.8E-10 | 1.8E-10 | |
| Rb-86 | 1.6E-10 | 1.2E-10 | 3.0E-10 | |
| Sb-125 | 1.1E-10 | 1.1E-10 | 1.4E-10 | |
| Pm-147 | 9.5E-11 | 1.3E-09 | 8.8E-10 | |
| Cm-242 | 5.2E-11 | 6.7E-09 | 2.5E-09 | |
| Cm-244 | 4.9E-11 | 6.3E-09 | 2.4E-09 | |
| Ni-63 | 4.0E-11 | 9.6E-10 | 3.0E-10 | |
| Te-125m | 3.1E-11 | 3.2E-11 | 2.7E-10 | |
| Te-123m | 1.7E-11 | 1.7E-11 | 1.0E-10 | |
| Pu-241 | 1.6E-11 | 1.1E-11 | 2.7E-11 | |
| Am-242m | 1.0E-11 | 1.1E-11 | 1.8E-11 | |
| Tc-99 | 9.8E-12 | 2.2E-09 | 6.5E-09 | |
| Sr-90 | 1.6E-12 | 5.9E-12 | 1.6E-12 | |
| I-129 | 1.5E-12 | 8.5E-10 | 3.7E-10 | |
| Sr-89 | 1.3E-12 | 4.7E-12 | 1.3E-12 | |
| Sm-151 | 2.6E-13 | 5.5E-12 | 2.2E-12 | |
| Cs-135 | 1.3E-17 | 7.1E-18 | 1.1E-17 | |
| Y-90 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Rh-103m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Te-129 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 2.2E-05 | 2.2E-05 | 2.3E-05 | |

Table X-6 Assessment result of environmental protection (Source term based on measured values (J1-G tank group))

| Nuclide | Exposure assessment result (mGy/day) | | | Remarks |
|---------|--------------------------------------|---------|---------------|---------|
| | Flatfish | Crab | Brown seaweed | |
| Fe-59 | 3.6E-05 | 3.6E-05 | 3.8E-05 | |
| Sn-119m | 7.1E-06 | 6.8E-06 | 5.0E-06 | |
| Sn-123 | 5.9E-06 | 5.7E-06 | 6.1E-06 | |
| Sn-126 | 2.7E-06 | 2.6E-06 | 2.5E-06 | |
| Pm-148 | 8.1E-07 | 7.8E-07 | 1.1E-06 | |
| Eu-152 | 6.3E-07 | 5.9E-07 | 6.3E-07 | |
| Y-91 | 5.3E-07 | 3.2E-07 | 2.4E-06 | |
| Ce-144 | 4.8E-07 | 2.8E-07 | 4.8E-07 | |
| Tb-160 | 4.4E-07 | 4.4E-07 | 4.7E-07 | |
| Eu-154 | 3.6E-07 | 3.4E-07 | 3.6E-07 | |
| Co-60 | 2.4E-07 | 2.4E-07 | 2.6E-07 | |
| Pm-148m | 2.3E-07 | 2.2E-07 | 2.5E-07 | |
| Pm-146 | 1.3E-07 | 1.3E-07 | 1.4E-07 | |
| Cd-115m | 1.2E-07 | 5.5E-07 | 2.4E-08 | |
| Mn-54 | 9.3E-08 | 8.5E-08 | 9.3E-08 | |
| Gd-153 | 5.1E-08 | 4.7E-08 | 5.9E-08 | |
| Nb-95 | 4.0E-08 | 3.9E-08 | 4.1E-08 | |
| Ce-141 | 3.8E-08 | 3.7E-08 | 3.9E-08 | |
| C-14 | 3.0E-08 | 2.5E-08 | 2.0E-08 | |
| Eu-155 | 3.0E-08 | 2.9E-08 | 3.0E-08 | |
| Am-243 | 1.8E-08 | 2.2E-08 | 2.0E-08 | |
| Co-58 | 1.5E-08 | 1.5E-08 | 1.5E-08 | |
| Ru-106 | 1.1E-08 | 1.1E-08 | 1.3E-08 | |
| Cm-243 | 1.0E-08 | 2.6E-08 | 1.6E-08 | |
| Zn-65 | 4.9E-09 | 9.8E-09 | 4.8E-09 | |
| H-3 | 4.7E-09 | 4.7E-09 | 1.8E-09 | |
| Te-127m | 4.3E-09 | 4.3E-09 | 4.0E-08 | |
| Te-127 | 3.0E-09 | 3.0E-09 | 2.8E-08 | |
| Te-129m | 2.4E-09 | 2.4E-09 | 2.2E-08 | |
| Ag-110m | 2.0E-09 | 1.1E-08 | 1.7E-09 | |
| Am-241 | 2.0E-09 | 6.4E-09 | 2.0E-09 | |
| Ru-103 | 1.4E-09 | 1.4E-09 | 1.4E-09 | |
| Cd-113m | 1.4E-09 | 6.2E-09 | 1.1E-10 | |

| Nuclide | Exposure assessment result (mGy/day) | | | Remarks |
|---------|--------------------------------------|---------|---------------|----------------------------------|
| | Flatfish | Crab | Brown seaweed | |
| Pu-238 | 1.2E-09 | 8.2E-10 | 2.0E-09 | |
| Ba-140 | 1.2E-09 | 1.6E-09 | 2.2E-09 | |
| Pu-240 | 1.1E-09 | 7.6E-10 | 1.8E-09 | |
| Pu-239 | 1.1E-09 | 7.6E-10 | 1.8E-09 | |
| Cs-137 | 1.1E-09 | 1.0E-09 | 1.1E-09 | |
| Cs-134 | 6.0E-10 | 5.7E-10 | 6.0E-10 | |
| Sb-124 | 5.3E-10 | 5.0E-10 | 6.4E-10 | |
| Rb-86 | 4.7E-10 | 3.5E-10 | 8.4E-10 | |
| Cs-136 | 4.2E-10 | 4.2E-10 | 4.2E-10 | |
| Pm-147 | 2.6E-10 | 3.5E-09 | 2.4E-09 | |
| Sb-125 | 2.1E-10 | 2.0E-10 | 2.6E-10 | |
| Cm-242 | 1.3E-10 | 1.7E-08 | 6.5E-09 | |
| Ni-63 | 1.3E-10 | 3.0E-09 | 9.4E-10 | |
| Cm-244 | 1.3E-10 | 1.6E-08 | 6.2E-09 | |
| Te-125m | 5.7E-11 | 6.0E-11 | 5.0E-10 | |
| Pu-241 | 4.1E-11 | 2.8E-11 | 6.8E-11 | |
| Te-123m | 3.7E-11 | 3.8E-11 | 2.2E-10 | |
| Tc-99 | 3.2E-11 | 7.3E-09 | 2.1E-08 | |
| Am-242m | 2.7E-11 | 3.0E-11 | 4.8E-11 | |
| Sr-90 | 4.4E-12 | 1.6E-11 | 4.3E-12 | |
| Sr-89 | 3.4E-12 | 1.2E-11 | 3.3E-12 | |
| I-129 | 1.2E-12 | 7.1E-10 | 3.1E-10 | |
| Sm-151 | 7.1E-13 | 1.5E-11 | 6.2E-12 | |
| Cs-135 | 6.9E-17 | 3.8E-17 | 5.6E-17 | |
| Y-90 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Rh-103m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Rh-106 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Te-129 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Ba-137m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Pr-144m | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| Total | 5.6E-05 | 5.5E-05 | 5.9E-05 | |

Attachment XI Conservativeness of the external exposure dose conversion factor

The dose conversion factor used for the dose assessment of external exposure is quoted from the Handbook for Determining Environmental Impacts of Decommissioning Work (hereinafter called “Decommissioning Handbook”). It has some defects: for example, its target is only the gamma radiation and conversion factors are not prepared for some of the 64 nuclides. For the unprepared conversion factors, conservativeness is secured by quoting the most conservative conversion factor for each of the $\beta\gamma$ and α nuclides, Co-60 and Am-241, respectively. For verification, comparison was performed using the dose conversion factor of external exposure created overseas.

As the target of comparison, we used Federal Guidance Report No.15, “External Exposure to Radionuclides in Air, Water and Soil” (Environmental Protection Agency, 2019; hereinafter called “FGR15”) [XI-1] provided by the U.S. Environmental Protection Agency for radiation protection of U.S. citizens. FGR15 shows the dose conversion factor for the calculation of external exposure of humans from radioactive materials on the ground surface and in the soil, air, and water, and the target nuclides include all of the 64 nuclides subject to the assessment of ALPS treated water, so we attempted an assessment using the dose conversion factor shown in FGR15.

XI-1. Assessment method

Same as the exposure assessment method shown in the chapter 6-1. “Exposure assessment under normal conditions” and only the dose conversion factor is switched. However, external exposure from radioactive materials adhered to fishing nets are excluded from comparison targets because there is no appropriate dose conversion factor in FGR15. The following shows the assessment model and used parameters of each exposure pathway in FGR15.

(1) External exposure from the seawater surface

The effective dose conversion factor from radiation from seawater is calculated by multiplying the external dose conversion factor in immersion in water shown in Table 4-7. Reference person effective dose rate coefficients for water immersion. of FGR15 by the reduction factor of 0.5 considering that there is no radiation source (seawater) upward (Table XI-1). Figure XI-1 shows an image diagram of the assessment model. Shielding by hulls was ignored in the safe side.

Equation (XI-1) shows the calculation equation of the effective dose D_1 (mSv/year) from radiation from the seawater surface.

$$D_1 = 1000 \cdot 1000 \cdot 3600 \cdot \sum_i (K_1)_i \cdot (x_1)_i \cdot t_1 \quad \text{(XI-1)}$$

where

$(K_1)_i$ is the effective dose conversion factor from radiation from nuclide i in immersion in water ((Sv/s)/(Bq/m³))

$(x_1)_i$ is the concentration of nuclide i in seawater (Bq/L)

t_1 is the annual exposure time (h/year)

1000 is the factor of unit conversion (Sv to mSv) of the effective dose

1000 is the factor of unit conversion (Bq/L to Bq/m³) of the concentration in seawater

3600 is the factor of unit conversion (h/year to s/year) of the annual exposure time

As in the chapter 6-1. "Exposure assessment under normal conditions", the concentration of radioactive materials in seawater used for the assessment was the annual average concentration of the sea surface (top layer) within the 10 km × 10 km area around the power plant.




Figure XI-1 Conceptual diagram of the exposure assessment model from radioactive materials in seawater during work at sea

(2) External exposure from hulls

Assess the external radiation exposure from radioactive materials migrated from seawater to hulls during work at sea. The effective dose conversion factor from radiation from radioactive materials migrated from seawater to hulls is the external dose conversion factor in immersion in water shown in Table 4-1. Reference person effective dose rate coefficients for ground surface. of FGR15. (Table XI-2). Figure XI-2 shows an image diagram of the assessment model.

Equations (XI-2) and (XI-3) show the calculation equation of the effective dose D_2 (mSv/year) from radioactive materials adhered to hulls.

$$D_2 = 1000 \cdot 3600 \cdot \sum_i (K_2)_i \cdot (S_2)_i \cdot t_2 \quad (\text{XI-2})$$

$$(S_2)_i = (F_2)_i \cdot (x_2)_i \quad (\text{XI-3})$$

where

- $(K_2)_i$ is the effective dose conversion factor from radiation from nuclide i from hulls ((Sv/s)/(Bq/m²))
- $(S_2)_i$ is the contamination density of nuclide i in hulls (Bq/m²)
- t_2 is the annual exposure time (h/year)
- $(F_2)_i$ is the migration factor of nuclide i from seawater to hulls ((Bq/m²)/(Bq/L))
- $(x_2)_i$ is the concentration of nuclide i in seawater (Bq/L) at the assessment point
- 1000 is the factor of unit conversion (Sv to mSv) of the effective dose
- 3600 is the factor of unit conversion (h/year to s/year) of the annual exposure time

As in the chapter 6-1. "Exposure assessment under normal conditions", the migration factor to hulls is 100((Bq/m²)/(Bq/L)) from the Application for the Designation of Reprocessing Business at Rokkasho business facility.

As in the chapter 6-1. "Exposure assessment under normal conditions, the concentration of radioactive materials in seawater used for the assessment was the annual average concentration of the sea surface (top layer) within the 10 km × 10 km area around the power plant.




Figure XI-2 Conceptual diagram of the exposure assessment model from radioactive materials adhered to hulls during work at sea

(3) External exposure under water such as during swimming

Assess the external exposure from radioactive materials in the surrounding seawater during swimming and underwater work. The effective dose conversion factor from radiation from radioactive materials in seawater is the external dose conversion factor in immersion in water shown in Table 4-7. Reference person effective dose rate coefficients for water immersion. of FGR15 (Table XI-3). Figure XI-3 shows an image diagram of the assessment model.

Equation (XI-4) shows the calculation equation of the effective dose D_3 (mSv/year) from radiation during swimming and underwater work.

$$D_3 = 1000 \cdot 1000 \cdot 3600 \cdot \sum_i (K_3)_i \cdot (x_3)_i \cdot t_3 \quad (\text{XI-4})$$

where

$(K_3)_i$ is the effective dose conversion factor from radiation from nuclide i from seawater ((Sv/s)/(Bq/m³))

$(x_3)_i$ is the concentration of nuclide i in seawater (Bq/L)

t_3 is the annual exposure time (h/year)

1000 is the factor of unit conversion (Sv to mSv) of the effective dose

1000 is the factor of unit conversion (Bq/L to Bq/m³) of the concentration in seawater

3600 is the factor of unit conversion (h/year to s/year) of the annual exposure time

As in the chapter 6-1. "Exposure assessment under normal conditions", the concentration of radioactive materials in seawater used for the assessment site and for the assessment is the average concentration in sea water around the beach to the north of the power plant where the evacuation order has been lifted.




Figure XI-3 Conceptual diagram of the exposure assessment model from radioactive materials in seawater

(4) External exposure from beach sand

Assess the external exposure from radioactive materials migrated from seawater to beach sand while staying at a beach. The effective dose conversion factor from radiation from radioactive materials at a beach is the external dose conversion factor regarding exposure from radioactive materials in the soil shown in Table 4-5. Reference person effective dose rate coefficients for soil to infinite depth. of FGR15 (Table XI-4). Figure XI-4 shows an image diagram of the assessment model.

Equation (XI-5) shows the calculation equation of the effective dose D_4 (mSv/year) from the gamma radiation from beach sand.

$$D_4 = 1000 \cdot 1600 \cdot 3600 \cdot \sum_i (K_4)_i \cdot (x_4)_i \cdot (F_4)_i \cdot t_4 \quad (\text{XI-5})$$

where

$(K_4)_i$ is the effective dose conversion factor from radiation from nuclide i from beach sand ((Sv/s)/(Bq/m³))

- $(x_4)_i$ is the concentration of nuclide i in seawater (Bq/L)
- $(F_4)_i$ is the migration factor of nuclide i from seawater to beaches ((Bq/kg)/(Bq/L))
- t_4 is the annual exposure time (h/year)
- 1000 is the factor of unit conversion (Sv to mSv) of the effective dose
- 1600 is the factor of unit conversion (Bq/kg to Bq/m³) of the radioactive material concentration in the soil
- 3600 is the factor of unit conversion (h/year to s/year) of the annual exposure time

As with the chapter 6-1. "Exposure assessment under normal conditions", the migration factor of nuclides to beaches is 1,000[(Bq/kg)/(Bq/L)] for all nuclides based on "Dose Assessment to the General Public in the Safety Review of Commercial Light Water Reactor Facilities."

As in the chapter 6-1. "Exposure assessment under normal conditions", the concentration of radioactive materials in seawater used for the assessment site and for the assessment is the average concentration in sea water around the beach to the north of the power plant where the evacuation order has been lifted.




Figure XI-4 Conceptual diagram of the exposure assessment model from radioactive materials adhered to beach sand

XI-2. Setting of the representative person subject to the exposure assessment

The features of representative persons subject to the exposure assessment were the same as 6-2-5. as follows.

- Engage in fishing 120 days (2,880 hours) a year, of which 80 days (1,920 hours) are spent near fishing nets.
- Stay at the beach 500 hours a year and swim for 96 hours.

Table XI-1 Dose conversion factor for the effective dose from the radiation from the sea surface using FGR15

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|---|
| H-3 | 3.1E-27 | |
| C-14 | 1.4E-21 | |
| Mn-54 | 4.0E-17 | |
| Fe-59 | 6.0E-17 | |
| Co-58 | 4.6E-17 | |
| Co-60 | 1.3E-16 | |
| Ni-63 | 3.9E-24 | |
| Zn-65 | 2.9E-17 | |
| Rb-86 | 4.9E-18 | |
| Sr-89 | 2.5E-19 | |
| Sr-90 | 5.4E-20 | |
| Y-90 | 4.7E-19 | |
| Y-91 | 4.2E-19 | |
| Nb-95 | 3.6E-17 | |
| Tc-99 | 1.5E-20 | |
| Ru-103 | 2.2E-17 | |
| Ru-106 | 2.8E-25 | |
| Rh-103m | 5.1E-21 | |
| Rh-106 | 1.0E-17 | |
| Ag-110m | 1.3E-16 | |
| Cd-113m | 5.2E-20 | |
| Cd-115m | 1.9E-18 | |
| Sn-119m | 8.3E-20 | |
| Sn-123 | 5.6E-19 | |
| Sn-126 | 7.4E-17 | The progeny nuclide Sb-126m is considered |
| Sb-124 | 9.3E-17 | |
| Sb-125 | 1.9E-17 | |
| Te-123m | 5.5E-18 | |
| Te-125m | 3.0E-19 | |
| Te-127 | 2.8E-19 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|--|
| Te-127m | 9.9E-20 | |
| Te-129 | 2.9E-18 | |
| Te-129m | 1.5E-18 | |
| I-129 | 2.6E-19 | |
| Cs-134 | 7.3E-17 | |
| Cs-135 | 1.2E-20 | |
| Cs-136 | 1.0E-16 | |
| Cs-137 | 5.2E-20 | |
| Ba-137m | 2.8E-17 | |
| Ba-140 | 1.2E-16 | The progeny nuclide La-140 is considered |
| Ce-141 | 2.9E-18 | |
| Ce-144 | 6.8E-19 | |
| Pr-144 | 2.2E-18 | |
| Pr-144m | 2.4E-19 | |
| Pm-146 | 3.4E-17 | |
| Pm-147 | 4.7E-21 | |
| Pm-148 | 2.9E-17 | |
| Pm-148m | 9.3E-17 | |
| Sm-151 | 3.1E-23 | |
| Eu-152 | 5.6E-17 | |
| Eu-154 | 6.1E-17 | |
| Eu-155 | 2.0E-18 | |
| Gd-153 | 2.8E-18 | |
| Tb-160 | 5.5E-17 | |
| Pu-238 | 3.3E-21 | |
| Pu-239 | 3.6E-21 | |
| Pu-240 | 3.2E-21 | |
| Pu-241 | 5.7E-23 | |
| Am-241 | 6.0E-19 | |
| Am-242m | 5.5E-19 | The progeny nuclide Am-242 is considered |
| Am-243 | 8.6E-18 | The progeny nuclide Np-239 is considered |
| Cm-242 | 3.8E-21 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|---------|
| Cm-243 | 5.0E-18 | |
| Cm-244 | 3.9E-21 | |

Table XI-2 Dose conversion factor for the effective dose from the radiation from hulls using FGR15

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ²)) | Remarks |
|---------|---|---|
| H-3 | 6.7E-22 | |
| C-14 | 6.1E-19 | |
| Mn-54 | 5.3E-16 | |
| Fe-59 | 7.3E-16 | |
| Co-58 | 6.2E-16 | |
| Co-60 | 1.5E-15 | |
| Ni-63 | 8.0E-20 | |
| Zn-65 | 3.6E-16 | |
| Rb-86 | 1.6E-16 | |
| Sr-89 | 8.9E-17 | |
| Sr-90 | 6.5E-18 | |
| Y-90 | 1.5E-16 | |
| Y-91 | 9.4E-17 | |
| Nb-95 | 4.9E-16 | |
| Tc-99 | 2.0E-18 | |
| Ru-103 | 3.2E-16 | |
| Ru-106 | 1.7E-20 | |
| Rh-103m | 4.3E-20 | |
| Rh-106 | 3.4E-16 | |
| Ag-110m | 1.7E-15 | |
| Cd-113m | 6.3E-18 | |
| Cd-115m | 1.1E-16 | |
| Sn-119m | 9.6E-19 | |
| Sn-123 | 8.1E-17 | |
| Sn-126 | 1.1E-15 | The progeny nuclide Sb-126m is considered |
| Sb-124 | 1.2E-15 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ²)) | Remarks |
|---------|---|--|
| Sb-125 | 2.7E-16 | |
| Te-123m | 7.7E-17 | |
| Te-125m | 4.1E-18 | |
| Te-127 | 1.5E-17 | |
| Te-127m | 1.7E-18 | |
| Te-129 | 1.1E-16 | |
| Te-129m | 5.1E-17 | |
| I-129 | 4.4E-18 | |
| Cs-134 | 1.0E-15 | |
| Cs-135 | 1.6E-18 | |
| Cs-136 | 1.3E-15 | |
| Cs-137 | 7.9E-18 | |
| Ba-137m | 3.9E-16 | |
| Ba-140 | 1.6E-15 | The progeny nuclide La-140 is considered |
| Ce-141 | 4.5E-17 | |
| Ce-144 | 1.1E-17 | |
| Pr-144 | 2.0E-16 | |
| Pr-144m | 3.5E-18 | |
| Pm-146 | 4.8E-16 | |
| Pm-147 | 9.4E-19 | |
| Pm-148 | 4.6E-16 | |
| Pm-148m | 1.3E-15 | |
| Sm-151 | 1.1E-19 | |
| Eu-152 | 7.2E-16 | |
| Eu-154 | 7.9E-16 | |
| Eu-155 | 3.1E-17 | |
| Gd-153 | 4.3E-17 | |
| Tb-160 | 7.1E-16 | |
| Pu-238 | 2.1E-20 | |
| Pu-239 | 4.2E-20 | |
| Pu-240 | 2.2E-20 | |
| Pu-241 | 1.7E-21 | |
| Am-241 | 9.9E-18 | |
| Am-242m | 1.4E-17 | The progeny nuclide Am-242 is considered |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ²)) | Remarks |
|---------|---|--|
| Am-243 | 1.3E-16 | The progeny nuclide Np-239 is considered |
| Cm-242 | 2.6E-20 | |
| Cm-243 | 7.1E-17 | |
| Cm-244 | 3.1E-20 | |

Table XI-3 Dose conversion factor for the effective dose from seawater during swimming and underwater work using FGR15

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|---------|
| H-3 | 6.2E-27 | |
| C-14 | 2.8E-21 | |
| Mn-54 | 8.0E-17 | |
| Fe-59 | 1.2E-16 | |
| Co-58 | 9.2E-17 | |
| Co-60 | 2.5E-16 | |
| Ni-63 | 7.8E-24 | |
| Zn-65 | 5.7E-17 | |
| Rb-86 | 9.8E-18 | |
| Sr-89 | 5.1E-19 | |
| Sr-90 | 1.1E-19 | |
| Y-90 | 9.5E-19 | |
| Y-91 | 8.4E-19 | |
| Nb-95 | 7.3E-17 | |
| Tc-99 | 3.1E-20 | |
| Ru-103 | 4.5E-17 | |
| Ru-106 | 5.7E-25 | |
| Rh-103m | 1.0E-20 | |
| Rh-106 | 2.1E-17 | |
| Ag-110m | 2.7E-16 | |
| Cd-113m | 1.0E-19 | |
| Cd-115m | 3.8E-18 | |
| Sn-119m | 1.7E-19 | |
| Sn-123 | 1.1E-18 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|---|
| Sn-126 | 1.5E-16 | The progeny nuclide Sb-126m is considered |
| Sb-124 | 1.9E-16 | |
| Sb-125 | 3.8E-17 | |
| Te-123m | 1.1E-17 | |
| Te-125m | 6.0E-19 | |
| Te-127 | 5.6E-19 | |
| Te-127m | 2.0E-19 | |
| Te-129 | 5.7E-18 | |
| Te-129m | 3.1E-18 | |
| I-129 | 5.1E-19 | |
| Cs-134 | 1.5E-16 | |
| Cs-135 | 2.3E-20 | |
| Cs-136 | 2.1E-16 | |
| Cs-137 | 1.0E-19 | |
| Ba-137m | 5.5E-17 | |
| Ba-140 | 2.5E-16 | The progeny nuclide La-140 is considered |
| Ce-141 | 5.8E-18 | |
| Ce-144 | 1.4E-18 | |
| Pr-144 | 4.3E-18 | |
| Pr-144m | 4.8E-19 | |
| Pm-146 | 6.8E-17 | |
| Pm-147 | 9.4E-21 | |
| Pm-148 | 5.8E-17 | |
| Pm-148m | 1.9E-16 | |
| Sm-151 | 6.1E-23 | |
| Eu-152 | 1.1E-16 | |
| Eu-154 | 1.2E-16 | |
| Eu-155 | 3.9E-18 | |
| Gd-153 | 5.6E-18 | |
| Tb-160 | 1.1E-16 | |
| Pu-238 | 6.6E-21 | |
| Pu-239 | 7.3E-21 | |
| Pu-240 | 6.5E-21 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|--|
| Pu-241 | 1.1E-22 | |
| Am-241 | 1.2E-18 | |
| Am-242m | 1.1E-18 | The progeny nuclide Am-242 is considered |
| Am-243 | 1.7E-17 | The progeny nuclide Np-239 is considered |
| Cm-242 | 7.5E-21 | |
| Cm-243 | 1.0E-17 | |
| Cm-244 | 7.9E-21 | |

Table XI-4 Dose conversion factor for the effective dose from the radiation from beach sand using FGR15

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|---------|
| H-3 | 3.4E-23 | |
| C-14 | 3.1E-20 | |
| Mn-54 | 2.6E-17 | |
| Fe-59 | 3.9E-17 | |
| Co-58 | 3.0E-17 | |
| Co-60 | 8.3E-17 | |
| Ni-63 | 4.1E-21 | |
| Zn-65 | 1.9E-17 | |
| Rb-86 | 4.4E-18 | |
| Sr-89 | 1.2E-18 | |
| Sr-90 | 2.6E-19 | |
| Y-90 | 2.3E-18 | |
| Y-91 | 1.4E-18 | |
| Nb-95 | 2.4E-17 | |
| Tc-99 | 1.0E-19 | |
| Ru-103 | 1.4E-17 | |
| Ru-106 | 8.6E-22 | |
| Rh-103m | 6.6E-22 | |
| Rh-106 | 1.0E-17 | |
| Ag-110m | 8.7E-17 | |
| Cd-113m | 2.5E-19 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|---|
| Cd-115m | 2.3E-18 | |
| Sn-119m | 1.2E-20 | |
| Sn-123 | 1.3E-18 | |
| Sn-126 | 4.8E-17 | The progeny nuclide Sb-126m is considered |
| Sb-124 | 6.1E-17 | |
| Sb-125 | 1.2E-17 | |
| Te-123m | 3.1E-18 | |
| Te-125m | 5.1E-20 | |
| Te-127 | 4.6E-19 | |
| Te-127m | 2.9E-20 | |
| Te-129 | 2.7E-18 | |
| Te-129m | 1.3E-18 | |
| I-129 | 7.9E-20 | |
| Cs-134 | 4.8E-17 | |
| Cs-135 | 8.4E-20 | |
| Cs-136 | 6.6E-17 | |
| Cs-137 | 2.6E-19 | |
| Ba-137m | 1.8E-17 | |
| Ba-140 | 8.3E-17 | The progeny nuclide La-140 is considered |
| Ce-141 | 1.8E-18 | |
| Ce-144 | 4.2E-19 | |
| Pr-144 | 4.2E-18 | |
| Pr-144m | 8.7E-20 | |
| Pm-146 | 2.2E-17 | |
| Pm-147 | 4.8E-20 | |
| Pm-148 | 2.0E-17 | |
| Pm-148m | 6.0E-17 | |
| Sm-151 | 5.5E-21 | |
| Eu-152 | 3.6E-17 | |
| Eu-154 | 3.9E-17 | |
| Eu-155 | 9.5E-19 | |
| Gd-153 | 1.2E-18 | |
| Tb-160 | 3.5E-17 | |
| Pu-238 | 5.3E-22 | |

| Nuclide | Dose conversion factor for the effective dose ((Sv/s)/(Bq/m ³)) | Remarks |
|---------|---|--|
| Pu-239 | 1.5E-21 | |
| Pu-240 | 5.5E-22 | |
| Pu-241 | 7.5E-23 | |
| Am-241 | 2.2E-19 | |
| Am-242m | 1.2E-18 | The progeny nuclide Am-242 is considered |
| Am-243 | 4.8E-18 | The progeny nuclide Np-239 is considered |
| Cm-242 | 5.9E-22 | |
| Cm-243 | 2.9E-18 | |
| Cm-244 | 1.0E-21 | |

XI-3. Exposure assessment result

Table XI-6 shows comparison with the assessment result of Table 6-1-22 in the results of the external exposure dose assessments of the following three cases.

Source term based on the composition of nuclides of the measured value

- i. K4 tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.29)
- ii. J1-C tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.35)
- iii. J1-G tank group (Sum of the ratios to regulatory concentration limits of 63 nuclides other than tritium: 0.22)

In all assessments, the result using the conversion factor in the Decommissioning Handbook was larger than those using the conversion factor in FGR15. In the assessment using the conversion factor of the Decommissioning Handbook, the assessment results are considered to be conservative because conservative conversion factors such as Co-60 were used for the nuclides for which conversion factors were not calculated.

Table XI-6 Comparison with the external exposure dose assessment result using the dose conversion factor of FGR15

| Source term | Source term based on measured values | | | | | |
|------------------------|--------------------------------------|---------|--------------------------|---------|--------------------------|---------|
| | i. K4 tank group | | ii. J1-C tank group | | iii. J1-G tank group | |
| Dose conversion factor | Decommissioning Handbook | FGR15 | Decommissioning Handbook | FGR15 | Decommissioning Handbook | FGR15 |
| Seawater surface | 6.5E-09 | 9.4E-10 | 1.7E-08 | 3.5E-10 | 4.7E-08 | 8.4E-10 |
| Hull | 4.8E-09 | 1.7E-09 | 1.2E-08 | 8.9E-10 | 3.3E-08 | 2.1E-09 |
| Swimming | 4.5E-09 | 4.6E-10 | 1.2E-08 | 1.7E-10 | 3.2E-08 | 4.1E-10 |
| Beach sand | 7.8E-06 | 1.4E-06 | 2.1E-05 | 5.7E-07 | 5.6E-05 | 1.4E-06 |


References

- [XI-1] EPA, FEDERAL GUIDANCE REPORT NO.15 "EXTERNAL EXPOSURE TO RADIONUCLIDES IN AIR, WATER AND SOIL",2019

Attachment XII Impact of the assessment range of concentrations in seawater used for the assessment of exposures

In the chapter 6-1-2. (4) "Setting of the representative person", for the concentration in the seawater used for the exposure assessment, the average concentration within 10 km x 10 km around the FDNPS is used considering the distance from the nearby fishing port (about 6 km) because fishing is assumed as the feature of the representative person. However, since the actual behaviors of the representative person is uncertain, we changed the assessment target range from 5 km x 5 km to 20 km in the north-south direction x 10 km in the east-west direction to calculate exposure.

The target range of the sea area is set to 5 km x 5 km and 20 km x 10 km around the power plant as shown in Figure XII-1.



*Areas where common fishery rights are not established

Figure XII-1 Assessment range to confirm the impact of the range of concentrations in seawater used for the assessment of exposures

XII-1. Assessment method

We performed the same assessment as 6-1. Exposure assessment under normal conditions and changed the calculation range of the average concentration of tritium only for the concentration in the seawater used for the assessment.

Table XII-1 shows the annual average concentration within 5 km × 5 km and 20 km × 10 km around the FDNPS in the case of the annual discharge amount of 22 TBq (2.2E+13Bq) of tritium. We compared the concentrations in 2014 and 2019 and decided to use the concentration of 2019, which is higher, for the exposure assessment.

Tables XII-2 to 4 show this result and the radioactive material concentration in the seawater for the assessment calculated from the annual discharge amount of each nuclide shown in Tables 6-1-1 to 6-1-3 used for the assessment in each term. Since the sandy beach assessment point was the same, the concentration in the seawater used for the assessment of exposure from swimming, ingestion of water, inhalation of seawater spray, and beach sand was set to the same regardless of the assessment target range.

Table XII-1 Tritium concentration in the seawater in the case of the annual tritium discharge amount of 2.2E+13Bq

| | Depth | Calculation result (Bq/L) | | | Concentration for assessment (Bq/L) |
|--|------------|---|---|----------------|-------------------------------------|
| | | Meteorological and oceanographic data of 2014 | Meteorological and oceanographic data of 2019 | Difference (%) | |
| Annual average concentration within 5 km × 5 km around the FDNPS | All layers | 1.5E-01 | 1.7E-01 | 13 | 1.7E-01 |
| | Top layer | 2.1E-01 | 2.4E-01 | 14 | 2.4E-01 |
| Annual average concentration within 20 km × 10 km around the FDNPS | All layers | 4.1E-02 | 4.8E-02 | 17 | 4.8E-02 |
| | Top layer | 8.8E-02 | 1.1E-01 | 25 | 1.1E-01 |

Table XII-2 Concentration in the seawater used for the assessment (Source term based on measured values (K4 tank group))

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------|---------------------------------|--|--|--|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| H-3 | 2.2E+13 | 1.7E-01 | 2.4E-01 | 4.8E-02 | 1.1E-01 |
| C-14 | 1.7E+09 | 1.3E-05 | 1.9E-05 | 3.8E-06 | 8.7E-06 |
| Mn-54 | 7.8E+05 | 6.0E-09 | 8.5E-09 | 1.7E-09 | 3.9E-09 |

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------|---------------------------------|--|--|--|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| Fe-59 | 2.0E+06 | 1.5E-08 | 2.1E-08 | 4.3E-09 | 9.8E-09 |
| Co-58 | 9.3E+05 | 7.2E-09 | 1.0E-08 | 2.0E-09 | 4.6E-09 |
| Co-60 | 5.1E+07 | 3.9E-07 | 5.6E-07 | 1.1E-07 | 2.5E-07 |
| Ni-63 | 2.5E+08 | 2.0E-06 | 2.8E-06 | 5.6E-07 | 1.3E-06 |
| Zn-65 | 1.7E+06 | 1.3E-08 | 1.9E-08 | 3.8E-09 | 8.7E-09 |
| Rb-86 | 2.2E+07 | 1.7E-07 | 2.4E-07 | 4.8E-08 | 1.1E-07 |
| Sr-89 | 1.2E+07 | 8.9E-08 | 1.3E-07 | 2.5E-08 | 5.8E-08 |
| Sr-90 | 2.5E+07 | 2.0E-07 | 2.8E-07 | 5.6E-08 | 1.3E-07 |
| Y-90 | 2.5E+07 | 2.0E-07 | 2.8E-07 | 5.6E-08 | 1.3E-07 |
| Y-91 | 2.5E+08 | 2.0E-06 | 2.8E-06 | 5.6E-07 | 1.3E-06 |
| Nb-95 | 1.2E+06 | 8.9E-09 | 1.3E-08 | 2.5E-09 | 5.8E-09 |
| Tc-99 | 8.1E+07 | 6.3E-07 | 8.8E-07 | 1.8E-07 | 4.1E-07 |
| Ru-103 | 1.2E+06 | 8.9E-09 | 1.3E-08 | 2.5E-09 | 5.8E-09 |
| Ru-106 | 1.9E+08 | 1.4E-06 | 2.0E-06 | 4.0E-07 | 9.3E-07 |
| Rh-103m | 1.2E+06 | 8.9E-09 | 1.3E-08 | 2.5E-09 | 5.8E-09 |
| Rh-106 | 1.9E+08 | 1.4E-06 | 2.0E-06 | 4.0E-07 | 9.3E-07 |
| Ag-110m | 6.5E+05 | 5.0E-09 | 7.1E-09 | 1.4E-09 | 3.2E-09 |
| Cd-113m | 2.1E+06 | 1.6E-08 | 2.3E-08 | 4.5E-09 | 1.0E-08 |
| Cd-115m | 7.4E+07 | 5.7E-07 | 8.1E-07 | 1.6E-07 | 3.7E-07 |
| Sn-119m | 2.0E+07 | 1.5E-07 | 2.1E-07 | 4.3E-08 | 9.8E-08 |
| Sn-123 | 1.4E+08 | 1.1E-06 | 1.5E-06 | 3.0E-07 | 6.9E-07 |
| Sn-126 | 3.1E+06 | 2.4E-08 | 3.4E-08 | 6.8E-09 | 1.6E-08 |
| Sb-124 | 1.1E+06 | 8.5E-09 | 1.2E-08 | 2.4E-09 | 5.5E-09 |
| Sb-125 | 3.8E+07 | 3.0E-07 | 4.2E-07 | 8.3E-08 | 1.9E-07 |
| Te-123m | 1.1E+06 | 8.2E-09 | 1.2E-08 | 2.3E-09 | 5.3E-09 |
| Te-125m | 3.8E+07 | 3.0E-07 | 4.2E-07 | 8.3E-08 | 1.9E-07 |
| Te-127 | 3.7E+07 | 2.9E-07 | 4.0E-07 | 8.1E-08 | 1.9E-07 |
| Te-127m | 3.7E+07 | 2.9E-07 | 4.0E-07 | 8.1E-08 | 1.9E-07 |
| Te-129 | 3.7E+07 | 2.9E-07 | 4.0E-07 | 8.1E-08 | 1.9E-07 |
| Te-129m | 3.7E+07 | 2.9E-07 | 4.0E-07 | 8.1E-08 | 1.9E-07 |
| I-129 | 2.4E+08 | 1.9E-06 | 2.7E-06 | 5.3E-07 | 1.2E-06 |
| Cs-134 | 5.2E+06 | 4.0E-08 | 5.7E-08 | 1.1E-08 | 2.6E-08 |

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------------------|---------------------------------|--|--|---|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| Cs-135 | 2.9E+02 | 2.2E-12 | 3.2E-12 | 6.3E-13 | 1.4E-12 |
| Cs-136 | 3.5E+06 | 2.7E-08 | 3.8E-08 | 7.6E-09 | 1.7E-08 |
| Cs-137 | 4.9E+07 | 3.8E-07 | 5.3E-07 | 1.1E-07 | 2.4E-07 |
| Ba-137m | 4.9E+07 | 3.8E-07 | 5.3E-07 | 1.1E-07 | 2.4E-07 |
| Ba-140 | 1.1E+07 | 8.5E-08 | 1.2E-07 | 2.4E-08 | 5.5E-08 |
| Ce-141 | 2.9E+06 | 2.2E-08 | 3.2E-08 | 6.3E-09 | 1.4E-08 |
| Ce-144 | 7.3E+06 | 5.6E-08 | 8.0E-08 | 1.6E-08 | 3.6E-08 |
| Pr-144 | 7.3E+06 | 5.6E-08 | 8.0E-08 | 1.6E-08 | 3.6E-08 |
| Pr-144m | 7.3E+06 | 5.6E-08 | 8.0E-08 | 1.6E-08 | 3.6E-08 |
| Pm-146 | 1.1E+07 | 8.8E-08 | 1.2E-07 | 2.5E-08 | 5.7E-08 |
| Pm-147 | 2.2E+07 | 1.7E-07 | 2.4E-07 | 4.8E-08 | 1.1E-07 |
| Pm-148 | 5.8E+07 | 4.5E-07 | 6.3E-07 | 1.3E-07 | 2.9E-07 |
| Pm-148m | 9.7E+05 | 7.5E-09 | 1.1E-08 | 2.1E-09 | 4.9E-09 |
| Sm-151 | 1.0E+05 | 8.1E-10 | 1.1E-09 | 2.3E-10 | 5.2E-10 |
| Eu-152 | 3.2E+06 | 2.5E-08 | 3.5E-08 | 7.1E-09 | 1.6E-08 |
| Eu-154 | 1.4E+06 | 1.1E-08 | 1.5E-08 | 3.0E-09 | 6.9E-09 |
| Eu-155 | 3.8E+06 | 3.0E-08 | 4.2E-08 | 8.3E-09 | 1.9E-08 |
| Gd-153 | 3.7E+06 | 2.9E-08 | 4.0E-08 | 8.1E-09 | 1.9E-08 |
| Tb-160 | 3.2E+06 | 2.5E-08 | 3.5E-08 | 7.1E-09 | 1.6E-08 |
| Pu-238 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Pu-239 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Pu-240 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Pu-241 | 3.2E+06 | 2.5E-08 | 3.5E-08 | 7.1E-09 | 1.6E-08 |
| Am-241 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Am-242m | 4.5E+03 | 3.5E-11 | 4.9E-11 | 9.9E-12 | 2.3E-11 |
| Am-243 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Cm-242 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Cm-243 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Cm-244 | 7.3E+04 | 5.6E-10 | 8.0E-10 | 1.6E-10 | 3.6E-10 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | From fishing nets Ingestion of seafood | From sea surface From hulls |

Table XII-3 Concentration in the seawater used for the assessment (Source term based on measured values (J1-C tank group))

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------|---------------------------------|--|--|--|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| H-3 | 2.2E+13 | 1.7E-01 | 2.4E-01 | 4.8E-02 | 1.1E-01 |
| C-14 | 4.8E+08 | 3.7E-06 | 5.3E-06 | 1.1E-06 | 2.4E-06 |
| Mn-54 | 1.0E+06 | 7.9E-09 | 1.1E-08 | 2.2E-09 | 5.1E-09 |
| Fe-59 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.1E-09 | 1.2E-08 |
| Co-58 | 1.1E+06 | 8.5E-09 | 1.2E-08 | 2.4E-09 | 5.5E-09 |
| Co-60 | 8.9E+06 | 6.8E-08 | 9.7E-08 | 1.9E-08 | 4.4E-08 |
| Ni-63 | 2.3E+08 | 1.8E-06 | 2.5E-06 | 5.0E-07 | 1.1E-06 |
| Zn-65 | 2.5E+06 | 1.9E-08 | 2.8E-08 | 5.5E-09 | 1.3E-08 |
| Rb-86 | 1.3E+07 | 1.0E-07 | 1.5E-07 | 2.9E-08 | 6.7E-08 |
| Sr-89 | 1.4E+06 | 1.1E-08 | 1.6E-08 | 3.2E-09 | 7.2E-09 |
| Sr-90 | 9.7E+05 | 7.5E-09 | 1.1E-08 | 2.1E-09 | 4.8E-09 |
| Y-90 | 9.7E+05 | 7.5E-09 | 1.1E-08 | 2.1E-09 | 4.8E-09 |
| Y-91 | 4.6E+08 | 3.5E-06 | 5.0E-06 | 1.0E-06 | 2.3E-06 |
| Nb-95 | 1.3E+06 | 1.0E-08 | 1.5E-08 | 2.9E-09 | 6.7E-09 |
| Tc-99 | 3.2E+07 | 2.5E-07 | 3.5E-07 | 7.0E-08 | 1.6E-07 |
| Ru-103 | 1.4E+06 | 1.1E-08 | 1.6E-08 | 3.1E-09 | 7.1E-09 |
| Ru-106 | 3.8E+07 | 2.9E-07 | 4.1E-07 | 8.2E-08 | 1.9E-07 |
| Rh-103m | 1.4E+06 | 1.1E-08 | 1.6E-08 | 3.1E-09 | 7.1E-09 |
| Rh-106 | 3.8E+07 | 2.9E-07 | 4.1E-07 | 8.2E-08 | 1.9E-07 |
| Ag-110m | 1.2E+06 | 8.9E-09 | 1.3E-08 | 2.5E-09 | 5.8E-09 |
| Cd-113m | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Cd-115m | 7.2E+07 | 5.6E-07 | 7.9E-07 | 1.6E-07 | 3.6E-07 |
| Sn-119m | 1.1E+09 | 8.7E-06 | 1.2E-05 | 2.5E-06 | 5.6E-06 |
| Sn-123 | 1.8E+08 | 1.4E-06 | 1.9E-06 | 3.9E-07 | 8.9E-07 |
| Sn-126 | 7.8E+06 | 6.0E-08 | 8.5E-08 | 1.7E-08 | 3.9E-08 |
| Sb-124 | 2.6E+06 | 2.0E-08 | 2.8E-08 | 5.7E-09 | 1.3E-08 |
| Sb-125 | 6.2E+06 | 4.8E-08 | 6.7E-08 | 1.3E-08 | 3.1E-08 |
| Te-123m | 2.5E+06 | 1.9E-08 | 2.7E-08 | 5.4E-09 | 1.2E-08 |
| Te-125m | 6.2E+06 | 4.8E-08 | 6.7E-08 | 1.3E-08 | 3.1E-08 |
| Te-127 | 1.3E+08 | 9.7E-07 | 1.4E-06 | 2.8E-07 | 6.3E-07 |

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------|---------------------------------|--|--|--|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| Te-127m | 1.3E+08 | 1.0E-06 | 1.4E-06 | 2.9E-07 | 6.6E-07 |
| Te-129 | 3.8E+07 | 2.9E-07 | 4.1E-07 | 8.2E-08 | 1.9E-07 |
| Te-129m | 3.8E+07 | 2.9E-07 | 4.1E-07 | 8.2E-08 | 1.9E-07 |
| I-129 | 3.2E+07 | 2.5E-07 | 3.5E-07 | 7.0E-08 | 1.6E-07 |
| Cs-134 | 2.0E+06 | 1.6E-08 | 2.2E-08 | 4.4E-09 | 1.0E-08 |
| Cs-135 | 3.2E+01 | 2.5E-13 | 3.5E-13 | 7.0E-14 | 1.6E-13 |
| Cs-136 | 1.3E+06 | 9.7E-09 | 1.4E-08 | 2.8E-09 | 6.3E-09 |
| Cs-137 | 5.1E+06 | 3.9E-08 | 5.6E-08 | 1.1E-08 | 2.5E-08 |
| Ba-137m | 5.1E+06 | 3.9E-08 | 5.6E-08 | 1.1E-08 | 2.5E-08 |
| Ba-140 | 5.4E+06 | 4.1E-08 | 5.9E-08 | 1.2E-08 | 2.7E-08 |
| Ce-141 | 7.0E+06 | 5.4E-08 | 7.6E-08 | 1.5E-08 | 3.5E-08 |
| Ce-144 | 1.5E+07 | 1.2E-07 | 1.7E-07 | 3.3E-08 | 7.6E-08 |
| Pr-144 | 1.5E+07 | 1.2E-07 | 1.7E-07 | 3.3E-08 | 7.6E-08 |
| Pr-144m | 1.5E+07 | 1.2E-07 | 1.7E-07 | 3.3E-08 | 7.6E-08 |
| Pm-146 | 1.8E+06 | 1.4E-08 | 2.0E-08 | 3.9E-09 | 9.0E-09 |
| Pm-147 | 2.1E+07 | 1.7E-07 | 2.3E-07 | 4.7E-08 | 1.1E-07 |
| Pm-148 | 6.2E+06 | 4.8E-08 | 6.7E-08 | 1.3E-08 | 3.1E-08 |
| Pm-148m | 1.3E+06 | 1.0E-08 | 1.4E-08 | 2.8E-09 | 6.4E-09 |
| Sm-151 | 3.0E+05 | 2.3E-09 | 3.2E-09 | 6.4E-10 | 1.5E-09 |
| Eu-152 | 7.5E+06 | 5.8E-08 | 8.2E-08 | 1.6E-08 | 3.8E-08 |
| Eu-154 | 3.0E+06 | 2.3E-08 | 3.2E-08 | 6.4E-09 | 1.5E-08 |
| Eu-155 | 9.1E+06 | 7.0E-08 | 1.0E-07 | 2.0E-08 | 4.6E-08 |
| Gd-153 | 7.0E+06 | 5.4E-08 | 7.6E-08 | 1.5E-08 | 3.5E-08 |
| Tb-160 | 3.8E+06 | 2.9E-08 | 4.1E-08 | 8.2E-09 | 1.9E-08 |
| Pu-238 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |
| Pu-239 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |
| Pu-240 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |
| Pu-241 | 3.2E+07 | 2.5E-07 | 3.5E-07 | 7.0E-08 | 1.6E-07 |
| Am-241 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |
| Am-242m | 1.6E+04 | 1.2E-10 | 1.7E-10 | 3.5E-11 | 7.9E-11 |
| Am-243 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |
| Cm-242 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------------------|---------------------------------|--|--|---|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| Cm-243 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |
| Cm-244 | 8.9E+05 | 6.8E-09 | 9.7E-09 | 1.9E-09 | 4.4E-09 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | From fishing nets Ingestion of seafood | From sea surface From hulls |

Table XII-4 Concentration in the seawater used for the assessment (Source term based on measured value (J1-G tank group))

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------|---------------------------------|--|--|--|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| H-3 | 2.2E+13 | 1.7E-01 | 2.4E-01 | 4.8E-02 | 1.1E-01 |
| C-14 | 1.3E+09 | 1.0E-05 | 1.4E-05 | 2.8E-06 | 6.5E-06 |
| Mn-54 | 3.1E+06 | 2.4E-08 | 3.4E-08 | 6.8E-09 | 1.5E-08 |
| Fe-59 | 5.9E+06 | 4.5E-08 | 6.4E-08 | 1.3E-08 | 2.9E-08 |
| Co-58 | 3.0E+06 | 2.3E-08 | 3.3E-08 | 6.6E-09 | 1.5E-08 |
| Co-60 | 1.9E+07 | 1.4E-07 | 2.0E-07 | 4.1E-08 | 9.4E-08 |
| Ni-63 | 7.2E+08 | 5.5E-06 | 7.8E-06 | 1.6E-06 | 3.6E-06 |
| Zn-65 | 6.5E+06 | 5.0E-08 | 7.1E-08 | 1.4E-08 | 3.3E-08 |
| Rb-86 | 3.8E+07 | 3.0E-07 | 4.2E-07 | 8.4E-08 | 1.9E-07 |
| Sr-89 | 3.7E+06 | 2.8E-08 | 4.0E-08 | 8.0E-09 | 1.8E-08 |
| Sr-90 | 2.6E+06 | 2.0E-08 | 2.8E-08 | 5.7E-09 | 1.3E-08 |
| Y-90 | 2.6E+06 | 2.0E-08 | 2.8E-08 | 5.7E-09 | 1.3E-08 |
| Y-91 | 9.8E+08 | 7.6E-06 | 1.1E-05 | 2.1E-06 | 4.9E-06 |
| Nb-95 | 3.8E+06 | 3.0E-08 | 4.2E-08 | 8.4E-09 | 1.9E-08 |
| Tc-99 | 1.1E+08 | 8.2E-07 | 1.2E-06 | 2.3E-07 | 5.3E-07 |
| Ru-103 | 4.2E+06 | 3.2E-08 | 4.5E-08 | 9.1E-09 | 2.1E-08 |
| Ru-106 | 3.9E+07 | 3.0E-07 | 4.3E-07 | 8.5E-08 | 2.0E-07 |
| Rh-103m | 4.2E+06 | 3.2E-08 | 4.5E-08 | 9.1E-09 | 2.1E-08 |
| Rh-106 | 3.9E+07 | 3.0E-07 | 4.3E-07 | 8.5E-08 | 2.0E-07 |
| Ag-110m | 3.3E+06 | 2.5E-08 | 3.6E-08 | 7.1E-09 | 1.6E-08 |
| Cd-113m | 7.0E+06 | 5.4E-08 | 7.6E-08 | 1.5E-08 | 3.5E-08 |

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------|---------------------------------|--|--|--|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| Cd-115m | 1.9E+08 | 1.4E-06 | 2.0E-06 | 4.1E-07 | 9.4E-07 |
| Sn-119m | 3.3E+09 | 2.5E-05 | 3.6E-05 | 7.1E-06 | 1.6E-05 |
| Sn-123 | 5.1E+08 | 4.0E-06 | 5.6E-06 | 1.1E-06 | 2.6E-06 |
| Sn-126 | 1.2E+07 | 9.4E-08 | 1.3E-07 | 2.7E-08 | 6.1E-08 |
| Sb-124 | 6.8E+06 | 5.3E-08 | 7.5E-08 | 1.5E-08 | 3.4E-08 |
| Sb-125 | 1.1E+07 | 8.8E-08 | 1.2E-07 | 2.5E-08 | 5.7E-08 |
| Te-123m | 5.5E+06 | 4.2E-08 | 6.0E-08 | 1.2E-08 | 2.7E-08 |
| Te-125m | 1.1E+07 | 8.8E-08 | 1.2E-07 | 2.5E-08 | 5.7E-08 |
| Te-127 | 3.5E+08 | 2.7E-06 | 3.8E-06 | 7.6E-07 | 1.8E-06 |
| Te-127m | 3.7E+08 | 2.8E-06 | 4.0E-06 | 8.0E-07 | 1.8E-06 |
| Te-129 | 9.8E+07 | 7.6E-07 | 1.1E-06 | 2.1E-07 | 4.9E-07 |
| Te-129m | 9.8E+07 | 7.6E-07 | 1.1E-06 | 2.1E-07 | 4.9E-07 |
| I-129 | 2.7E+07 | 2.1E-07 | 2.9E-07 | 5.9E-08 | 1.3E-07 |
| Cs-134 | 5.5E+06 | 4.2E-08 | 6.0E-08 | 1.2E-08 | 2.7E-08 |
| Cs-135 | 1.7E+02 | 1.3E-12 | 1.9E-12 | 3.7E-13 | 8.6E-13 |
| Cs-136 | 2.9E+06 | 2.3E-08 | 3.2E-08 | 6.4E-09 | 1.5E-08 |
| Cs-137 | 2.7E+07 | 2.1E-07 | 2.9E-07 | 5.9E-08 | 1.3E-07 |
| Ba-137m | 2.7E+07 | 2.1E-07 | 2.9E-07 | 5.9E-08 | 1.3E-07 |
| Ba-140 | 1.4E+07 | 1.1E-07 | 1.5E-07 | 3.0E-08 | 6.9E-08 |
| Ce-141 | 9.8E+06 | 7.6E-08 | 1.1E-07 | 2.1E-08 | 4.9E-08 |
| Ce-144 | 4.5E+07 | 3.5E-07 | 4.9E-07 | 9.8E-08 | 2.2E-07 |
| Pr-144 | 4.5E+07 | 3.5E-07 | 4.9E-07 | 9.8E-08 | 2.2E-07 |
| Pr-144m | 4.5E+07 | 3.5E-07 | 4.9E-07 | 9.8E-08 | 2.2E-07 |
| Pm-146 | 5.1E+06 | 4.0E-08 | 5.6E-08 | 1.1E-08 | 2.6E-08 |
| Pm-147 | 5.9E+07 | 4.5E-07 | 6.4E-07 | 1.3E-07 | 2.9E-07 |
| Pm-148 | 3.7E+07 | 2.8E-07 | 4.0E-07 | 8.0E-08 | 1.8E-07 |
| Pm-148m | 3.3E+06 | 2.6E-08 | 3.6E-08 | 7.3E-09 | 1.7E-08 |
| Sm-151 | 8.1E+05 | 6.3E-09 | 8.9E-09 | 1.8E-09 | 4.1E-09 |
| Eu-152 | 1.5E+07 | 1.2E-07 | 1.7E-07 | 3.4E-08 | 7.7E-08 |
| Eu-154 | 8.1E+06 | 6.3E-08 | 8.9E-08 | 1.8E-08 | 4.1E-08 |
| Eu-155 | 1.5E+07 | 1.1E-07 | 1.6E-07 | 3.2E-08 | 7.3E-08 |
| Gd-153 | 1.5E+07 | 1.2E-07 | 1.7E-07 | 3.4E-08 | 7.7E-08 |

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | | |
|----------------------------|---------------------------------|--|--|---|--|
| | | Average of all layers within 5km×5km | Average of the top layers within 5km×5km | Average of all layers within 20km×10km | Average of the top layers within 20km×10km |
| Tb-160 | 1.1E+07 | 8.8E-08 | 1.2E-07 | 2.5E-08 | 5.7E-08 |
| Pu-238 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Pu-239 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Pu-240 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Pu-241 | 8.1E+07 | 6.3E-07 | 8.9E-07 | 1.8E-07 | 4.1E-07 |
| Am-241 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Am-242m | 4.2E+04 | 3.2E-10 | 4.5E-10 | 9.1E-11 | 2.1E-10 |
| Am-243 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Cm-242 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Cm-243 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Cm-244 | 2.3E+06 | 1.8E-08 | 2.5E-08 | 5.0E-09 | 1.1E-08 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | From fishing nets Ingestion of seafood | From sea surface From hulls |

XII-2. Assessment results

Tables XII-5 to 10 show the assessment results. The assessment result with the assessment area set to 10 km × 10 km was 0.00003 (3E-05) to 0.0004 (4E-04) mSv/year while that of 5 km × 5 km was 0.00006 (6E-05) to 0.001 (1E-03) mSv/ year, which is two to three times higher.

Moreover, when the assessment area is set to 20 km × 10 km, the result is 0.00002 (2E-05) to 0.0003 (3E-04) mSv/year, which is slightly lower than that of 10 km × 10 km.

In all cases, the results remained significantly smaller than the dose limit of 1 mSv/year for the general public and the dose target of 0.05 mSv/year for domestic nuclear power plants, which is equivalent to the dose constraint value.

In addition, for infants whose effective dose factor and the assessment value of internal exposure are high, the assessment result of internal exposure from ingestion of seafood is 0.000087 (8.7E-05) to 0.0022 (2.2E-03) mSv/year with the assessment area set to 5 km × 5 km, which is about 3 times higher than 0.000029 (2.9E-05) to 0.00071 (7.1E-04) mSv/year with 10 km × 10 km.

Moreover, when the assessment area is set to 20 km × 10 km, the result is 0.000025 (2.5E-05) to 0.00061 (6.1E-04) mSv/year, which is lower than that of 10 km × 10 km.

Table XII-5 Human exposure assessment result (Source term based on measured values (K4 tank group))

| Assessed case | Assessment area of the concentration | 10 km × 10 km | | 5 km × 5 km | | 20 km × 10 km | |
|------------------------------|--------------------------------------|---------------|---------|-------------|---------|---------------|---------|
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| External exposure (mSv/year) | Sea surface | 6.5E-09 | | 1.3E-08 | | 6.0E-09 | |
| | Hull | 4.8E-09 | | 9.5E-09 | | 4.4E-09 | |
| | During swimming | 4.5E-09 | | 4.5E-09 | | 4.5E-09 | |
| | Beach sand | 7.8E-06 | | 7.8E-06 | | 7.8E-06 | |
| | Fishing net | 1.6E-06 | | 4.9E-06 | | 1.4E-06 | |
| Internal exposure (mSv/year) | Ingestion of water | 3.3E-07 | | 3.3E-07 | | 3.3E-07 | |
| | Inhalation of spray | 9.3E-08 | | 9.3E-08 | | 9.3E-08 | |
| | Ingestion of seafood | 1.5E-05 | 6.1E-05 | 4.6E-05 | 1.9E-04 | 1.3E-05 | 5.2E-05 |
| Total (mSv/year) | | 3E-05 | 7E-05 | 6E-05 | 2E-04 | 2E-05 | 6E-05 |

Table XII-6 Human exposure assessment result (Source term based on measured values (J1-C tank group))

| Assessed case | Assessment range of the concentration | 10 km × 10 km | | 5 km × 5 km | | 20 km × 10 km | |
|------------------------------|---------------------------------------|---------------|---------|-------------|---------|---------------|---------|
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| External exposure (mSv/year) | Sea surface | 1.7E-08 | | 3.5E-08 | | 1.6E-08 | |
| | Hull | 1.2E-08 | | 2.5E-08 | | 1.1E-08 | |
| | During swimming | 1.2E-08 | | 1.2E-08 | | 1.2E-08 | |
| | Beach sand | 2.1E-05 | | 2.1E-05 | | 2.1E-05 | |
| | Fishing net | 4.3E-06 | | 1.3E-05 | | 3.7E-06 | |
| Internal exposure (mSv/year) | Ingestion of water | 3.1E-07 | | 3.1E-07 | | 3.1E-07 | |
| | Inhalation of spray | 2.0E-07 | | 2.0E-07 | | 2.0E-07 | |
| | Ingestion of seafood | 2.8E-05 | 1.1E-04 | 8.5E-05 | 3.2E-04 | 2.4E-05 | 9.2E-05 |
| Total (mSv/year) | | 5E-05 | 1E-04 | 1E-04 | 4E-04 | 5E-05 | 1E-04 |

Table XII-7 Human exposure assessment result (Source term based on measured values (J1-G tank group))

| Assessed case | Assessment range of the concentration | 10 km × 10 km | | 5 km × 5 km | | 20 km × 10 km | |
|------------------------------|---------------------------------------|---------------|---------|-------------|---------|---------------|---------|
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| External exposure (mSv/year) | Sea surface | 4.7E-08 | | 9.4E-08 | | 4.3E-08 | |
| | Hull | 3.3E-08 | | 6.6E-08 | | 3.0E-08 | |
| | During swimming | 3.2E-08 | | 3.2E-08 | | 3.2E-08 | |
| | Beach sand | 5.6E-05 | | 5.6E-05 | | 5.6E-05 | |
| | Fishing net | 1.2E-05 | | 3.5E-05 | | 9.9E-06 | |
| Internal exposure (mSv/year) | Ingestion of water | 3.2E-07 | | 3.2E-07 | | 3.2E-07 | |
| | Inhalation of spray | 4.0E-07 | | 4.0E-07 | | 4.0E-07 | |
| | Ingestion of seafood | 7.9E-05 | 3.0E-04 | 2.4E-04 | 9.1E-04 | 6.7E-05 | 2.6E-04 |
| Total (mSv/year) | | 1E-04 | 4E-04 | 3E-04 | 1E-03 | 1E-04 | 3E-04 |

Table XII-8 Age-specific internal exposure assessment result (Source term based on measured values (K4 tank group))

| Assessed case | Assessment range of the concentration | 10 km × 10 km | | 5 km × 5 km | | 20 km × 10 km | |
|--|---------------------------------------|---------------|---------|-------------|---------|---------------|---------|
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| Internal exposure from ingestion of water (mSv/year) | Adult | 3.3E-07 | | 3.3E-07 | | 3.3E-07 | |
| | Child under school age | 5.7E-07 | | 5.7E-07 | | 5.7E-07 | |
| | Infant | - | | - | | - | |
| Internal exposure from inhalation of spray (mSv/year) | Adult | 9.3E-08 | | 9.3E-08 | | 9.3E-08 | |
| | Child under school age | 6.2E-08 | | 6.2E-08 | | 6.2E-08 | |
| | Infant | 4.0E-08 | | 4.0E-08 | | 4.0E-08 | |
| Internal exposure from ingestion of seafood (mSv/year) | Adult | 1.5E-05 | 6.1E-05 | 4.6E-05 | 1.9E-04 | 1.3E-05 | 5.2E-05 |
| | Child under school age | 2.4E-05 | 9.4E-05 | 7.2E-05 | 2.9E-04 | 2.0E-05 | 8.1E-05 |
| | Infants | 2.9E-05 | 1.1E-04 | 8.7E-05 | 3.3E-04 | 2.5E-05 | 9.3E-05 |

Table XII-9 Age-specific internal exposure assessment result (Source term based on measured values (J1-C tank group))

| Assessed case | Assessment range of the concentration | 10 km × 10 km | | 5 km × 5 km | | 20 km × 10 km | |
|--|---------------------------------------|---------------|---------|-------------|---------|---------------|---------|
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| Internal exposure from ingestion of water (mSv/year) | Adult | 3.1E-07 | | 3.1E-07 | | 3.1E-07 | |
| | Child under school age | 5.4E-07 | | 5.4E-07 | | 5.4E-07 | |
| | Infant | - | | - | | - | |
| Internal exposure from inhalation of spray (mSv/year) | Adult | 2.0E-07 | | 2.0E-07 | | 2.0E-07 | |
| | Child under school age | 1.1E-07 | | 1.1E-07 | | 1.1E-07 | |
| | Infant | 6.5E-08 | | 6.5E-08 | | 6.5E-08 | |
| Internal exposure from ingestion of seafood (mSv/year) | Adult | 2.8E-05 | 1.1E-04 | 8.5E-05 | 3.2E-04 | 2.4E-05 | 9.2E-05 |
| | Child under school age | 5.1E-05 | 2.0E-04 | 1.6E-04 | 6.0E-04 | 4.4E-05 | 1.7E-04 |
| | Infant | 6.7E-05 | 2.5E-04 | 2.0E-04 | 7.6E-04 | 5.7E-05 | 2.2E-04 |

Table XII-10 Age-specific internal exposure assessment result (Source term based on measured values (J1-G tank group))

| Assessed case | Assessment range of the concentration | 10 km × 10 km | | 5 km × 5 km | | 20 km × 10 km | |
|--|---------------------------------------|---------------|---------|-------------|---------|---------------|---------|
| | Ingestion of seafood | Average | Large | Average | Large | Average | Large |
| Internal exposure from ingestion of water (mSv/year) | Adult | 3.2E-07 | | 3.2E-07 | | 3.2E-07 | |
| | Child under school age | 5.5E-07 | | 5.5E-07 | | 5.5E-07 | |
| | Infant | - | | - | | - | |
| Internal exposure from inhalation of spray (mSv/year) | Adult | 4.0E-07 | | 4.0E-07 | | 4.0E-07 | |
| | Child under school age | 2.2E-07 | | 2.2E-07 | | 2.2E-07 | |
| | Infant | 1.2E-07 | | 1.2E-07 | | 1.2E-07 | |
| Internal exposure from ingestion of seafood (mSv/year) | Adult | 7.9E-05 | 3.0E-04 | 2.4E-04 | 9.1E-04 | 6.7E-05 | 2.6E-04 |
| | Child under school age | 1.5E-04 | 5.6E-04 | 4.4E-04 | 1.7E-03 | 1.2E-04 | 4.8E-04 |
| | Infant | 1.9E-04 | 7.1E-04 | 5.8E-04 | 2.2E-03 | 1.6E-04 | 6.1E-04 |

Reference A Site boundary dose assessment of Fukushima Daiichi Nuclear Power Station and the regulatory concentration limit in the Japanese laws

In the Fukushima Daiichi Nuclear Power Station, which is a specific nuclear facility, it is required to take appropriate inhibition measures for radioactive materials discharged to the environment including air, sea, etc., to reduce the dose around the site as much as possible, and make the effective dose on the site boundary from debris, contaminated water, etc., generated and stored in the facility after the accident (assessment value of the effective dose including additional discharge of radioactive materials from the entire facility) less than 1 mSv/year.

In addition, to dispose of liquid waste including radioactive materials, it is required to reduce the concentration of radioactive materials in wastewater as much as possible by filtration, evaporation, adsorption by the ion exchange resin method, etc., attenuation of radioactivity over time, dilution with a large amount of water, etc., at the wastewater facility, and keep the concentration of radioactive materials in wastewater below the concentration limit set by the Nuclear Regulation Authority at drains and the wastewater surveillance facility.

In accordance with “public notice that stipulates the required matters regarding the safety of TEPCO Fukushima Daiichi Nuclear Power Station reactor facilities and the protection of specified nuclear fuel materials”, the concentration limit set by the Nuclear Regulation Authority is defined as the concentration set by Appended table 1 “Pronouncement which set the dose limit based on the regulations such as the Regulations on Business of Smelting of Nuclear Source Materials or Nuclear Fuel Materials”, if only one type of a radioactive material is contained and the type of the radioactive material is identified. This concentration is called “regulatory concentration limit.”

This concentration is set so that the average dose from internal exposure of adults drinking 2L of the water every day for 70 years will be 1 mSv/year. In other words, the laws set a limit so that even if a person drinks water directly from a drain, the average dose of 70 years will not exceed 1 mSv/year.

For example, the limits for tritium and Cs-137 are 60Bq/cm³ (60,000Bq/L) and 0.09 Bq/cm³ (90Bq/L), respectively. Therefore, if a person drinks 2L of water containing 60,000Bq/L of tritium alone or 90Bq/L of Cs-137 alone every day for 70 years, the average exposure of 70 years will be 1 mSv/year.

On the other hand, if liquid waste containing two or more types of radioactive materials is disposed of and a person drinks 2L of water containing the nuclides each of which reaches the regulatory concentration limit (e.g. water containing 60,000Bq/L of tritium and 90Bq/L of Cs-137) every day for 70 years, the exposure from each nuclide alone will reach 1 mSv/year, 2 mSv/year in total, thereby the overall exposure exceeding 1 mSv/year. Therefore, to not exceed 1 mSv/year, the regulatory concentration limits of nuclides are set in a way that the sum of their ratios does not exceed 1. In other words, it is set in a way that R_n in the following equation does not exceed 1.

$$R_n = \sum_{i=1}^n \frac{C_{i,measured}}{C_{i,limit}}$$

where

- R_n Sum of the ratios to regulatory concentrations limits (dimensionless)
- $C_{i, measured}$ Concentration of nuclide i in liquid waste to be discharged (Bq/cm³)
- $C_{i, limit}$ Regulatory concentration limit of nuclide i (Bq/cm³)
- n Number of types of nuclides contained in liquid waste to be discharged

For discharge of ALPS treated water into the sea we are currently planning, the following conditions are to be verified:

- (1) The sum of the ratios to regulatory concentrations limits of 63 nuclides excluding tritium falls below 1 in the facility for measurement and confirmation before dilution with seawater;
- (2) The sum of the ratios to regulatory concentrations limits of 64 nuclides excluding tritium falls below 1 in the discharge vertical shaft after dilution with seawater.

In (2), the water shall be diluted with seawater 100 or more times so that the tritium concentration falls below 1,500Bq/L. If the tritium concentration can be diluted by 100 times up to 1,500Bq/L, the sum of the ratios to regulatory concentrations limits of radioactive materials at the discharge vertical shaft will be up to

$$\begin{aligned} & \text{(Sum of the ratios to regulatory concentrations limits of 63 nuclides) + (Regulatory} \\ & \quad \text{concentration ratio of tritium)} \\ & = \frac{R_{(1),63}}{100} + \frac{1,500}{60,000} = \frac{1}{100} + \frac{1}{40} = 0.035 \end{aligned}$$

because the sum of the ratios to regulatory concentrations limits of other than tritium before dilution is managed to be less than 1 in (1) and the concentration of tritium is 1,500Bq/L. Among the dose assessments on the site boundary mentioned at the beginning, the assessment of the contribution of the wastewater of liquid waste is also calculated according to this concept. If the sum of the ratios to regulatory concentrations limits is exactly 1, exposure of this discharge of ALPS treated water into the sea is assessed to be less than 0.035 mSv/ in this assessment method because the exposure dose on the site boundary (drain) is assessed to be 1 mSv/year.

Reference B Timeline of consideration of each disposal method of ALPS treated water

B1. Timeline of consideration

At the Committee on Countermeasures for Contaminated Water Treatment¹ on December 10, 2013, the risks associated with storage of water treated (hereinafter called “ALPS treated water”) with the advanced liquid processing system (hereinafter called “ALPS”), etc. at the TEPCO Fukushima Daiichi Nuclear Power Station (hereinafter called “FDNPS”) were clarified. On December 4, 2013, the review team of the International Atomic Energy Agency (hereinafter called “IAEA”) advised to “examine all options” for handling of ALPS treated water.

Therefore, the government extracted all options from the neutral viewpoint as the basic material for the determination of long-term treatment of ALPS treated water, as well as set up the Tritiated Water Taskforce (hereinafter called “the Taskforce”) under the Committee on Countermeasures for Contaminated Water Treatment for the purpose of the technical assessment of each option (not for harmonizing views among stakeholders or unifying options) and has been proceeding with technical consideration for 2 years and 5 months. After that, the government established the Subcommittee on Handling of the ALPS Treated Water (hereinafter called “the Subcommittee”) under the Committee on Countermeasures for Contaminated Water Treatment and have conducted comprehensive consideration for 38 months from the professional perspective, in terms of international best practices, options with the least adverse impact on human health and the environment, social impacts such as reputation damage, and technical feasibility in accordance with the knowledge summarized in the Taskforce report.

(1) Overview of consideration by the Taskforce

The Taskforce took place a total of 15 times from December 25, 2013 to May 27, 2016, with the participation of the Nuclear Regulation Authority and related ministries and agencies, in addition to nine members who are experts in the fields of nuclear energy, environmental science, radiation medicine, radiation biology, and fishery chemistry.

The Taskforce organized the basic knowledge as such on tritium regarding its property, dynamics in the atmospheric/geosphere/marine environment, and impacts on the environment and human body (radiation dose, biological concentration, in vivo half-life,

¹ Committee set up under the ministerial meeting on measures for decommissioning/ contaminated water/ treated water. This committee was set up to totally examine the contaminated treatment measures of Fukushima Daiichi and consider the measures to radically solve the problems and to handle leakage accidents of contaminated water including tritium treatment measures.

etc.)^{2 3 4}, set the assessment cases based on the uniformed handling conditions for parallel comparison of 11 options combining five methods (geosphere injection, discharge into the sea, vapor release, hydrogen release, and underground burial) with the presence or absence of pretreatment such as dilution or isotope separation considering foreign cases, etc., and performed technical assessments.

For technical assessments, technical feasibility and regulatory feasibility were set as the basic requirements (items used as criteria to judge feasibility). As conditions which may be constraints on selection, the following evaluation items were set: time and cost required for disposal, scale (area required for disposal), whether any secondary waste is generated/its type and amount, the occurrence of excessive worker exposure from the disposal, and incidental conditions (other conditions which may be constraints).

(2) Overview of consideration by the Subcommittee

The Subcommittee met a total 17 times from November 11, 2016 to January 31, 2020, with the participations of 13 experts in the fields of nuclear power, geotechnical engineering, sociology, environmental science, agriculture, radiobiology, radiation science, and fishery chemistry, and related ministries. The Subcommittee had further discussions about the impact of tritium on organisms^{5 6} as well as comprehensively

² Regarding the environment dynamics of tritium, it was reported that tritium discharged into air exhibited such behaviors such as turbulent dispersion in air, dry or wet deposition on the ground surface, underground advection and diffusion, and evaporation from the ground surface; that a simple assessment is difficult due to a big variation in the dispersion state depending on the weather conditions at the time of discharge; and that the concentration is reduced as it gets away from the location of discharge though it depends on the discharge method and discharge position (Summary of an explanation by Mr. Haruyasu Nagai at the 4th Taskforce, Pages 1 to 9 of the minutes).

³ As for the environmental impact of tritium, it was explained that there were two types of tritium in organic substances, namely free water tritium (hereinafter called "FWT") and organically bound tritium (hereinafter called "OBT"), OBT was easy to be absorbed by organisms and has long biological half-life, the in vivo FWT concentration and water tritium concentration counterweighed (becomes almost equal) immediately in the aquatic environment, the concentration factor of tritium (ratio of the in vivo concentration to the water concentration) is 1 or less, dose assessments of marine organisms were performed for "reference animals" (e.g. marine organisms with different shapes such as flatfish and crab), generally the calculation was performed from the radioactive material concentration (Bq/kg - raw organism), and there would be no significant impact on aquatic habitat unless an extremely high concentration of tritium is retained in the aquatic environment (Summary of an explanation by the Taskforce Member Mr. Hideki Kakiuchi at the 3rd meeting of the Taskforce, pp.2-10 of the minutes, Summary of an explanation by the Taskforce Member Takami Morita in the 3rd Taskforce, Pages 14 to 18 of the minutes).

⁴ As for the impact of tritium on human bodies, it was explained that the impact of tritium on human bodies was much smaller than that of radioactive cesium set as the standard of radioactive materials in foods, about 1/1,000; tritium caused almost no external exposure, and internal exposure would be considered because it is radionuclide with low-energy beta rays; and tritium exists in two forms, namely FWT and OBT, in organisms and, according to ICRP (International Commission on Radiological Protection), the in vivo half-lives of FWT and OBT were about 10 days and 40 days, respectively (Summary of an explanation by the Taskforce Member Mr. Hideki Kakiuchi in the 3rd Taskforce, Pages 2 to 10 of the minutes; Summary of an explanation by the Taskforce Member Mr. Hideo Tatsuzaki at the 3rd Taskforce, Pages 21 to 25 of the minutes; Summary of an explanation by the Taskforce Member Mr. Hiroshi Tauchi at the 3rd Taskforce, Pages 26 to 33 of the minutes).

⁵ It was explained that tritium just emits weak beta rays, the only exposure form with significant impact was internal exposure, it is said that there was almost no in-vivo concentration as characteristics, and it was passed out of the human body by metabolism about 10 days after entering the body since it was a kind of water (Summary of a statement by the Subcommittee Member Yamanishi at the 2nd Subcommittee, Page 34 of the minutes).

⁶ It was explained that tritium was not concentrated on specific organisms or organs because molecules containing tritium had

considered the expansion of the tank storage capacity, the possibility to continue tank storage, etc., in addition to the technical viewpoints of the disposal methods and the advantages and disadvantages of the disposal methods taking into consideration the social and environmental impacts of disposal for each of the five disposal methods of ALPS treated water.

The proceedings of the meetings were open to the public, and those who applied and were registered in advance were able to listen to the proceedings at the venue as observers. All of the contents and materials from the discussion of each meeting are available on the website of METI⁷. The following shows the details of consideration at the Taskforce and the Subcommittee.

the same properties as normal water molecules (Summary of an explanation by the Subcommittee Member Tauchi at the 11th Subcommittee, Page 19 to 24, 32 of the minutes). The following shows the discussion related to these:

- (1) "For example, data from Sellafield Bay in the UK shows that the concentration of organically bound tritium in fish is higher than the concentration in seawater when measured at a certain point in time. However, this is because there was a very high concentration of tritiated water that was previously discharged into the sea. When that was taken in, the OBT remained because it has a longer half-life than water. The data shows that, as the years go by, the organic-bound form of the substance decreases rapidly when its concentration in seawater is almost undetectable. Therefore, this is not something that should be called bioaccumulation. Bioaccumulation means that substances in the environment accumulate and become more concentrated in living organisms. I hope you understand that this will not happen with tritium" (statement by the Subcommittee Member Tauchi at the 11th Subcommittee, Page 32 of the minutes).
- (2) In response to the question "Have there been any examples of tritium concentrated in nature?" (statement by the Committee Member Mr. Tauchi at the 11th meeting of the Subcommittee, p.32 of the minutes), the answer was "As far as I know, there have been no such cases. If there had been, the tritiated water in the tank could be concentrated by living organisms and removed, but that is not the case" (statement by the Subcommittee Member Tauchi at the 11th Subcommittee, Pages 32 to 33 of the minutes).
- (3) "As far as I know, there have been no cases where microorganisms have been cultured in tritiated water in so-called laboratory experiments, and where water-to-biological concentration has been observed. In addition, as Mr. Hiroshi Tauchi mentioned, the tritium concentration in living organisms can appear to be high in the environment. This is due to the fact that organic matter has been accidentally discharged from factories in the past. Because fish migrate, the opposite phenomenon is observed when fish grown in areas with low tritium concentrations go to areas with high concentrations. We have observed that living organisms grown in a place with high tritium concentration appear to be highly tritium-concentrated when they go to a place with low tritium concentration. This is the reality of the situation" (statement of the Subcommittee Member Kakiuchi at the 11th Subcommittee, Pages 33 to 34 of the minutes).

⁷ https://www.meti.go.jp/earthquake/nuclear/osensuitaisaku/archive/task_force3.html
https://www.meti.go.jp/earthquake/nuclear/osensuitaisaku/archive/task_force4.html
https://www.meti.go.jp/earthquake/nuclear/osensuitaisaku.html#osensuitaisaku_mt

B2. Discussion about each disposal method and result of the comparison

(1) Taskforce

The Taskforce set and evaluated the basic requirements (technical feasibility and regulatory feasibility) as well as conditions which may be constraints (time, cost, scale, secondary waste, worker exposure, etc.) as evaluation items for each case (as shown in the Table B-1) and prepared a report as a basic material for future consideration ("Tritiated Water Taskforce Report"⁸) in June 3, 2016 after the discussion and consideration on the technical point of view of each disposal method, environmental impacts, difficulty of monitoring, issues to secure the site, comparisons to precedents, increasing capacity of storage in tanks, and issues arising from storing water in tanks as mentioned below in footnotes of B2. (2) (ii), (3) and (4) using excerption of the discussions,

This report suggests that consideration should be proceeded with from comprehensive viewpoints including not only technical ones such as the feasibility, economy, required time, etc., as well as social ones such as reputation damage because the result may cause big impact on the reputation.

Table: Conditions which may be constraints

| Disposal method | Geosphere injection | Discharge into the sea | Vapor release | Hydrogen release | Underground burial |
|---------------------|--|------------------------|---------------------|----------------------|--|
| Period ⁹ | 104+20n months 912 months (for monitoring) (n=Number of survey points) | 91 months | 120 months | 106 months | 98 months 912 months (for monitoring) |
| Cost ¹⁰ | 18+0.65n billion yen+Monitoring cost (n=Number of survey points) | 3.4 billion yen | 34.9 billion yen | 100 billion yen | 243.1 billion yen |
| Scale | 380 m ² | 400 m ² | 2000 m ² | 2.000 m ² | 285.000 m ² |

⁸ Available on the web site of the Ministry of Economy, Trade and Industry.

https://www.meti.go.jp/english/earthquake/nuclear/decommissioning/pdf/20160915_01a.pdf

⁹ The procedure is divided in to the plant construction phase and treatment phase, but depending on the method, technical development and some lead time may be required before plant construction (summary of a statement by the Taskforce Member Tokuhiko Yamamoto at the 12th meeting, Page 19 of the minutes)

¹⁰ The following shows the related discussion in the Taskforce.

- (1) It turned out that there is no realistic technology to solve the problem with the treatment method of tritium in France within the allowable range of costs. Such a technology may exist but will be too costly. Therefore, it was concluded that such technologies would not be feasible (Summary of a statement by Mr. Jean-Luc Lachaume, at the 7th Taskforce, Page 15 of the minutes).
- (2) In France, not segregation but direct discharge of tritium into a river or the sea was adopted considering the cost, advantages, etc. (Summary of a statement by the Committee Member, Mr. Jean-Luc Lachaume, at the 7th Taskforce, Page 21 of the minutes).

| Disposal method | Geosphere injection | Discharge into the sea | Vapor release | Hydrogen release | Underground burial |
|---|---|---|---|---|---|
| Secondary waste | N/A | N/A | Depending on the components of treated water, incineration ash may be generated. | Residues may be generated as secondary waste. | N/A |
| Radiation Exposure of Workers ¹¹ | No points to consider in particular | No points to consider in particular | There are no points to consider in particular since the height of the exhaust pipe will be sufficiently high. | There are no points to consider in particular since the height of the exhaust pipe will be sufficiently high. | To prevent radiation exposure of workers during the burial operation, installing a cover etc. is needed. |
| Others | The costs and duration of the exploration will increase in the event that it is difficult to find a suitable geosphere layer. | In the case of using a divider between the intake water pit and the discharge port, the cost will increase. ¹² | The duration may be extended, in case the release operation needs to be suspended due to precipitation. ¹³ | The duration may be extended, in case the release operation needs to be suspended due to precipitation. ¹⁴ | A large amount of concrete and bentonite will be needed. Construction spoil will be produced. ¹⁵ |

(2) Subcommittee

On February 10, 2020, the Subcommittee prepared a report (“The Subcommittee on Handling of the ALPS Treated Water Report”¹⁶) considering the result of the Taskforce. The following shows the major contents of consideration.

¹¹ “I believe the exposure of workers is quite important, and it should be taken into account. With regard to exposure of workers, if the workers to be deployed were changed rapidly, it would be possible to comply with laws and regulations, but I would like to keep this to a realistic level” (statement by the Taskforce Member Hideo Tatsuzaki at the 13th Taskforce, Page 14 of the minutes).

¹² “In the case of discharge into the sea, if tritium were released and the same water was taken in again, it would make no sense whatsoever. In order to deal with this, some methods of partitioning with wharves, etc. are described, but I'm wondering whether or not it is necessary to state this as an ancillary condition when the cost is calculated” (statement by the Taskforce Member Takami Morita at the 14th Taskforce, Page 13 of the minutes).

¹³ “When it comes to implementation of vapor release or hydrogen release, I wonder if it is possible to do so in the midst of heavy snow or rain. If so, I believe the annual operating results, or the actual number of operations, may vary” (statement by the Taskforce Member Mr. Takami Morita at the 13th meeting of the Taskforce, p.13 of the minutes).

¹⁴ Same as the above.

¹⁵ “There is a problem of residual soil buried underground, which hardly arises when it is placed above the groundwater level. This makes me think that the story will be quite different depending on whether we build the plant above or below this groundwater level” (statement by the Taskforce Member Takami Morita at the 13th Taskforce, Page 13 of the minutes).

¹⁶ Available on the web site of the Ministry of Economy, Trade and Industry.

https://www.meti.go.jp/earthquake/nuclear/osensuitaisaku/committee/takakusyu/pdf/018_00_01.pdf

(i) Social impacts of each disposal method

As for social impacts, the impacts on life and economy (reputation damage) are assumed but it is difficult to comprehensively compare their significance.¹⁷ Therefore, it was concluded that no matter which disposal method of discharge into the sea/vapor release is selected, it will be necessary to prepare for possible reputation damage after disposal considering the characteristics of each disposal method.

(ii) Technical viewpoints of each disposal method considering environmental and social impacts

The Subcommittee considered the realistic options considering in terms of environmental impacts including the continuation of tank storage (as shown in B2. (4) below) based on the technical viewpoint in accordance with the five disposal methods consideration results proposed at the Taskforce (geosphere injection, hydrogen release, underground burial, vapor release, and discharge into the sea.) As a result, for geosphere injection, there was an issue with securing of the site and also the method had not been established to monitor the behavior and effects of tritiated water after geosphere injection^{18 19}. For hydrogen release, further technical development

¹⁷ "I do not believe that the superiority of social impact is necessarily clear in our discussions so far, as to which has a greater or lesser social impact" (Summary of a statement by the Subcommittee Member Tokuhiko Yamamoto at the 16th Subcommittee, Page 25 of the minutes).

¹⁸ As for geosphere injection, lack of knowledge of appropriate stratum, monitoring, etc. are difficult (Summary of our statement at the 14th Subcommittee, Page 37 of the minutes).

¹⁹ The following shows the related matters discussed at the Subcommittee and then the Taskforce.

- (1) If geosphere injection is performed other than at the site, thousands of trucks with water will drive on roads in the prefecture and even an accident of one of the truck will stop the entire process, which is risky (Summary of a statement by Mr. Chuck Negin at the 6th Taskforce, Page 36 of the minutes).
- (2) The French regulations prohibit geosphere disposal of radioactive materials (Summary of a statement by Mr. Jean-Luc Lachaume, at the 7th Taskforce, Page 5 of the minutes).
- (3) Of course, those without standards require much time and effort. Other one than discharge into the sea after dilution and vapor release after dilution are difficult to assess without knowing the details (Summary of a statement by the regulatory authorities (Chief Mr. Shinji Kinjo) at the 8th Taskforce, Page 35 of the minutes).
- (4) It is very important how to explain the option of underground burial while there is a case in France. It cannot be assessed because no underground experiment has been conducted (Summary of a statement by the Taskforce Member Hiroshi Tauchi at the 8th Taskforce, Page 40 of the minutes).
- (5) The current legal system does not assume burial disposal of fluid, so it is not an easy task (Summary of a statement by Taskforce Member Hideo Tatsuzaki at the 9th Taskforce, Page 27 of the minutes).
- (6) Judging from the requirements of the international guidelines of IAEA and ICRP, direct injection of tritium water is not allowed globally (Summary of a statement by the regulatory authorities (Chief Shinji Kinjo) at the 12th Taskforce, Page 11 of the minutes).
- (7) Especially as for geosphere injection, there is no precedent case, so there is no regulation. However, it is a waste of opportunity to abandon it due to the lack of regulatory standards. It would be appreciated if consideration could be made (Summary of a statement by Mr. Takasaka, an expert observer, at the 13th Taskforce, Page 17 of the minutes).
- (8) For example, though the method is underground burial, the disposal site of even low-level radioactive waste is a great concern. There may be no candidate for the place of storage of tritium water. If so, the span of time up to construction will be massive (Summary of a statement by the Taskforce Member Yoshihisa Takakura at the 14th Taskforce, Page 16 of the minutes).

was required and there is the possibility of hydrogen explosion²⁰. For underground burial, there was a risk of vapor release of tritium caused by heat generated by solidification, new legislation was required, and there was an issue of securing of the site^{21 22 23}. In addition, the Subcommittee showed its view that there was no realistic model of assessment of environmental impacts of geosphere injection, hydrogen release, and underground burial. However, for vapor release and discharge into the

²⁰ The following shows the related discussion in the Taskforce.

- (1) With hydrogen distillation, even a small device can achieve a high segregation efficiency thanks to the large separation factor, which is an advantage, but it also has disadvantages: the cost is high due to the necessity for ancillary facilities for achieving a very low liquid hydrogen temperature of about 20 kelvin and it is necessary to consider safety measures for the issue of explosion protection of hydrogen gas, etc., due to high pressure caused by gasification of hydrogen when running out of the coolant and use of massive hydrogen gas (Summary of an explanation by the Taskforce Member Toshihiko Yamanishi at the 2nd Taskforce, Page 11 of the minutes).
- (2) The electrolysis method consumes a lot of energy, so as of now electrolysis is rarely used alone for segregation (Summary of an explanation by the Taskforce Member Toshihiko Yamanishi at the 2nd Taskforce, Page 13 of the minutes).
- (3) Though the concentration is low, it is significantly different from past research and development and actually operating plants in that extensive treatment is required. Water treatment in Fukushima is much different from that of the past plants and had no track record (Summary of an explanation by the Taskforce Member Toshihiko Yamanishi at the 2nd Taskforce, Page 16 of the minutes).
- (4) The treatment amount is thousands of times greater than that of currently operating plants. Normally, in the engineering field, scale-up means making the scale 10 or less times greater, not applying a three-digit figure as it is. It is a difficult question whether the current technology is applicable (Summary of a statement by the Taskforce Member Toshihiko Yamanishi at the 2nd Taskforce, Page 17 of the minutes).

²¹ The following shows the related discussion in the Taskforce.

- (1) Currently, it is not assumed at all to dispose of liquid waste by injection in Japan. It is only assumed to dispose of solid waste. It is stipulated in the rules (Summary of an explanation by Mr. Yoshiaki Sakamoto at the 4th Taskforce, Page 22 of the minutes)
- (2) Basically, the result of the safety assessment depends on the assumed extent of deterioration of concrete; based on it, the degree of leakage is assessed (Summary of an explanation by the Committee Member Yoshiaki Sakamoto at the 4th Taskforce, Page 24 of the minutes)
- (3) "For the 800,000 cubic meters, we will need at least 300,000 square meters of land, which will be a very difficult situation" (Summary of an explanation by Mr. Yoshiaki Sakamoto at the 10th Taskforce, Page 7 of the minutes).
- (4) In the case of tritium, some effects may appear due to combination of flow of water and dispersion (Summary of an explanation by Mr. Yoshiaki Sakamoto at the 10th Taskforce, Page 12 of the minutes).
- (5) For treatment and disposal of radioactive waste, the current basic philosophy is that it should be disposed of in waste body. Cementation of tritium water is somewhat out of the course of this philosophy (Summary of a statement by the regulatory authorities (Chief Shinji Kinjo) at the 10th Taskforce, Page 14 of the minutes)
- (6) "I think you are assuming concrete burial but this is only for solid waste from demolition. Also, it is clearly stated in the laws and regulations. However, there is nothing that allows to bury liquid waste as well" (Summary of a statement by the regulatory authorities (Chief Shinji Kinjo) at the 13th Taskforce, Page 19 of the minutes).
- (7) For example, though the method is underground burial, the disposal site of even low-level radioactive waste is a great concern. There may be no candidate for the place of storage of tritium water. If so, the span of time up to construction will be massive (Summary of a statement by the Taskforce Member Yoshihisa Takakura at the 14th Taskforce, Page 16 of the minutes)

²² As for underground burial, there is no track record of disposal, a larger land is required than continuation of storage because solidification makes the volume three or six times larger, and it was reported that solidification generates heat, which causes evaporation of moisture. For this report, no opinion was provided from the Committee (Summary of our report at the 14th Subcommittee, Page 22 of the minutes)

²³ Hydrogen release is the same as vapor release because even if waste is buried underground, tritium will move from the corresponding location, which makes monitoring difficult (Summary of an explanation by the Subcommittee Member Toshihiko Yamanishi at the 16th Subcommittee, Page 31 of the minutes)

sea, environmental impacts were assessed using the assessment model of public exposure in the event of exposure of radioactive nuclides to the environment set by the United Nations Scientific Committee on the Effects of Atomic Radiation (UNSCEAR) and all results were sufficiently lower than the annual exposure amount from the nature in Japan, 2.1 mSv (the environmental impact of discharge into the sea is half or less than that of vapor release)²⁴.

On one hand, since it is difficult to expect the time required to solve these issues and temporal constraints have to be considered, so geosphere injection, hydrogen discharge, and underground burial are associated with many issues from regulatory, technical, and temporal viewpoints. On the other hand, vapor release and discharge into the sea²⁵ were concluded as realistic options^{26 27}.

(3) Advantages and disadvantages of vapor release and discharge into the sea

The Subcommittee compared the advantages and disadvantages of the realistic options, namely vapor release and discharge into the sea.

As a result, it was concluded that though vapor release had a precedent case of the accident reactor at Three Mile Island in the United States occurred in 1979 as well as actual cases of discharge at the time of ventilation even in normal reactors, the wastewater amount in the precedent case of Three Mile Island was significantly smaller than ALPS treated water and there was no domestic case of vaporizing liquid for vapor

²⁴ Explanation by the Secretariat at the 15th Subcommittee, Pages 13 to 16 of the minutes. Even if all treated water stored in tanks is treated in one year, the environmental impact is about 0.052 μ SV to 0.62 μ SV per year and 1.3 μ SV per year in discharge into the sea and air, respectively. The following shows the discussion related to these:

- (1) To the question of whether the impact is an order of magnitude smaller than exposure from natural radiation even under excessive assumption that the total amount stored in tanks, 860 trillion Bq, is discharged every year for 100 years (Summary of a statement by the Subcommittee Member Sakita at the 15th Subcommittee, Page 19 of the minutes), the answer was yes (Summary of the answer by the Secretariat at the 15th Subcommittee, Page 19 of the minutes).
- (2) Even in the case of a heavy water moderated reactor in Canada, which discharges a lot of tritium, the impact of the concentration of tritium drops to a level close to the background in a location about 5 km away, so there was a statement that the simulation result based on UNSCEAR was appropriate as a simulation result of the impact on residents in locations about 5 km away from the facility (Summary of a statement by the Subcommittee Member Kakiuchi at the 15th Subcommittee, Pages 19 to 20 of the minutes).

²⁵ It was explained that tritium had been generated by domestic and foreign nuclear power plants, etc., associated with their operation and a part of such tritium had been discharged into the sea, rivers, lakes and marshes, and air according to the regulations in each country (Summary of an explanation by the Secretariat at the 8th Subcommittee, Pages 4 of the minutes).

²⁶ It is important to commit to perform the proven options, namely discharge into the sea and vapor release, among the five disposal methods (Summary of an explanation by the Subcommittee Member Yuko Sakita at the 16th Taskforce, Page 28 of the minutes).

²⁷ Among the five disposal methods, only discharge into the sea and vapor discharge are technically feasible (Summary of an explanation by the Subcommittee Member Toshihiko Yamanishi at the 16th Subcommittee, Page 31 of the minutes).

release for the purpose of disposal of liquid radioactive waste^{28 29}. In addition, prediction is difficult due to deposition on the ground surface and evaporation into the air after vapor release, and there will be demerit that the fluctuation of the monitoring result caused by the weather conditions is larger than discharge into the sea^{30 31}. Moreover, from social viewpoints, a wider range of industries are expected to be affected as compared to the case of discharge into the sea and reputation damage may occur in

²⁸ The following shows the related discussion in the Taskforce.

- (1) The amount of water handled at TMI (Note: Three Mile Island) is completely different from that of Fukushima, so naturally technical discussion will be different. It was reported that the amounts of contaminated water were about 10 thousand tons and the evaporated amount was about 8,400 tons. Therefore, naturally the technologies to be provided and the assessment will be different, but even TMI achieved the goal in more than 10 years (Summary of a statement by the regulatory authorities (Chief Shinji Kinjo) at the 1st Taskforce, Page 28 of the minutes).
- (2) Though the concentration is low, it is significantly different from past research and development and actually operating plants in that extensive treatment is required. Water treatment in Fukushima is much different from that of the past plants and had no track record (Summary of an explanation by the Taskforce Member Toshihiko Yamanishi at the 2nd Taskforce, Page 16 of the minutes).
- (3) The scales of Three Mile and Fukushima are completely different. In the case of Three Mile, an accident occurred in only one reactor and the condition has calmed down, but the condition of Fukushima has yet to calm down (Summary of a statement by the Taskforce Member Yoshihisa Takakura at the 6th Taskforce, Page 18 of the minutes).
- (4) I understand that there is a big difference between the two accidents. And I also understand that the problem in Japan is much more significant than in TMI. In principle, we had no problem of accumulation. So we could wait and see. However, in the case of Fukushima, it is very important to solve the problem as soon as possible (Summary of a statement by Mr. Chuck Negin at the 6th Taskforce, Page 18 of the minutes).
- (5) It is necessary to proceed with discussion understanding the similarity to and difference from TMI, but we must remember that although the concentration of the tritium is very close, the amount is much larger in Fukushima. In the case of TMI, in reality, the reactor is 160 km away from the coast, which would be almost equivalent to the case of a reactor at an inland site in the case of Japan, so the geographical environment seems to be much different (Summary of a statement by the Taskforce Member Tokuhiro Yamamoto at the 6th Taskforce, Page 21 of the minutes).
- (6) In France, the amount of tritium discharged in liquid is much greater than that discharged into air. This is because tritium causes a greater impact on human body when released in gas than in liquid (Summary of an explanation by Mr. Jean-Luc Lachaume, at the 7th Taskforce, Page 7 of the minutes).
- (7) In the case of Three Mile, it was possible because the amount was very limited, but it is too different from the case of Fukushima to be applicable (Summary of a statement by the Committee Member Yoshihisa Takakura at the 13th Taskforce, Page 11 of the minutes).

²⁹ In terms of the required time and cost, discharge into the sea is easier. The reason vapor release was performed in the case of the Three Mile accident is that the reactor was not adjacent to the sea (Summary of a statement by the Subcommittee Member Ichiro Yamamoto at the 14th Subcommittee, Page 39 of the minutes).

³⁰ It was reported that there was a problem with monitoring for vapor release because it is difficult to predict generation and dispersion of waste, especially salt, caused by evaporation of ALPS water. For this report, no opinion was provided from the Committee (Summary of our report at the 14th Subcommittee, Page 22 of the minutes).

³¹ The following shows the related discussion in the Taskforce.

- (1) As for atmospheric dispersion, the speed of especially redispersion of tritium is high. Tritium is much different from other radioactive materials in that most of it evaporates again and returns to the air (Summary of an explanation by Mr. Haruyasu Nagai at the 4th Taskforce, Page 2 of the minutes).
- (2) The dispersion condition greatly depends on the weather conditions at the time of discharge. It also greatly varies within a day. As the weather condition varies from hour to hour, the conditions change from moment to moment, so the necessity for adjusting the assessment based on the conditions is a difficult point in atmospheric dispersion (Summary of an explanation by Mr. Haruyasu Nagai at the 4th Taskforce, Pages 2 and 3 of the minutes).
- (3) We assessed the reduction of the concentration caused by marine dispersion from the viewpoint of the degree of dilution by advection and diffusion assuming discharge from a typical Pacific coast. The concentration of the lattice in the discharge position and 2 km lattice decreases by 1, 2, and 3 digits about 10 km, 50 km, and 100 km downstream. This is different from air. The current varies little, so prediction is easier (Summary of an explanation by Mr. Haruyasu Nagai at the 4th Taskforce, Page 8 of the minutes).

industries in Fukushima and the whole of the surrounding areas.

On the other hand, there are many actual cases of discharge into the sea as being implemented in domestic and foreign nuclear facilities on daily bases and about 31.6 billion to 83 trillion Bq/year (actual average of 3 years before the accident) per site is diluted and discharged into the sea, etc., from the domestic nuclear power plants.

Therefore, the discharge into the sea was concluded to be possible within the proven range even considering the disposal amount. In addition, because the composition of the discharge facility is simpler than the composition of the vapor release facility, and knowhow on the design of the discharge system and its handling are known. Thus, it was concluded that it will be able to surely dispose the waster better than vapor release in knowledge of the facility and operation point of view. Moreover, in the case of discharge into the sea, the condition of dilution dispersion after discharge is relatively easy to predict because the variation in the current is smaller than the impacts of rain and wind direction in the case of vapor release, so it was easier to consider the construction of the surveillance framework by monitoring^{32 33 34}.

From social viewpoints, discharge into the sea may cause reputation damage in the fishing industry and tourism in Fukushima and the surrounding sea area. Especially, the catches of the fishing industry in Fukushima, which is now in test operation, are yet to be less than 20% of that before the earthquake and the Fukushima Daiichi accident.

Considering these, it is necessary to consider countermeasures³⁵.

(4) Consideration of the expansion of the tank storage capacity and continuation of tank storage

The Subcommittee considered the measure to expand the tank storage capacity and continue tank storage without disposing of ALPS treated water as follows³⁶.

³² See footnote [31] (3)

³³ For our explanation that there is no technically difficult issue in discharge into the sea, no opinion was shown (Summary of our report at the 14th Subcommittee, Page 21 of the minutes).

³⁴ There are several methods of discharge into the sea including construction of a new pool or equalizing the concentration before discharge in a new tank, etc., and then rechecking them, which is not technically difficult up to construction (Summary of a statement by the Subcommittee Member Yoshihisa Takakura at the 16th Subcommittee, Page 37 of the minutes).

³⁵ It was explained that the social impacts of discharge in the sea widely affects areas outside Fukushima, but the impacts on land areas are limited and the directly affected parties are limited to the fishing industry and a part of tourism, such as sea bathing while vapor release widely affects up to areas outside Fukushima and may directly affects all products. There was no objection (Summary of an explanation by the Secretariat at the 12th Subcommittee, Pages 13 of the minutes).

³⁶ The following shows the related discussion in the Taskforce.

(1) "Even if it is stored, there is a possibility of sudden leakage.", "Even if it is stored in tanks, is it enough to just store it? I think that some sort of tank maintenance will probably be necessary during that period, and depending on the endurance of the tanks, it may be necessary to transfer it from one tank to another, and so on, and the risk of accidents, including radiation exposure of workers, must be considered." (Statement of the Taskforce Member Hideo Tatsuzaki at the 1st Taskforce, Pages 18 and 19 of the minutes).

(2) As long as a lot of tritium water is stored, the risk will not become zero. There must be some risks associated with

(i) Expansion of the tank storage capacity

The Subcommittee considered storage in large-capacity aboveground tanks and storage in underground and offshore tanks. As a result, it was concluded that the storage capacity of large-capacity aboveground and underground tanks is not significantly larger than that of the existing standard tanks but had issues such as much greater leakage amounts in the case of damage. Offshore tanks of the size adopted for oil storage bases are difficult to install because the water depth is shallow in the Fukushima Daiichi port. Moreover, it is difficult to collect leaked water before dilution. In accordance of those considerations, there was no advantage in installation of the large tanks, etc. at Fukushima Daiichi³⁷.

Though storage by transfer to outside of the site was also considered, in order to prevent leakage or accident caused by transfer of water before dilution, it takes much time to plan and prepare a method to transfer a lot of treated water due to the necessity for transfer facilities compliant with laws and regulations (e.g. nuclear material protection facility surrounding the piping for transfer (fence, etc.)) as well as getting approval from the local governments on the transfer route. In addition, it was concluded to take much time because proper facilities, diverse preliminary adjustments, and procedures for permission are required due to the necessity for permission as a radioactive waste storage facility since radioactive materials are handled³⁸.

continuation of storage (Summary of a statement by the Taskforce Member Tokuhiko Yamamoto at the 1st Taskforce, Page 22 of the minutes).

(3) In reality, one 1,000-ton tank is prepared every two days, which is associated with concerns of leakage and human errors. Tritium must be handled smoothly, otherwise there will be so many tanks that management, etc., may be very difficult. If it continues for 30 or 40 years, we will run out of space for tanks (Summary of a statement by the Taskforce Member Yoshihisa Takakura at the 4th Taskforce, Page 28 of the minutes).

(4) For storage, it is necessary to consider the possibility of future relocation of the storage space; if we wait for the half-life, it will be unrealistic to wait for, for example, three half-lives because it is too long. In addition, we have to take some countermeasures against the risk of unexpected accidents during storage such as the risk of discharge of stored water (Summary of a statement by the Taskforce Member Hideo Tatsuzaki at the 4th Taskforce, Pages 32 and 33 of the minutes).

(5) "Of course, accidents can occur in the course of the construction of the tanks, and there is also the risk of massive leakage if the tanks are damaged. In that sense, we think it is riskier to keep the water in the tanks on the site" (Statement of the regulatory authorities (Chief Shinji Kinjo) at the 13th Taskforce, Page 22 of the minutes).

(6) "At present, for example, we have already built almost all the tanks in the areas that are relatively close to where contaminated water is generated and where tanks can be placed. If we build new tanks in the future, we would have to set up pipes to transfer the water over a long distance, and if we transfer the water over such a long distance, there would naturally be risks of leakage and other problems. Even if we manage to increase the capacity of the current area by replacing the tanks with new ones with a larger capacity, there is not much room left in the current area." (Our statement at the 14th Taskforce, Pages 17 and 18 of the minutes).

³⁷ The advantages and disadvantages of each of the following methods assumed in the case of continuation of storage were explained: storage in large-capacity tanks, storage in large-capacity underground tanks, and storage in offshore tanks (Summary of our explanation at the 13th Subcommittee, Pages 34 and 35 of the minutes)

³⁸ It was explained that storage outside the site requires approval from the local governments on the transfer route in the case of transfer without dilution and transfer facilities, etc., compliant with laws and regulations were required, and there was no opinion to it (Summary of our explanation at the 13th Subcommittee, Page 35 of the minutes).

(ii) Continuation of tank storage

At the Subcommittee, the possibility of continuation of storage in tanks was also taken into consideration, however there is an issue pointed out as actual risk of handling of remaining ALPS treated water after storage, including the fracture of the tank due to the earthquake³⁹ ⁴⁰. In principle, it is important to proceed with reconstruction of Fukushima and decommissioning in parallel and it is necessary to finish disposal of ALPS treated water as a part of decommissioning in order to complete decommissioning of Fukushima Daiichi, so it was concluded that the water would have to be treated by the end of decommissioning even if storage was continued⁴¹.

In addition, the Subcommittee concluded that transfer of radioactive waste to outside the site and expansion of the site to continue tank storage required understanding from the local governments, etc., of the area where the storage facility would be constructed and get permission as a radioactive waste storage facility, which would require so much adjustments and time up to implementation that the only possible method was to use standard tanks with improved installation efficiency at the site and the room for addition of more tanks than specified in the current plan was limited.

The Subcommittee pointed out that decommissioning required securing of places for construction of various facilities such temporary storage facilities for spent fuel and fuel debris, analysis facilities for various samples, storage facilities for fuel debris retrieval equipment, mock-up and training facilities for fuel debris retrieval, and waste recycling facilities⁴².

B3. Assessment by IAEA

While the government had been proceeding with consideration, IAEA reviewed the disposal methods of ALPS treated water at all of the 4th peer review missions and recommended the Government of Japan to urgently determine how to dispose of ALPS treated water, which had been accumulated in the tanks at the Fukushima Daiichi site in the report of the 4th mission issued on January 31, 2019⁴³ ⁴⁴.

³⁹ Continuation of storage in tanks is associated with a fracture risk of tanks due to earthquake (Summary of a statement by the Subcommittee Member Hideki Kakiuchi at the 13th Subcommittee, Page 25 of the minutes).

⁴⁰ Even if we select continuation of storage, eventually it will be necessary to treat remaining tritium (Summary of a statement by the Subcommittee Member Hideki Kakiuchi at the 13th Subcommittee, Page 25 of the minutes)

⁴¹ To the question "Will decommissioning continue as long as storage continues?" the Secretariat answered yes (Summary of a statement by the Subcommittee Member Takami Morita and summary of our statement at the 14th Subcommittee, Pages 24 and 25 of the minutes).

⁴² Decommissioning required securing of areas in order not to hinder other operations (Summary of a statement by the Subcommittee Member Tokuhiko Yamamoto at the 13th Subcommittee, Page 26 of the minutes).

⁴³ IAEA "Mission Report IAEA International Peer Review Mission on Mid-And-Long-Term Roadmap Towards the Decommissioning of TEPCO's Fukushima Daiichi Nuclear Power Station (Fourth Mission) Tokyo and Fukushima Daiichi NPS, Japan 5-13 November," Page 8, etc.

⁴⁴ The IAEA also emphasized that the decision of the basic policy on handling of treated water by the Japanese government would encourage the whole procedure of decommissioning saying "The decision on ALPS treated water disposition path

Then, IAEA appraised the consideration result of the disposal methods of ALPS treated water by the government as mentioned above as follows in the report issued on April 2, 2020, in the review performed as follow-up for the 4th mission.

“Regarding the technical aspects, the IAEA Review Team considers that the recommendations made by the ALPS Subcommittee are based on a sufficiently comprehensive analysis and on a sound scientific and technical basis. The IAEA Review Team considers that the proposed objective of completing the disposition of the ALPS treated water by the time of the end of the decommissioning work is aligned with current international good practices. The IAEA Review Team considers the two options (namely controlled vapor release and controlled discharges into the sea, the latter of which is routinely used by operating nuclear power plants and fuel cycle facilities in Japan and worldwide) selected out of the initial five options are technically feasible and would allow the timeline objective to be achieved.

With the volume of ALPS treated water expected to reach the planned tank capacity of approximately 1.37 million m³ around the summer of 2022⁴⁵, and taking into account that further treatment to meet regulatory standards for discharge before dilution and control of the stored water before disposition would be needed for implementation of any of the solutions considered by the Government of Japan, a decision on the disposition path should be taken urgently engaging all stakeholders.”^{46 47}

B4. Summary

As described above, the Taskforce and Subcommittee discussed disposal of ALPS treated water, which had been an issue in decommissioning of Fukushima Daiichi, in detail for as long as six years, and considered the five disposal methods (geosphere injection, hydrogen release, underground burial, vapor release, and discharge into the sea) and continuation of tank storage from technical viewpoints. Based on the consideration result, the Subcommittee presented the conclusion that proven vapor release or discharge into the sea are the realistic options. Then the Subcommittee compared vapor release and discharge into the sea to present a view that discharge into the sea had more track records in terms of the relationship with the discharge disposal amount and was more reliable

was an important advisory point of previous reviews, and it will facilitate the implementation of the whole decommissioning plan.” (Acknowledgement 2) in the 5th review mission report prepared after the policy was decided.

⁴⁵ The timing when the tanks are expected to be full is as of 2020 and may change depending on conditions.

⁴⁶ IAEA “Review Report IAEA Follow-up Review of Progress Made on Management of ALPS Treated Water and the Report of the Subcommittee on Handling of ALPS Treated water at TEPCO’s Fukushima Daiichi Nuclear Power Station,” Page 6.

⁴⁷ The Director General Grossi of IAEA also made a similar statement when the Japanese government decided the Basic Policy. “... Controlled water discharges into the sea are routinely used by operating nuclear power plants in the world and in the region under specific regulatory authorisations based on safety and environmental impact assessments.”, IAEA website dated April 13, 2021.

<https://www.iaea.org/newscenter/pressreleases/iaea-ready-to-support-japan-on-fukushima-water-disposal-director-general-grossi-says>

including ease of handling of discharge facilities and monitoring methods.

The Subcommittee also presented a negative view on the continuation of storage in tanks considering the necessity for disposal of ALPS treated water for decommissioning of Fukushima Daiichi, the substantial need for the land required for future decommissioning due to the limited room for the additional tanks than specified in the current plan, and the risk factors such as the risk of leakage of treated water caused by a rupture of a tank.

Thus, the Subcommittee assessed disposal of ALPS treated water is appropriate based on the premise of the disadvantage of continuation of storage in tanks and the advantage of discharge, which has no issue with safety as long as discharge complies with the regulatory standard.

This consideration result of the government was appraised by IAEA.

Reference C Setting of Management Values and Exposure Assessment of Hypothetical ALPS Treated Water

In discharge of ALPS treated water into the sea, sufficient safety is secured by verifying that the sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium (62 nuclides to removal by ALPS and C-14) is less than 1 and diluting with seawater 100 or more times at the time of discharge so that the tritium concentration greatly falls below the regulatory concentration limit, but migration in the environment varies among nuclides, so the impact on exposure is different even among nuclides with the same regulatory concentrations limit. We decided to individually manage eight nuclides important in terms of exposure in order to limit this uncertainty of the source term and reduce the impacts on the external environment further. The management values were set by the following procedure.

1. Selection of nuclides important in terms of exposure
2. Setting of the management values of the selected nuclides

If any concentration exceeding the set management value is detected, we do not discharge the water and transfer it to secondary treatment. However, these eight nuclides shall be reviewed as needed based on the review result of nuclides subject to measurement before future discharge.

C1. Selection of nuclides subject to management

Regulatory concentration limits are set so that the annual exposure does not exceed 1mSv even in the case of ingestion of radioactive materials contained in the liquid on a daily basis. Therefore, the annual exposure amount from direct ingestion is comparable among different nuclides as long as their regulatory concentration ratios are the same, and the annual exposure will not exceed 1 mSv and as long as the sum of the ratios to regulatory concentrations limits is less than 1 even if multiple nuclides are included.

On the other hand, the behavior varies among elements such as migration to organisms in the environment, so the impact on exposure varies among nuclides discharged even with the same regulator concentration limit.

Therefore, to verify the exposure impact of each nuclide discharged with the same regulator concentration limit, we assessed exposure from discharge of ALPS treated water containing the corresponding nuclides only at the regulatory concentration limits (the sum of the ratios to regulatory concentrations limits is 1) for one year, though it is unrealistic, and selected nuclides important in terms of exposure assessment.

a. Source term

Based on the following conditions, we set the source term of each nuclide (annual discharge amount) of each nuclide as shown in Table C-1.

- Set the tritium concentration used for assessment at 100,000 Bq/L, which is the lower than the ever since measured tritium concentration of about 150,000 Bq/L, to estimate larger annual discharge volume of water and annual discharge amount of the nuclides other than tritium which proportion to the annual discharge volume of water.
- Set the annual discharge amount by multiplying the regulatory concentration of each nuclide by the annual discharge volume of water.

b. Concentration of each nuclide used for the exposure assessment in the seawater

The concentration of each nuclide in the seawater used for exposure assessment was calculated from the ratio of tritium to the annual discharge amount of each nuclide based on the annual average concentration within 10 km × 10 km of the tritium concentration in the seawater (all layers) in Table 6-1-17. Table C-2 shows the concentration of each nuclide in the seawater used for the assessment.

c. Assessment targets

The assessment targets are internal exposure from beach sand, which is significantly affected by external exposure, internal exposure from ingestion of seafood, and exposure for environment protection.

The exposure assessment method is the same as 6-1-2. "Assessment method" and persons subject to the assessment evaluation are those who ingest a large amount of seafood.

d. Exposure assessment result and selection of nuclides subject to management

Table C-3 shows the assessment result of internal exposure of adults from each nuclide discharged at the regulatory concentration limit in descending order of the value. We selected the eight nuclides whose exposure amount exceeds 0.001 mSv/year when discharged at the regulatory concentration limit as nuclides subject to management, which are nuclides with significant impacts on the exposure assessment.

As for external exposure from beach sand, there are some nuclides whose exposure amount exceeds 0.001 mSv/year when discharged at the regulatory concentration limit, but as shown in Table C-4, the dose conversion factor of Co-60 is used for all of these nuclides and the actual impact on external exposure is much smaller than Co-60 considering the energy and discharge rate of photons discharged by each nuclide, so such nuclides are deemed not to be subject to management.

e. Confirmation regarding environmental protection

Consideration had focused on the impact of human exposure, but this time we confirmed whether there is any nuclide subject to management from the viewpoint of environmental protection.

Specifically, we assessed the impact of exposure of each nuclide on marine plants and animals by the assessment method shown in 7-2. "Assessment method" using the source term of a. Table C-5 shows the assessment results in descending order of the value.

The nuclide with the greatest impact of exposure is Fe-59, but it is lower than the lower limit value of the derived consideration reference level (DCRL). We judged that there was no nuclide to be added as a management target from the viewpoint of environmental protection because Fe-59 had been subject to management for reduction of human exposure and the assessment values of the other nuclides are an order of magnitude smaller than that of Fe-59.

Table C-1 Source term to verify the impacts of 63 nuclides other than tritium (annual discharge amount)

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|--|
| H-3 | 1.0E+05 | 2.2E+08 | 2.2E+13 | <ul style="list-style-type: none"> • For the annual discharge amount of tritium, the upper limit value is used. • The concentration of tritium is set to a lower value than the concentration of stored ALPS treated water, etc., because a relatively large annual discharge volume of water is set. • This source term is used for the assessment of the case of discharge of ALPS treated water containing only the corresponding nuclides at their regulatory concentration limits (the sum of the ratios to regulatory concentrations limits is 1) to verify the impact of exposure of each nuclide, and water of such quality will be never been discharged actually. |
| C-14 | 2.0E+03 | 2.2E+08 | 4.4E+11 | |
| Mn-54 | 1.0E+03 | 2.2E+08 | 2.2E+11 | |
| Fe-59 | 4.0E+02 | 2.2E+08 | 8.8E+10 | |
| Co-58 | 1.0E+03 | 2.2E+08 | 2.2E+11 | |
| Co-60 | 2.0E+02 | 2.2E+08 | 4.4E+10 | |
| Ni-63 | 6.0E+03 | 2.2E+08 | 1.3E+12 | |
| Zn-65 | 2.0E+02 | 2.2E+08 | 4.4E+10 | |
| Rb-86 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Sr-89 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Sr-90 | 3.0E+01 | 2.2E+08 | 6.6E+09 | |
| Y-90 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Y-91 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Nb-95 | 1.0E+03 | 2.2E+08 | 2.2E+11 | |
| Tc-99 | 1.0E+03 | 2.2E+08 | 2.2E+11 | |
| Ru-103 | 1.0E+03 | 2.2E+08 | 2.2E+11 | |
| Ru-106 | 1.0E+02 | 2.2E+08 | 2.2E+10 | |
| Rh-103m | 2.0E+05 | 2.2E+08 | 4.4E+13 | |
| Rh-106 | 3.0E+05 | 2.2E+08 | 6.6E+13 | |
| Ag-110m | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Cd-113m | 4.0E+01 | 2.2E+08 | 8.8E+09 | |
| Cd-115m | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Sn-119m | 2.0E+03 | 2.2E+08 | 4.4E+11 | |
| Sn-123 | 4.0E+02 | 2.2E+08 | 8.8E+10 | |
| Sn-126 | 2.0E+02 | 2.2E+08 | 4.4E+10 | |
| Sb-124 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Sb-125 | 8.0E+02 | 2.2E+08 | 1.8E+11 | |
| Te-123m | 6.0E+02 | 2.2E+08 | 1.3E+11 | |
| Te-125m | 9.0E+02 | 2.2E+08 | 2.0E+11 | |
| Te-127 | 5.0E+03 | 2.2E+08 | 1.1E+12 | |
| Te-127m | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Te-129 | 1.0E+04 | 2.2E+08 | 2.2E+12 | |
| Te-129m | 3.0E+02 | 2.2E+08 | 6.6E+10 | |

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---------|
| I-129 | 9.0E+00 | 2.2E+08 | 2.0E+09 | |
| Cs-134 | 6.0E+01 | 2.2E+08 | 1.3E+10 | |
| Cs-135 | 6.0E+02 | 2.2E+08 | 1.3E+11 | |
| Cs-136 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Cs-137 | 9.0E+01 | 2.2E+08 | 2.0E+10 | |
| Ba-137m | 8.0E+05 | 2.2E+08 | 1.8E+14 | |
| Ba-140 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Ce-141 | 1.0E+03 | 2.2E+08 | 2.2E+11 | |
| Ce-144 | 2.0E+02 | 2.2E+08 | 4.4E+10 | |
| Pr-144 | 2.0E+04 | 2.2E+08 | 4.4E+12 | |
| Pr-144m | 4.0E+04 | 2.2E+08 | 8.8E+12 | |
| Pm-146 | 9.0E+02 | 2.2E+08 | 2.0E+11 | |
| Pm-147 | 3.0E+03 | 2.2E+08 | 6.6E+11 | |
| Pm-148 | 3.0E+02 | 2.2E+08 | 6.6E+10 | |
| Pm-148m | 5.0E+02 | 2.2E+08 | 1.1E+11 | |
| Sm-151 | 8.0E+03 | 2.2E+08 | 1.8E+12 | |
| Eu-152 | 6.0E+02 | 2.2E+08 | 1.3E+11 | |
| Eu-154 | 4.0E+02 | 2.2E+08 | 8.8E+10 | |
| Eu-155 | 3.0E+03 | 2.2E+08 | 6.6E+11 | |
| Gd-153 | 3.0E+03 | 2.2E+08 | 6.6E+11 | |
| Tb-160 | 5.0E+02 | 2.2E+08 | 1.1E+11 | |
| Pu-238 | 4.0E+00 | 2.2E+08 | 8.8E+08 | |
| Pu-239 | 4.0E+00 | 2.2E+08 | 8.8E+08 | |
| Pu-240 | 4.0E+00 | 2.2E+08 | 8.8E+08 | |
| Pu-241 | 2.0E+02 | 2.2E+08 | 4.4E+10 | |
| Am-241 | 5.0E+00 | 2.2E+08 | 1.1E+09 | |
| Am-242m | 5.0E+00 | 2.2E+08 | 1.1E+09 | |
| Am-243 | 5.0E+00 | 2.2E+08 | 1.1E+09 | |
| Cm-242 | 6.0E+01 | 2.2E+08 | 1.3E+10 | |
| Cm-243 | 6.0E+00 | 2.2E+08 | 1.3E+09 | |
| Cm-244 | 7.0E+00 | 2.2E+08 | 1.5E+09 | |

Table C-2 Concentration in the seawater used for the assessment

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) | Concentration in the seawater used for the assessment (Sandy beach assessment point) |
|----------------|------------------------------|--|--|
| | | Mean concentration of all layers (Bq/L) | Mean concentration of all layers (Bq/L) |
| H-3 | 2.2E+13 | 5.6E-02 | 8.8E-01 |
| C-14 | 4.4E+11 | 1.1E-03 | 1.8E-02 |
| Mn-54 | 2.2E+11 | 5.6E-04 | 8.8E-03 |
| Fe-59 | 8.8E+10 | 2.2E-04 | 3.5E-03 |
| Co-58 | 2.2E+11 | 5.6E-04 | 8.8E-03 |
| Co-60 | 4.4E+10 | 1.1E-04 | 1.8E-03 |
| Ni-63 | 1.3E+12 | 3.4E-03 | 5.3E-02 |
| Zn-65 | 4.4E+10 | 1.1E-04 | 1.8E-03 |
| Rb-86 | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Sr-89 | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Sr-90 | 6.6E+09 | 1.7E-05 | 2.6E-04 |
| Y-90 | 6.6E+10 | 1.7E-04 | 2.6E-04 |
| Y-91 | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Nb-95 | 2.2E+11 | 5.6E-04 | 8.8E-03 |
| Tc-99 | 2.2E+11 | 5.6E-04 | 8.8E-03 |
| Ru-103 | 2.2E+11 | 5.6E-04 | 8.8E-03 |
| Ru-106 | 2.2E+10 | 5.6E-05 | 8.8E-04 |
| Rh-103m | 4.4E+13 | 1.1E-01 | 8.8E-03 |
| Rh-106 | 6.6E+13 | 1.7E-01 | 8.8E-04 |
| Ag-110m | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Cd-113m | 8.8E+09 | 2.2E-05 | 3.5E-04 |
| Cd-115m | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Sn-119m | 4.4E+11 | 1.1E-03 | 1.8E-02 |
| Sn-123 | 8.8E+10 | 2.2E-04 | 3.5E-03 |
| Sn-126 | 4.4E+10 | 1.1E-04 | 1.8E-03 |
| Sb-124 | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Sb-125 | 1.8E+11 | 4.5E-04 | 7.0E-03 |
| Te-123m | 1.3E+11 | 3.4E-04 | 5.3E-03 |
| Te-125m | 2.0E+11 | 5.0E-04 | 7.9E-03 |
| Te-127 | 1.1E+12 | 2.8E-03 | 4.4E-02 |
| Te-127m | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Te-129 | 2.2E+12 | 5.6E-03 | 2.6E-03 |
| Te-129m | 6.6E+10 | 1.7E-04 | 2.6E-03 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (within 10 km × 10 km) | Concentration in the seawater used for the assessment (Sandy beach assessment point) |
|-------------------------|------------------------------|--|--|
| | | Mean concentration of all layers (Bq/L) | Mean concentration of all layers (Bq/L) |
| I-129 | 2.0E+09 | 5.0E-06 | 7.9E-05 |
| Cs-134 | 1.3E+10 | 3.4E-05 | 5.3E-04 |
| Cs-135 | 1.3E+11 | 3.4E-04 | 5.3E-03 |
| Cs-136 | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Cs-137 | 2.0E+10 | 5.0E-05 | 7.9E-04 |
| Ba-137m | 1.8E+14 | 4.5E-01 | 7.9E-04 |
| Ba-140 | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Ce-141 | 2.2E+11 | 5.6E-04 | 8.8E-03 |
| Ce-144 | 4.4E+10 | 1.1E-04 | 1.8E-03 |
| Pr-144 | 4.4E+12 | 1.1E-02 | 1.8E-03 |
| Pr-144m | 8.8E+12 | 2.2E-02 | 1.8E-03 |
| Pm-146 | 2.0E+11 | 5.0E-04 | 7.9E-03 |
| Pm-147 | 6.6E+11 | 1.7E-03 | 2.6E-02 |
| Pm-148 | 6.6E+10 | 1.7E-04 | 2.6E-03 |
| Pm-148m | 1.1E+11 | 2.8E-04 | 4.4E-03 |
| Sm-151 | 1.8E+12 | 4.5E-03 | 7.0E-02 |
| Eu-152 | 1.3E+11 | 3.4E-04 | 5.3E-03 |
| Eu-154 | 8.8E+10 | 2.2E-04 | 3.5E-03 |
| Eu-155 | 6.6E+11 | 1.7E-03 | 2.6E-02 |
| Gd-153 | 6.6E+11 | 1.7E-03 | 2.6E-02 |
| Tb-160 | 1.1E+11 | 2.8E-04 | 4.4E-03 |
| Pu-238 | 8.8E+08 | 2.2E-06 | 3.5E-05 |
| Pu-239 | 8.8E+08 | 2.2E-06 | 3.5E-05 |
| Pu-240 | 8.8E+08 | 2.2E-06 | 3.5E-05 |
| Pu-241 | 4.4E+10 | 1.1E-04 | 1.8E-03 |
| Am-241 | 1.1E+09 | 2.8E-06 | 4.4E-05 |
| Am-242m | 1.1E+09 | 2.8E-06 | 4.4E-05 |
| Am-243 | 1.1E+09 | 2.8E-06 | 4.4E-05 |
| Cm-242 | 1.3E+10 | 3.4E-05 | 5.3E-04 |
| Cm-243 | 1.3E+09 | 3.4E-06 | 5.3E-05 |
| Cm-244 | 1.5E+09 | 3.9E-06 | 6.2E-05 |
| Target exposure pathway | | Ingestion of seafood | From beach sand |

Table C-3 Internal exposure assessment result from ingestion of seafood in the case of discharge of each nuclide at the regulatory concentration limit (adult)
(Selected 8 nuclides exceeding 0.001 mSv/year as management targets)

| No. | Target nuclide | Regulatory concentration limit (Bq/L) | Internal exposure dose from ingestion of seafood (mSv/year) | Remarks |
|-----|----------------|---------------------------------------|---|----------------------------------|
| 1 | Sn-126 | 6.0E+04 | 2.6E-02 | Operation and management targets |
| 2 | Sn-123 | 2.0E+03 | 2.3E-02 | Operation and management targets |
| 3 | Sn-119m | 1.0E+03 | 1.9E-02 | Operation and management targets |
| 4 | Fe-59 | 4.0E+02 | 5.6E-03 | Operation and management targets |
| 5 | Cd-115m | 1.0E+03 | 1.4E-03 | Operation and management targets |
| 6 | C-14 | 2.0E+02 | 1.3E-03 | Operation and management targets |
| 7 | Cd-113m | 6.0E+03 | 1.3E-03 | Operation and management targets |
| 8 | Ag-110m | 2.0E+02 | 1.0E-03 | Operation and management targets |
| 9 | Zn-65 | 3.0E+02 | 8.4E-04 | |
| 10 | Mn-54 | 3.0E+02 | 5.2E-04 | |
| 11 | Co-58 | 3.0E+01 | 2.5E-04 | |
| 12 | Co-60 | 3.0E+02 | 2.3E-04 | |
| 13 | Tc-99 | 3.0E+02 | 2.1E-04 | |
| 14 | Te-129m | 1.0E+03 | 1.4E-04 | |
| 15 | Te-127 | 1.0E+03 | 1.3E-04 | |
| 16 | Te-123m | 1.0E+03 | 1.3E-04 | |
| 17 | Eu-155 | 1.0E+02 | 1.3E-04 | |
| 18 | Te-125m | 2.0E+05 | 1.2E-04 | |
| 19 | Pm-148m | 3.0E+05 | 1.1E-04 | |
| 20 | Eu-152 | 3.0E+02 | 1.1E-04 | |
| 21 | Te-127m | 4.0E+01 | 1.1E-04 | |
| 22 | Gd-153 | 3.0E+02 | 1.1E-04 | |
| 23 | Pm-146 | 2.0E+03 | 1.1E-04 | |
| 24 | Pm-148 | 4.0E+02 | 1.1E-04 | |
| 25 | Eu-154 | 2.0E+02 | 1.1E-04 | |
| 26 | I-129 | 3.0E+02 | 1.1E-04 | |
| 27 | Sm-151 | 8.0E+02 | 1.0E-04 | |
| 28 | Pm-147 | 6.0E+02 | 1.0E-04 | |
| 29 | Am-241 | 9.0E+02 | 1.0E-04 | |
| 30 | Am-243 | 5.0E+03 | 1.0E-04 | |
| 31 | Am-242m | 3.0E+02 | 9.7E-05 | |
| 32 | Pu-239 | 1.0E+04 | 8.4E-05 | |
| 33 | Pu-240 | 3.0E+02 | 8.4E-05 | |

| No. | Target nuclide | Regulatory concentration limit (Bq/L) | Internal exposure dose from ingestion of seafood (mSv/year) | Remarks |
|-----|----------------|---------------------------------------|---|----------------------------------|
| 34 | Ce-144 | 9.0E+00 | 8.4E-05 | |
| 35 | Pu-241 | 6.0E+01 | 8.1E-05 | |
| 36 | Pu-238 | 6.0E+02 | 7.8E-05 | |
| 37 | Ni-63 | 3.0E+02 | 7.7E-05 | |
| 38 | Cm-243 | 9.0E+01 | 6.3E-05 | |
| 39 | Cm-244 | 8.0E+05 | 5.9E-05 | |
| 40 | Ce-141 | 3.0E+02 | 5.7E-05 | |
| 41 | Cm-242 | 1.0E+03 | 5.0E-05 | |
| 42 | Tb-160 | 2.0E+02 | 4.9E-05 | |
| 43 | Nb-95 | 2.0E+04 | 2.7E-05 | |
| 44 | Sb-125 | 4.0E+04 | 2.4E-05 | |
| 45 | Sb-124 | 9.0E+02 | 2.0E-05 | |
| 46 | Ru-103 | 3.0E+03 | 2.0E-05 | |
| 47 | Ru-106 | 3.0E+02 | 1.9E-05 | |
| 48 | Y-91 | 5.0E+02 | 1.7E-05 | |
| 49 | Cs-135 | 8.0E+03 | 6.2E-06 | |
| 50 | Cs-137 | 6.0E+02 | 6.1E-06 | |
| 51 | Cs-134 | 4.0E+02 | 5.9E-06 | |
| 52 | Cs-136 | 3.0E+03 | 4.7E-06 | |
| 53 | Te-129 | 3.0E+03 | 3.0E-06 | |
| 54 | Y-90 | 5.0E+02 | 2.0E-06 | |
| 55 | Ba-140 | 4.0E+00 | 9.8E-07 | |
| 56 | Pr-144 | 4.0E+00 | 6.7E-07 | |
| 57 | Rb-86 | 4.0E+00 | 6.3E-07 | |
| 58 | Sr-90 | 2.0E+02 | 2.9E-07 | |
| 59 | Sr-89 | 5.0E+00 | 2.7E-07 | |
| 60 | Rh-103m | 5.0E+00 | 1.8E-07 | |
| 61 | H-3 | 5.0E+00 | 1.3E-07 | |
| 62 | Rh-106 | 6.0E+01 | 0.0E+00 | Assessed with the parent nuclide |
| 63 | Ba-137m | 6.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| 64 | Pr-144m | 7.0E+00 | 0.0E+00 | Assessed with the parent nuclide |

Table C-4 Result of the external exposure assessment from beach sand in the case of discharge of each nuclide at the regulatory concentration limit

| | Nuclide | Regulatory concentration limit (Bq/L) | Exposure from beach sand (mSv/year) | Remarks |
|----|---------|---------------------------------------|-------------------------------------|---|
| 1 | Te-127 | 5.0E+03 | 1.0E-02 | For the dose conversion factor, refer to the value of Co-60 |
| 2 | Eu-155 | 3.0E+03 | 6.2E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 3 | Gd-153 | 3.0E+03 | 6.2E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 4 | Sn-119m | 2.0E+03 | 4.1E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 5 | Nb-95 | 1.0E+03 | 2.1E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 6 | Ru-103 | 1.0E+03 | 2.1E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 7 | Ce-141 | 1.0E+03 | 2.1E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 8 | Pm-146 | 9.0E+02 | 1.9E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 9 | Te-123m | 6.0E+02 | 1.2E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 10 | Cs-135 | 6.0E+02 | 1.2E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 11 | Pm-148m | 5.0E+02 | 1.0E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 12 | Tb-160 | 5.0E+02 | 1.0E-03 | For the dose conversion factor, refer to the value of Co-60 |
| 13 | Co-58 | 1.0E+03 | 8.4E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 14 | Sn-123 | 4.0E+02 | 8.3E-04 | |
| 15 | Mn-54 | 1.0E+03 | 7.0E-04 | |
| 16 | Rb-86 | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 17 | Sr-89 | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 18 | Y-91 | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 19 | Ag-110m | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 20 | Cd-115m | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 21 | Sb-124 | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 22 | Te-127m | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 23 | Te-129m | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 24 | Cs-136 | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 25 | Ba-140 | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 26 | Pm-148 | 3.0E+02 | 6.2E-04 | For the dose conversion factor, refer to the value of Co-60 |
| 27 | Eu-152 | 6.0E+02 | 5.5E-04 | |
| 28 | Co-60 | 2.0E+02 | 4.1E-04 | |
| 29 | Eu-154 | 4.0E+02 | 4.0E-04 | |
| 30 | Sb-125 | 8.0E+02 | 2.9E-04 | |
| 31 | Zn-65 | 2.0E+02 | 9.7E-05 | |
| 32 | Cs-134 | 6.0E+01 | 8.2E-05 | |
| 33 | Cs-137 | 9.0E+01 | 4.8E-05 | |
| 34 | Ru-106 | 1.0E+02 | 1.9E-05 | |
| 35 | Pu-241 | 2.0E+02 | 1.8E-05 | |

| | Nuclide | Regulatory concentration limit (Bq/L) | Exposure from beach sand (mSv/year) | Remarks |
|----|---------|---------------------------------------|-------------------------------------|--|
| 36 | Ce-144 | 2.0E+02 | 8.8E-06 | |
| 37 | Te-125m | 9.0E+02 | 7.5E-06 | |
| 38 | Sn-126 | 2.0E+02 | 4.6E-06 | |
| 39 | Cm-243 | 6.0E+00 | 8.2E-07 | For the dose conversion factor, refer to the value of Am-243 |
| 40 | Am-243 | 5.0E+00 | 6.8E-07 | |
| 41 | Sr-90 | 3.0E+01 | 1.6E-07 | |
| 42 | I-129 | 9.0E+00 | 5.1E-08 | |
| 43 | Pm-147 | 3.0E+03 | 4.6E-08 | |
| 44 | Am-242m | 5.0E+00 | 4.4E-08 | |
| 45 | Am-241 | 5.0E+00 | 3.7E-08 | |
| 46 | Fe-59 | 4.0E+02 | 2.8E-08 | |
| 47 | Tc-99 | 1.0E+03 | 2.8E-08 | |
| 48 | Sm-151 | 8.0E+03 | 2.2E-08 | |
| 49 | Cm-242 | 6.0E+01 | 9.8E-09 | |
| 50 | Cd-113m | 4.0E+01 | 7.2E-09 | |
| 51 | Cm-244 | 7.0E+00 | 1.1E-09 | |
| 52 | Pu-238 | 4.0E+00 | 6.3E-10 | |
| 53 | Pu-240 | 4.0E+00 | 6.2E-10 | |
| 54 | Pu-239 | 4.0E+00 | 3.7E-10 | |
| 55 | H-3 | 6.0E+04 | 0.0E+00 | |
| 56 | C-14 | 2.0E+03 | 0.0E+00 | |
| 57 | Ni-63 | 6.0E+03 | 0.0E+00 | |
| 58 | Y-90 | 3.0E+02 | 0.0E+00 | Assessed with the parent nuclide |
| 59 | Rh-103m | 2.0E+05 | 0.0E+00 | Assessed with the parent nuclide |
| 60 | Rh-106 | 3.0E+05 | 0.0E+00 | Assessed with the parent nuclide |
| 61 | Te-129 | 1.0E+04 | 0.0E+00 | Assessed with the parent nuclide |
| 62 | Ba-137m | 8.0E+05 | 0.0E+00 | Assessed with the parent nuclide |
| 63 | Pr-144 | 2.0E+04 | 0.0E+00 | Assessed with the parent nuclide |
| 64 | Pr-144m | 4.0E+04 | 0.0E+00 | Assessed with the parent nuclide |

*Nuclides subject to management are hatched

Table C-5 Result of the environmental protection assessment in the case of discharge of each nuclide at the regulatory concentration limit

| | Nuclide | Regulatory concentration limit (Bq/L) | Exposure assessment result (mGy/day) | | | Remarks |
|----|---------|---------------------------------------|--------------------------------------|---------|---------------|---------|
| | | | Flatfish | Crab | Brown seaweed | |
| 1 | Fe-59 | 4.0E+02 | 5.4E-01 | 5.4E-01 | 5.8E-01 | |
| 2 | Sn-126 | 2.0E+02 | 9.7E-03 | 9.3E-03 | 9.0E-03 | |
| 3 | Pm-148m | 5.0E+02 | 7.5E-03 | 7.2E-03 | 8.1E-03 | |
| 4 | Mn-54 | 1.0E+03 | 6.6E-03 | 6.0E-03 | 6.6E-03 | |
| 5 | Eu-152 | 6.0E+02 | 5.4E-03 | 5.1E-03 | 5.4E-03 | |
| 6 | Pm-146 | 9.0E+02 | 5.1E-03 | 4.9E-03 | 5.4E-03 | |
| 7 | Tb-160 | 5.0E+02 | 4.2E-03 | 4.2E-03 | 4.5E-03 | |
| 8 | Eu-154 | 4.0E+02 | 3.8E-03 | 3.6E-03 | 3.8E-03 | |
| 9 | Nb-95 | 1.0E+03 | 2.3E-03 | 2.3E-03 | 2.4E-03 | |
| 10 | Gd-153 | 3.0E+03 | 2.2E-03 | 2.0E-03 | 2.5E-03 | |
| 11 | Pm-148 | 3.0E+02 | 1.5E-03 | 1.4E-03 | 2.0E-03 | |
| 12 | Eu-155 | 3.0E+03 | 1.3E-03 | 1.3E-03 | 1.3E-03 | |
| 13 | Co-58 | 1.0E+03 | 1.1E-03 | 1.1E-03 | 1.1E-03 | |
| 14 | Sn-123 | 4.0E+02 | 1.0E-03 | 9.7E-04 | 1.0E-03 | |
| 15 | Sn-119m | 2.0E+03 | 9.6E-04 | 9.1E-04 | 6.7E-04 | |
| 16 | Ce-141 | 1.0E+03 | 8.6E-04 | 8.2E-04 | 8.9E-04 | |
| 17 | Co-60 | 2.0E+02 | 5.6E-04 | 5.6E-04 | 6.1E-04 | |
| 18 | Ce-144 | 2.0E+02 | 4.7E-04 | 2.7E-04 | 4.7E-04 | |
| 19 | Ru-103 | 1.0E+03 | 7.4E-05 | 7.4E-05 | 7.6E-05 | |
| 20 | Cd-115m | 3.0E+02 | 4.4E-05 | 1.9E-04 | 8.3E-06 | |
| 21 | Ag-110m | 3.0E+02 | 4.1E-05 | 2.3E-04 | 3.5E-05 | |
| 22 | Y-91 | 3.0E+02 | 3.6E-05 | 2.2E-05 | 1.6E-04 | |
| 23 | Zn-65 | 2.0E+02 | 3.3E-05 | 6.6E-05 | 3.2E-05 | |
| 24 | C-14 | 2.0E+03 | 1.0E-05 | 8.4E-06 | 6.7E-06 | |
| 25 | Cs-136 | 3.0E+02 | 9.5E-06 | 9.4E-06 | 9.4E-06 | |
| 26 | Te-127 | 5.0E+03 | 9.4E-06 | 9.4E-06 | 8.7E-05 | |
| 27 | Am-243 | 5.0E+00 | 8.8E-06 | 1.1E-05 | 9.7E-06 | |
| 28 | Ru-106 | 1.0E+02 | 6.4E-06 | 6.4E-06 | 7.6E-06 | |
| 29 | Cm-243 | 6.0E+00 | 5.8E-06 | 1.5E-05 | 9.4E-06 | |
| 30 | Ba-140 | 3.0E+02 | 5.6E-06 | 7.7E-06 | 1.0E-05 | |
| 31 | Sb-124 | 3.0E+02 | 5.1E-06 | 4.8E-06 | 6.1E-06 | |
| 32 | Sb-125 | 8.0E+02 | 3.2E-06 | 3.0E-06 | 4.0E-06 | |
| 33 | Pm-147 | 3.0E+03 | 2.9E-06 | 3.9E-05 | 2.7E-05 | |
| 34 | Cd-113m | 4.0E+01 | 1.7E-06 | 7.8E-06 | 1.4E-07 | |
| 35 | Te-129m | 3.0E+02 | 1.6E-06 | 1.6E-06 | 1.5E-05 | |

| | Nuclide | Regulatory concentration limit (Bq/L) | Exposure assessment result (mGy/day) | | | Remarks |
|----|---------|---------------------------------------|--------------------------------------|---------|---------------|----------------------------------|
| | | | Flatfish | Crab | Brown seaweed | |
| 36 | Sm-151 | 8.0E+03 | 1.5E-06 | 3.3E-05 | 1.3E-05 | |
| 37 | Cs-134 | 6.0E+01 | 1.5E-06 | 1.4E-06 | 1.5E-06 | |
| 38 | Te-125m | 9.0E+02 | 1.0E-06 | 1.0E-06 | 8.8E-06 | |
| 39 | Am-241 | 5.0E+00 | 9.4E-07 | 3.1E-06 | 9.7E-07 | |
| 40 | Te-123m | 6.0E+02 | 9.0E-07 | 9.2E-07 | 5.4E-06 | |
| 41 | Cs-137 | 9.0E+01 | 8.0E-07 | 7.7E-07 | 8.0E-07 | |
| 42 | Rb-86 | 6.0E+01 | 7.8E-07 | 9.9E-05 | 3.7E-05 | |
| 43 | Cm-242 | 3.0E+02 | 7.7E-07 | 7.7E-07 | 7.2E-06 | |
| 44 | Te-127m | 5.0E+00 | 7.2E-07 | 8.0E-07 | 1.3E-06 | |
| 45 | Am-242m | 3.0E+02 | 6.7E-07 | 5.3E-07 | 1.3E-06 | |
| 46 | Pu-238 | 4.0E+00 | 4.6E-07 | 3.1E-07 | 7.6E-07 | |
| 47 | Pu-240 | 4.0E+00 | 4.3E-07 | 2.9E-07 | 7.1E-07 | |
| 48 | Pu-239 | 4.0E+00 | 4.3E-07 | 2.9E-07 | 7.1E-07 | |
| 49 | Ni-63 | 6.0E+03 | 2.3E-07 | 5.5E-06 | 1.7E-06 | |
| 50 | Cm-244 | 7.0E+00 | 8.6E-08 | 1.1E-05 | 4.2E-06 | |
| 51 | Tc-99 | 1.0E+03 | 6.7E-08 | 1.5E-05 | 4.5E-05 | |
| 52 | Sr-89 | 3.0E+02 | 6.1E-08 | 2.1E-07 | 6.0E-08 | |
| 53 | Cs-135 | 6.0E+02 | 5.3E-08 | 2.9E-08 | 4.3E-08 | |
| 54 | Pu-241 | 2.0E+02 | 2.2E-08 | 1.5E-08 | 3.7E-08 | |
| 55 | Sr-90 | 3.0E+01 | 1.1E-08 | 4.1E-08 | 1.1E-08 | |
| 56 | H-3 | 6.0E+04 | 4.7E-09 | 4.7E-09 | 1.8E-09 | |
| 57 | I-129 | 9.0E+00 | 9.1E-11 | 5.2E-08 | 2.3E-08 | |
| 58 | Y-90 | 3.0E+02 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| 59 | Rh-103m | 2.0E+05 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| 60 | Rh-106 | 3.0E+05 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| 61 | Te-129 | 1.0E+04 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| 62 | Ba-137m | 8.0E+05 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| 63 | Pr-144 | 2.0E+04 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |
| 64 | Pr-144m | 4.0E+04 | 0.0E+00 | 0.0E+00 | 0.0E+00 | Assessed with the parent nuclide |

* Nuclides subject to management are hatched

C2. Setting of management values

In the analysis results of tanks and ALPS outlet water, seven nuclides excluding C-14 were not detected among the nuclides subject to management. The management values of the undetected nuclides are obtained by rounding up 120% of the minimum detection limit (larger result of the two tank groups) in the secondary treatment performance test considering errors. That of C-14, which was detected, is obtained by rounding up the concentration twice as high as the maximum value.

Figure C-1 and Table C-6 show the setting flow of management values and the set management values, respectively.




Figure C-1 Flow of setting of management values

Table C-6 Set management values

| Undetected nuclide | Nuclide | Regulatory concentration limit (Bq/L) | Minimum detection limit (Bq/L) | Minimum detection limit ×1.2 (Bq/L) | Operation and management value (Bq/L) | Ratio to regulatory concentration limit |
|--|------------------|---------------------------------------|---------------------------------------|-------------------------------------|---------------------------------------|---|
| | Fe-59 | 4.0E+02 | 8.66E-02 | 1.04E-01 | 2E-01 | 5.0E-04 |
| | Ag-110m | 3.0E+02 | 4.26E-02 | 5.11E-02 | 6E-02 | 2.0E-04 |
| | Cd-113m | 4.0E+01 | 8.55E-02 | 1.03E-01 | 2E-01 | 5.0E-03 |
| | Cd-115m | 3.0E+02 | 2.70E+00 | 3.24E+00 | 4E+00 | 1.3E-02 |
| | Sn-119m | 2.0E+03 | 4.24E+01 | 5.09E+01 | 6E+01 | 3.0E-02 |
| | Sn-123 | 4.0E+02 | 6.59E+00 | 7.91E+00 | 8E+00 | 2.0E-02 |
| | Sn-126 | 2.0E+02 | 2.92E-01 | 3.50E-01 | 4E-01 | 2.0E-03 |
| | Detected nuclide | Nuclide | Regulatory concentration limit (Bq/L) | Maximum detected value (Bq/L) | Maximum detected value×2 (Bq/L) | Operation and management value (Bq/L) |
| C-14 | | 2.0E+03 | 2.15E+02 | 4.30E+02 | 5E+02 | 2.5E-01 |
| Total of regulatory concentration ratios | | | | | | 3.2E-01 |

C3. Simulation assessment of human exposure from ALPS treated water

To verify that the management values set in C2. reduce the risk caused by the uncertainty of the source term, we assessed the exposure from continuous discharge of simulated ALPS treated water containing only nuclides with relatively great impacts of exposure such as the nuclides subject to management as a very conservative assessment, though such ALPS treated water cannot exist in reality.

a. Setting of the source terms

Based on the following steps, we set the source term of each nuclide (annual discharge amount) of each nuclide as shown in Table C-7.

- The annual discharge amount of tritium shall be the upper limit: 22 TBq (2.2E+13Bq).
- The annual discharge volume of ALPS treated water is conservatively estimated as 220 million L (2.2E+08L) by setting a low tritium concentration of ALPS treated water used for the assessment to 100 thousand Bq/L below the minimum concentration of tritium confirmed so far (about 150 thousand Bq/L). Because of this, the annual discharge amount of nuclides other than tritium is conservatively estimated.
- Among 63 nuclides other than tritium, the management value, which is the upper limit, is set to the concentrations of 8 nuclides with relatively great impacts on exposure. The sum of the ratios to regulatory concentrations limits of the 8 nuclides is 0.32.
- For the other 55 nuclides, Zn-65, whose impact on exposure is relatively great following the 8 nuclides subject to management, shall be assessed, and the concentration of Zn-65 is set to 140Bq/L, which is equivalent to the regulatory concentration ratio of 0.68. Because of this, the sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium become 1, which is the upper limit value in discharge management.
- Set the annual discharge amount of 9 nuclides by multiplying the concentrations of the 8 nuclides subject to management and Zn-65 by the annual discharge volume of water of 220 million L.

b. Concentration of each nuclide used for the exposure assessment in the seawater

For the concentration of each nuclide in the seawater used for exposure assessment, the concentration of the other nuclides was calculated from the ratio of tritium to the annual discharge amount of the other nuclides in the source term based on the annual average concentration within 10 km × 10 km and the annual average concentration of the sandy beach assessment point in the tritium concentration in the seawater (all layers) in Table 6-1-17. Table C-8 shows the concentration of each nuclide in the seawater used for the assessment.

c. Exposure assessment method

The migration pathway, the exposure pathway, exposure assessment method, and the setting of the representative person are the same as those of 6-1. "Exposure assessment under normal conditions".

d. Exposure assessment result

Table C-9 shows the result of the exposure assessment using the source term with simulated ALPS treated water containing only the nuclides with relatively great impacts on exposure. Even if the source term that seems to be the most conservative in terms of discharge management is used, the results were much smaller than the dose limit of 1 mSv/year for the general public and the dose target of 0.05 mSv/year, which is equivalent to the dose constraint value.

Table C-7 Source term using hypothetical ALPS treated water (annual discharge amount)

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual discharge amount (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|------------------------------|---|
| H-3 | 1.0E+05 | 2.2E+08 | 2.2E+13 | <ul style="list-style-type: none"> For the annual discharge amount of tritium, the upper limit value is used. In actual discharge, the water is diluted with seawater 100 or more times so that the tritium concentration will become less than 1,500Bq/L, so the Sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium in the discharged water will be less than 0.01. |
| C-14 | 5.0E+02 | | 1.1E+11 | |
| Fe-59 | 2.0E-01 | | 4.4E+07 | |
| Zn-65 | 1.4E+02 | | 3.1E+10 | |
| Ag-110m | 6.0E-02 | | 1.3E+07 | |
| Cd-113m | 2.0E-01 | | 4.4E+07 | |
| Cd-115m | 4.0E+00 | | 8.8E+08 | |
| Sn-119m | 6.0E+01 | | 1.3E+10 | |
| Sn-123 | 8.0E+00 | | 1.8E+09 | |
| Sn-126 | 4.0E-01 | | 8.8E+07 | |

Table C-8 Concentration in the seawater used for the assessment (Source term using hypothetical ALPS treated water)

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------|------------------------------|--|---|---|
| | | Average of all layers within 10×10 km | Average of the top layers within 10×10 km | Average of all layers of the sandy beach assessment point |
| H-3 | 2.2E+13 | 5.6E-02 | 1.2E-01 | 8.8E-01 |
| C-14 | 1.3E+09 | 2.8E-04 | 6.0E-04 | 4.4E-03 |
| Fe-59 | 5.9E+06 | 1.1E-07 | 2.4E-07 | 1.8E-06 |
| Zn-65 | 6.5E+06 | 7.8E-05 | 1.7E-04 | 1.2E-03 |
| Ag-110m | 3.3E+06 | 3.4E-08 | 7.2E-08 | 5.3E-07 |
| Cd-113m | 7.0E+06 | 1.1E-07 | 2.4E-07 | 1.8E-06 |
| Cd-115m | 1.9E+08 | 2.2E-06 | 4.8E-06 | 3.5E-05 |
| Sn-119m | 3.3E+09 | 3.4E-05 | 7.2E-05 | 5.3E-04 |
| Sn-123 | 5.1E+08 | 4.5E-06 | 9.6E-06 | 7.0E-05 |

| Target nuclide | Annual discharge amount (Bq) | Concentration in the seawater used for the assessment (Bq/L) | | |
|----------------------------|------------------------------|--|---|---|
| | | Average of all layers within 10×10 km | Average of the top layers within 10×10 km | Average of all layers of the sandy beach assessment point |
| Sn-126 | 1.2E+07 | 2.2E-07 | 4.8E-07 | 3.5E-06 |
| Target exposure assessment | | From fishing nets Ingestion of seafood | From sea surface From hulls | During swimming From beach sand Ingestion of seawater Inhalation of seawater spray |

Table C-9 Human exposure assessment result (Assessment area: 10 km × 10 km)

| Assessed case | Source term | Source term using hypothetical ALPS treated water | |
|------------------------------|----------------------|---|---------|
| | | Average | Large |
| External exposure (mSv/year) | Sea surface | 1.8E-07 | |
| | Hull | 1.4E-07 | |
| | During swimming | 1.2E-07 | |
| | Beach sand | 2.2E-04 | |
| | Fishing net | 4.5E-05 | |
| Internal exposure (mSv/year) | Ingestion of water | 4.6E-07 | |
| | Inhalation of spray | 2.1E-07 | |
| | Ingestion of seafood | 4.8E-04 | 2.0E-03 |
| Total (mSv/year) | | 7E-04 | 2E-03 |

**Table C-10 Assessment result of internal exposure from ingestion of seafood by age
(10 km × 10 km)**

| Assessed case | Source term | Source term using hypothetical ALPS treated water | |
|--|------------------------|---|---------|
| | Ingestion of seafood | Average | Large |
| Internal exposure from ingestion of seawater (mSv/year) | Adult | 4.6E-07 | |
| | Child under school age | 8.7E-07 | |
| | Infant | - | |
| Internal exposure from inhalation of seawater spray (mSv/year) | Adult | 2.1E-07 | |
| | Child under school age | 1.6E-07 | |
| | Infant | 1.0E-07 | |
| Internal exposure from ingestion of seafood (mSv/year) | Adult | 4.8E-04 | 2.0E-03 |
| | Child under school age | 7.5E-04 | 3.1E-03 |
| | Infant | 9.4E-04 | 3.9E-03 |

C4. Assessment of environmental protection with ALPS treated water

As with the human exposure assessment, we assessed exposure of animals and plants in the case of continuous discharge of simulated ALPS treated water.

a. Setting of the source terms

As with C3. a. Setting of the source term, based on the following steps, we set the source term of each nuclide (annual discharge amount) of each nuclide as shown in Table C-11.

- The annual discharge amount of tritium shall be the upper limit: 22 TBq ($2.2E+13$ Bq).
- The annual discharge volume of ALPS treated water is conservatively estimated as 220 million L ($2.2E+08$ L) by setting a low tritium concentration of ALPS treated water used for the assessment to 100 thousand Bq/L below the minimum concentration of tritium confirmed so far (about 150 thousand Bq/L). Because of this, the annual discharge amount of nuclides other than tritium is conservatively estimated.
- Among 63 nuclides other than tritium, the management value, which is the upper limit, is set to the concentrations of 2 nuclides with relatively great impacts on exposure. The sum of the ratios to regulatory concentrations limits of the 2 nuclides (Fe-59 and Sn-126) is 0.0025 ($2.5E-03$).
- For the other 61 nuclides, Pm-148m, whose impact on exposure is relatively great following the 2 nuclides subject to management, shall be assessed, and the concentration of Pm-148m is set to 499Bq/L, which is equivalent to the regulatory concentration ratio of 0.9975 ($9.975E-01$). Because of this, the sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium become 1, which is the upper limit value in discharge management.
- Set the annual discharge amount of 3 nuclides by multiplying the concentrations of the 2 nuclides subject to management and Pm-148m by the annual discharge volume of water of 220 million L.

b. Concentration of each nuclide used for the exposure assessment in the seawater

For the concentration of each nuclide in the seawater used for exposure assessment, the concentration of the other nuclides was calculated from the ratio of tritium to the annual discharge amount of the other nuclides in the source term based on the tritium concentration in the seawater (bottom layer) in Table 7-3-1. Table C-12 shows the concentration of each nuclide in the seawater used for the assessment.

c. Exposure assessment method

The migration pathway, the exposure pathway, exposure assessment method, and the setting of the representative person are the same as those of 7. Assessment of environmental protection.

d. Exposure assessment result

Table C-13 shows the result of the exposure assessment of the standard animals and plants using the source term with simulated ALPS treated water containing only the nuclides with relatively great impacts on exposure. Even if the source term, which seems to be the most conservative in terms of discharge management, is used, the dose rate is much lower than the lower limit value of derived consideration reference level (DCRL)

Table C-11 Source term using hypothetical ALPS treated water (annual discharge amount)

| Target nuclide | Nuclide concentration (Bq/L) | Annual discharge volume of water (L) | Annual volume of discharge (Bq) | Remarks |
|----------------|------------------------------|--------------------------------------|---------------------------------|---|
| H-3 | 1.0E+05 | 2.2E+08 | 2.2E+13 | <ul style="list-style-type: none"> • For the annual discharge amount of tritium, the upper limit value is used. • In actual discharge, the water is diluted with seawater 100 or more times so that the tritium concentration will become less than 1,500Bq/L, so the Sum of the ratios to regulatory concentrations limits of 63 nuclides other than tritium in the discharged water will be less than 0.01. |
| Fe-59 | 2.0E-01 | | 4.4E+07 | |
| Sn-126 | 4.0E-01 | | 8.8E+07 | |
| Pm-148m | 5.0E+02 | | 1.1E+11 | |

Table C-12 Concentration in the seawater used for the assessment (Source term using hypothetical ALPS treated water)

| Target nuclide | Annual volume of discharge (Bq) | Concentration in the seawater used for the assessment (Bq/L) |
|----------------------------|---------------------------------|--|
| | | Within 10 × 10 km Average of the bottom layer |
| H-3 | 2.2E+13 | 5.6E-02 |
| Fe-59 | 4.4E+07 | 1.2E-07 |
| Sn-126 | 8.8E+07 | 2.4E-07 |
| Pm-148m | 1.1E+11 | 3.0E-04 |
| Target exposure assessment | | Environmental protection |

Table C-13 Assessment result regarding environmental protection

| Assessed case | | Source term using hypothetical ALPS treated water |
|---|---------------|---|
| Exposure (mGy/day) | Flatfish | 7.8E-03 |
| | Crab | 7.5E-03 |
| | Brown seaweed | 8.4E-03 |
| derived consideration reference level (DCRL) | | |
| Flatfish: 1-10 mGy/day Crab: 10-100 mGy/day Brown seaweed: 1-10 mGy/day | | |

Reference D Assessment result of environmental impacts including other elements than radiation related to discharge of ALPS treated water

We have assessed non-radiological environmental impacts associated with the discharge of ALPS treated water into the sea. This document presents the result of our review of whether non-radiological factors associated with the presence and operation of facilities and its construction related to the discharge of ALPS treated water into the sea “could cause substantial pollution or significant and harmful changes in the marine environment.” In conclusion, we have assessed that none of such element was associated with such risks. First, we analyzed the measurement items specified in the Water Pollution Prevention Law and related ordinances of Fukushima Prefecture other than radioactive materials contained in the stored ALPS treated water. The analysis result is described in Attachment II “Properties of ALPS treated water,” with which we verified that all measurement items are below the standard values and that even if these water are discharged into the water, any significant or harmful changes will not occur in the marine environment due to non-radioactive substances contained in these water in the case of discharge into the sea. Moreover, we also assessed the possibility for non-radiological environmental impacts from discharge of ALPS treated water into the sea or its method. Tables D-1 and D-2 show the systems subject to the assessment and their overview, and the overview of the assessment result, respectively. We considered the following two factors as those which may cause an impact:

- a. Presence or operation of the facilities related to discharge of ALPS treated water into the sea (facilities related to measurement/confirmation, transfer, dilution, and discharge) (middle column);
- b. Implementation of installation or operation of the facilities (right column).

We assessed the possible impacts of these influencing factors on the components of various environment such as air quality, water quality, geology, terrain, soil, and ecosystem. We also included the impacts of the radioactivity which already exist in the environment as the targets of the assessment. As a result, the expected effects on these components of the environment were evaluated to be either none or sufficiently small to be negligible. The targets are the same conditions as those of discharge of ALPS treated water into the sea, impacts of discharge of contents, and impacts of construction of the related facilities assumed in the radiation impact assessment handled in this report.

Table D-1 Facilities related to discharge of ALPS treated water into the sea

| Classification of facilities | Facilities | Specifications |
|---|---|--|
| Measurement /confirmation facilities | Measurement/confirmation tanks | For measurement and confirmation, reuse 30 out of 35 current units (about 34 thousand m ³) installed in the K 4 area as facilities |
| | Circulation pump | 160 m ³ /h/unit × 2 units |
| | Stirring equipment | One unit per tank, A total of 30 units |
| | Piping, valve, etc. | Connecting tube (nominal diameter of the pressure hose equivalent to 200A or steel pipe 100A) Duplicate boundary valves in series to prevent water mixing among tank groups |
| Transfer facilities | ALPS treated water transfer pump | 30 m ³ /h/unit × 2 units (1 reserve) |
| | Emergency isolation valve | Install two valves with different operating principles and installation locations in series for multiplexing and diversification |
| | Flowmeter | |
| | Other valves, piping, etc. | |
| Dilution facilities | Water intake channel | Reuse the Unit 5 facility |
| | Seawater transfer pump | 7,086 m ³ /h × 3 units |
| | Flowmeter | |
| | Seawater pipe header | Nominal diameters of 2200A and 1800A |
| | Discharge vertical shaft (upper-stream storage) | 1 reinforced concrete storage, Height about 37 m × Width about 18 m × Depth about 7 m, Capacity about 2,000 m ³ |
| | Other valves, piping, etc. | |
| Related facilities | Discharge vertical shaft (down-stream storage) | 1 reinforced concrete storage, Height about 7 m × Width about 12m × Depth about 18 m, Capacity about 800 m ³ |
| | Discharge tunnel | Shield tunnel, Inner diameter about 3 m, Overall length about 1 km |
| | Discharge outlet | Discharge outlet caisson: W about 9 m × D about 12 m × H about 10 m (Discharge outlet: 3 m in four directions, Height 2 m) Backfill the upper base about 40 m × about 40 m, lower base about 16 m × about 16 m, and depth about 11 m in the surrounding with anti-washout underwater concrete, etc. |

For the allocation, installation, and operation of these facilities, we made the following considerations in order to reduce the impacts on the environment as much as possible.

- We made considerations to prevent new terrain modifications by reusing 30 tanks out of a total of 35 tanks of the existing K4 area tank group (about 34,000 m³) for facilities for measurement and confirmation (the other 5 tanks continue to be used as ALPS treated water storage) as facilities related to discharge of ALPS treated water into the sea.
- The dilution facilities to be newly installed shall be installed in the existing development area in the FDNPS to prevent new terrain modifications excluding discharge vertical shafts and tunnel outlets.
- For the water intake channel, the existing Unit 5 water intake channel is reused to avoid new terrain modifications.
- Discharge is designed to minimize the impacts of the presence, operation, and construction of facilities by the undersea tunnel method, which affects no impact to the terrain such as seabed surface by drilling bedrock, for maximum environmental protection.

Table D-2 shows the details of the consideration of the items of environmental impact assessments of other elements than radiation based on the plan reflecting these design considerations. All of them were judged to have no impact on the environment.

Table D-2 TEPCO's consideration result of the non-radiological environmental impact assessment of nuclides contained in the ALPS treated water¹

| Impact factors | Presence and operation of the facilities | Implementation of construction |
|--|--|--|
| Environmental elements | Presence of facilities related to discharge of ALPS treated water into the sea - Discharge of ALPS treated water using the facilities | Construction of facilities related to discharge of ALPS treated water into the sea |
| Atmosphere environment (Air quality and noise/vibration) | The motor operation method or pneumatic method shall be adopted for the power to drive active components such as pumps or valves and no facility to emit air pollutants shall be installed. In addition, the total flow rate of 3 seawater dilution pumps in normal operation for discharge of ALPS treated water and 1 ALPS treated water transfer pump (maximum daily amount: about 510 thousand m ³) is smaller than that in normal operation of the circulation water pump of a general nuclear power plant (about 9 times as large daily amount in Unit 1, which is the smallest, if FDNPS before the accident is used as an example: about 4.25 million m ³). The area surrounding the FDNPS is used as an intermediate storage facility | The ships used for construction are 1 dredger, 2 crane barges, and 1 concrete plant vessel (not operated simultaneously). Heavy equipment is up to about 20 units/day. The shield machine (diameter of about 3m) is one unit. Material transportation is up to about 30 units/day. Only the installation of the intake and discharge facilities is construction out of the site and most of the installation of the intake and discharge facilities is construction of the undersea tunnel. The construction is limited to the inside of the FDNPS and the area where no fishing is conducted on a daily basis and the surrounding area of the FDNPS within about 2 km from the place of construction are used for the |

¹ Based on table 1.1 in "Environmental Impact Assessment Technical Guide" p.6.

| Impact factors | Presence and operation of the facilities | Implementation of construction |
|--|--|--|
| Environmental elements | Presence of facilities related to discharge of ALPS treated water into the sea - Discharge of ALPS treated water using the facilities | Construction of facilities related to discharge of ALPS treated water into the sea |
| | completely surrounding the land side of the FDNPS, and the closest place in the outside Difficult-to-Return Zone is at least 1 km away from the site boundary of FDNPS and about 2 km away from the place assumed to be the construction site (seaside area of Unit 5). Therefore, there is no target whose impact on the life environment should be assessed within the possible range of noise, vibration, etc. | intermediate storage facilities, so there is no target whose impact on the life environment should be assessed within the range where noise, vibration, etc., caused by the construction may cause any impact. |
| Water environment (Water quality/Water temperature/Flow velocity)* Other than radioactive materials | <p>ALPS treated water is contaminated water with the contained radioactive materials eliminated by coagulating sedimentation, absorbents, filters, etc. Heavy metal, infusible suspended substances, organic substances, etc., are eliminated. No treatment to increase the pollution load, which causes an increase in COD, etc., is performed. It was verified in past measurement² that the water quality of ALPS treated water sufficiently meets the wastewater standard. Moreover, in actual discharge of ALPS treated water, the water to be discharged shall be verified to meet the wastewater standard.</p> <p>In addition, seawater to be taken and discharged is only used for dilution of ALPS treated water and is not heated. The temperature of ALPS treated water stored on land may change due to the ambient temperature. However, it is not in an equilibrium state with the seawater temperature and discharged after diluted 100 or more times with seawater, so there is almost no difference between the temperatures of wastewater and seawater.</p> <p>The discharge flow velocity from the discharge outlet is as slow as about 1m/s even in the case of the maximum flow rate with the three seawater dilution pumps in operation. Water is discharged straight up from the seabed with a water depth of about 12 m. Therefore, changes</p> | There is no target to be assessed because occurrence of water turbidity caused by the construction is deemed to be limited because the construction of the intake facilities is performed in the port, most of the discharge facilities is constructed by the shield method as undersea tunnels, and a rocky shore is selected as the site for tunnel outlets. |

² December 28, 2018 "Analysis of chemical substances in ALPS treated water tanks"
https://www.meti.go.jp/earthquake/nuclear/osensuitaisaku/committee/takakusyu/pdf/012_04_01.pdf

| Impact factors | Presence and operation of the facilities | Implementation of construction |
|---|--|--|
| Environmental elements | Presence of facilities related to discharge of ALPS treated water into the sea - Discharge of ALPS treated water using the facilities | Construction of facilities related to discharge of ALPS treated water into the sea |
| | in the flow velocity are limited to near the discharge outlet. | |
| Other environments (terrain/geology, subgrade, and soil) | The discharge flow velocity from the discharge outlet is as slow as about 1m/s even in the case of the maximum flow rate with the three seawater dilution pumps in operation. Water is discharged straight up from the seabed. The protrusion from the seabed height is limited to a height of about 2 m within about 3 m in the four directions. The square area of about 40 m around the discharge outlet (about 1,600 m ²) is backfilled. Therefore, changes in the flow velocity are limited to near the discharge outlet, and there is no risk of scouring. Pumping of groundwater, which causes ground subsidence, shall not be performed and it is planned not to use any substance which causes soil contamination. | Terrain modifications are limited to very small areas, namely the discharge vertical shaft (upper-stream storage of about 670 m ² , down-stream storage of about 80 m ² , a total of about 750 m ²) and the outlet of the undersea tunnel (about 1,600 m ²) by avoiding new terrain modifications by reuse of the existing facilities, installation of the undersea tunnel by the shield method which gives very low change to terrain drilling bedrock. |
| Animals, plants, and ecosystem | Most of the facilities are installed in places where site preparation has been completed within the site of the FDNPS. The facility for discharge is an undersea tunnel and requires the minimum necessary area of about 40 m x about 40 m (about 1,600 m ²) near the outlet. The impact of discharge of ALPS treated water on tidal currents, etc., is small and there is almost no impact of the operation of the facility on organisms, because of ALPS treated water being diluted 100 or more times with the seawater of the adjacent sea and the low discharge flow velocity of about 1 m/s. | New terrain modifications are avoided by reuse of the existing facilities, installation of the undersea tunnel by the shield method, etc. No important species, habitat, etc., have been found in the sea area where construction is to be performed. |
| Rich natural environment (landscape, etc.) | There is no item to be assessed because the existing facilities are reused and the scale of the facilities to be newly installed is small. | Since the scales of the facilities to be installed are small, the traffic of vehicles for transportation of materials, etc., is assumed to be up to 20 vehicles/day, which is limited. |
| Environmental loads (waste, emission of greenhouse gas, etc.) | Discharge of ALPS treated water does not generate any new waste. In addition, the motor operation method or pneumatic method shall be adopted for the power to drive active components such as pumps or valves used for the facilities for discharging ALPS treated | Construction waste soil is generated (about 40 thousand m ³) associated with excavation of the undersea tunnel, but the generated amount is small and it is disposed of at the existing soil disposal site in the premises without transfer to outside. |

| Impact factors | Presence and operation of the facilities | Implementation of construction |
|--|--|---|
| Environmental elements | Presence of facilities related to discharge of ALPS treated water into the sea - Discharge of ALPS treated water using the facilities | Construction of facilities related to discharge of ALPS treated water into the sea |
| | water into the sea, so no greenhouse gas including that generated by combustion of fossil fuel is emitted. Therefore, there is no item to be assessed. | Therefore, there is no item to be assessed. |
| Radioactive materials already exist in environment | The planned discharge outlet is installed in a rocky shore outside the port, the surrounding square area of 40 m is backfilled with concrete, etc., and water is discharge straight up at a low flow velocity of about 1 m per second, so discharge of treated water does not swirl marine sediment or disperse radioactive materials. The seawater for diluting the ALPS treated water is planned to be drawn from the outside of the port (north side of the Unit 5/6 discharge outlet) by blocking the intake path opening channel with partition weir (rubble mound and sheet) from the port of the Unit 1-4 side considering that the concentration of radioactive materials is slightly higher than that of the seawater in the surrounding sea area and that it may swirl marine sediment, etc., in the port. As shown in attachment V "Impacts of intake and discharge of diluted water on outside," the result of the assessment of exposure considering the impact of the radioactive materials, which may be contained in drawn seawater in the case of intake of seawater outside this port is 9.6E-05 mSv/year, which is much lower than 0.05mv/year. | It is considered that construction in the port has almost no impact such as dispersion of radioactive materials, etc., thanks to installation of contamination prevention fences for construction, careful work at slower construction speed than usual, etc., in order to reduce sedimentation sand swirled in the port. It was confirmed that the concentration of radioactive materials in the seawater did not vary significantly during similar construction performed in the port (pouring materials such as riprap into the sea by using working crafts and backhoes) in the past three years ³ . Actually, the concentration of radioactive materials in the seawater in the port is below the domestic regulatory standard even inside the intake path opening channel of Units 1 to 4, in which the concentrations are relatively high (Cs-137 1E+00Bq/L order, Sr-90 1E+00Bq/L order, 10E+2Bq/L as of 2021) ⁴ . In addition, it is considered that the tunnel outlet construction outside the port has almost no impact, such as swirling of the seabed sediment, because a rocky shore is selected for the construction area, the excavation area is as small as about 40 m × 40 m, the concentration of radioactive materials contained the marine sediment is low ⁵ according to the investigation result of the surrounding sea area, and measures such as temporarily |

³ 9th Review Meeting on the Implementation Plan Regarding the Handling of ALPS Treated Water Material 1-1, pp. 39 -40
https://www.tepco.co.jp/en/hd/decommission/information/committee/pdf/2022/alps_22021501-e.pdf

⁴ 35th Environmental Monitoring and Evaluation Sub-committee of the Safety Monitoring Council on Decommissioning of the Nuclear Power Station of Fukushima Prefecture Material 2-1, p.1
<https://www.pref.fukushima.lg.jp/uploaded/attachment/495913.pdf>

⁵ The Nuclear Regulation Authority "Change of the radioactivity concentration of the sediment in sea area close to Fukushima Daiichi NPS / coastal sea area"
https://radioactivity.nsr.go.jp/en/contents/8000/7747/24/engan_soil.pdf

| Impact factors | Presence and operation of the facilities | Implementation of construction |
|------------------------|--|--|
| Environmental elements | Presence of facilities related to discharge of ALPS treated water into the sea - Discharge of ALPS treated water using the facilities | Construction of facilities related to discharge of ALPS treated water into the sea |
| | | suspending the construction will be taken if a significant change in the turbidity of seawater is observed during the construction period. Therefore, we assessed that there is almost no impact of construction such as dispersion of radioactive materials, etc. |

Reference E State of consultation with domestic and foreign stakeholders

The Basic Policy of the government on the handling of ALPS treated water states that “every effort will be made to foster understanding among the public and international community” and we are proactively working with the government to promote risk communication.

E1. Activities toward steady implementation of the Basic Policy

On April 16, 2021, the government established “the Council of Relevant Cabinet Ministers for Steady Implementation of the Basic Policy on the Handling of ALPS Treated Water,” and decided to speedily and steadily take countermeasures stipulated in the Basic Policy as a united government, and to listen carefully voices of stakeholders and those who concern about the impact, and to take necessary additional measures in a flexible countermeasures to dispel their concerns.

Specifically, a working group of the Council was held in various regions including Fukushima, Miyagi, and Ibaraki, and opinions were exchanged with local governments, those who are engaged in agriculture, forestry, fisheries, commerce and tourism etc. The Council also developed the “Immediate Measures Associated with the handling of ALPS Treated Water at the Fukushima Daiichi Nuclear Power Station of Tokyo Electric Power Company Holdings, Inc. (Decision at the 2nd Ministerial Council on Measures for Steady Implementation of the Basic Policy on the Handling of ALPS treated water, August 2021)”¹ and “Action plan for Steady Implementation of the Basic Policy for the Handling of ALPS Treated Water (Decision at the 3rd Ministerial Council on Measures for Steady Implementation of the Basic Policy on the Handling of ALPS Treated Water, December 2021)”².

In the abovementioned action plan, the results of the assessment of the radiation impacts on humans and the environment and the result of the ocean diffusion simulation shall be explained and disseminated by preparing easy-to-understand materials as part of efforts over the next one year. The results of the assessment will be revised and enhanced based on the review by the IAEA, review by the Nuclear Regulatory Commission, and opinions from the public, and will be verified over the medium to long term based on the latest status and actual discharge data to confirm that no impact has occurred.

¹ Web site of the Cabinet Secretariat (August 24, 2021) “List of materials distributed at the ministerial meeting on measures for steady implementation of the basic policy on handling of ALPS treated water (2nd)” Material 3 https://www.kantei.go.jp/jp/singi/hairo_osensui/alps_shorisui/dai2/index.html

² Web site of the Cabinet Secretariat (December 28, 2021) “List of materials distributed at the ministerial meeting on measures for steady implementation of the basic policy on handling of ALPS treated water (3rd)” Material 1 https://www.kantei.go.jp/jp/singi/hairo_osensui/alps_shorisui/dai3/index.html

E2. Responses to public comments regarding the Radiological Impact Assessment Report
After the public action of this report on November 17, 2021, we received 400 or more opinions from both inside and outside of Japan in response to our Public Comment Procedure. We have revised the contents of the report in April 2022, by taking into account the public comments we received through this procedure³.

In addition, we explained the contents of the radiological impact assessment in various occasions. For example, on December 6, 2021 and January 19, 2022, we explained the contents of the Radiation Impact Assessment at the Environmental Monitoring and Evaluation Sub-committee of the Safety Monitoring Council on Decommissioning of the Nuclear Power Station of Fukushima Prefecture. Moreover, we have also provided about 3,000 explanations to those who are engaged in fishery, seafood processing and distribution industry, agriculture, commerce and industry and tourism, local governments, civil groups, etc. respectively (result of FY 2021).

E3. Transmission to and consultation with the international community

(1) Cooperation with the IAEA

On the day following the announcement of the Basic Policy, then Minister of Economy, Trade and Industry, Kajiyama (hereinafter called “Minister Kajiyama”), had a teleconference with Rafael Mariano Grossi, the Director General of IAEA. The Minister Kajiyama requested the IAEA to disseminate information on IAEA's assessment of the safety related aspects of ALPS treated water with the international community as well as Japan based on their scientific knowledge. Also, he made a formal request in the following areas: (1) dispatch of review missions, (2) support to environmental monitoring, and (3) ensuring transparency towards the international community. Director General Grossi welcomed the announcement of the Basic Policy, responded positively to the request made by Minister Kajiyama, and will cooperate and work together with Japan in a highly transparent manner in each stage of the process, before, during and after the discharge⁴. In addition, the Director General Grossi said in the statement announced by IAEA in response to the Basic Policy “The Japanese Government’s decision is in line with practice globally, even though the large amount of water at the Fukushima plant makes it a unique and complex case,” “Nuclear safety is a national responsibility and it was for the Government of Japan to decide how to address the critical issue of water management. I’m confident that the Government will continue to interact with all parties in a transparent and open way as it works to implement today’s decision,” and “Our cooperation and our presence will help build confidence – in Japan and beyond – that

³ With regard to the major opinions collected through the call for opinions and our responded, please refer to our reply issues at the same time of the revised report.

⁴ Web site of the Ministry of Economy, Trade and Industry (April 14, 2021) “Minister Kajiyama met with IAEA Director General Grossi”

https://www.meti.go.jp/english/press/2021/0414_001.html

the water disposal is carried out without an adverse impact on human health and the environment.”⁵

Based on the communication between the leaders of the government and the IAEA, both parties accelerated preparation for cooperation, and the Terms of Reference (TOR) for the Cooperation Framework for ALPS treated water was signed in July 2021. Following this TOR, IAEA decided to conduct a review regarding safety and other aspects of the handling of ALPS treated water including the assessment of the radiation impact on human and environment in accordance with IAEA safety standards⁶.

Based on the TOR, the review mission of safety aspects of ALPS treated water was conducted from February 14 to 18 this year. IAEA members and international experts visited the FDNPS and had discussions with the Ministry of Economy, Trade and Industry. In addition, they also saw and reviewed the ALPS, the K4 tank groups to be reused for measurement and confirmation of the concentration of radioactive materials contained in the treated water before dilution and discharge, and the harbor area which is being considered for the installation of facilities for dilution and discharge of the treated water⁷. The contents of discussions with the IAEA were also reflected in the review of this report.

(2) Briefing for diplomats and bilateral exchange of opinions

In addition to providing explanations to domestic parties, we also attended the Video Conference briefing session for diplomats in Tokyo held on November 18, 2021, the day after the publication of the first edition of the report, and the Video Conference briefing session for the Government of Republic of Korea held on December 3, 2021, both in the presence of government officials, to provide detailed explanation of the contents of the report. In addition, we also provided individual explanation to interested countries and regions together with the relevant Ministries of the government.

At these Video Conference briefing sessions, we explained that the result of the assessment of the radiation impacts on humans and environment in accordance with the internationally recognized methods was significantly lower than the dose limit of the public, etc. and that it would take measures according to the international standards and practices, with maximum consideration given to the impacts on the health and safety of environment and humans. We

⁵ Web site of IAEA (April 13, 2021) "IAEA Ready to Support Japan on Fukushima Water Disposal, Director General Grossi Says"

<https://www.iaea.org/newscenter/pressreleases/iaea-ready-to-support-japan-on-fukushima-water-disposal-director-general-grossi-says>

⁶ This report was reviewed by IAEA as a part of the review of the safety of ALPS treated water based on TOR mentioned above.

⁷ Web site of the Ministry of Economy, Trade and Industry (February 18, 2022) "IAEA conducted a review of the safety of ALPS treated water at TEPCO's Fukushima Daiichi Nuclear Power Station."

https://www.meti.go.jp/english/press/2022/0218_001.html

also carefully answered the questions from foreign governments during the question-and-answer session.

The Government of Japan has provided explanations to foreign governments through Embassies, Consulates and Permanent Missions of Japan overseas as well as explanations to diplomats in Tokyo, and we also have provided the necessary information including technical contents at request.

Through these activities, the Government of Japan and we have been engaged in mutual communication with not only domestic parties but also the international community, and in revising this report, we have taken into consideration the opinions provided through these communications.