

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/2 0:00	5	24	15	14	17	37	115	97
2011/7/2 0:10	5	24	15	14	17	37	115	97
2011/7/2 0:20	5	24	15	14	17	37	115	97
2011/7/2 0:30	5	24	15	14	17	37	115	97
2011/7/2 0:40	5	24	15	14	17	37	115	97
2011/7/2 0:50	5	24	15	14	17	37	115	97
2011/7/2 1:00	5	24	15	14	17	37	115	97
2011/7/2 1:10	5	24	15	14	17	37	115	97
2011/7/2 1:20	5	24	15	14	17	37	115	97
2011/7/2 1:30	5	24	15	14	17	37	115	97
2011/7/2 1:40	5	24	15	14	17	37	115	97
2011/7/2 1:50	5	24	15	14	17	37	115	97
2011/7/2 2:00	5	24	15	14	17	37	115	97
2011/7/2 2:10	5	23	15	14	17	37	115	97
2011/7/2 2:20	5	24	15	14	17	37	115	97
2011/7/2 2:30	5	24	15	14	17	37	115	97
2011/7/2 2:40	5	23	15	14	17	37	115	97
2011/7/2 2:50	5	23	15	14	17	37	115	97
2011/7/2 3:00	5	23	15	14	17	37	115	97
2011/7/2 3:10	5	23	15	14	17	37	115	97
2011/7/2 3:20	5	23	15	14	17	37	115	97
2011/7/2 3:30	5	23	15	14	17	37	115	97
2011/7/2 3:40	5	23	15	14	17	37	115	97
2011/7/2 3:50	5	23	15	14	17	37	115	97
2011/7/2 4:00	5	23	15	14	17	37	115	97
2011/7/2 4:10	5	23	15	14	17	37	115	97
2011/7/2 4:20	5	23	15	14	17	37	115	97
2011/7/2 4:30	5	23	15	14	17	37	115	97
2011/7/2 4:40	5	23	15	14	17	37	115	97
2011/7/2 4:50	5	23	15	14	17	37	115	97
2011/7/2 5:00	5	23	15	14	17	37	115	96
2011/7/2 5:10	5	23	15	14	17	37	115	96
2011/7/2 5:20	5	23	15	14	17	37	115	96
2011/7/2 5:30	5	23	15	14	17	37	115	96
2011/7/2 5:40	5	23	15	14	17	37	115	96
2011/7/2 5:50	5	23	15	14	17	37	115	96
2011/7/2 6:00	5	23	15	14	17	37	115	96

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/2 6:10	5	23	15	14	17	37	115	96
2011/7/2 6:20	5	23	15	14	17	37	115	97
2011/7/2 6:30	5	23	15	14	17	37	115	97
2011/7/2 6:40	5	23	15	14	17	37	115	97
2011/7/2 6:50	5	23	15	14	17	37	115	97
2011/7/2 7:00	5	23	15	14	17	37	115	97
2011/7/2 7:10	5	23	15	14	17	37	115	97
2011/7/2 7:20	5	23	15	14	17	37	115	97
2011/7/2 7:30	5	24	15	14	17	37	115	97
2011/7/2 7:40	5	24	15	14	17	37	115	97
2011/7/2 7:50	5	24	15	14	17	37	115	97
2011/7/2 8:00	5	24	15	14	17	37	115	97
2011/7/2 8:10	5	24	15	14	17	37	115	97
2011/7/2 8:20	5	24	15	14	17	37	115	97
2011/7/2 8:30	5	24	15	14	17	37	115	97
2011/7/2 8:40	5	24	15	14	17	37	115	97
2011/7/2 8:50	5	24	15	14	17	37	115	97
2011/7/2 9:00	5	24	15	14	17	37	115	96
2011/7/2 9:10	5	24	15	14	17	37	115	96
2011/7/2 9:20	5	24	15	14	17	37	115	96
2011/7/2 9:30	5	24	15	14	17	37	115	96
2011/7/2 9:40	5	24	15	14	17	37	115	97
2011/7/2 9:50	5	24	15	14	17	37	115	96
2011/7/2 10:00	5	24	15	14	17	37	115	96
2011/7/2 10:10	5	24	15	14	17	37	115	96
2011/7/2 10:20	5	24	15	14	17	37	115	96
2011/7/2 10:30	5	24	15	14	17	37	115	96
2011/7/2 10:40	5	24	15	14	17	37	115	96
2011/7/2 10:50	5	24	15	14	17	37	115	96
2011/7/2 11:00	5	24	15	14	17	37	115	96
2011/7/2 11:10	5	24	15	14	17	37	115	97
2011/7/2 11:20	5	24	15	14	17	37	115	97
2011/7/2 11:30	5	24	15	14	17	37	115	97
2011/7/2 11:40	5	24	15	14	17	37	115	97
2011/7/2 11:50	5	24	15	14	17	37	115	97
2011/7/2 12:00	5	24	15	14	17	37	115	97
2011/7/2 12:10	5	24	15	14	17	37	115	97

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/2 12:20	5	24	15	14	17	37	115	97
2011/7/2 12:30	5	24	15	14	17	37	115	97
2011/7/2 12:40	5	24	15	14	17	37	115	97
2011/7/2 12:50	5	24	15	14	17	37	115	97
2011/7/2 13:00	5	24	15	14	17	37	115	96
2011/7/2 13:10	5	24	15	14	17	37	115	96
2011/7/2 13:20	5	24	15	14	17	37	115	96
2011/7/2 13:30	5	24	15	14	17	37	115	96
2011/7/2 13:40	5	24	15	14	17	37	115	96
2011/7/2 13:50	5	24	15	14	17	37	115	96
2011/7/2 14:00	5	24	15	14	17	37	115	96
2011/7/2 14:10	5	24	15	14	17	37	115	96
2011/7/2 14:20	5	24	15	14	17	37	115	96
2011/7/2 14:30	5	24	15	14	17	37	115	97
2011/7/2 14:40	5	24	15	14	17	37	115	97
2011/7/2 14:50	5	24	15	14	17	37	115	97
2011/7/2 15:00	5	24	15	14	17	37	115	97
2011/7/2 15:10	5	24	15	14	17	37	115	96
2011/7/2 15:20	5	24	15	14	17	37	115	96
2011/7/2 15:30	5	24	15	14	17	37	115	96
2011/7/2 15:40	5	24	15	14	17	37	115	96
2011/7/2 15:50	5	24	15	14	17	37	115	96
2011/7/2 16:00	5	24	15	14	17	37	115	96
2011/7/2 16:10	5	24	15	14	17	37	115	96
2011/7/2 16:20	5	24	15	14	17	37	115	96
2011/7/2 16:30	5	24	15	14	17	37	115	96
2011/7/2 16:40	5	24	15	14	17	37	115	96
2011/7/2 16:50	5	24	15	14	17	37	115	96
2011/7/2 17:00	5	24	15	14	17	37	115	96
2011/7/2 17:10	5	24	15	14	17	37	115	97
2011/7/2 17:20	5	24	15	14	17	37	115	97
2011/7/2 17:30	5	24	15	14	17	37	115	97
2011/7/2 17:40	5	24	15	14	17	37	115	97
2011/7/2 17:50	5	24	15	14	17	37	115	97
2011/7/2 18:00	5	24	15	14	17	37	115	97
2011/7/2 18:10	5	24	15	14	17	37	115	97
2011/7/2 18:20	5	24	15	14	17	37	115	97

Radiation Dose measured at Monitoring Post of Fukushima Daiichi Nuclear Power Station(μ Sv/h)

Date	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	MP-8
2011/7/2 18:30	5	24	15	14	17	37	115	97
2011/7/2 18:40	5	24	15	14	17	37	115	97
2011/7/2 18:50	5	24	15	14	17	37	115	97
2011/7/2 19:00	5	24	15	14	17	37	115	97
2011/7/2 19:10	5	24	15	14	17	37	115	97
2011/7/2 19:20	5	24	15	14	17	37	115	97
2011/7/2 19:30	5	24	15	14	17	37	115	97
2011/7/2 19:40	5	24	15	14	17	37	115	97
2011/7/2 19:50	5	24	15	14	17	37	115	97
2011/7/2 20:00	5	24	15	14	17	37	115	97
2011/7/2 20:10	5	24	15	14	17	37	115	97
2011/7/2 20:20	5	24	15	14	17	37	115	97
2011/7/2 20:30	5	24	15	14	17	37	115	97
2011/7/2 20:40	5	24	15	14	17	37	115	97
2011/7/2 20:50	5	24	15	14	17	37	115	97
2011/7/2 21:00	5	24	15	14	17	37	115	97
2011/7/2 21:10	5	24	15	14	17	37	115	97
2011/7/2 21:20	5	24	15	14	17	37	115	97
2011/7/2 21:30	5	24	15	14	17	37	115	97
2011/7/2 21:40	5	24	15	14	17	37	115	97
2011/7/2 21:50	5	24	15	14	17	37	115	97
2011/7/2 22:00	5	24	15	14	17	37	115	97
2011/7/2 22:10	5	24	15	14	17	37	115	97
2011/7/2 22:20	5	24	15	14	17	37	115	97
2011/7/2 22:30	5	24	15	14	17	37	115	97
2011/7/2 22:40	5	24	15	14	17	37	115	97
2011/7/2 22:50	5	24	15	14	17	37	115	97
2011/7/2 23:00	5	24	15	14	17	37	115	97
2011/7/2 23:10	5	24	15	14	17	37	115	97
2011/7/2 23:20	5	24	15	14	17	37	115	97
2011/7/2 23:30	5	24	15	14	17	37	115	97
2011/7/2 23:40	5	24	15	14	17	37	115	97
2011/7/2 23:50	5	24	15	14	17	37	115	97

Fixed point Monitoring Status by Temporary Monitoring Post at Fukushima Daiichi Nuclear Power Station

Date	Radiation Dose Rate (μ Sv/h) At the Main Buiding	Radiation Dose Rate (μ Sv/h) At the Main Gate	Radiation Dose Rate (μ Sv/h) At the West Gate
2011/7/2 0:00	340	35	13
2011/7/2 0:30	340	35	13
2011/7/2 1:00	339	35	13
2011/7/2 1:30	339	35	13
2011/7/2 2:00	341	35	13
2011/7/2 2:30	341	35	13
2011/7/2 3:00	340	35	13
2011/7/2 3:30	341	35	13
2011/7/2 4:00	341	34	13
2011/7/2 4:30	340	35	13
2011/7/2 5:00	340	35	13
2011/7/2 5:30	342	35	13
2011/7/2 6:00	340	34	13
2011/7/2 6:30	341	34	13
2011/7/2 7:00	340	35	14
2011/7/2 7:30	340	35	13
2011/7/2 8:00	342	35	13
2011/7/2 8:30	340	35	14
2011/7/2 9:00	340	35	13
2011/7/2 9:30	337	35	13
2011/7/2 10:00	339	35	13
2011/7/2 10:30	340	35	13
2011/7/2 11:00	337	35	13
2011/7/2 11:30	338	35	13
2011/7/2 12:00	334	35	13
2011/7/2 12:30	334	35	13
2011/7/2 13:00	333	35	13
2011/7/2 13:30	333	35	13
2011/7/2 14:00	332	35	13
2011/7/2 14:30	334	35	13
2011/7/2 15:00	334	35	13
2011/7/2 15:30	333	35	13
2011/7/2 16:00	333	35	13
2011/7/2 16:30	334	35	13
2011/7/2 17:00	334	35	13
2011/7/2 17:30	334	35	13
2011/7/2 18:00	333	35	13
2011/7/2 18:30	333	35	13
2011/7/2 19:00	334	35	13
2011/7/2 19:30	335	35	13
2011/7/2 20:00	335	35	13
2011/7/2 20:30	338	35	13
2011/7/2 21:00	337	35	13
2011/7/2 21:30	336	35	13
2011/7/2 22:00	338	35	13
2011/7/2 22:30	337	35	13
2011/7/2 23:00	339	35	13
2011/7/2 23:30	337	34	13

Monitoring data by a monitoring car* at Fukushima Daiichi Nuclear Power Station (μ Sv/h)

* The data from monitoring car may deficit as the vehicle may change monitoring point.

Measuring Point	Measurement Date	γ Ray	Neutron Ray	Weather	Wind Direction	Wind Velocity (m/s)	
Main Gate	2011/7/2 0:00	28.2	<0.01	Fine	SW	0.3	
Main Gate	2011/7/2 0:10	28.2	<0.01	Fine	SW	0.6	
Main Gate	2011/7/2 0:20	28.2	<0.01	Fine	ENE	0.4	
Main Gate	2011/7/2 0:30	28.2	<0.01	Fine	N	0.8	
Main Gate	2011/7/2 0:40	28.1	<0.01	Fine	NNE	1.1	
Main Gate	2011/7/2 0:50	28.2	<0.01	Fine	NNE	1.3	
Main Gate	2011/7/2 1:00	28.2	<0.01	Fine	N	0.9	
Main Gate	2011/7/2 1:10	28.1	<0.01	Fine	N	1.1	
Main Gate	2011/7/2 1:20	28.0	<0.01	Fine	W	1.0	
Main Gate	2011/7/2 1:30	28.1	<0.01	Fine	W	0.6	
Main Gate	2011/7/2 1:40	28.0	<0.01	Fine	N	0.4	
Main Gate	2011/7/2 1:50	28.2	<0.01	Fine	NE	0.5	
Main Gate	2011/7/2 2:00	28.1	<0.01	Fine	ENE	0.4	
Main Gate	2011/7/2 2:10	28.0	<0.01	Fine	N	0.3	
Main Gate	2011/7/2 2:20	28.0	<0.01	Fine	ESE	0.4	
Main Gate	2011/7/2 2:30	28.2	<0.01	Fine	SW	0.5	
Main Gate	2011/7/2 2:40	28.1	<0.01	Fine	SW	0.5	
Main Gate	2011/7/2 2:50	28.1	<0.01	Fine	SW	0.7	
Main Gate	2011/7/2 3:00	28.2	<0.01	Fine	WNNW	0.8	
Main Gate	2011/7/2 3:10	28.0	<0.01	Fine	NNW	1.4	
Main Gate	2011/7/2 3:20	28.1	<0.01	Fine	NNW	1.7	
Main Gate	2011/7/2 3:30	28.1	<0.01	Fine	NW	1.2	
Main Gate	2011/7/2 3:40	28.0	<0.01	Fine	NW	1.4	
Main Gate	2011/7/2 3:50	28.0	<0.01	Cloudy	N	1.6	
Main Gate	2011/7/2 4:00	28.0	<0.01	Cloudy	N	1.5	
Main Gate	2011/7/2 4:10	28.0	<0.01	Cloudy	NNW	1.5	
Main Gate	2011/7/2 4:20	28.0	<0.01	Cloudy	NW	1.5	
Main Gate	2011/7/2 4:30	28.0	<0.01	Cloudy	N	1.6	
Main Gate	2011/7/2 4:40	28.0	<0.01	Cloudy	NNW	1.1	
Main Gate	2011/7/2 4:50	28.1	<0.01	Cloudy	WNNW	1.3	
Main Gate	2011/7/2 5:00	28.0	<0.01	Cloudy	N	1.6	
Main Gate	2011/7/2 5:10	28.1	<0.01	Cloudy	NNW	1.4	
Main Gate	2011/7/2 5:20	28.2	<0.01	Cloudy	NNW	1.4	
Main Gate	2011/7/2 5:30	28.2	<0.01	Cloudy	NNW	1.7	
Main Gate	2011/7/2 5:40	28.3	<0.01	Cloudy	NW	1.8	
Main Gate	2011/7/2 5:50	28.2	<0.01	Fine	NW	1.7	
Main Gate	2011/7/2 6:00	28.2	<0.01	Fine	NW	1.2	
Main Gate	2011/7/2 6:10	28.2	<0.01	Cloudy	NW	1.2	
Main Gate	2011/7/2 6:20	28.3	<0.01	Cloudy	N	0.9	
Main Gate	2011/7/2 6:30	28.2	<0.01	Cloudy	N	1.1	
Main Gate	2011/7/2 6:40	28.2	<0.01	Cloudy	N	1.4	
Main Gate	2011/7/2 6:50	28.2	<0.01	Cloudy	N	1.7	
Main Gate	2011/7/2 7:00	28.2	<0.01	Cloudy	N	1.6	
Main Gate	2011/7/2 7:10	28.2	<0.01	Cloudy	N	1.0	
Main Gate	2011/7/2 7:20	28.2	<0.01	Cloudy	NE	0.8	
Main Gate	2011/7/2 7:30	28.2	<0.01	Cloudy	ENE	0.9	
Main Gate	2011/7/2 7:40	28.3	<0.01	Cloudy	NE	0.9	
Main Gate	2011/7/2 7:50	28.2	<0.01	Cloudy	E	1.1	
Main Gate	2011/7/2 8:00	28.2	<0.01	Cloudy	E	1.5	
Main Gate	2011/7/2 8:10	28.3	<0.01	Cloudy	ESE	1.2	
Main Gate	2011/7/2 8:20	28.3	<0.01	Cloudy	E	1.6	
Main Gate	2011/7/2 8:30	28.3	<0.01	Cloudy	NNE	1.1	
Main Gate	2011/7/2 8:40	28.2	<0.01	Cloudy	E	0.9	
Main Gate	2011/7/2 8:50	28.2	<0.01	Cloudy	E	1.2	
Main Gate	2011/7/2 9:00	28.1	<0.01	Cloudy	ESE	1.6	
Main Gate	2011/7/2 9:10	28.3	<0.01	Fine	NNE	1.6	
Main Gate	2011/7/2 9:20	28.3	<0.01	Fine	NNE	1.4	
	2011/7/2 9:30	The data at this point was missed since samplings were conducted at other points during the nitrogen injection to the Unit 2 reactor containment vessel.					
	2011/7/2 9:40						
	2011/7/2 9:50						
Main Gate	2011/7/2 10:00	27.9	<0.01	Fine	ENE	1.4	
Main Gate	2011/7/2 10:10	28.1	<0.01	Fine	NE	1.4	
Main Gate	2011/7/2 10:20	28.1	<0.01	Fine	NNE	1.7	
Main Gate	2011/7/2 10:30	28.2	<0.01	Fine	NE	1.3	
Main Gate	2011/7/2 10:40	28.0	<0.01	Fine	ESE	1.8	
Main Gate	2011/7/2 10:50	27.9	<0.01	Fine	NNE	1.6	
Main Gate	2011/7/2 11:00	28.0	<0.01	Cloudy	N	2.0	
Main Gate	2011/7/2 11:10	27.8	<0.01	Cloudy	NE	1.6	
Main Gate	2011/7/2 11:20	28.0	<0.01	Cloudy	N	1.6	
West Gate	2011/7/2 11:30	13.8	<0.01	Cloudy	NE	1.2	
West Gate	2011/7/2 11:40	13.9	<0.01	Cloudy	ENE	1.4	

Measuring Point	Measurement Date	γ Ray	Neutron Ray	Weather	Wind Direction	Wind Velocity (m/s)
West Gate	2011/7/2 11:50	13.8	<0.01	Cloudy	ENE	1.0
Main Gate	2011/7/2 12:00	27.9	<0.01	Cloudy	NW	2.6
Main Gate	2011/7/2 12:10	27.6	<0.01	Cloudy	SSE	1.4
Main Gate	2011/7/2 12:20	27.5	<0.01	Cloudy	E	1.1
Main Gate	2011/7/2 12:30	28.2	<0.01	Cloudy	NE	1.3
Main Gate	2011/7/2 12:40	28.4	<0.01	Cloudy	NE	1.3
Main Gate	2011/7/2 12:50	28.3	<0.01	Cloudy	N	1.4
Main Gate	2011/7/2 13:00	28.5	<0.01	Cloudy	NE	1.7
Main Gate	2011/7/2 13:10	28.5	<0.01	Cloudy	SE	1.0
Main Gate	2011/7/2 13:20	28.3	<0.01	Cloudy	E	1.0
Main Gate	2011/7/2 13:30	28.5	<0.01	Cloudy	SE	1.7
Main Gate	2011/7/2 13:40	28.5	<0.01	Cloudy	E	1.2
Main Gate	2011/7/2 13:50	28.2	<0.01	Cloudy	W	1.2
Main Gate	2011/7/2 14:00	28.2	<0.01	Cloudy	N	0.8
Main Gate	2011/7/2 14:10	28.4	<0.01	Cloudy	SE	1.0
Main Gate	2011/7/2 14:20	28.5	<0.01	Cloudy	E	0.9
Main Gate	2011/7/2 14:30	28.3	<0.01	Cloudy	E	1.0
Main Gate	2011/7/2 14:40	28.4	<0.01	Cloudy	N	1.3
Main Gate	2011/7/2 14:50	28.4	<0.01	Cloudy	N	1.5
Main Gate	2011/7/2 15:00	28.4	<0.01	Cloudy	N	1.4
Main Gate	2011/7/2 15:10	28.3	<0.01	Cloudy	E	1.0
Main Gate	2011/7/2 15:20	28.3	<0.01	Cloudy	E	1.2
Main Gate	2011/7/2 15:30	28.3	<0.01	Cloudy	N	1.2
Main Gate	2011/7/2 15:40	28.6	<0.01	Cloudy	N	1.2
Main Gate	2011/7/2 15:50	28.4	<0.01	Cloudy	SE	0.9
Main Gate	2011/7/2 16:00	28.3	<0.01	Cloudy	NNW	1.1
Main Gate	2011/7/2 16:10	28.4	<0.01	Cloudy	N	1.1
Main Gate	2011/7/2 16:20	28.3	<0.01	Cloudy	NE	1.1
Main Gate	2011/7/2 16:30	28.4	<0.01	Cloudy	NE	0.8
Main Gate	2011/7/2 16:40	28.3	<0.01	Cloudy	E	0.7
Main Gate	2011/7/2 16:50	28.3	<0.01	Cloudy	E	0.6
Main Gate	2011/7/2 17:00	28.4	<0.01	Cloudy	SE	1.0
Main Gate	2011/7/2 17:10	28.4	<0.01	Cloudy	SE	0.9
Main Gate	2011/7/2 17:20	28.3	<0.01	Cloudy	E	1.2
Main Gate	2011/7/2 17:30	28.5	<0.01	Cloudy	S	1.0
Main Gate	2011/7/2 17:40	28.5	<0.01	Cloudy	S	1.1
Main Gate	2011/7/2 17:50	28.5	<0.01	Cloudy	S	1.0
Main Gate	2011/7/2 18:00	28.6	<0.01	Cloudy	S	0.8
Main Gate	2011/7/2 18:10	28.5	<0.01	Cloudy	S	0.6
Main Gate	2011/7/2 18:20	28.5	<0.01	Cloudy	S	0.5
Main Gate	2011/7/2 18:30	28.5	<0.01	Cloudy	S	0.5
Main Gate	2011/7/2 18:40	28.5	<0.01	Cloudy	W	0.5
Main Gate	2011/7/2 18:50	28.5	<0.01	Cloudy	W	0.5
Main Gate	2011/7/2 19:00	28.5	<0.01	Cloudy	W	0.4
Main Gate	2011/7/2 19:10	28.6	<0.01	Cloudy	SW	0.5
Main Gate	2011/7/2 19:20	28.5	<0.01	Cloudy	WSW	0.4
Main Gate	2011/7/2 19:30	28.5	<0.01	Cloudy	NE	0.4
Main Gate	2011/7/2 19:40	28.5	<0.01	Cloudy	N	0.7
Main Gate	2011/7/2 19:50	28.6	<0.01	Cloudy	NNW	0.9
Main Gate	2011/7/2 20:00	28.5	<0.01	Cloudy	NE	0.8
Main Gate	2011/7/2 20:10	28.5	<0.01	Cloudy	NW	0.4
Main Gate	2011/7/2 20:20	28.6	<0.01	Cloudy	NW	0.5
Main Gate	2011/7/2 20:30	28.5	<0.01	Cloudy	NW	1.1
Main Gate	2011/7/2 20:40	28.5	<0.01	Cloudy	W	1.0
Main Gate	2011/7/2 20:50	28.5	<0.01	Cloudy	WSW	0.8
Main Gate	2011/7/2 21:00	28.5	<0.01	Cloudy	WSW	0.6
Main Gate	2011/7/2 21:10	28.5	<0.01	Cloudy	WNW	0.6
Main Gate	2011/7/2 21:20	28.5	<0.01	Cloudy	NE	0.7
Main Gate	2011/7/2 21:30	28.6	<0.01	Cloudy	WNW	0.6
Main Gate	2011/7/2 21:40	28.5	<0.01	Cloudy	WSW	0.8
Main Gate	2011/7/2 21:50	28.4	<0.01	Cloudy	NNW	0.7
Main Gate	2011/7/2 22:00	28.4	<0.01	Cloudy	WNW	1.0
Main Gate	2011/7/2 22:10	28.4	<0.01	Cloudy	SSE	0.3
Main Gate	2011/7/2 22:20	28.3	<0.01	Cloudy	SSE	0.5
Main Gate	2011/7/2 22:30	28.3	<0.01	Cloudy	SE	0.6
Main Gate	2011/7/2 22:40	28.3	<0.01	Cloudy	SSE	0.6
Main Gate	2011/7/2 22:50	28.3	<0.01	Cloudy	SSE	0.7
Main Gate	2011/7/2 23:00	28.3	<0.01	Cloudy	E	1.2
Main Gate	2011/7/2 23:10	28.3	<0.01	Cloudy	NE	0.6
Main Gate	2011/7/2 23:20	28.4	<0.01	Cloudy	SSE	0.4
Main Gate	2011/7/2 23:30	28.3	<0.01	Cloudy	W	0.7
Main Gate	2011/7/2 23:40	28.3	<0.01	Cloudy	NW	1.5
Main Gate	2011/7/2 23:50	28.3	<0.01	Cloudy	WNW	1.2

Fukushima Daiichi Nuclear Power Plant

2011/7/2
as of 23:50

周辺監視区域 : supervised outside area
敷地境界 : site boundary

