

Fukushima Daiichi Nuclear Power Station:

The Monitoring Result after opening the Airlock in the Reactor Building of Unit 2

Date and time of measuring	Data of climate (Monitoring car)			Airborne Radiation Rate (μ Sv/h)(site boundary)								
	Climate	Wind direction	Wind speed	Monitoring car※1	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7※2	MP-8※2
2011/6/19 12:00	Cloudy	S	2.9	30.2	5	24	15	15	18	39	120	102
2011/6/19 13:00	Cloudy	S	1.9	30.4	5	24	15	15	18	39	120	102
2011/6/19 14:00	Cloudy	SSE	2.6	30.3	5	24	15	15	18	39	120	90
2011/6/19 15:00	Shine	S	2.2	30.2	5	24	15	15	18	39	120	90
2011/6/19 16:00	Shine	SSE	2.4	30.3	5	24	15	15	18	39	120	102
2011/6/19 17:00	Shine	SSE	1.9	30.1	5	24	15	15	18	39	120	102
2011/6/19 18:00	Shine	S	2.6	30.4	5	24	15	15	18	39	120	102
2011/6/19 19:00	Shine	E	0.6	14.2	5	24	15	15	18	39	120	102
2011/6/19 20:00	Shine	SW	0.4	14.3	5	24	15	15	18	39	120	102
2011/6/19 21:00	Shine	SE	0.3	14.3	5	24	15	15	18	39	120	102
2011/6/19 22:00	Shine	SW	0.3	14.2	5	24	15	15	18	39	120	102
2011/6/19 23:00	Shine	SSW	0.3	14.3	5	24	15	15	18	39	120	102
2011/6/20 0:00	Shine	SW	0.4	14.3	5	24	15	15	18	39	120	102
2011/6/20 1:00	Shine	NW	0.5	14.2	5	24	15	15	18	39	120	102
2011/6/20 2:00	Shine	SW	0.8	14.1	5	24	15	15	18	39	120	102
2011/6/20 3:00	Shine	WSW	0.3	14.4	5	24	15	15	18	39	120	102
2011/6/20 4:00	Shine	WNW	0.6	14.1	5	24	15	15	18	39	120	102
2011/6/20 5:00	Shine	NW	0.5	14.2	5	24	15	15	18	39	120	102
2011/6/20 6:00	Shine	WSW	0.6	14.3	5	24	15	15	18	39	120	102

※1: From 12:00~18:00 measuring at the front gate and afterward at west gate

※2: Measurements of data of MP-7 and MP-8 at 14:00 and 15:00 were conducted by manually due to the power switching work