The red words are revised due to the 'Incorrect data for pressure at Primary Containment Vessel of Unit1" which we announced on November 29.

Fukushima Daiichi Nuclear Power Station Plant Parameters

[INote]

Some indicators might not be functioning properly beyond the normal condition for usage affected by the earthquake and subsequent events. We comprehensively evaluate situation in plants using all the available information from indicators and also focusing on trends, taking uncertainty

of indicators into consideration.

| As of 12:00 on September 3 | O |
|----------------------------|---|
|----------------------------|---|

| Water level in the reactor Water sevel in the reactor Pressure in the Sys | uel range A: Downscale uel range B:-1650 mm | Unit 2 Fresh water feeding Feed water system 4.0m³/h, CS line 6.0m³/h (as of 11:00 , 9/30) Fuel range A:-1850 mm | Fresh water feeding Feed water system 2.5m³/h, CS line 8.0m³/h (as of 11:00 , 9/30) Fuel range A:-2300 mm Fuel range B:-2250 mm (as of 11:00 , 9/30) **3 | - | Unit 5 #2 (Heat removal of the react injection is unnecessary) Stoppage range | | |
|---|--|--|--|--|---|---|--|
| Water level in the reactor (as Pressure in the Sys Sys | uel range B:-1650 mm | Fuel range B:-2150 mm | Fuel range B:-2250 mm %3 | 7 | | | |
| Pressure in the Sys | ystem B:-MPa g | | | | 1926mm (as of 12:00, 9/30) | Stoppage range 2385mm (as of 12:00, 9/30) | |
| | | (as of 11:00, 9/30) | System A:-0.174 MPa g (A) %3 System B:-0.115 MPa g (C) %3 (as of 11:00, 9/30) | | 0.007 MPa g (as of 12:00, 9/30) | 0.026 MPa g (as of 12:00, 9/30) | |
| Water temperature of the reactor | e of (Since there is no water inflow in the system it is impossible to collect the data) | |] | 37.2 °C (as of 12:00 , 9/30) | 24.6 °C (as of 12:00, 9/30) | | |
| Temperature around Ten | emperature in feed-water nozzle:75,6 °C emperature at reactor vessel bottom:77,5 °C as of 11:00,9/30) | Temperature in feed-water nozzle:89.8 °C Temperature at reactor vessel bottom:99.4 °C (as of 11:00, 9/30) | Temperature in feed-water nozzle:75.0 °C Temperature at reactor vessel bottom:78.1 °C (as of 11:00, 9/30) | %2 (Monitoring is unnecessary since all fuel are | *2 (monitoring through water temperature of the reactor) | | |
| Pressure in D/W · S/C | | D/W:0,110 MPa abs S/C: Downscale | D/W:0.1015 MPa abs S/C:0.1876 MPa abs (as of 11:00, 9/30) | takeoff) | | | |
| D/W Atmosphere HVI | IVH return:78.6 °C | RPV bellow seal'82°C | RPV bellow seal:97.3 °C | | *2 | | |
| CAMS radiation S/C | (B):5.12E+02Sv/h | D/W(A):8.83E+00Sv/h (Bi:3.93E+00Sv/h | D/W(A):3.39E+00Sv/h | (Monitoring is unnecessary since heat removeractor is functioning.) | | since heat removal of | |
| Temperature in S/C Sys | ystem B:43.4 °C | System A:49.9 °C System B:49.9 °C (as of 11:00 , 9/30) | System A:44,3 °C System B:44,5 °C (as of 11:00 , 9/30) | | | | |
| Designed usable D/W pressure 0.3 | .384MPa g (0.485MPa abs) | 0.384MPa g (0.485MPa abs) | 0.384MPa g (0.485MPa abs) | | | | |
| Designed usable D/W maximum pressure 0.4 | .427MPa g (0.528MPa abs) | 0.427MPa g (0.528MPa abs) | 0.427MPa g (0.528MPa abs) | | | - | |
| Temperature in the spent fuel pool | 25.5 °C (as of 11:00 , 9/30) | 28.0°C (as of 11:00 , 9/30) | 27.3 °C (as of 11:00, 9/30) | 36℃ (as of 11:00 , 9/30) | 27.8 °C (as of 12:00 , 9/30) | $27.5 ^{\circ}\text{C}$ (as of 12:00 , 9/30) | |
| FPC skimmer surge tank level | 3920mm (as of 11:00 , 9/30) | 2800mm (as of 11:00 , 9/30) | 4430mm (as of 11:00 , 9/30) | 4500mm (as of 11:00 , 9/30) | *2 | | |
| Power source | Receiving offsite is | power (P/C2C) | Receiving offsite power (P/C4D) | | Receiving o | ffsite power | |
| Others am | As the temporary system of sea water pump on Unit 5 m on Sep. 30, then SHC mode B system started at 11:3 Data of Pressure in D/W of Unit 1 on 11/29 was correc | | ne main system, SHC mode A system shut down at 11:3 | Temperature in the Common Spent Fuel Storage: 30°C (as of 10:10, 9/30) | 5u: SHC mode (from 11:34 ,9/30) | 6u: SHC Mode (from 11:25 ,9/15) | |

Pressure conversion Gauge pressure (MPa g) = Absolute pressure (MPa abs) - atmospheric pressure (normal atmospheric pressure 0.1013 MPa)

Absolute pressure (MPa abs) = Gauge pressure (MPa g) + atmospheric pressure (normal atmospheric pressure 0.1013 MPa)

%1 : Instrument failure

%2 : Not covered for colleting data

*3: continuously monitoring the status

Fukushima Daiichi Nuclear Power Station Supplemental explanation for the plant parameters

■Supplemental explanation for each parameter

| Item | Recording manner | Measurement manner | Ch number or number of systems | |
|--|---|---|--|--|
| Status of water injection to the reactor | Water inflow (CS line: Core Spray system) | Temporary | System 1 / 1 | |
| Water level in the reactors | Data measured by the water gauge, which monitor the fuel range | Main indicator | System A 1/1Ch System B 1/1Ch | |
| Pressure in the reactor | Measure voltage value of pressure instrument by the main indicator panel and convert to the pressure. One representing value is noted among multiple data on each System A, B. | Unit 1/2 Temporary Unit 3 Measures voltage value through the main indicator panel and converts them to the pressure | Temporary indicator: 1/1 system Main:System A 1/2Ch System B 1/2Ch | |
| Temperature in the reactor | Since there is no water inflow at the points, where thermometers are set, no data is collected. | | _ | |
| Temperature around the reactor vessel | Data measured at feed-water nozzle and at reactor vessel bottom (1U, 3U: RPV Bottom Head, 2U: RPV Wall Above Bottom Head) are noted among multiple data to view the whole picture. | Main recorder | Point of Feed-water nozzle 1/4Ch reactor vessel bottom 1/2Ch (Unit1) 1/1Ch (Unit2/3) | |
| Pressure in D/W • S/C | Data from main instrument. Measure voltage value by the main instrument panel converted to the pressure in case main instruments are not in function. As to the D/W pressure of Unit2, the reading of the temporary indicator is described. (D/W: Dry Well, S/C: Suppression Chamber) | (D/W) Unit 1:Main recorder Unit 2:Temporary Unit 3:Main instrument panel (converted from voltage) (S/C) Unit 1/2:Main indicator Unit 3:Main instrument panel (converted from voltage) | | |
| D/W Atmosphere temperature | Data at upper point (RPV Bellows Air) and middle point (HVH return) are noted among multiple data to view the whole picture, (RPV : Reactor Pressure Vessel, HVH : Heating Ventilating Handling Unit) | Unit 1: Main instrument panel (converted from voltage) Unit 2/3: Main recorder | RPV Bellows Air 1/5Ch D/W HVH return 1/5Ch | |
| CAMS radiation monitor | Data from the instrument reading of main indicator. (CAMS : Containment Atmospheric Monitoring System) | Main indicator | D/W System A 1/1Ch System B 1/1Ch S/C System A 1/1Ch System B 1/1Ch | |
| Temperature in S/C | Data from the instrument reading of main recorder. One representing value is noted among multiple data on each System A, B. | Main recorder | System A1/4Ch (Unit 1) 、8Ch (Unit 2/3) System B1/4Ch (Unit 1) 、8Ch (Unit 2/3) | |
| Temperature in the spent fuel pool | Data from the instrument reading or from the measurement reading of samples of main indicator and temporary insuturment (Non-thermal mode: Urgent Heat load Mode、SHC mode: Shut down Cooling Mode) | Unit:2Main recorder Unit1/3/4:Temporary indicator | Main: 1 / 1 Ch (Unit 2) Temporary indicator: 1 / 1 system (Unit 1/3/4) | |
| FPC skimmer surge tank level | Unit2, 4 are the FPC skimmer surge tank level measured main indicator. Unit1, 3 are the FPC skimmer surge tank level estimated from temporary pressure gages. (reference value) (FPC: Fuel Pool Cooling system) | Unit2/4:Main indicator Unit1/3:Temporary instrument (Pressure gages) | Main indicator: 1/1system (Unit 2/4) Temporary instrument: 1/1system (Unit 1/3) | |

Supplemental explanation for notes

| ltem | Contents | Status As of 12:00 on September 30 |
|---------------------------------------|---|--|
| Instrument failure | Instrument failure : down of instrument reading (over) scale/failure of instrument | Unit 1 CAMS D/W radiation monitor Unit 2 Pressure in S/C, CAMS D/W(B) radiation monitor, CAMS S/C(B) radiation monitor Unit 3 — |
| | Unit4: Monitoring is not implemented since all fuel are takeoff. Unit5/6: Monitoring is not implemented since heat removal of reactor is functioning | _ |
| Continuously monitoring the status | Inaccurate Data defined from relation with other Parameters such as negative figure. | Unit 1 Reactor water level (B) Unit 2 Reactor water level, RPV bellow air temperature, Unit 3 Reactor water level, reactor pressure, RPV bellow air temperature, CAMS D/W(A) radiation monitor |