

<Reference>

July 7, 2013

Tokyo Electric Power Company

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection
Underground Water Obtained at Bank Protection

Unit: Bq/L

		Underground water observation hole No.1	Underground water observation hole No.1-1	Underground water observation hole No.1-2	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling			Jul 5, 2013	Jul 5, 2013		
Time of sampling			11:00 AM	12:10 PM		
Cs-134 (Approx. 2 years)			ND (0.42)	99		
Cs-137 (Approx.30 years)			0.55	210		
The other γ	Ru-106 (Approx. 370 days)		7.7	95		
	Mn-54 (Approx. 310 days)		1.0	62		
	Co-60 (Approx. 5 years)		ND	1.2		
	Sb-125 (Approx. 3 years)		ND	35		
All β			3,800	900,000		
H-3 (Approx. 12 years)			600,000	380,000		
Sr-90 (Approx. 29 years)			-	Under analysis		

* Data announced this time is provided in a thick-frame. The other data was announced on July 5.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.