

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection
 Underground Water Obtained at Bank Protection

Unit: Bq/L

	Underground water observation hole No.1	Underground water observation hole No.1-1 ^{*1}	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-4	Underground water observation hole No.2	Underground water observation hole No.3
Date of sampling	Jul 11, 2013		Jul 11, 2013		Jul 11, 2013	Jul 11, 2013	Jul 11, 2013
Time of sampling	12:51 PM		1:25 PM		12:25 PM	11:30 AM	10:55 AM
Cs-134 (Approx. 2 years)	ND(0.61)		8,200		0.91	ND(0.47)	1.9
Cs-137 (Approx.30 years)	1.0		17,000		2.0	1.2	4.8
The other γ	Ru-106 (Approx. 370 days)	15	ND		ND	ND	ND
	Sb-125 (Approx. 3 years)	1.7	ND		ND	ND	ND
All β	1,600		890,000		250	1,400	1400
H-3 (Approx. 12 years)	Under analysis		Under analysis		Under analysis	Under analysis	Under analysis
Sr-90 (Approx. 29 years)	- *		- *		- *	- *	- *

*1 No sampling was performed at the groundwater observation hole No.1-1 since chemical injection work was ongoing.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

* The errors have corrected on July 12.