

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/3)
Underground Water Obtained at Bank Protection

Unit: Bq/L

	Underground water observation hole No.0-1	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-4	Underground water observation hole No.1-5	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.3	Underground water observation hole No.3-1
Date of sampling	Aug 15, 2013	Aug 15, 2013	Aug 15, 2013	Aug 15, 2013	Aug 15, 2013	Aug 15, 2013	Aug 15, 2013	Aug 15, 2013		Aug 16, 2013
Time of sampling	10:52 AM	12:01 PM	1:35 PM	12:26 PM	11:30 AM	1:02 PM	11:32 AM	10:56 AM		12:21 PM
Cs-134 (Approx. 2 years)	0.39	ND(0.54)	150	ND(0.64)	ND(0.47)	150	ND(0.46)	ND(0.37)		0.67
Cs-137 (Approx.30 years)	1.1	ND(0.49)	360	ND(0.76)	1.2	320	ND(0.53)	ND(0.52)		1.8
The other γ	Ru-106 (Approx. 370 days)	ND	11	160	11	ND	ND	ND		ND
	Sb-125 (Approx. 3 years)	ND	ND	95	ND	ND	9.3	ND		ND
All β	210	1,700	880,000	160,000	220	21,000	200	ND(18)		ND(20)
H-3 (Approx. 12 years)	35,000	370,000	300,000	190,000	76,000	72,000	550	260		370
Sr-90 (Approx. 29 years)	-	-	-	-	-	-	-	-		-

* Data announced this time is provided in a thick-frame. The other data was announced on August 16 and 17.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/3)
Underground Water Obtained at Bank Protection

Unit: Bq/L

	Underground water observation hole No.0-1	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-3	Underground water observation hole No.1-4	Underground water observation hole No.1-5	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.3	Underground water observation hole No.3-1
Date of sampling		Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013		
Time of sampling		10:21 AM	12:06 PM	10:54 AM	9:50 AM	11:40 AM	9:57 AM	9:18 AM		
Cs-134 (Approx. 2 years)		3.2	880	ND(0.56)	1.1	130	ND(0.42)	ND(0.45)		
Cs-137 (Approx.30 years)		4.3	1,900	ND(0.65)	2.1	260	0.68	ND(0.61)		
The other γ	Ru-106 (Approx. 370 days)	14	ND	14	ND	ND	ND	ND		
	Sb-125 (Approx. 3 years)	ND	200	ND	ND	ND	ND	ND		
All β		1,500	870,000	120,000	380	13,000	420	ND(18)		
H-3 (Approx. 12 years)		Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis		
Sr-90 (Approx. 29 years)		-	-	-	-	-	-	-		

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (3/3)
Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)
Date of Sampling	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013		Aug 19, 2013	Aug 19, 2013			Aug 19, 2013	Aug 19, 2013	Aug 19, 2013
Time of sampling	6:10 AM	6:30 AM	5:53 AM		6:43 AM	6:09 AM			6:17 AM	6:21 AM	6:28 AM
Cs-134(Approx. 2 years)	ND(1.4)	2.4	3.3		8	24			26	12	68
Cs-137(Approx.30 years)	ND(1.5)	4.7	7.4		19	41			52	30	140
All β	ND(18)	46	28		280	540			490	310	270
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis		Under analysis	Under analysis			Under analysis	Under analysis	Under analysis
Sr-90(Approx. 29 years)	Under analysis	-	Under analysis		Under analysis	Under analysis			Under analysis	Under analysis	Under analysis

Unit: Bq/L

	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater*	East side of the port entrance*	South side of the south breakwater*
Date of Sampling	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013	Aug 19, 2013			
Time of sampling	6:32 AM	6:37 AM	5:20 AM	7:22 AM	7:30 AM	7:33 AM	7:36 AM	7:27 AM			
Cs-134(Approx. 2 years)	20	20	ND(1.4)	1.6	2.9	2.6	ND(2.0)	2.1			
Cs-137(Approx.30 years)	43	49	ND(1.5)	4.7	6.6	6.5	4.7	4.6			
All β	160	200	ND(18)	69	74	57	69	79			
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis			
Sr-90(Approx. 29 years)	Under analysis	Under analysis	Under analysis	Under analysis	-	-	-	-			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

		Groundwater observation hole No.0-1	Groundwater observation hole No.1	Groundwater observation hole No.1-1	Groundwater observation hole No.1-2	Groundwater observation hole No.1-3	Groundwater observation hole No.1-4	Groundwater observation hole No.1-5
Cs-134 (Approx. 2 years)		0.66 [8/10]	1.1 [7/1]	1.9 [7/8]	11,000 [7/9]	ND	1.5 [7/8]	310 [8/5]
Cs-137 (Approx.30 years)		1.6 [8/8]	1.5 [7/1]	3.6 [7/8]	22,000 [7/9]	1.4 [7/12]	3.6 [7/8]	650 [8/5]
The other y	Ru-106 (Approx. 370 days)	ND	26 [5/24]	7.9 [7/8]	160 [8/15]	17 [7/22] [8/8]	3.1 [8/8]	ND
	Mn-54 (Approx. 310 days)	ND	ND	1.0 [7/5]	62 [7/5]	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	0.50 [7/19]	ND	3.1 [7/8]	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	1.7 [7/11]	ND	250 [7/15]	1.4 [7/12]	ND	12 [8/8]
All β		290 [8/10]	1,900 [5/24]	4,400 [7/8]	900,000 [7/5] [7/9]	160,000 [8/12] [8/15]	330 [7/8]	56,000 [8/5]
H-3 (Approx. 12 years)		34000 [8/10]	500,000 [5/24] [6/7]	630,000 [7/8]	390,000 [8/5]	290,000 [7/12]	98,000 [7/11]	70,000 [8/12]
Sr-90(Approx. 29 years)		Under analysis	1,200 [6/7]	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis

Unit: Bq/L

		Groundwater observation hole No.2	Groundwater observation hole No.2-1	Groundwater observation hole No.3	Groundwater observation hole No.3-1
Cs-134 (Approx. 2 years)		0.50 [7/9]	0.44 [8/1]	3.5 [7/25]	1.2 [7/25]
Cs-137 (Approx.30 years)		1.2 [7/11] [8/1]	1.0 [7/29]	5.9 [8/8]	2.6 [8/1]
The other y	Ru-106 (Approx. 370 days)	ND	ND	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND
All β		1,700 [7/8]	380 [7/29]	1,400 [7/11]	180 [8/1]
H-3 (Approx. 12 years)		870 [8/8]	290 [8/12]	3,200 [2012/12/12]	460 [8/1]
Sr-90(Approx. 29 years)		54 [5/31]	Under analysis	8.3 [2012/12/12]	Under analysis

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement* (Seawater)

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)
Cs-134(Approx. 2 years)	1.8 [6/21]	ND	5.3 [8/5]	34 [8/13]	16 [8/12]	24 [8/12]	27 [8/10]	9.9 [7/23]	20 [8/12]	21 [8/12]	350 [7/15]
Cs-137(Approx.30 years)	3.3 [6/26]	3.1 [7/15]	8.6 [8/5]	81 [8/13]	33 [8/12]	51 [8/12]	56 [8/10]	20 [8/15]	42 [8/12]	37 [8/12]	770 [7/15]
All β	ND	20 [7/2]	40 [7/3]	1,100 [8/15]	320 [8/12]	700 [8/12]	740 [8/15]	450 [7/16]	370 [8/12]	410 [8/12]	1000 [7/15]
H-3 (Approx. 12 years)	8.6 [6/26]	11 [7/15]	340 [6/26]	4,700 [8/15]	460 [7/15]	2,500 [8/12]	2,600 [8/15]	1,200 [8/4]	570 [8/12]	720 [8/12]	380 [8/12]
Sr-90 (Approx. 29 years)	5.8 [6/26]	-	7.4 [6/26]	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis

Unit: Bq/L

	1F, Between the water intake channel of Unit 3 and Unit 4	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	East side of the port entrance	South side of the south breakwater
Cs-134(Approx. 2 years)	22 [8/12]	46 [7/8]	ND	ND	ND	ND	ND	ND	ND	ND	ND
Cs-137(Approx.30 years)	45 [8/12]	93 [7/8]	3.0 [7/15]	3.7 [6/26]	3.3 [7/4]	3.3 [6/26]	ND	ND	ND	ND	ND
All β	390 [8/12]	310 [8/12]	ND	31 [6/26]	40 [7/4]	60 [7/4]	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	650 [8/12]	400 [8/12]	ND	29 [6/26]	44 [7/4]	37 [7/4]	6.5 [8/12]	3.4 [8/12]	Under analysis	Under analysis	Under analysis
Sr-90 (Approx. 29 years)	Under analysis	Under analysis	0.36 [6/26]	3.5 [6/20]	Under analysis	Under analysis	-	-	-	-	-

* The highest result announced in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided.

As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14.

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses.

* "-" indicates that the measurement was out of range.