


Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank protection

East seawall break



— : Location where ground improvement work was completed, or being implemented (as of October 28)

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/2)
Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-16	Groundwater pumped up from the well point
Date of sampling	/	/	/	/	/	/	/	/	/	/	/
Time of sampling	/	/	/	/	/	/	/	/	/	/	/
Chloride (unit: ppm)	/	/	/	/	/	/	/	/	/	/	/
Cs-134 (Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/
Cs-137 (Approx.30 years)	/	/	/	/	/	/	/	/	/	/	/
The other γ	/	/	/	/	/	/	/	/	/	/	/
	/	/	/	/	/	/	/	/	/	/	/
	/	/	/	/	/	/	/	/	/	/	/
All β	/	/	/	/	/	/	/	/	/	/	
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	

	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.3	Underground water observation hole No.3-4
Date of sampling	Oct 27, 2013	/	/	Oct 27, 2013	/	/
Time of sampling	9:30 AM	/	/	9:56 AM	/	/
Cs-134 (Approx. 2 years)	ND(0.43)	/	/	ND(0.44)	/	/
Cs-137 (Approx.30 years)	0.72	/	/	ND(0.54)	/	/
The other γ	/	/	/	/	/	/
	/	/	/	/	/	/
	/	/	/	/	/	/
All β	230	/	/	850	/	/
H-3 (Approx. 12 years)	650	/	/	1,000	/	/
Sr-90 (Approx. 29 years)	-	/	/	-	/	/

* Data announced this time is provided in a thick-frame. The other data was announced on October 28.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/2)
Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-16	Groundwater pumped up from the well point
Date of sampling	/	/	/	/	/	/	/	/	/	/	/
Time of sampling	/	/	/	/	/	/	/	/	/	/	/
Chloride (unit: ppm)	/	/	/	/	/	/	/	/	/	/	/
Cs-134 (Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/
Cs-137 (Approx.30 years)	/	/	/	/	/	/	/	/	/	/	/
The other γ	/	/	/	/	/	/	/	/	/	/	/
	/	/	/	/	/	/	/	/	/	/	/
	/	/	/	/	/	/	/	/	/	/	/
All β	/	/	/	/	/	/	/	/	/	/	
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	

	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.3	Underground water observation hole No.3-4
Date of sampling	Oct 30, 2013	/	/	Oct 30, 2013	/	Oct 30, 2013
Time of sampling	9:58 AM	/	/	10:30 AM	/	11:19 AM
Cs-134 (Approx. 2 years)	ND(0.38)	/	/	0.56	/	1.8
Cs-137 (Approx.30 years)	0.65	/	/	0.53	/	3.8
The other γ	Mn-54 (Approx. 310 days)	ND	/	ND	/	0.5
		/	/	/	/	/
All β	270	/	/	1,100	/	ND(17)
H-3 (Approx. 12 years)	Under analysis	/	/	Under analysis	/	Under analysis
Sr-90 (Approx. 29 years)	-	/	/	-	/	-

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

	Groundwater observation hole No.0-1	Groundwater observation hole No.0-2	Groundwater observation hole No.0-4	Groundwater observation hole No.1	Groundwater observation hole No.1-1	Groundwater observation hole No.1-2	Groundwater observation hole No.1-3	Groundwater observation hole No.1-4	Groundwater observation hole No.1-5	Groundwater observation hole No.1-8	Groundwater observation hole No.1-9	Groundwater observation hole No.1-11	Groundwater observation hole No.1-12	Groundwater observation hole No.1-16	Groundwater pumped up from the well point (notch tank)	
Cs-134 (Approx. 2 years)	5.1 (10/20)	(1/0) (10/13)	ND	13 (8/29)	1.9 (7/8)	11,000 (7/9)	10 (9/2)	1.5 (7/8)	310 (8/5)	43 (10/28)	170 (9/3)	0.92 (10/14)	74 (10/21)	1.5 (10/3)	110 (9/23)	
Cs-137 (Approx.30 years)	9.5 (10/20)	1.6 (10/13)	ND	31 (8/29)	3.6 (7/8)	22,000 (7/9)	24 (9/2)	3.6 (7/8)	650 (8/5)	95 (9/16)	380 (9/3)	2.0 (10/10)	170 (10/21)	3.4 (10/10)	250 (9/23)	
The other γ	Ru-106 (Approx. 370 days)	ND	ND	ND	26 (5/24)	7.9 (7/8)	160 (8/15)	17 (7/22) (8/8)	3.1 (8/8)	ND	ND	ND	ND	5.4 (10/28)	9.2 (10/28)	25 (9/2)
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	1.0 (7/5)	62 (7/5)	ND	ND	ND	2.6 (10/28)	ND	ND	ND	ND	
	Co-60 (Approx. 5 years)	ND	ND	ND	0.50 (7/19)	ND	3.1 (7/8)	ND	ND	ND	0.44 (10/28)	ND	ND	0.51 (10/24)	0.64 (10/28)	ND
	Sb-125 (Approx. 3 years)	ND	ND	ND	1.7 (7/11)	ND	250 (7/15)	1.4 (7/12) (8/26)	ND	12 (8/8)	ND	ND	ND	61	4.5 (10/28)	ND
All β	300 (8/22)	(3/27) (10/13)	ND	1,900 (5/24)	4,400 (7/8)	900,000 (7/5) (7/9)	160,000 (8/12) (8/15)	380 (8/19)	56,000 (8/5)	11,000 (10/28)	600 (9/8)	72 (10/3)	730 (10/21)	880,000 (10/14)	700,000 (9/23)	
H-3 (Approx. 12 years)	45,000 (8/29)	ND	13000 (10/27)	500,000 (5/24) (6/7)	630,000 (7/8)	57,000 (10/3)	290,000 (7/12)	98,000 (7/11)	72,000 (8/15)	2500 (10/14)	770 (10/1)	85,000 (9/13)	390,000 (10/24)	43,000 (9/26)	460,000 (8/19)	
Sr-90(Approx. 29 years)	Under analysis	Under analysis	Under analysis	1,200 (6/7)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis (10/21)	Under analysis	-	

Unit: Bq/L

	Groundwater observation hole No.2	Groundwater observation hole No.2-1	Groundwater observation hole No.2-5 ¹	Groundwater observation hole No.2-6	Groundwater observation hole No.3	Groundwater observation hole No.3-1	Groundwater observation hole No.3-4
Cs-134 (Approx. 2 years)	0.50 (7/9)	0.66 (9/1)	3.7 (9/29)	0.42 (9/22)	3.5 (7/25)	1.2 (7/25) (8/8)	1.0 (9/25)
Cs-137 (Approx.30 years)	1.2 (7/11) (8/1)	1.1 (8/29) (9/1)	10 (9/29)	0.6 (10/13)	5.9 (8/8)	2.6 (8/1)	2.3 (10/23)
The other γ	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	0.77 (9/29)	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	26 (9/29)	ND	1.1 (9/5)	ND
All β	1,700 (7/8)	380 (7/29)	46,000 (9/29)	850 (10/27)	1,400 (7/11)	180 (8/1)	ND
H-3 (Approx. 12 years)	850 (8/26)	440 (8/26)	1,500 (9/29)	1,100 (10/13) (10/17)	3,200 (2012/12/12)	460 (8/1)	170 (9/18)
Sr-90(Approx. 29 years)	54 (5/31)	Under analysis	Under analysis	Under analysis	8.3 (2012/12/12)	Under analysis	Under analysis

*1 Although we previously announced the analysis result of γ and all β on September 29, we have reanalyze the sample.

The analysis result of No.2-5 is the reference value, since we could not sample groundwater by a regular procedure.

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses.