


### Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank protection

East seawall break



— : Location where ground improvement work was completed, or being implemented (as of November 6)

## Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (1/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16	Groundwater pumped up from the well point
Date of sampling													
Time of sampling													
Chloride (unit: ppm)													
Cs-134 (Approx. 2 years)													
Cs-137 (Approx.30 years)													
The other γ													
All β													
H-3 (Approx. 12 years)													
Sr-90 (Approx. 29 years)													

	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.3	Underground water observation hole No.3-4
Date of sampling	Nov 13, 2013			Nov 13, 2013		Nov 13, 2013
Time of sampling	9:16 AM			9:50 AM		10:50 AM
Cs-134 (Approx. 2 years)	ND(0.39)			ND(0.44)		1.5
Cs-137 (Approx.30 years)	0.76			ND(0.55)		3.6
The other γ						
All β	320			2,000		ND(17)
H-3 (Approx. 12 years)	510			1,100		ND(120)
Sr-90 (Approx. 29 years)	-			-		-

\* Data announced this time is provided in a thick-frame. The other data was announced on November 143.  
 \* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.  
 \* "-" indicates that the measurement was out of range.

## Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (2/4) Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

	Underground water observation hole No.0-1	Underground water observation hole No.0-1-2	Underground water observation hole No.0-2	Underground water observation hole No.0-4	Underground water observation hole No.1	Underground water observation hole No.1-2	Underground water observation hole No.1-8	Underground water observation hole No.1-9	Underground water observation hole No.1-11	Underground water observation hole No.1-12	Underground water observation hole No.1-14	Underground water observation hole No.1-16	Groundwater pumped up from the well point
Date of sampling	Nov 17, 2013	Nov 17, 2013	Nov 17, 2013	Nov 17, 2013	/	/	/	Nov 17, 2013	/	/	/	/	/
Time of sampling	9:42 AM	10:02 AM	10:42 AM	11:35 AM	/	/	/	6:16 AM	/	/	/	/	/
Chloride (unit: ppm)	-	-	-	-	/	/	/	380	/	/	/	/	/
Cs-134 (Approx. 2 years)	5.3	ND(0.40)	ND(0.39)	ND(0.40)	/	/	/	13	/	/	/	/	/
Cs-137 (Approx.30 years)	12	0.51	ND(0.54)	ND(0.52)	/	/	/	30	/	/	/	/	/
The other γ					/	/	/		/	/	/	/	/
					/	/	/		/	/	/	/	/
					/	/	/		/	/	/	/	/
All β	93	ND(18)	ND(18)	ND(18)	/	/	2,100	/	/	/	/	/	
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	/	/	Under analysis	/	/	/	/	/	/
Sr-90 (Approx. 29 years)	-	-	-	-	/	/	-	/	/	/	/	/	/

	Underground water observation hole No.2	Underground water observation hole No.2-1	Underground water observation hole No.2-5	Underground water observation hole No.2-6	Underground water observation hole No.3	Underground water observation hole No.3-4
Date of sampling	Nov 17, 2013	/	/	Nov 17, 2013	/	/
Time of sampling	9:20 AM	/	/	9:45 AM	/	/
Cs-134 (Approx. 2 years)	ND(0.44)	/	/	ND(0.40)	/	/
Cs-137 (Approx.30 years)	0.84	/	/	0.60	/	/
The other γ		/	/		/	/
		/	/		/	/
		/	/		/	/
All β	270	/	/	2,100	/	/
H-3 (Approx. 12 years)	Under analysis	/	/	Under analysis	/	/
Sr-90 (Approx. 29 years)	-	/	/	-	/	/

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

# Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Seawater)



## Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (3/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	Nov 14, 2013	/	/	Nov 14, 2013	Nov 14, 2013	/	/	/	/		
Time of sampling	/	/	/	6:17 AM	/	/	6:25 AM	6:25 AM	/	/	/	/		
Cs-134(Approx. 2 years)	/	/	/	22	/	/	21	19	/	/	/	/	60	10
Cs-137(Approx.30 years)	/	/	/	51	/	/	53	47	/	/	/	/	90	10
All β	/	/	/	680	/	/	670	250	/	/	/	/		
H-3 (Approx. 12 years)	/	/	/	1,900	/	/	1,400	790	/	/	/	/	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	-	/	/	-	-	/	/	/	/	30	10

Unit: Bq/L

	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	/	/	/	/	/	/	/	/	/		
Time of sampling	/	/	/	/	/	/	/	/	/	/	/	/		
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/	/	60	10
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/	/	/	/	/	90	10
All β	/	/	/	/	/	/	/	/	/	/	/	/		
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	/	/	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	/	/	30	10

\* Data announced this time is provided in a thick-frame. The other data was announced on November 15.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

\* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm<sup>3</sup> to Bq/L]).

## Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (4/4) Seawater

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	Nov 17, 2013	/	/	Nov 17, 2013	Nov 17, 2013	/	/	/	/		
Time of sampling	/	/	/	6:36 AM	/	/	6:18 AM	6:18 AM	/	/	/	/		
Cs-134(Approx. 2 years)	/	/	/	8.0	/	/	18	16	/	/	/	/	60	10
Cs-137(Approx.30 years)	/	/	/	21	/	/	49	42	/	/	/	/	90	10
All β	/	/	/	400	/	/	330	210	/	/	/	/		
H-3 (Approx. 12 years)	/	/	/	Under analysis	/	/	Under analysis	Under analysis	/	/	/	/	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	-	/	/	-	-	/	/	/	/	30	10

Unit: Bq/L

	1F, Unit 4 Screen (Inside the Silt Fence)	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the port entrance	Southeast side of the port entrance	South side of the south breakwater	Density Limit Specified by the Reactor Regulation *	WHO Guidelines for drinking-water quality
Date of Sampling	/	/	/	/	/	/	/	/	/	/	/	/		
Time of sampling	/	/	/	/	/	/	/	/	/	/	/	/		
Cs-134(Approx. 2 years)	/	/	/	/	/	/	/	/	/	/	/	/	60	10
Cs-137(Approx.30 years)	/	/	/	/	/	/	/	/	/	/	/	/	90	10
All β	/	/	/	/	/	/	/	/	/	/	/	/		
H-3 (Approx. 12 years)	/	/	/	/	/	/	/	/	/	/	/	/	60,000	10,000
Sr-90 (Approx. 29 years)	/	/	/	/	/	/	/	/	/	/	/	/	30	10

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* "-" indicates that the measurement was out of range.

\* Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2 [the amount is converted from Bq/cm<sup>3</sup> to Bq/L]).

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

	Groundwater observation hole No.0-1	Groundwater observation hole No.0-1-2	Groundwater observation hole No.0-2	Groundwater observation hole No.0-4	Groundwater observation hole No.1	Groundwater observation hole No.1-1	Groundwater observation hole No.1-2	Groundwater observation hole No.1-3	Groundwater observation hole No.1-4	Groundwater observation hole No.1-5	Groundwater observation hole No.1-8	Groundwater observation hole No.1-9
Cs-134 (Approx. 2 years)	6.3 [ 11/10 ]	ND	0.61 [ 10/13 ]	ND	13 [ 8/29 ]	1.9 [ 7/8 ]	11,000 [ 7/9 ]	10 [ 9/2 ]	1.5 [ 7/8 ]	310 [ 8/5 ]	43 [ 10/28 ]	170 [ 9/3 ]
Cs-137 (Approx.30 years)	14 [ 11/10 ]	ND	1.6 [ 10/13 ]	0.48 [ 11/10 ]	31 [ 8/29 ]	3.6 [ 7/8 ]	22,000 [ 7/9 ]	24 [ 9/2 ]	3.6 [ 7/8 ]	650 [ 8/5 ]	95 [ 10/28 ]	380 [ 9/3 ]
The other γ	Ru-106 (Approx. 370 days)	ND	ND	ND	26 [ 5/24 ]	7.9 [ 7/8 ]	160 [ 8/15 ]	17 [ 7/22 ] [ 8/8 ]	3.1 [ 8/8 ]	ND	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND	1.0 [ 7/5 ]	62 [ 7/5 ]	ND	ND	ND	3.6 [ 11/11 ]	ND
	Co-60 (Approx. 5 years)	ND	ND	ND	0.50 [ 7/19 ]	ND	3.1 [ 7/8 ]	ND	ND	ND	0.44 [ 10/28 ]	ND
	Sb-125 (Approx. 3 years)	ND	ND	ND	ND	1.7 [ 7/11 ]	ND	250 [ 7/15 ]	1.4 [ 7/12 ] [ 8/26 ]	ND	12 [ 8/8 ]	ND
All β	300 [ 8/22 ]	21 [ 11/10 ]	87 [ 10/13 ]	ND	1,900 [ 5/24 ]	4,400 [ 7/8 ]	900,000 [ 7/5 ] [ 7/9 ]	160,000 [ 8/12 ] [ 8/15 ]	380 [ 8/19 ]	56,000 [ 8/5 ]	11,000 [ 10/28 ] [ 11/11 ]	600 [ 9/8 ]
H-3 (Approx. 12 years)	45,000 [ 8/29 ]	36,000 [ 11/10 ]	ND	19,000 [ 11/10 ]	500,000 [ 5/24 ] [ 6/7 ]	630,000 [ 7/8 ]	430,000 [ 9/16 ]	290,000 [ 7/12 ]	98,000 [ 7/11 ]	72,000 [ 8/15 ]	2,700 [ 11/11 ]	810 [ 11/12 ]
Sr-90(Approx. 29 years)	Under analysis	Under analysis	Under analysis	Under analysis	1,200 [ 6/7 ]	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis

Unit: Bq/L

	Groundwater observation hole No.1-11	Groundwater observation hole No.1-12	Groundwater observation hole No.1-14	Groundwater observation hole No.1-16	Groundwater pumped up from the well point (notch tank)
Cs-134 (Approx. 2 years)	0.94 [ 10/31 ]	74 [ 10/21 ]	1.2 [ 11/14 ]	1.6 [ 11/14 ]	110 [ 9/23 ]
Cs-137 (Approx.30 years)	2.0 [ 10/10 ] [ 11/11 ]	170 [ 10/21 ]	2.0 [ 11/10 ]	3.4 [ 10/10 ]	250 [ 9/23 ]
The other γ	Ru-106 (Approx. 370 days)	ND	5.4 [ 10/28 ]	ND	9.2 [ 10/28 ]
	Mn-54 (Approx. 310 days)	ND	ND	ND	ND
	Co-60 (Approx. 5 years)	ND	0.51 [ 10/24 ]	ND	0.9 [ 11/7 ]
	Sb-125 (Approx. 3 years)	ND	61 [ 10/21 ]	ND	7.5 [ 11/11 ]
All β	72 [ 10/3 ]	730 [ 10/21 ]	33 [ 11/10 ]	880,000 [ 10/14 ]	700,000 [ 9/23 ]
H-3 (Approx. 12 years)	85,000 [ 9/13 ]	440,000 [ 10/31 ]	2,600 [ 11/10 ]	43,000 [ 9/26 ]	460,000 [ 8/19 ]
Sr-90(Approx. 29 years)	Under analysis	Under analysis [ 10/21 ]	Under analysis	Under analysis	-

Unit: Bq/L

	Groundwater observation hole No.2	Groundwater observation hole No.2-1	Groundwater observation hole No.2-5 <sup>*1</sup>	Groundwater observation hole No.2-6	Groundwater observation hole No.3	Groundwater observation hole No.3-1	Groundwater observation hole No.3-4
Cs-134 (Approx. 2 years)	0.50 [ 7/9 ]	0.66 [ 9/1 ]	3.9 [ 11/7 ]	0.56 [ 10/30 ]	3.5 [ 7/25 ]	1.2 [ 7/25 ] [ 8/8 ]	1.8 [ 10/30 ]
Cs-137 (Approx.30 years)	1.2 [ 7/11 ] [ 8/1 ]	1.1 [ 8/29 ] [ 9/1 ]	10 [ 9/29 ]	0.61 [ 10/13 ]	5.9 [ 8/8 ]	2.6 [ 8/1 ]	3.8 [ 10/30 ]
The other γ	Ru-106 (Approx. 370 days)	ND	ND	ND	ND	ND	ND
	Mn-54 (Approx. 310 days)	ND	ND	0.77 [ 9/29 ]	ND	ND	0.54 [ 10/30 ]
	Co-60 (Approx. 5 years)	ND	ND	ND	ND	ND	ND
	Sb-125 (Approx. 3 years)	ND	ND	26 [ 9/29 ]	ND	1.1 [ 9/5 ]	ND
All β	1,700 [ 7/8 ]	380 [ 7/29 ]	46,000 [ 9/29 ]	2,000 [ 11/13 ]	1,400 [ 7/11 ]	180 [ 8/1 ]	ND
H-3 (Approx. 12 years)	850 [ 6/26 ]	440 [ 8/26 ]	3,100 [ 11/7 ]	1,100 [ 10/13 ] [ 10/17 ] [ 11/6 ] [ 11/10 ]	3,200 [ H24. 12/12 ]	460 [ 8/1 ]	170 [ 9/18 ]
Sr-90(Approx. 29 years)	54 [ 5/31 ]	Under analysis	Under analysis	Under analysis	8.3 [ 2012/12/ 12 ]	Under analysis	Under analysis

\*1 Although we previously announced the analysis result of γ and all β on September 29, we have reanalyze the sample.

The analysis result of No.2-5 is the reference value, since we could not sample groundwater by a regular procedure.

\* "ND" indicates that the measurement result is below the detection limit.

\* Date of sampling is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement\* (Seawater)

Unit: Bq/L

	1F, North side of Unit 5,6 discharge channel	1F, In front of Unit 6 water intake channel	1F, In front of shallow draft quay	1F, North side of Unit 1-4 water intake channel	1F, North side of Unit 1-4 water intake channel (north side of East Seawall Break)	1F, Unit 1 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 1 and Unit 2 (surface layer)	1F, Between the water intake channel of Unit 1 and Unit 2 (lower layer)	1F, Unit 2 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 2 and Unit 3 (surface layer)	1F, Between the water intake channel of Unit 2 and Unit 3 (lower layer)	1F, Unit 3 Screen (Inside the Silt Fence)	1F, Between the water intake channel of Unit 3 and Unit 4 (surface layer)	1F, Between the water intake channel of Unit 3 and Unit 4 (lower layer)	1F, Unit 4 Screen (Inside the Silt Fence)
Cs-134(Approx. 2 years)	1.8 [ 6/21]	2.4 [ 8/19]	5.3 [ 8/5]	89 [ 10/10]	32 [ 10/11]	73 [ 10/10]	87 [ 10/10]	93 [ 10/10]	370 [ 10/9]	46 [ 10/11]	3.5 [ 8/20]	350 [ 7/15]	28 [ 9/16]	4.8 [ 8/20]	62 [ 9/16]
Cs-137(Approx.30 years)	3.3 [ 6/26]	4.7 [ 8/19]	<u>8.6</u> [ 8/5]	190 [ 10/10]	73 [ 10/11]	170 [ 10/10]	200 [ 10/10]	200 [ 10/10]	830 [ 10/9]	110 [ 10/11]	9.8 [ 8/20]	770 [ 7/15]	50 [ 9/16]	7.7 [ 8/20]	140 [ 9/16]
All β	ND	46 [ 8/19]	<u>40</u> [ 7/3]	1,400 [ 11/7]	320 [ 8/12]	740 [ 10/28]	740 [ 8/15] [ 10/13] [ 10/31]	450 [ 7/16]	1,700 [ 10/9]	480 [ 10/7]	85 [ 8/20]	1,000 [ 7/15]	390 [ 8/12]	57 [ 8/20]	360 [ 10/7]
H-3 (Approx. 12 years)	8.6 [ 6/26]	24 [ 8/19]	340 [ 6/26]	4,800 [ 11/7]	510 [ 9/2]	2,800 [ 10/28]	2,700 [ 11/7]	1,600 [ 9/1]	2,100 [ 10/28]	1,200 [ 10/7]	-	410 [ 9/2]	650 [ 8/12]	-	400 [ 8/12] [ 10/7]
Sr-90 (Approx. 29 years)	5.8 [ 6/26]	-	7.4 [ 6/26]	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	-	Under analysis	Under analysis	-	Under analysis

Unit: Bq/L

	1F, Around the south discharge channel	1F, Port entrance	1F, East side in the port	1F, West side in the port	1F, North side in the port	1F, South side in the port	North side of the north breakwater	Northeast side of the port entrance	East side of the south breakwater	Southeast side of the north breakwater	South side of the south breakwater
Cs-134(Approx. 2 years)	ND	2.7 [ 10/11]	3.3 [ 10/17]	2.6 [ 8/19]	2.5 [ 10/17]	3.5 [ 10/17]	ND	ND	ND	ND	ND
Cs-137(Approx.30 years)	3.0 [ 7/15]	7.3 [ 10/11]	9.0 [ 10/17]	6.5 [ 8/19]	5.8 [ 10/17]	7.8 [ 10/17]	ND	ND	1.6 [ 10/18]	ND	ND
All β	ND	69 [ 8/19]	74 [ 8/19]	60 [ 7/4]	69 [ 8/19]	79 [ 8/19]	ND	ND	ND	ND	ND
H-3 (Approx. 12 years)	ND	68 [ 8/19]	67 [ 8/19]	59 [ 8/19]	52 [ 8/19]	60 [ 8/19]	4.7 [ 8/14]	ND	6.4 [ 10/8]	ND	ND
Sr-90 (Approx. 29 years)	0.36 [ 6/26]	3.5 [ 6/20]	Under analysis	Under analysis	-	-	-	-	-	-	-

\* The highest result announced in "Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection" or the other handouts is provided.

As for "1F, North side of Unit 1-4 water intake channel", the data is obtained since January 14, 2013. For the other locations, the data is obtained since June 14.

\* "ND" indicates that the measurement result is below the detection limit.

\* Date of sampling is provided in parentheses.

\* "-" indicates that the measurement was out of range.

[Reference] Standard values

Unit: Bq/L

The underlined part was corrected on January 10, 2014.

	Cs-134	Cs-137	H-3	Sr-90
Density Limit Specified by the Rule for the Installation, Operation, etc. of Commercial Nuclear Power Reactors (the density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2)	60	90	60,000	30
WHO Guidelines for drinking-water quality	10	10	10,000	10