


Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection (Sampling Locations of Underground Water Obtained at Bank Protection)

● Sampling locations of underground water obtained at bank protection

East seawall break



— : Location where ground improvement work was completed, or being implemented (as of November 6)

Detailed Analysis Results in the Port of Fukushima Daiichi NPS, around Discharge Channel and Bank Protection Underground Water Obtained at Bank Protection

Unit: Bq/L (exclude chloride)

| | Underground water observation hole No.0-1 | Underground water observation hole No.0-1-2 | Underground water observation hole No.0-2 | Underground water observation hole No.0-3-1 | Underground water observation hole No.0-4 | Underground water observation hole No.1 | Underground water observation hole No.1-8 | Underground water observation hole No.1-9 | Underground water observation hole No.1-11 | Underground water observation hole No.1-12 | Underground water observation hole No.1-14 | Underground water observation hole No.1-16 | Underground water observation hole No.1-17 |
|--------------------------|---|---|---|---|---|---|---|---|--|--|--|--|--|
| Date of sampling | | | | | | | | | | | | | |
| Time of sampling | | | | | | | | | | | | | |
| Chloride (unit: ppm) | | | | | | | | | | | | | |
| Cs-134 (Approx. 2 years) | | | | | | | | | | | | | |
| Cs-137 (Approx.30 years) | | | | | | | | | | | | | |
| The other γ | Co-60 (Approx. 5 years) | | | | | | | | | | | | |
| | Ru-106 (Approx. 370 days) | | | | | | | | | | | | |
| All β | | | | | | | | | | | | | |
| H-3 (Approx. 12 years) | | | | | | | | | | | | | |
| Sr-90 (Approx. 29 years) | | | | | | | | | | | | | |

| | Groundwater pumped up from the well point | Underground water observation hole No.2 | Underground water observation hole No.2-5 | Underground water observation hole No.2-6 | Underground water observation hole No.2-7 | Underground water observation hole No.3 | Underground water observation hole No.3-4 | Underground water observation hole No.3-5 |
|--------------------------|---|---|---|---|---|---|---|---|
| Date of sampling | | | | | | | | Nov 23, 2013 |
| Time of sampling | | | | | | | | 9:25 AM |
| Chloride (unit: ppm) | | | | | | | | 145 |
| Cs-134 (Approx. 2 years) | | | | | | | | - |
| Cs-137 (Approx.30 years) | | | | | | | | - |
| The other γ | | | | | | | | - |
| | | | | | | | | - |
| All β | | | | | | | | 22 |
| H-3 (Approx. 12 years) | | | | | | | | ND(120) |
| Sr-90 (Approx. 29 years) | | | | | | | | - |

* Data of No. 3-5 is provided in a thick-frame. The other data was previously announced on November 23.

* Since the result of No.3-5 was too high to be measured by turbidity meter, chloride, all β and tritium were analyzed as a reference.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* "-" indicates that the measurement was out of range.

<Reference> The Highest Dose Until the Previous Measurement (Groundwater Obtained at Bank Protection)

Unit: Bq/L

| | Groundwater observation hole No.0-1 | Groundwater observation hole No.0-1-2 | Groundwater observation hole No.0-2 | Groundwater observation hole No.0-3-1 | Groundwater observation hole No.0-4 | Groundwater observation hole No.1 | Groundwater observation hole No.1-1* | Groundwater observation hole No.1-2* | Groundwater observation hole No.1-3* | Groundwater observation hole No.1-4* | Groundwater observation hole No.1-5* | Groundwater observation hole No.1-8 |
|--------------------------|-------------------------------------|---------------------------------------|-------------------------------------|---------------------------------------|-------------------------------------|-----------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|-------------------------------------|
| Cs-134 (Approx. 2 years) | 6.3 [11/10] | ND | 0.61 [10/13] | ND | ND | 13 [8/29] | 1.9 [7/8] | 11,000 [7/9] | 10 [9/2] | 1.5 [7/8] | 310 [8/5] | 43 [10/28] |
| Cs-137 (Approx.30 years) | 14 [11/10] | 0.51 [11/17] | 1.6 [10/13] | 0.86 [11/20] | 0.48 [11/10] | 31 [8/29] | 3.6 [7/8] | 22,000 [7/9] | 24 [9/2] | 3.6 [7/8] | 650 [8/5] | 96 [11/18] |
| The other y | Ru-106 (Approx. 370 days) | ND | ND | ND | ND | 26 [5/24] | 7.9 [7/8] | 160 [8/15] | 17 [7/22] [8/8] | 3.1 [8/8] | ND | ND |
| | Mn-54 (Approx. 310 days) | ND | ND | ND | ND | ND | 1.0 [7/5] | 62 [7/5] | ND | ND | ND | 5.2 [11/18] |
| | Co-60 (Approx. 5 years) | ND | ND | ND | ND | 0.50 [7/19] | ND | 3.1 [7/8] | ND | ND | ND | 0.58 [11/18] |
| | Sb-125 (Approx. 3 years) | ND | ND | ND | ND | 1.7 [7/11] | ND | 250 [7/15] | 1.4 [7/12] [8/26] | ND | 12 [8/8] | ND |
| All β | 300 [8/22] | 21 [11/10] | 87 [10/13] | ND | ND | 1,900 [5/24] | 4,400 [7/8] | 900,000 [7/5] [7/9] | 160,000 [8/12] [8/15] | 380 [8/19] | 56,000 [8/5] | 14,000 [11/18] |
| H-3 (Approx. 12 years) | 45,000 [8/29] | 48,000 [11/17] | 130 [11/17] | ND | 19,000 [11/10] | 500,000 [5/24] [6/7] | 630,000 [7/8] | 430,000 [9/16] | 290,000 [7/12] | 98,000 [7/11] | 72,000 [8/15] | 4,900 [11/18] |
| Sr-90(Approx. 29 years) | Under analysis | Under analysis | Under analysis | Under analysis | 1,200 [6/7] | Under analysis | Under analysis | Under analysis | Under analysis | Under analysis | Under analysis | Under analysis |

Unit: Bq/L

| | Groundwater observation hole No.1-9 | Groundwater observation hole No.1-11 | Groundwater observation hole No.1-12 | Groundwater observation hole No.1-14 | Groundwater observation hole No.1-16 | Groundwater observation hole No.1-17 | Groundwater pumped up from the well point (notch tank) |
|--------------------------|-------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--|
| Cs-134 (Approx. 2 years) | 170 [9/3] | 0.94 [10/31] | 74 [10/21] | 1.2 [11/14] | 1.6 [11/14] | ND [11/22] | 110 [9/23] |
| Cs-137 (Approx.30 years) | 380 [9/3] | 2.0 [10/10] [11/11] | 170 [10/21] | 2.3 [11/21] | 3.4 [10/10] | ND [11/22] | 250 [9/23] |
| The other y | Ru-106 (Approx. 370 days) | ND | ND | 5.4 [10/28] | ND | 9.2 [10/28] | 4.0 [11/22] |
| | Mn-54 (Approx. 310 days) | ND | ND | ND | ND | ND | ND |
| | Co-60 (Approx. 5 years) | ND | ND | 0.51 [10/24] | ND | 0.9 [11/7] | 0.41 [11/22] |
| | Sb-125 (Approx. 3 years) | ND | ND | 61 [10/21] | ND | 8.6 [11/18] | ND |
| All β | 2,100 [11/17] | 72 [10/3] | 730 [10/21] | 160 [11/21] | 880,000 [10/14] | 44 [11/22] | 700,000 [9/23] |
| H-3 (Approx. 12 years) | 860 [11/14] | 85,000 [9/13] | 440,000 [10/31] | 3,600 [11/14] [11/18] | 43,000 [9/26] | 9,800 [11/22] | 460,000 [8/19] |
| Sr-90(Approx. 29 years) | Under analysis | Under analysis | Under analysis [10/21] | Under analysis | Under analysis | Under analysis | - |

Unit: Bq/L

| | Groundwater observation hole No.2 | Groundwater observation hole No.2-1* | Groundwater observation hole No.2-5 ^{*1} | Groundwater observation hole No.2-6 | Groundwater observation hole No.2-7 | Groundwater observation hole No.3 | Groundwater observation hole No.3-1 | Groundwater observation hole No.3-4 | Groundwater observation hole No.3-5 |
|--------------------------|-----------------------------------|--------------------------------------|---|--|-------------------------------------|-----------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| Cs-134 (Approx. 2 years) | 0.50 [7/9] | 0.66 [9/1] | 3.9 [11/7] | 0.56 [10/30] | 1.3 [11/21] | 3.5 [7/25] | 1.2 [7/25] [8/8] | 1.8 [10/30] | - |
| Cs-137 (Approx.30 years) | 1.2 [7/11] [8/1] | 1.1 [8/29] [9/1] | 10 [9/29] | 0.61 [10/13] | 3.1 [11/21] | 5.9 [8/8] | 2.6 [8/1] | 3.8 [10/30] | - |
| The other y | Ru-106 (Approx. 370 days) | ND | ND | ND | ND | ND | ND | ND | - |
| | Mn-54 (Approx. 310 days) | ND | ND | 0.77 [9/29] | ND | ND | ND | 0.54 [10/30] | - |
| | Co-60 (Approx. 5 years) | ND | ND | ND | ND | ND | ND | ND | - |
| | Sb-125 (Approx. 3 years) | ND | ND | 26 [9/29] | ND | ND | 1.1 [9/5] | ND | - |
| All β | 1,700 [7/8] | 380 [7/29] | 46,000 [9/29] | 2,100 [11/17] | 18 [11/21] | 1,400 [7/11] | 180 [8/1] | ND | 22 [11/23] |
| H-3 (Approx. 12 years) | 850 [6/26] | 440 [8/26] | 3,100 [11/7] | 1,100 [10/13] [10/17] [11/6] [11/10] [11/13] | 1,000 [11/21] | 3,200 [H24. 12/12] | 460 [8/1] | 170 [9/18] | Under analysis |
| Sr-90(Approx. 29 years) | 54 [5/31] | Under analysis | Under analysis | Under analysis | Under analysis | 8.3 [2012/12/ 12] | Under analysis | Under analysis | - |

*1 The analysis result of No.2-5 obtained on September 29 is the reference value, since we could not sample groundwater by a regular procedure.

*2 Since the water of No.3-5 obtained on November 23 was highly turbid, only chloride, all β and tritium were analyzed as a reference.

* "ND" indicates that the measurement result is below the detection limit.

* Date of sampling is provided in parentheses.

* "*" is provided next to the name of the holes where the sampling could not be performed due to the chemical injection of ground improvement.