

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area						
	E-1	E-2	E-3	E-4	E-5	E-6	E-8
Date of Sampling	Oct 6, 2013	Oct 6, 2013	Oct 6, 2013	Oct 6, 2013	Oct 6, 2013		
Time of sampling	10:18 AM	10:28 AM	11:22 AM	11:15 AM	10:48 AM		
All β	250	40	78	87	ND(19)		
H-3 (Approx. 12 years)	230,000	440	160	220	2,700		

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

