

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 19, 2013	Oct 19, 2013	Oct 19, 2013	Oct 19, 2013	Oct 19, 2013	/	/	/
Time of sampling	9:15 AM	9:00 AM	8:50 AM	8:40 AM	8:30 AM	/	/	/
All $\beta$	330,000	21	82	ND(19)	ND(19)	/	/	/
H-3 (Approx. 12 years)	550,000	330	220	130	2,100	/	/	/

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

