

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 26, 2013	Oct 26, 2013	Oct 26, 2013	Oct 26, 2013	Oct 26, 2013	/	/	/
Time of sampling	9:07 AM	8:50 AM	8:35 AM	8:18 AM	8:05 AM	/	/	/
All β	260,000	36	43	ND(19)	19	/	/	/
H-3 (Approx. 12 years)	220,000	380	220	290	2,000	/	/	/

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

