

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area							
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8
Date of Sampling	Oct 27, 2013	Oct 27, 2013	Oct 27, 2013	Oct 27, 2013	Oct 27, 2013	/	/	/
Time of sampling	10:55 AM	11:45 AM	10:45 AM	10:37 AM	10:21 AM	/	/	/
All $\beta$	210,000	ND(20)	22	21	ND(20)	/	/	/
H-3 (Approx. 12 years)	190,000	340	290	490	1,700	/	/	/

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

