

# Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>  
November 15, 2013  
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area								
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-10
Date of Sampling	Nov 13, 2013	Nov 13, 2013	Nov 13, 2013	Nov 13, 2013	Nov 13, 2013	Nov 13, 2013	Nov 13, 2013	Nov 13, 2013	Nov 13, 2013
Time of sampling	9:40 AM	9:25 AM	9:53 AM	9:38 AM	9:30 AM	10:20 AM	10:48 AM	10:34 AM	10:06 AM
All β	650,000	39	ND(19)	ND(19)	ND(19)	ND(19)	ND(19)	ND(19)	25
H-3 (Approx. 12 years)	310,000	470	520	1,400	3,100	200	650	2300	17,000

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

## <Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
All β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	730 [11/7]	1,200 [11/8,11/9,11/12]	3,100 [11/10]

	E-6	E-7	E-8	E-10
All β	46 [9/20]	ND	17 [10/3]	28 [11/6]
H-3 (Approx. 12 years)	340 [9/25,10/9]	840 [10/9]	1,900 [11/6]	7,700 [11/6]

Unit: Bq/L, sampling date is provided in parentheses.

