

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
December 3, 2013
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area										
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	Well point
Date of Sampling	Dec 1, 2013	Dec 1, 2013	Dec 1, 2013	Dec 1, 2013	Dec 1, 2013	/	/	/	/	/	Dec 1, 2013
Time of sampling	11:35 AM	11:30 AM	11:15 AM	11:05 AM	10:55 AM	/	/	/	/	/	11:38 AM
All β	8,000	ND(18)	ND(18)	ND(18)	ND(18)	/	/	/	/	/	2400
H-3 (Approx. 12 years)	4,000	400	660	1,400	2,500	/	/	/	/	/	160,000

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5
All β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5]	810 [11/25]	2,000 [11/25]	3,100 [11/10,11/13]

	E-6	E-7	E-8	E-9	E-10	Well point
All β	46 [9/20]	ND	17 [10/3]	380 [11/25]	28 [11/6]	16,000 [11/28]
H-3 (Approx. 12 years)	340 [9/25,10/9]	840 [10/9]	2,300 [11/13]	51,000 [11/25]	17,000 [11/13]	190,000 [11/30]

Unit: Bq/L, sampling date is provided in parentheses.

