

Underground Reservoir Nuclide Analysis Results (As of April 24, 2013)

	Underground Reservoir (Drain hole water)													
	i		ii		iii		iv		v		vi		vii	
	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side
Sampled time	5:20 AM	5:20 AM	5:30 AM	5:30 AM	5:50 AM	5:50 AM	6:00 AM	6:00 AM	Out of range	Out of range	6:20 AM	6:20 AM	Out of range	Out of range
Tritium (Bq/cm ³)	3.9E+0	<2.5E-1	4.5E-1	<2.5E-1	<2.5E-1	<2.5E-1	1.1E+0	<2.4E-1			1.0E+0	<2.4E-1		

Half-life period Tritium: Approx. 12 years

	Underground Reservoir (Leakage detector hole water)													
	i		ii		iii		iv		v		vi		vii	
	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side	Northeast side	Southwest side
Sampled time	8:00 AM	8:05 AM	8:10 AM	8:15 AM	Not sampled	8:25 AM	9:00 AM	Not sampled			9:25 AM	Not sampled		
Tritium (Bq/cm ³)	1.1E+3	<2.6E-1	1.8E+0	<2.6E-1		5.1E+0	<2.6E-1				<2.5E-1			

Half-life period Tritium: Approx. 12 years

(Note 1) Analysis of tritium is conducted once a week.

(Note 2) O.OE±O is the same as O.O x 10±O.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
 (As of April 22 - 24, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Apr 22, 2013									Apr 23, 2013	Apr 24, 2013				
Sampled time	10:57 AM	11:36 AM	12:51 PM	11:50 AM	11:55 AM	12:06 PM	12:05 PM	10:26 AM	1:13 PM	11:19 AM	11:33 AM				
Chloride concentration (ppm)	17	9	11	46	43	99	18	8	8	<1	9				
Tritium (Bq/cm ³)	<2.4E-1	<2.4E-1	<2.4E-1	<2.5E-1	<2.5E-1	<2.5E-1	<2.5E-1	<2.6E-1	<2.6E-1	3.8E+0	9.3E-1				
All β(Bq/cm ³)	<2.8E-2	<2.8E-2	<2.8E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.8E-2	<2.8E-2	<3.2E-2	<2.8E-2				

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on April 23, 24 and 25.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.