

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
 (As of May 13 and 14, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	May 14, 2013										May 13, 2013				
Sampled time	Not sampled	10:21 AM	10:35 AM	9:55 AM	10:00 AM	10:05 AM	10:10 AM	9:01 AM	10:08 AM	9:40 AM	9:51 AM	9:10 AM	9:28 AM	10:00 AM	11:02 AM
Chloride concentration (ppm)		9	13	15	66	85	12	8	7	9	11	8	10	18	9
Tritium (Bq/cm <sup>3</sup> )		1.2E-1	<8.0E-3	2.7E-2	2.2E-2	2.2E-2	5.8E-2	8.3E-2	4.2E-2	3.5E+0	9.5E-1	8.1E-2	8.4E-2	2.5E-2	5.8E-2
All β(Bq/cm <sup>3</sup> )		<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.2E-2	<3.2E-2	<3.2E-2	<3.2E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on May 14 and 15.

(Note 2) O.OE±O is the same as O.O x 10<sup>±0</sup>.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.