

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
(As of September 23 and 24, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Sep 24, 2013										Sep 23, 2013				
Sampled time	Not sampled	9:45 AM	9:22 AM	8:10 AM	8:13 AM	8:15 AM	8:20 AM	8:47 AM	9:17 AM	9:00 AM	9:45 AM	8:29 AM	8:12 AM	8:51 AM	8:40 AM
Chloride concentration (ppm)		10	12	40	75	90	10	9	6	10	11	8	10	16	10
Tritium (Bq/cm <sup>3</sup> )		8.6E-2	<8.5E-3	9.3E-3	2.2E-2	<6.7E-3	4.4E-2	8.8E-2	4.2E-2	1.6E+0	2.1E+0	7.0E-2	8.6E-2	4.6E-2	5.6E-2
All β(Bq/cm <sup>3</sup> )		<2.6E-2	<2.6E-2	<1.6E-2	<1.6E-2	<1.6E-2	<1.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on September 24 and 25.

(Note 2) O.OE±O is the same as O.O x 10<sup>±0</sup>.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.