

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of September 30 and October 1, 2013)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Oct 1, 2013										Sep 30, 2013				
Sampled time	Not sampled	9:58 AM	9:37 AM	9:20 AM	9:25 AM	9:30 AM	9:35 AM	9:13 AM	9:56 AM	9:11 AM	10:23 AM	9:46 AM	8:42 AM	9:05 AM	9:13 AM
Chloride concentration (ppm)		10	11	30	70	70	9	10	7	11	12	8	10	17	10
Tritium (Bq/cm ³)		8.7E-2	<6.6E-3	1.4E-2	2.5E-2	<4.7E-3	4.5E-2	7.3E-2	3.5E-2	1.6E+0	2.5E+0	6.6E-2	7.7E-2	3.3E-2	4.8E-2
All β(Bq/cm ³)		<2.8E-2	<2.8E-2	<1.7E-2	<1.7E-2	<1.7E-2	<1.7E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.6E-2	<2.6E-2	<2.6E-2	<2.6E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on October 1 and 2.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.