

Reference
-----------

Nuclide Analysis of the Radioactive Materials in the Fallouts obtained inside and outside of Fukushima Daiichi Nuclear Power Station

	Sampling Point		Sampling Period		Radioactivity Density of Samples (Bq/m <sup>2</sup> ) (Half-life)		
			From	To	I-131 (approx. 8 days)	Cs-134 (approx. 2 years)	Cs-137 (approx. 30 years)
Fukushima Daiichi NPS		Environment Management Building	2012/12/28 10:00 AM	2013/2/1 1:40 PM	ND	220	400
Fukushima Daini NPS		Administrative Office Building	2012/12/28 10:40 AM	2013/2/1 2:30 PM	ND	64	92

\* Bq/m<sup>2</sup> = MBq/km<sup>2</sup>

\* "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 65Bq/m<sup>2</sup>

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.