

## Gas Sampling Results of Unit 3 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station

(Data summarized on March 25)

Place of Sampling	Exit of Unit 3 PCV Gas Control System			
Type of Sampling	Particulate Filter		Charcoal Filter	
Time of Sampling	Mar 17, 2013 10:37 AM - 10:47 AM		Mar 17, 2013 10:47 AM - 11:17 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )	Detection Limit Density (Bq/cm <sup>3</sup> )	Density of Sample (Bq/cm <sup>3</sup> )	Detection Limit Density (Bq/cm <sup>3</sup> )
I-131 (Approx. 8 days)	ND	1.0E-06	ND	6.2E-07
Cs-134 (Approx. 2 years)	ND	2.4E-06	2.1E-06	1.4E-06
Cs-137 (Approx. 30 years)	5.6E-06	3.0E-06	4.8E-06	1.8E-06

\* O.OE - O is the same as O.O x 10<sup>-O</sup>

\* "ND" indicates that the measurement result is below the detection limit.

This sampling is intended for the nuclides analysis results of cesium and iodine.