

## Gas Sampling Results of Unit 3 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station

(Data summarized on September 30)

Place of Sampling	Exit of Unit 3 PCV Gas Control System			
Type of Sampling	Particulate Filter		Charcoal Filter	
Time of Sampling	Sep 25, 2013 11:59 AM - 12:09 PM		Sep 25, 2013 12:09 PM - 12:39 PM	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )	Detection Limit Density (Bq/cm <sup>3</sup> )	Density of Sample (Bq/cm <sup>3</sup> )	Detection Limit Density (Bq/cm <sup>3</sup> )
I-131 (Approx. 8 days)	ND	1.1E-06	ND	5.2E-07
Cs-134 (Approx. 2 years)	ND	2.2E-06	ND	1.2E-06
Cs-137 (Approx. 30 years)	3.5E-06	3.0E-06	ND	1.7E-06

\* O.OE - O is the same as O.O x 10<sup>-O</sup>

\* "ND" indicates that the measurement result is below the detection limit.

This sampling is intended for the nuclides analysis result of cesium and iodine.