

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

Unit: Bq/L

	Pump wells of the groundwater bypass					
	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Sep 5, 2013	Sep 5, 2013	Sep 5, 2013	Sep 5, 2013	Sep 5, 2013	Sep 5, 2013
Time of sampling	8:50 AM	8:55 AM	9:00 AM	9:05 AM	9:10 AM	9:15 AM
All $\beta$	ND(17)	ND(17)	ND(17)	ND(17)	ND(17)	ND(17)
Tritium	500	63	46	230	330	870

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.