

Reference

## Nuclides Analysis Result of the Radioactive Materials in the Air at the Exhaust System of the Unit 2 Reactor Building

(Data summarized on October 11)

Place of Sampling	The Exhaust System of the Unit 2 Reactor Building (The entrance of cover exhaust system filter)		The Exhaust System of the Unit 2 Reactor Building (The exit of cover exhaust system filter)		② Density Limit Specified by the Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
Time of Sampling	Oct 4, 2013 11:02 AM - 1:01 PM		Oct 4, 2013 10:54 AM - 12:54 PM		
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	①Density of Sample (Bq/cm <sup>3</sup> )	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	3.7E-07	0.00	ND	-	2E-03
Cs-137 (Approx. 30 years)	1.0E-06	0.00	ND	-	3E-03

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as O.O x 10<sup>0</sup>

Data of other nuclides is under examination.

\* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits of the exhaust system at the Unit 2 Reactor Building (the entrance of cover exhaust system filter) are as follows.

Volatile; I-131: Approx. 2E-7Bq/cm<sup>3</sup>, Cs-134: Approx. 4E-7Bq/cm<sup>3</sup>, Cs-137: Approx. 6E-7Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 1E-7Bq/cm<sup>3</sup>

The detection limits of the exhaust system at the Unit 2 Reactor Building (the exit of cover exhaust system filter) are as follows.

Volatile; I-131: Approx. 2E-7Bq/cm<sup>3</sup>, Cs-134: Approx. 4E-7Bq/cm<sup>3</sup>, Cs-137: Approx. 6E-7Bq/cm<sup>3</sup>

Particulate; I-131: Approx. 1E-7Bq/cm<sup>3</sup>, Cs-134: Approx. 3E-7Bq/cm<sup>3</sup>, Cs-137: Approx. 3E-7Bq/cm<sup>3</sup>