

Reference

Nuclides Analysis Result of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS <1/4>

(Data summarized on March 25)

| Place of Sampling | Incineration Workshop Building Opening (Southeast Side) | | On-site Bunker Building Opening (Large Equipment Hatch) | | Miscellaneous Solid Waste Volume Reduction Treatment Building Opening (Northeast Side) | | Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2) |
|----------------------------------|--|-------------------------|--|-------------------------|---|-------------------------|---|
| Time of Sampling | Mar 17, 2013 1:00 PM - 2:00 PM | | Mar 17, 2013 12:50 PM - 1:50 PM | | Mar 17, 2013 12:50 PM - 1:50 PM | | |
| Detected Nuclides (Half-life) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | |
| I-131 (Approx. 8 days) | ND | - | ND | - | ND | - | |
| Cs-134 (Approx. 2 years) | ND | - | ND | - | ND | - | 2E-03 |
| Cs-137 (Approx. 30 years) | ND | - | ND | - | ND | - | 3E-03 |

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 4E-6Bq/cm³, Cs-134: Approx. 1E-5Bq/cm³, Cs-137: Approx. 1E-5Bq/cm³

Particulate; I-131: Approx. 3E-6Bq/cm³, Cs-134: Approx. 6E-6Bq/cm³, Cs-137: Approx. 7E-6Bq/cm³

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Result of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS <2/4>

(Data summarized on March 25)

| Place of Sampling | Process Main Building (East Side Opening) | | Unit 1 Waste Treatment Building (West Side Opening) | | Unit 2 Waste Treatment Building (West Side Opening) | | Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2) |
|----------------------------------|--|----------------------------|--|----------------------------|--|----------------------------|---|
| Time of Sampling | Mar 17, 2013 1:00 PM - 2:00 PM | | Mar 17, 2013 9:00 AM - 10:00 AM | | Mar 17, 2013 9:00 AM - 10:00 AM | | |
| Detected Nuclides (Half-life) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | |
| I-131 (Approx. 8 days) | ND | - | ND | - | ND | - | 1E-03 |
| Cs-134 (Approx. 2 years) | ND | - | ND | - | ND | - | 2E-03 |
| Cs-137 (Approx. 30 years) | ND | - | ND | - | 8.0E-06 | 0.00 | 3E-03 |

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10⁻⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 5E-6Bq/cm³, Cs-134: Approx. 1E-5Bq/cm³, Cs-137: Approx. 1E-5Bq/cm³

Particulate; I-131: Approx. 3E-6Bq/cm³, Cs-134: Approx. 6E-6Bq/cm³, Cs-137: Approx. 7E-6Bq/cm³

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Result of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS <3/4>

(Data summarized on March 25)

| Place of Sampling | Unit 4 Reactor Building Opening (Northwest Side Opening) | | Unit 4 Reactor Building Opening (Large Equipment Hatch) | | Unit 1 Turbine Building Opening (Large Equipment Hatch) | | Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2) |
|----------------------------------|---|----------------------------|--|----------------------------|--|----------------------------|---|
| Time of Sampling | Mar 17, 2013 9:10 AM - 10:10 AM | | Mar 17, 2013 9:10 AM - 10:10 AM | | Mar 17, 2013 10:55 AM - 11:55 AM | | |
| Detected Nuclides (Half-life) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | |
| I-131 (Approx. 8 days) | ND | - | ND | - | ND | - | 1E-03 |
| Cs-134 (Approx. 2 years) | ND | - | ND | - | ND | - | 2E-03 |
| Cs-137 (Approx. 30 years) | ND | - | ND | - | 8.0E-06 | 0.00 | 3E-03 |

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10⁻⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 5E-6Bq/cm³, Cs-134: Approx. 1E-5Bq/cm³, Cs-137: Approx. 1E-5Bq/cm³

Particulate; I-131: Approx. 3E-6Bq/cm³, Cs-134: Approx. 6E-6Bq/cm³, Cs-137: Approx. 7E-6Bq/cm³

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Result of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS <4/4>

(Data summarized on March 25)

| Place of Sampling | Unit 2 Turbine Building Opening (Large Equipment Hatch) | | Unit 3 Turbine Building Opening (Large Equipment Hatch) | | Unit 4 Turbine Building Opening (Large Equipment Hatch) | | Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2) |
|----------------------------------|--|----------------------------|--|----------------------------|--|----------------------------|---|
| Time of Sampling | Mar 17, 2013 10:55 AM - 11:55 AM | | Mar 17, 2013 11:05 AM - 12:05 PM | | Mar 17, 2013 11:05 AM - 12:05 PM | | |
| Detected Nuclides (Half-life) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | Density of Sample (Bq/cm ³) | Scaling Factor (/) | |
| I-131 (Approx. 8 days) | ND | - | ND | - | ND | - | 1E-03 |
| Cs-134 (Approx. 2 years) | ND | - | ND | - | ND | - | 2E-03 |
| Cs-137 (Approx. 30 years) | ND | - | ND | - | ND | - | 3E-03 |

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE - O is the same as O.O x 10⁻⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows.

Volatile; I-131: Approx. 5E-6Bq/cm³, Cs-134: Approx. 1E-5Bq/cm³, Cs-137: Approx. 1E-5Bq/cm³

Particulate; I-131: Approx. 3E-6Bq/cm³, Cs-134: Approx. 6E-6Bq/cm³, Cs-137: Approx. 7E-6Bq/cm³

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.