

Sampling Results Regarding the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/cm³ (Exclude chloride)

		Water from the tank No.5 at the H4 area
Date of Sampling		Aug 23, 2013
Time of sampling		9:00 PM
Chloride (ppm)		5,200
Cs-134(Approx. 2 years)		4.4E+1
Cs-137(Approx.30 years)		9.2E+1
The other γ	Sb-125 (Approx. 3 years)	5.3E+1
All β		2.0E+5
H-3 (Approx. 12 years)		2.4E+3

(Note) 0.0E+0 is the same as 0.0 x 10⁰

* Data announced this time is provided in a thick-frame. The other data was announced on August 26.